

Summary of Investigation Findings

CITY OF HEWITT

200 PATRIOT CT

HEWITT, MCLENNAN COUNTY, TX 76643

Investigation #

1868244

Investigation Date: 01/05/2023

Additional ID(s): 1550031

No Violations Associated to this Investigation

ADDITIONAL ISSUES

Description	Additional Comments
Item #1	The City of Hewitt water system's minimum required production capacity has exceeded 85% of its existing capacity [291.93(3)]. With 6,132 connections, 3,679.2 gpm is required, and 4,185 gpm is provided.