

# ATTACHMENT No. 1

**From:** [Plan Review](#)  
**To:** [Jeff Remas](#); [Ingrid Allen](#)  
**Subject:** 1124 Highland Beach Drive Dock  
**Date:** Wednesday, October 27, 2021 2:59:50 PM  
**Attachments:** [648B163E3E5E483CB2210366C382087C\[2034936\].png](#)  
[1124A\[8036\].jpg](#)  
[1124b.jpg](#)  
[1124c.jpg](#)  
[1124d.jpg](#)  
[1124f.jpg](#)  
[1124e.jpg](#)

---

Good morning, I visited 1124 Highland Beach Drive at 10am on 10/25/21 to determine current site conditions. The dock installed is (approximately) 80 ft in length, depth from seawall into canal is 5 ft at widest point, 9 wooden pilings installed. Distance from setback is approximately 15 ft from each property line. The dimensions appear to match the documents submitted to the planning board. Please see attached photos and contact me if you require additional information. Thank you



Respectfully,  
**Michael Keenan**

*Town of Highland Beach*  
3616 S. Ocean Boulevard  
Highland Beach, FL 33487  
(561) 278-4540 Office  
(561) 278-2606 Fax  
[www.highlandbeach.us](http://www.highlandbeach.us)