



TOWN OF HIGHLAND BEACH AGENDA MEMORANDUM

MEETING TYPE: Town Commission Meeting

MEETING DATE *August 2, 2022*

SUBMITTED BY: Pat Roman, Public Works Director

SUBJECT: Approve and Authorize the Public Works Director to rehabilitate Lift Station Number Two, utilizing the existing agreement with Hinterland Group Inc.

SUMMARY:

The Town of Highland Beach Lift Station Number Two needs rehabilitation. The lift station was last renovated in 1980. The wet well needs to be coated, the piping and the valves need to be replaced.

To rehabilitate Lift Station Number Two, the station must be bypassed and taken out of service during the renovation. To bypass the station, a twenty-four-hour bypass pump must be brought in and the concrete driveway removed. After the project is completed and the equipment has been removed, the concrete driveway will have to be replaced.

We recommend having Hinterland Group Inc. of Riviera Beach, Florida perform this rehabilitation project on Lift Station Number Two, pursuant to the existing Service Agreement (RFP 20-003).

FISCAL IMPACT:

Funding for this project (\$66,700.00) is available in Account (401-535.000.562.000) Improvements other than Buildings in the 2021 – 2022 approved budget.

ATTACHMENTS:

Agreement between the Town of Highland Beach and Hinterland Group

RECOMMENDATION:

Commission approval.