

C. Items furnished by Owner for installation by Contractor:

Item	Unit	Quantity
8" PVC C900 pipe	LF	1740
6" ductile Iron pipe	LF	40ft (2 sticks)
6" field lock gaskets	Each	1
12 gauge Blue tracer wire 60 mill coating	LF	1740
6" wide Blue water line buried below tape	LF	1740
8" bell spicket pvc joint restraint (Romac 611 or equal)	Each	30
8" PVC Restrained MJ bolt gasket kit	Each	20
8" MJ bolt gasket glan pk	Each	2
6" ductile restrained MJ bolt gasket kit	Each	2
8 " FL cross	Each	2
8" FL gasket bolt kit	Each	8
8' MJ X 6' FL tee	Each	1
6" FL gasket bolt kit	Each	1
8" FL X MJ valve	Each	8
6" FL X MJ valve	Each	1
5 foot bury fire hydrant	Each	1
8" MJ 45	Each	2
8" MJ plug	Each	2

1.5 CONTRACTOR'S USE OF SITE

- A. Limit use of Site to allow:
1. Owner occupancy.
 2. Work by Owner.
 3. Work by Others.
- B. Construction Operations: Limited to areas indicated on Drawings
1. Noisy and Disruptive Operations (such as Use of Jack Hammers and Other Noisy Equipment): Not allowed in close proximity to existing building during regular hours of operation. Coordinate and schedule such operations with Owner to minimize disruptions.
- C. Time Restrictions for Performing Work: Weekdays 7AM to 7PM. Work on holidays is not allowed unless granted approval from the City.
- D. Utility Outages and Shutdown:
1. Coordinate and schedule electrical and other utility outages with Owner.
 2. Outages: Allowed only at previously agreed upon times.