



305 Best Ave.

ahrsales24hrservice@scicable.com

Date _____

Terms

Name _____

Phone

Address

Customer Complaint

7-2 3 hrs. Bar side walk in cooler warm not working
found high limit tripped for Refrigeration
control High limit - Took unit apart
blew out and cleaned very dirty outside
condenser - coil - Also Brushed off inside cooling
coil - Preset unit watching temp - pressures for unit
ran good BUT Hot - will return next day to monitor
system again - 7-3 - Returned system at temp. working good

2 options



Prices on New Equipment went up slightly but Equipment and line set need to be replaced new - IV Equipment, line set and labor cost \$14,600.⁰⁰

d) Equipment, check all of line set and labor cost \$13,000.

[illegible]

Date Completed _____

Work ordered by

Signature

Thereby acknowledge the satisfactory completion of the above described work.

truck charge & supplies	\$20. ⁰⁰
-------------------------	---------------------

Total Other

LABOR

Service labor	3 hrs @ 130. per hr.
---------------	----------------------

Total Labor

Total Materials

Total Other

~~22~~ Surcharge

TOTAL

Thank You

BALANCE DUE IN 30 DAYS.
ANY UNPAID BALANCE WILL RECEIVE
A FINANCE CHARGE OF
1.5% PER MONTH, 18% PER YEAR

2112