
Agenda Item

Firehouse Liquor On-Sale Walk-In Cooler

Meeting Date

July 14, 2026

Prepared By

Leaha M. Jackson, City Administrator

Background

The walk-in cooler in the on-sale was not working. AHR was called out to look at it and noted that the high-limit switch was tripping.

We had some trouble with this cooler in 2025, and AHR was able to get it working but recommended replacing the equipment. Included is a copy of the 2025 invoice with notes/recommendations. Staff asked for the updated quote attached for the replacement of the refrigeration equipment.

Recommended Action

Consider approving the quote from AHR to replace the equipment for the on-sale walk-in cooler, including the lines, for \$14,600.

Council Action: Motion by: _____ Second by: _____

Motion to:

Voted in Favor: _____ Voted Against: _____

Approved: _____ Denied: _____ Tabled: _____ No Action: _____