



Not to Scale

NOTES
PG-ENLIGHTEN IS NEITHER LICENSED NOR INSURED TO DETERMINE CODE COMPLIANCE. CODE COMPLIANCE REVIEW BY OTHERS.
ANY VARIANCE FROM REFLECTANCE VALUES, OBSTRUCTIONS, LIGHT LOSS FACTORS OR DIMENSIONAL DATA WILL AFFECT THE ACTUAL LIGHT LEVELS OBTAINED.
THIS ANALYSIS IS A MATHEMATICAL MODEL AND CAN BE ONLY AS ACCURATE AS IS PERMITTED BY THE THIRD-PARTY SOFTWARE AND THE IES STANDARDS USED.
FIXTURE TYPES AND QUANTITIES MAY CHANGE BASED ON UNKNOWN OBSTRUCTIONS OR FIELD CONDITIONS. THESE CHANGES MAY RESULT IN AN INCREASED QUANTITY OF FIXTURES.
FIXTURE TYPES AND QUANTITIES BASED ON PROVIDED LAYOUT AND DRAWINGS ARE FOR REFERENCE ONLY. TYPES AND QUANTITIES MAY CHANGE WITH FUTURE REVISIONS.
CALCULATION GRID VALUES 10'-0" O.C.

Calculation Summary										
Label	CalcType	Units	Avg	Max	Min	Max/Min	Calc Plane Ht			
Parking Lot_Floor	Illuminance	Fc	2.9	13.4	0.1	134.0	0			
Property Line	Illuminance	Fc	0.5	0.9	0.0	N.A.	N.A.			

Luminaire Schedule - Part numbers are provided by the manufacturer and are only intended to be used as a reference to output and optics used.										
Symbol	Qty	Tag	Manufacturer	Description	Arrangement	Luminaire Lumens	Arr. Lum. Lumens	Luminaire Watts	Arr. Watts	LLF
	1	F2-3	ILP	VAM2-28L-U-40-T3-[PMB;SLPF]	Single	28329	28329	166.2632	166.263	0.900
	4	F2-4	ILP	VAM2-28L-U-40-T4-[PMB;SLPF]	Single	28260	28260	166.516	166.516	0.900
	1	F2-4A	ILP	VAM2-28L-U-40-T4-[PMB;SLPF]	Back-Back	28260	56520	166.516	333.032	0.900
	2	Fx	ILP	VWM2-14L-U-40-T4	Single	13494	13494	96.24	96.24	0.900



PROJECT NAME:

APPAREL REDEFINED

Date:8/7/2026

Page 1 of 1

DRAWN BY:

ERIC SISCO

eric.sisco@pg-enlighten.com

913.486.3072

PG CONTACT:

AMY BROWN

amy.brown@pg-enlighten.com

847.228.1199

CLIENT NAME:

SOUTHSIDE ELECTRICAL