

MEMORANDUM

Date: June 6, 2023

To: Max Massi, Village Engineer
Angela Mesaros, Director of Community Development

From: Bryon Doerr, L&M Supervisor

Re: Buffalo Wild Wings Review #1

Cc:

-
1. Halsted requirements are met
 2. Swap out Arctic Dogwoods for Smooth Hydrangea
 3. Extra focus to contractor regarding L201 figure 1 tree planting. Leave trunk flare visible. Planting grade is a trunk flare, excavate root ball if necessary to find
 4. Notes 5.1 = and follow ANSI A300, Z133.1 and Z60.1