

Re: Land Use Permit 24-008 External Inbox x



Robin Sykes <rsykes@la-h-health.org>

to me, Aaron ▾

Tue, Mar 12, 1:46 PM ★ ↶ ⋮

Hello Cheri

Thank you for getting this information to our Department. I have reviewed the proposal and have these comments/requirements.

1. The bulk water station that will serve water to the public and also the water water provided for the campers must meet the requirements of: CDPHE Regulation WQCD Regulation 11: <https://www.coloradosos.gov/CCR/GenerateRulePdf.do?ruleVersionId=11290&fileName=5%20CCR%201002-11>.
2. The OWTS (Onsite wastewater treatment systems) for this commercial use must be designed by a Registered Professional Engineer as required in Regulation 43 (43.8.L.1.a): <https://www.coloradosos.gov/CCR/GenerateRulePdf.do?ruleVersionId=7543&fileName=5%20CCR%201002-43>. If the total volume of the sewage should exceed 2,000 gallons per day, it shall be under the jurisdiction of CDPHE and Regulation 22.
3. The Dump Station - Must be designed and constructed such that it has adequate volume (2000 gallons or more) and is also equipped with a visible and audible alarm (Regulation 43, 43.12.C.9.) There shall be a written agreement between facility and a licensed wastewater pumping company to assure that pumping will be conducted on a routine basis.

Although not mentioned in this narrative, if food is prepared or dispensed to the patrons restaurant/snack bar or grocery store (Retail Food Establishment), the jurisdiction falls under the authority of the Las Animas-Huerfano Counties District Health Department and the appropriate paperwork, licensing and inspections shall be required.

These requirements are the minimum required for this type of proposal, there may be more as the project unfolds.

Thank you

Robin