





3:03 PM



PLACE
Walsenburg, Huerfano Co



COLORADO STATE ELECTRICAL BOARD
1560 Broadway, Suite 1350
Denver, Colorado 80202

Automatic email - Do not reply to this email.

Inspection Report

Permit #: 986329

Date Inspected: 10-OCT-23

Permit Holder: KEITH PARSONS

1606 SHAYMUS CT WALSENBURG, CO 81089

Phone: 2056412633 **Fax:**

Email: keithparsons1@aol.com

Site: 1606 SHAYMUS CT Walsenburg County: Huerfano

Owner: KEITH PARSONS
KEITH PARSONS

Phone: 2056412633

Status: PARTIAL

Inspection Type: Rough In

Trim Permit: N

Construction Type: NEW **Building Type:** RESIDENTIAL

Inspector: Luke Hanson 303-869-3475

Corrections:

Comments: Slab OK to pour Conduits just exiting out of foundation wall at time of inspection, UFER ground OK