



Symbol	Qty	Label	Arrangement	Lumens/Lamp	LLF	Total Watts	Description
	2	P24	2 @ 90 degrees	40800	0.950	1200.08	RXAR-300-4-VS-CP-BR-A (300W, T4, 5000K)
	3	P14	Single	33500	1.000	751.2	RXAR-250-4-VS-CP-BR-A (250W, T4, 5000K)
	2	WF4	Single	33500	1.000	500.8	RXAR-250-4-VS-CP-BR-A (250W, T4, 5000K)
	10	WP4 100	Single	14400	1.000	2504	RXAR-WM RXAR-100-4-VS-CP-BR-A (100W, T4, 5000K) RXAR-WM
	3	P35	3 @ 90 Degrees	42300	0.950	2697.3	RXAR-300-5-VS-CP-BR-A (300W, T5, 5000K)
	2	P34	Single	40800	0.950	600.04	RXAR-300-4-VS-CP-BR-A (300W, T4, 5000K)

Calculation Summary					
Label	Avg	Max	Min	Avg/Min	Max/Min
CalcPts 1	1.83	11.8	0.0	N.A.	N.A.
Building 1 parking	2.49	10.1	0.5	4.98	20.20
Building 2 parking	2.49	9.9	0.5	4.98	19.80
Truck Lot	1.84	11.8	0.2	9.20	59.00

CONTRACTOR TO VERIFY ALL MOUNTING, COLOR AND VOLTAGE PRIOR TO ORDERING

