



# ZONING MEMORANDUM

**April 9, 2025**

Prepared for  
Town of Howey-in-the-Hills  
Attn: Sean O'Keefe, Town Manager



## **Mission Rise: Pre-Application Subdivision Plan Review Comments**

**Applicant: ASF TAP FL I LLC c/o Jason Humm**

Planning staff reviewed the proposed Mission Rise Preliminary Subdivision Plans for pre-application. All previous review comments have been addressed. Thank you. Below is some information that will help the applicant prepare for the Final Subdivision Plans review stage regarding requirements for tree replacement.

Please note that Landscaping, hardscaping, and irrigation plans are required to be submitted with Final Site Plans and Final Subdivision Plans. These plans shall be signed and sealed by a licensed landscape architect registered in the State of Florida. The Land Development Code (LDC) Chapter 7 provides the requirements for landscaping, hardscaping, and irrigation. This also includes tree replacements plans and will need to detail the following at that time:

- a. Based on the Tree Removal Table (Sheet C211) it appears that 4652.8 feet of trees are to be removed. Please provide the total number of trees on site and any replacement data consistent with the Land Development Code (LDC). Please revise the Table to indicate which are Specimen Trees and which are Heritage Trees and provide the replacement data in concert with the LDC. LDC Section 7.11.03 requires 50% of all specimen trees be preserved on a parcel. LDC Section 7.11.02 requires protection of all Historic Trees unless one of the following conditions is met:
  - i. The tree is not suitable for preservation as determined by a certified arborist.
  - ii. The tree is a threat to a principal structure or otherwise constitutes a hazard requiring removal as determined by a qualified arborist or professional engineer.
  - iii. The placement of the tree prohibits the economic use of the property for permissible development.



- b. Please indicate why the trees are being removed on the Tree Removal Table (Sheet C211) and whether any proposed to be removed are on the Town's prohibited plant list. If they are plant species that are prohibited by the Florida Department of Environmental Protection or the Florida Department of Agriculture, or listed as invasive by the Florida Exotic Pest Control, this information needs to be provided on the Tree Removal Table for each tree listed.
- c. Please provide data and evaluate, consistent with LDC Section 7.11.04, if any trees can be saved by redesign.
- d. Tree Protection Detail needs to be provided on the plans to comply with LDC Section 7.11.01.