

GRIFFEY ENGINEERING, INC.

October 12, 2022

Hillside Groves – Mass Grading Plan

Engineering Review Comments

Page 1

1. Submit copies of approvals from SJRWMD, FWC and Duke Energy prior to commencing work.
2. Call out that the concrete in the broadcrested weirs is to be fiber reinforced.
3. On the control structure detail, remove the requirement for an Osceola County benchmark disk.