



## Public Utilities

### February 2024– Monthly Report

Activity	Location/ Address	Notes
Service orders	41 throughout town	Meter installations, Rereads, Pressure checks.
Data Logs	3 throughout town	3 data logs for leak check and high usage
Repair	WTP 1	Replace time relay switch in VFD for HSP4
Maintenance	WTP 1	Pressure washed all building, finished painting all piping