



Public Utilities
July 2025– Monthly Report

Activity	Location/ Address	Notes
Locates	Throughout Town	76 utility locates
Service Orders	Throughout Town	37 service orders including register replacements, re-reads, start or end reading. Leak checks and high usage checks
Repairs	WTP 1 and Well 3	Electrical room AC repair at WTP 1
MTP 1	Maintenance	Ground storage tank pressure washed, and Aerator cleaned
DEP Inspection	WTP 1 and Well 3	Inspection on 7/30/25 Inspection went well, Inspector was impressed with the cleanliness of the ground storage tank and the record keeping.