

**Master Utility Design for
LIFT STATION ANALYSIS
Hillside Groves**

FOR

Lennar Homes LLC

Date: April 2022

BY



Connelly & Wicker Inc.

Planning • Engineering • Landscape Architecture

**1560 North Orange Ave.
Suite 210**


Winter Park, FL 32789

CWI Job #: 18-04-0004

Certificate of Authorization No. 3650

**Ryan R
Blaida**

Digitally signed by Ryan R Blaida
DN: c=US, o=CONNELLY AND
WICKER INC.,
ou=A01410D00000177017283E2
00013904, cn=Ryan R Blaida
Date: 2022.04.01 09:51:27 -04'00'



Ryan Blaida, P.E.

FL PE #61017

This item has been electronically signed and sealed
by Ryan Blaida on the date indicated here using
SHA authentication code. Printed copies of this
document are not considered signed and sealed,
and the SHA authentication code must be verified
on any electronic copies.

TABLE OF CONTENTS

Tab 1:	Introduction Overall Layout
Tab 2:	Lift Station 1-1 Design
Tab 3:	Lift Station 1-2 Design
Tab 4:	Lift Station 2-1 Design
Tab 5:	Lift Station 3-1 Design
Tab 6:	Lift Station 4-1 Design
Tab 7:	Hydraulic Model of Manifolded System



Connelly & Wicker Inc.

Planning • Engineering • Landscape Architecture

1560 North Orange Ave. | Suite 210 | Winter Park, Florida 32789

P: 407.261.3100 www.cwIeng.com

Tab 1: Introduction



Connelly & Wicker Inc.

Planning • Engineering • Landscape Architecture

1560 North Orange Ave. | Suite 210 | Winter Park, Florida 32789

P: 407.261.3100 www.cwIeng.com

A. Introduction

1. Project Overview

Hillside Groves is a 375.2-acre single-family residential home project located north of State Road 19 and southwest of W. Central Ave. and S. Florida Ave. in Howey in the Hills, Lake County, Florida. It is situated in Section 35, Township 20S, Range 25E. Please see Location Map and Figure 2 Aerial Map, both under Tab 2 of this report.

Hillside Groves is a large PUD with supporting roads and infrastructure. The purpose of this report is to demonstrate the lift station design will be able to discharge the wastewater into the existing town system.

2. Utility Provider


The City of Howey in the Hills is the potable water provider for this project. This analysis takes into consideration City of Howey in the Hills design criteria. Where specific criteria are not set by the city, standards from nearby utility providers will be utilized.

B. Lift Station Design

1. Introduction

Sanitary sewer from the single-family homes will be collected via a gravity system, then routed to five separate on-site lift stations. Lift Station 4-1 will discharge into a proposed future manhole, which will discharge to Lift Station 1-1. 1-1, 1-2 and 2-1 will manifold into a proposed 10" forcemain proposed with the boulevard within the project. This 10" forcemain will discharge to the existing City system in the Number 2 Road right of way. Lift station 3-1 will discharge to the existing forcemain within the SR 19 right of way

The following calculations demonstrate this design.





LEGEND

4" FORCEMAIN —

6" FORCEMAIN —

10" FORCEMAIN —

EXISTING FORCEMAIN —

 Connelly & Wicker Inc. Planning · Engineering · Landscape Architecture 1560 NORTH ORANGE AVE., SUITE 210 WINTER PARK, FLORIDA 32789 (407) 261-3100 FAX: (407) 261-3099 www.cweng.com FLORIDA REGISTRY: 3650 L.A. NUMBER: LC26000311	FORCEMAIN EXHIBIT	
		MARCH 2022 21-04-0008

Tab 2: Lift Station 1-1 Design



Connelly & Wicker Inc.

Planning • Engineering • Landscape Architecture

1560 North Orange Ave. | Suite 210 | Winter Park, Florida 32789

P: 407.261.3100 www.cwIeng.com



Project: Howey

Table: 1 - Summary of Wastewater Demands

Engineer(s): SC\RB

Date: 3/28/2022 Revised: 3/31/2022

Job No.: 21-004-0008

TABLE 1 - SUMMARY OF WASTEWATER DEMANDS - LS 1-1

PHASE	LAND USE	QUANTITY	UNITS	DEMAND	UNITS	ADF		PEAK FACTOR	MDF	
						(gpd)	(gpm)		(gpd)	(gpm)
1-1	SF Homes (actual)	146	UNITS	300	GPD/UNIT	43,800	30.4	2.5	109,500	76.0
4-1	SF Homes (additional)	177	UNITS	300	GPD/UNIT	53,100	36.9	2.5	132,750	92.2
TOTAL		323				96,900	67.3		242,250	168.2



Project: Howey
 Table: 2 - Lift Station Design
 Engineer(s): SC/RB
 Date: 3/28/2022
 Job No.: 21-004-0008

Revised: 3/31/2022

TABLE 2 - LIFT STATION DESIGN - LS 1-1

PUMP DATA

MANUFACTURER	Pentair	MODEL	Hydromatic-H4H
PUMP CURVE	SUB_S_E_AH_00021_B_4 Rev 2012-03-23		IMPELLER SIZE
PUMP HORSEPOWER	7.38 HP, rated	DESIGN SPEED	1750 RPM, rated

DESIGN FLOWS

ADF QIN 67.3 GPM

PDF QIN 168.2 GPM

HYDRAULIC MODEL RESULTS


MAX PRESSURE	180.0 GPM OUTFLOW @	44.3 FT TDH
MIN PRESSURE	70 GPM OUTFLOW @	38.7 FT TDH

WET WELL STORAGE

Q	180 (GPM) FLOW OUT OF WET WELL PUMP DISCHARGE, ONE RUNNING
S	168 (GPM) WASTEWATER FLOW INTO WET WELL - PDF IN
T	20 (MIN) ASSUMED CYCLE TIME
V	220.0 (GAL) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
	29.4 (FT ³) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
STORAGE DEPTH	2.00 FT

WET WELL DESIGN

ELEVATION	63.00 SLAB TOP (WW INVERT)
ELEVATION	63.25 PUMP VOLUTE
ELEVATION	65.00 BOTH PUMPS OFF
ELEVATION	67.00 START LEAD
ELEVATION	68.00 START LAG
ELEVATION	69.00 HIGH LEVEL ALARM
ELEVATION	90.00 TOP OF WET WELL
ELEVATION	70 INFLUENT INVERT
TOTAL LIFT STATION DEPTH	27.00 FT



ID - INSIDE DIAMETER	8 FT	FS - FLOOR SLAB THICKNESS	12 IN
W - WALL THICKNESS	8 IN	AD - ADD SLAB DIAMETER	16 IN
TS - TOP SLAB THICKNESS	0 IN	OD - TOTAL SLAB DIAMETER	12.0 FT

NOTE: ASSUMES 20' DEPTH AT INVERT

CYCLE TIME EVALUATION

AVERAGE DAILY FLOW

TIME ON	1.95 MIN
TIME OFF	3.27 MIN
TOTAL CYCLE TIME	5.22 MIN
STARTS PER HOUR	11

PEAK DAILY FLOW

TIME ON	18.69 MIN
TIME OFF	1.31 MIN
TOTAL CYCLE TIME	20.00 MIN
STARTS PER HOUR	3.0

DESIGN CHECKS

DEPTH FROM INFLUENT INVERT TO TOP OF SLAB (WET WELL INVERT)

REQUIRED	5 FT	PROVIDED	7.00 FT
TOTAL CYCLE TIME MINIMUM			
REQUIRED	10 MIN	PROVIDED	5.22 MIN

DEPTH FROM HIGH LEVEL ALARM TO ALL PUMPS OFF

REQUIRED

3 FT

PROVIDED

4.00 FT

WET WELL FLOATATION**ASSUMPTIONS**

- 1) WEIGHT OF PUMPS, FITTINGS, ETC. NOT INCLUDED.
- 2) WET WELL IS EMPTY - FLUID WEIGHT WITHIN STRUCTURE IS NOT CONSIDERED
- 3) GROUNDWATER LEVEL IS AT TOP OF WET WELL
- 4) SOIL FRICTION FORCE IS EXCLUDED, ONLY THE WEIGHT OF SOIL ON TOP OF BOTTON OF SLAB IS CONSIDERED

DOWNWARD FORCES

CONCRETE WALLS

CONCRETE WALLS 18.2 FT²
 27.00 FT (DEPTH OF WALLS)
 490.1 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.1 FT³

CONCRETE WEIGHT **0.0** CY - ADDITIONAL BALLAST
 603.2 FT³
 150 LB/FT³ (UNIT WEIGHT OF REENFORCED CONCRETE)
 90,478 LBS

SOIL WEIGHT 44.7 FT²
 27.00 FT (DEPTH OF WALLS)
 47.6 LB/FT³ (110 LB/FT³ - 62.4 LB/FT³ = WEIGHT OF SOIL - WEIGHT OF WATER)
 57,423 LBS

UPWARD FORCES (HYDROSTATIC)

CONCRETE WALLS

 68.4 FT²
 27.00 FT (DEPTH OF WALLS)
 1847.3 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.10 FT³

WEIGHT OF WATER

 1960.4 FT³
 62.4 LB/FT³
 122,326 LBS

TOTAL FORCES SUMMARY

DOWNWARD FORCE **147,901** LBS
UPWARD FORCE **122,326** LBS
SAFETY FACTOR **1.21**



Project: Howey
Table: 3 - Lift Station System Curve
Engineer(s): SC/RB
Date: 3/28/2022 Revised: 3/31/2022
Job No.: 21-004-0008

TABLE 3 - LIFT STATION SYSTEM CURVE - LS 1-1

STATIC/ELEVATION HEAD			
BOTH PUMPS OFF	65.00	FT	
HIGHPOINT ALONG FM	91.00	FT	
CONNECTION ELEVATION	84.00	FT	INVERT ELEVATION OF EXISTING FORCEMAIN
TOTAL STATIC LOSS	26.0	FT	
TOTAL STATIC LOSS	26.0	FT	

	LIFT STATION	LIFT STATION TO	CONNECTION TO
	RISER PIPES	CONNECTION	TO EXISTING FM
DESIGN FLOW (Q)	180 GPM	180 GPM	180 GPM
PIPE DIAMETER (D)	4 IN	6 IN	10 IN
PIPE LENGTH (L)	20 FT	1510 FT	3100 FT
HAZEN WILLIAMS COEFF (C)	120	120	120
VELOCITY (V)	4.60 FT/S	2.04 FT/S	0.74 FT/S
FLOW AREA (A)	0.09 FT ²	0.20 FT ²	0.55 FT
FRICTION LOSS (HF)	0.52 FT	5.42 FT	0.92 FT
TOTAL FRICTION LOSS	8.4	FT	

CONNECTION/PRESSURE HEAD							
CONNECTION PRESSURE (max)		15	PSI	CONNECTION PRESSURE (min)		5	PSI
TOTAL PRESSURE LOSS		34.7	FT	TOTAL PRESSURE LOSS		11.6	FT

MINOR HEAD LOSS			0
FITTING TYPE	K - VALUE	COUNT	
DISCHARGE	0.6	1	
90° BEND	0.3	2	
VALVES	1.5	1	
CHECK VALVES	2.0	2	
TEE CONNECTION	0.4	1	
OUTLET	1.0	1	
USER DEFINED	0.0	0	
TOTAL		8.1	
TOTAL MINOR LOSS	2.7	FT	

SYSTEM CURVE		
Min Pressure		
FLOW RATE	TDH	INCREMENT
GPM	FT	40.00
0	37.6	
40	38.0	
70	38.9	← SYSTEM PT
110	40.6	
150	43.1	
180	45.3	
220	48.8	
260	52.9	
300	57.6	
340	62.9	
380	68.8	
420	75.2	
Max Pressure		
FLOW RATE	TDH	INCREMENT
GPM	FT	40.00
0	61.4	
40	61.8	
80	62.9	
120	64.7	
160	67.0	
180	68.4	← SYSTEM PT
220	71.5	
260	75.3	
300	79.5	
340	84.3	
380	89.7	
420	95.5	

Item number	: Default	Size	: Hydromatic - H4H
Service	:	Stages	: 1
Quantity	: 1	Based on curve number	: SUB_S_E_AH_00021_B_4 Rev
Quote number	:		2012-03-23
		Date last saved	: 31 Mar 2022 8:24 AM

Operating Conditions

Flow, rated	: 180.0 USgpm
Differential head / pressure, rated (requested)	: 68.40 ft
Differential head / pressure, rated (actual)	: 71.34 ft
Suction pressure, rated / max	: 0.00 / 0.00 psi.g
NPSH available, rated	: Ample
Site Supply Frequency	: 60 Hz

Performance

Speed criteria	: Synchronous
Speed, rated	: 1750 rpm
Impeller diameter, rated	: 8.88 in
Impeller diameter, maximum	: 10.00 in
Impeller diameter, minimum	: 8.00 in
Efficiency	: 43.93 %
NPSH required / margin required	: - / 0.00 ft
nq (imp. eye flow) / S (imp. eye flow)	: 34 / - Metric units
Minimum Continuous Stable Flow	: 100.0 USgpm
Head, maximum, rated diameter	: 94.42 ft
Head rise to shutoff	: 32.35 %
Flow, best eff. point	: 462.3 USgpm
Flow ratio, rated / BEP	: 38.93 %
Diameter ratio (rated / max)	: 88.75 %
Head ratio (rated dia / max dia)	: 73.67 %
Cq/Ch/Ce/Cn [ANSI/HI 9.6.7-2010]	: 1.00 / 1.00 / 1.00 / 1.00
Selection status	: Acceptable

Liquid

Liquid type	: Water
Additional liquid description	:
Solids diameter, max	: 0.00 in
Solids diameter limit	: 3.00 in
Solids concentration, by volume	: 0.00 %
Temperature, max	: 68.00 deg F
Fluid density, rated / max	: 1.000 / 1.000 SG
Viscosity, rated	: 1.00 cP
Vapor pressure, rated	: 0.34 psi.a

Material


Material selected	: Standard
-------------------	------------

Pressure Data

Maximum working pressure	: 40.87 psi.g
Maximum allowable working pressure	: N/A
Maximum allowable suction pressure	: N/A
Hydrostatic test pressure	: N/A

Driver & Power Data (@Max density)

Driver sizing specification	: Maximum power
Margin over specification	: 0.00 %
Service factor	: 1.20 (used)
Power, hydraulic	: 3.24 hp
Power, rated	: 7.38 hp
Power, maximum, rated diameter	: 10.14 hp
Minimum recommended motor rating	: 10.00 hp / 7.46 kW



Tab 3: Lift Station 1-2 Design



Connelly & Wicker Inc.

Planning • Engineering • Landscape Architecture

1560 North Orange Ave. | Suite 210 | Winter Park, Florida 32789

P: 407.261.3100 www.cwIeng.com



Project: Howey
Table: 1 - Summary of Wastewater Demands
Engineer(s): SC\RB
Date: 3/28/2022 Revised: 3/31/2022
Job No.: 21-004-0008

TABLE 1 - SUMMARY OF WASTEWATER DEMANDS - LS 1-2

PHASE	LAND USE	QUANTITY	UNITS	DEMAND	UNITS	ADF		PEAK FACTOR	MDF	
						(gpd)	(gpm)		(gpd)	(gpm)
ER	SF Homes (actual)	161	UNITS	300	GPD/UNIT	48,300	33.5	2.5	120,750	83.9
ER	SF Homes (additional)		UNITS	300	GPD/UNIT	0	0.0	2.5	0	0.0
TOTAL		161				48,300	33.5		120,750	83.9



Project: Howey
 Table: 2 - Lift Station Design (1-2)
 Engineer(s): SC/RB
 Date: 3/28/2022
 Job No.: 21-004-0008

Revised: 3/31/2022

TABLE 2 - LIFT STATION DESIGN - LS 1-2

PUMP DATA

MANUFACTURER	Pentair	MODEL	Hydromatic-S4K	
PUMP CURVE	SUB_S_E_AH_00011_E_4 Rev 2012-03-23		IMPELLER SIZE	9.5 IN, rated
PUMP HORSEPOWER	7.9 HP, rated	DESIGN SPEED	1750 RPM, rated	

DESIGN FLOWS

ADF QIN 33.5 GPM

PDF QIN 83.9 GPM

HYDRAULIC MODEL RESULTS


MAX PRESSURE	85.0 GPM OUTFLOW @	96.5 FT TDH
MIN PRESSURE	36 GPM OUTFLOW @	49.4 FT TDH

WET WELL STORAGE

Q	85 (GPM) FLOW OUT OF WET WELL PUMP DISCHARGE, ONE RUNNING
S	84 (GPM) WASTEWATER FLOW INTO WET WELL - PDF IN
T	20 (MIN) ASSUMED CYCLE TIME
V	22.6 (GAL) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
	3.0 (FT ³) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
STORAGE DEPTH	2.00 FT

WET WELL DESIGN

ELEVATION	63.00 SLAB TOP (WW INVERT)
ELEVATION	63.25 PUMP VOLUTE
ELEVATION	65.00 BOTH PUMPS OFF
ELEVATION	67.00 START LEAD
ELEVATION	68.00 START LAG
ELEVATION	69.00 HIGH LEVEL ALARM
ELEVATION	90.00 TOP OF WET WELL
ELEVATION	70 INFLUENT INVERT
TOTAL LIFT STATION DEPTH	27.00 FT



ID - INSIDE DIAMETER	8 FT	FS - FLOOR SLAB THICKNESS	12 IN
W - WALL THICKNESS	8 IN	AD - ADD SLAB DIAMETER	16 IN
TS - TOP SLAB THICKNESS	0 IN	OD - TOTAL SLAB DIAMETER	12.0 FT

CYCLE TIME EVALUATION

AVERAGE DAILY FLOW

TIME ON	0.44 MIN
TIME OFF	0.67 MIN
TOTAL CYCLE TIME	1.11 MIN
STARTS PER HOUR	54

PEAK DAILY FLOW

TIME ON	19.73 MIN
TIME OFF	0.27 MIN
TOTAL CYCLE TIME	20.00 MIN
STARTS PER HOUR	3.0

DESIGN CHECKS

DEPTH FROM INFLUENT INVERT TO TOP OF SLAB (WET WELL INVERT)

REQUIRED	5 FT	PROVIDED	7.00 FT
TOTAL CYCLE TIME MINIMUM			
REQUIRED	10 MIN	PROVIDED	1.11 MIN

DEPTH FROM HIGH LEVEL ALARM TO ALL PUMPS OFF

REQUIRED

3 FT

PROVIDED

4.00 FT

WET WELL FLOATATION**ASSUMPTIONS**

- 1) WEIGHT OF PUMPS, FITTINGS, ETC. NOT INCLUDED.
- 2) WET WELL IS EMPTY - FLUID WEIGHT WITHIN STRUCTURE IS NOT CONSIDERED
- 3) GROUNDWATER LEVEL IS AT TOP OF WET WELL
- 4) SOIL FRICTION FORCE IS EXCLUDED, ONLY THE WEIGHT OF SOIL ON TOP OF BOTTON OF SLAB IS CONSIDERED

DOWNWARD FORCES

CONCRETE WALLS

CONCRETE WALLS 18.2 FT²
 27.00 FT (DEPTH OF WALLS)
 490.1 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.1 FT³

CONCRETE WEIGHT **0.0** CY - ADDITIONAL BALLAST
 603.2 FT³
 150 LB/FT³ (UNIT WEIGHT OF REENFORCED CONCRETE)
 90,478 LBS

SOIL WEIGHT 44.7 FT²
 27.00 FT (DEPTH OF WALLS)
 47.6 LB/FT³ (110 LB/FT³ - 62.4 LB/FT³ = WEIGHT OF SOIL - WEIGHT OF WATER)
 57,423 LBS

UPWARD FORCES (HYDROSTATIC)

CONCRETE WALLS

 68.4 FT²
 27.00 FT (DEPTH OF WALLS)
 1847.3 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.10 FT³

WEIGHT OF WATER

 1960.4 FT³
 62.4 LB/FT³
 122,326 LBS

TOTAL FORCES SUMMARY

DOWNWARD FORCE **147,901** LBS
UPWARD FORCE **122,326** LBS
SAFETY FACTOR **1.21**



Project: Howey
Table: 3 - Lift Station System Curve
Engineer(s): SC/RB
Date: 3/28/2022 Revised: 3/31/2022
Job No.: 21-004-0008

TABLE 3 - LIFT STATION SYSTEM CURVE - LS 1-2

STATIC/ELEVATION HEAD			
BOTH PUMPS OFF	65.00	FT	
HIGHPOINT ALONG FM	91.00	FT	
CONNECTION ELEVATION	84.00	FT	INVERT ELEVATION OF EXISTING FORCEMAIN
TOTAL STATIC LOSS	26.0	FT	
TOTAL STATIC LOSS	26.0	FT	

	LIFT STATION	LIFT STATION TO	CONNECTION TO
	RISER PIPES	CONNECTION	TO EXISTING FM
DESIGN FLOW (Q)	85 GPM	85 GPM	85 GPM
PIPE DIAMETER (D)	4 IN	6 IN	10 IN
PIPE LENGTH (L)	20 FT	1128 FT	2000 FT
HAZEN WILLIAMS COEFF (C)	120	120	120
VELOCITY (V)	2.17 FT/S	0.96 FT/S	0.35 FT/S
FLOW AREA (A)	0.09 FT ²	0.20 FT ²	0.55 FT
FRICTION LOSS (HF)	0.13 FT	1.01 FT	0.15 FT
TOTAL FRICTION LOSS	1.7	FT	

CONNECTION/PRESSURE HEAD							
CONNECTION PRESSURE (max)		30	PSI	CONNECTION PRESSURE (min)		10	PSI
TOTAL PRESSURE LOSS		69.3	FT	TOTAL PRESSURE LOSS		23.1	FT

MINOR HEAD LOSS			0
FITTING TYPE	K - VALUE	COUNT	
DISCHARGE	0.6	1	
90° BEND	0.3	2	
VALVES	1.5	1	
CHECK VALVES	2.0	2	
TEE CONNECTION	0.4	1	
OUTLET	1.0	1	
USER DEFINED	0.0	0	
TOTAL		8.1	
TOTAL MINOR LOSS	0.6	FT	

SYSTEM CURVE		
Min Pressure		
FLOW RATE	TDH	INCREMENT
GPM	FT	
0	49.1	18.00
18	49.2	
36	49.4	← SYSTEM PT
54	49.7	
72	50.1	
90	50.6	
108	51.2	
126	51.9	
144	52.6	
162	53.5	
180	54.5	
198	55.5	
Max Pressure		
FLOW RATE	TDH	INCREMENT
GPM	FT	
0	95.3	17.00
17	95.4	
34	95.5	
51	95.8	
68	96.1	
85	96.5	← SYSTEM PT
102	97.0	
119	97.5	
136	98.1	
153	98.8	
170	99.6	
187	100.4	

Item number	: Default	Size	: Hydromatic - S4K
Service	:	Stages	: 1
Quantity	: 1	Based on curve number	: SUB_S_E_AH_00011_E_4 Rev
Quote number	:		2012-03-23
		Date last saved	: 31 Mar 2022 8:35 AM

Operating Conditions

Flow, rated	: 85.00 USgpm
Differential head / pressure, rated (requested)	: 96.50 ft
Differential head / pressure, rated (actual)	: 96.82 ft
Suction pressure, rated / max	: 0.00 / 0.00 psi.g
NPSH available, rated	: Ample
Site Supply Frequency	: 60 Hz

Performance

Speed criteria	: Synchronous
Speed, rated	: 1750 rpm
Impeller diameter, rated	: 9.50 in
Impeller diameter, maximum	: 12.00 in
Impeller diameter, minimum	: 8.50 in
Efficiency	: 26.29 %
NPSH required / margin required	: - / 0.00 ft
nq (imp. eye flow) / S (imp. eye flow)	: 28 / - Metric units
Minimum Continuous Stable Flow	: 128.6 USgpm
Head, maximum, rated diameter	: 103.0 ft
Head rise to shutoff	: 6.41 %
Flow, best eff. point	: 592.4 USgpm
Flow ratio, rated / BEP	: 14.35 %
Diameter ratio (rated / max)	: 79.17 %
Head ratio (rated dia / max dia)	: 58.34 %
Cq/Ch/Ce/Cn [ANSI/HI 9.6.7-2010]	: 1.00 / 1.00 / 1.00 / 1.00

Liquid

Liquid type	: Water
Additional liquid description	:
Solids diameter, max	: 0.00 in
Solids diameter limit	: 3.00 in
Solids concentration, by volume	: 0.00 %
Temperature, max	: 68.00 deg F
Fluid density, rated / max	: 1.000 / 1.000 SG
Viscosity, rated	: 1.00 cP
Vapor pressure, rated	: 0.34 psi.a

Material


Material selected	: Standard
-------------------	------------

Pressure Data

Maximum working pressure	: 44.59 psi.g
Maximum allowable working pressure	: N/A
Maximum allowable suction pressure	: N/A
Hydrostatic test pressure	: N/A

Driver & Power Data (@Max density)

Driver sizing specification	: Maximum power
Margin over specification	: 0.00 %
Service factor	: 1.00
Power, hydraulic	: 2.08 hp
Power, rated	: 7.90 hp
Power, maximum, rated diameter	: 18.88 hp
Minimum recommended motor rating	: 20.00 hp / 14.91 kW



Tab 4: Lift Station 2-1 Design



Connelly & Wicker Inc.

Planning • Engineering • Landscape Architecture

1560 North Orange Ave. | Suite 210 | Winter Park, Florida 32789

P: 407.261.3100 www.cwIeng.com



Project: Howey
Table: 1 - Summary of Wastewater Demands
Engineer(s): SC\RB
Date: 3/28/2022 Revised: 3/31/2022
Job No.: 21-004-0008

TABLE 1 - SUMMARY OF WASTEWATER DEMANDS - LS 3-1

PHASE	LAND USE	QUANTITY	UNITS	DEMAND	UNITS	ADF		PEAK FACTOR	MDF	
						(gpd)	(gpm)		(gpd)	(gpm)
ER	SF Homes (actual)	80	UNITS	300	GPD/UNIT	24,000	16.7	2.5	60,000	41.7
ER	SF Homes (additional)		UNITS	300	GPD/UNIT	0	0.0	2.5	0	0.0
TOTAL		80				24,000	16.7		60,000	41.7



Project: Howey
Table: 2 - Lift Station Design
Engineer(s): SC/RB
Date: 3/28/2022
Job No.: 21-004-0008

Revised: 3/31/2022

TABLE 2 - LIFT STATION DESIGN - LS 2-1

PUMP DATA

MANUFACTURER	Pentair	MODEL	Hydromatic-S4K	
PUMP CURVE	SUB_S_E_AH_00011_E_4 Rev 2012-03-23		IMPELLER SIZE	9.5 IN, rated
PUMP HORSEPOWER	7.9 HP, rated	DESIGN SPEED	1750 RPM, rated	

DESIGN FLOWS

ADF QIN 16.7 GPM

PDF QIN 41.7 GPM

HYDRAULIC MODEL RESULTS


MAX PRESSURE	45.0 GPM OUTFLOW @	95.5 FT TDH
MIN PRESSURE	18 GPM OUTFLOW @	49.1 FT TDH

WET WELL STORAGE

Q	45 (GPM) FLOW OUT OF WET WELL PUMP DISCHARGE, ONE RUNNING
S	42 (GPM) WASTEWATER FLOW INTO WET WELL - PDF IN
T	20 (MIN) ASSUMED CYCLE TIME
V	61.7 (GAL) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
	8.3 (FT ³) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
STORAGE DEPTH	2.00 FT

WET WELL DESIGN

ELEVATION	63.00 SLAB TOP (WW INVERT)
ELEVATION	63.25 PUMP VOLUTE
ELEVATION	65.00 BOTH PUMPS OFF
ELEVATION	67.00 START LEAD
ELEVATION	68.00 START LAG
ELEVATION	69.00 HIGH LEVEL ALARM
ELEVATION	90.00 TOP OF WET WELL
ELEVATION	70 INFLUENT INVERT
TOTAL LIFT STATION DEPTH	27.00 FT



ID - INSIDE DIAMETER	8 FT	FS - FLOOR SLAB THICKNESS	12 IN
W - WALL THICKNESS	8 IN	AD - ADD SLAB DIAMETER	16 IN
TS - TOP SLAB THICKNESS	0 IN	OD - TOTAL SLAB DIAMETER	12.0 FT

CYCLE TIME EVALUATION

AVERAGE DAILY FLOW

TIME ON	2.18 MIN
TIME OFF	3.70 MIN
TOTAL CYCLE TIME	5.88 MIN
STARTS PER HOUR	10

PEAK DAILY FLOW

TIME ON	18.52 MIN
TIME OFF	1.48 MIN
TOTAL CYCLE TIME	20.00 MIN
STARTS PER HOUR	3.0

DESIGN CHECKS

DEPTH FROM INFLUENT INVERT TO TOP OF SLAB (WET WELL INVERT)

REQUIRED	5 FT	PROVIDED	7.00 FT
TOTAL CYCLE TIME MINIMUM			
REQUIRED	10 MIN	PROVIDED	5.88 MIN

DEPTH FROM HIGH LEVEL ALARM TO ALL PUMPS OFF

REQUIRED

3 FT

PROVIDED

4.00 FT

WET WELL FLOATATION**ASSUMPTIONS**

- 1) WEIGHT OF PUMPS, FITTINGS, ETC. NOT INCLUDED.
- 2) WET WELL IS EMPTY - FLUID WEIGHT WITHIN STRUCTURE IS NOT CONSIDERED
- 3) GROUNDWATER LEVEL IS AT TOP OF WET WELL
- 4) SOIL FRICTION FORCE IS EXCLUDED, ONLY THE WEIGHT OF SOIL ON TOP OF BOTTON OF SLAB IS CONSIDERED

DOWNWARD FORCES

CONCRETE WALLS

CONCRETE WALLS 18.2 FT²
 27.00 FT (DEPTH OF WALLS)
 490.1 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.1 FT³

CONCRETE WEIGHT **0.0** CY - ADDITIONAL BALLAST
 603.2 FT³
 150 LB/FT³ (UNIT WEIGHT OF REENFORCED CONCRETE)
 90,478 LBS

SOIL WEIGHT 44.7 FT²
 27.00 FT (DEPTH OF WALLS)
 47.6 LB/FT³ (110 LB/FT³ - 62.4 LB/FT³ = WEIGHT OF SOIL - WEIGHT OF WATER)
 57,423 LBS

UPWARD FORCES (HYDROSTATIC)

CONCRETE WALLS

 68.4 FT²
 27.00 FT (DEPTH OF WALLS)
 1847.3 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.10 FT³

WEIGHT OF WATER

 1960.4 FT³
 62.4 LB/FT³
 122,326 LBS

TOTAL FORCES SUMMARY

DOWNWARD FORCE **147,901** LBS
UPWARD FORCE **122,326** LBS
SAFETY FACTOR **1.21**



Project: Howey
Table: 3 - Lift Station System Curve
Engineer(s): SC/RB
Date: 3/28/2022 Revised: 3/31/2022
Job No.: 21-004-0008

TABLE 3 - LIFT STATION SYSTEM CURVE - LS 2-1

STATIC/ELEVATION HEAD			
BOTH PUMPS OFF	65.00	FT	
HIGHPOINT ALONG FM	91.00	FT	
CONNECTION ELEVATION	84.00	FT	INVERT ELEVATION OF EXISTING FORCEMAIN
TOTAL STATIC LOSS	26.0	FT	
TOTAL STATIC LOSS	26.0	FT	

	LIFT STATION	LIFT STATION TO	CONNECTION TO
	RISER PIPES	CONNECTION	TO EXISTING FM
DESIGN FLOW (Q)	45 GPM	45 GPM	45 GPM
PIPE DIAMETER (D)	4 IN	6 IN	10 IN
PIPE LENGTH (L)	20 FT	100 FT	1000 FT
HAZEN WILLIAMS COEFF (C)	120	120	120
VELOCITY (V)	1.15 FT/S	0.51 FT/S	0.18 FT/S
FLOW AREA (A)	0.09 FT ²	0.20 FT ²	0.55 FT
FRICTION LOSS (HF)	0.04 FT	0.03 FT	0.02 FT
TOTAL FRICTION LOSS	0.2	FT	

CONNECTION/PRESSURE HEAD			
CONNECTION PRESSURE (max)		30	PSI
CONNECTION PRESSURE (min)		10	PSI
TOTAL PRESSURE LOSS		69.3	FT
TOTAL PRESSURE LOSS		23.1	FT

MINOR HEAD LOSS			0
FITTING TYPE	K - VALUE	COUNT	
DISCHARGE	0.6	1	
90° BEND	0.3	2	
VALVES	1.5	1	
CHECK VALVES	2.0	2	
TEE CONNECTION	0.4	1	
OUTLET	1.0	1	
USER DEFINED	0.0	0	
TOTAL		8.1	
TOTAL MINOR LOSS	0.2	FT	

SYSTEM CURVE		
Min Pressure		
FLOW RATE	TDH	INCREMENT
GPM	FT	9.00
0	49.1	
9	49.1	
18	49.1	← SYSTEM PT
27	49.1	
36	49.2	
22	49.1	
31	49.1	
40	49.2	
49	49.2	
58	49.3	
67	49.3	
76	49.3	
Max Pressure		
FLOW RATE	TDH	INCREMENT
GPM	FT	10.00
0	95.4	
10	95.4	
20	95.4	
30	95.4	
40	95.5	
45	95.5	← SYSTEM PT
55	95.5	
65	95.6	
75	95.6	
85	95.6	
95	95.7	
105	95.8	

Item number	: Default	Size	: Hydromatic - S4K
Service	:	Stages	: 1
Quantity	: 1	Based on curve number	: SUB_S_E_AH_00011_E_4 Rev
Quote number	:		2012-03-23
		Date last saved	: 31 Mar 2022 8:30 AM

Operating Conditions

Flow, rated	: 85.00 USgpm
Differential head / pressure, rated (requested)	: 95.60 ft
Differential head / pressure, rated (actual)	: 96.82 ft
Suction pressure, rated / max	: 0.00 / 0.00 psi.g
NPSH available, rated	: Ample
Site Supply Frequency	: 60 Hz

Performance

Speed criteria	: Synchronous
Speed, rated	: 1750 rpm
Impeller diameter, rated	: 9.50 in
Impeller diameter, maximum	: 12.00 in
Impeller diameter, minimum	: 8.50 in
Efficiency	: 26.29 %
NPSH required / margin required	: - / 0.00 ft
nq (imp. eye flow) / S (imp. eye flow)	: 28 / - Metric units
Minimum Continuous Stable Flow	: 128.6 USgpm
Head, maximum, rated diameter	: 103.0 ft
Head rise to shutoff	: 6.41 %
Flow, best eff. point	: 592.4 USgpm
Flow ratio, rated / BEP	: 14.35 %
Diameter ratio (rated / max)	: 79.17 %
Head ratio (rated dia / max dia)	: 58.34 %
Cq/Ch/Ce/Cn [ANSI/HI 9.6.7-2010]	: 1.00 / 1.00 / 1.00 / 1.00

Liquid

Liquid type	: Water
Additional liquid description	:
Solids diameter, max	: 0.00 in
Solids diameter limit	: 3.00 in
Solids concentration, by volume	: 0.00 %
Temperature, max	: 68.00 deg F
Fluid density, rated / max	: 1.000 / 1.000 SG
Viscosity, rated	: 1.00 cP
Vapor pressure, rated	: 0.34 psi.a

Material


Material selected	: Standard
-------------------	------------

Pressure Data

Maximum working pressure	: 44.59 psi.g
Maximum allowable working pressure	: N/A
Maximum allowable suction pressure	: N/A
Hydrostatic test pressure	: N/A

Driver & Power Data (@Max density)

Driver sizing specification	: Maximum power
Margin over specification	: 0.00 %
Service factor	: 1.00
Power, hydraulic	: 2.08 hp
Power, rated	: 7.90 hp
Power, maximum, rated diameter	: 18.88 hp
Minimum recommended motor rating	: 20.00 hp / 14.91 kW



Tab 5: Lift Station 3-1 Design



Connelly & Wicker Inc.

Planning • Engineering • Landscape Architecture

1560 North Orange Ave. | Suite 210 | Winter Park, Florida 32789

P: 407.261.3100 www.cwIeng.com



Project: Howey
Table: 1 - Summary of Wastewater Demands
Engineer(s): SC\RB
Date: 3/28/2022 Revised: 3/31/2022
Job No.: 21-004-0008

TABLE 1 - SUMMARY OF WASTEWATER DEMANDS - LS 3-1

PHASE	LAND USE	QUANTITY	UNITS	DEMAND	UNITS	ADF		PEAK FACTOR	MDF	
						(gpd)	(gpm)		(gpd)	(gpm)
ER	SF Homes (actual)	73	UNITS	300	GPD/UNIT	21,900	15.2	2.5	54,750	38.0
ER	SF Homes (additional)		UNITS	300	GPD/UNIT	0	0.0	2.5	0	0.0
TOTAL		73				21,900	15.2		54,750	38.0



Project: Howey
Table: 2 - Lift Station Design
Engineer(s): SC/RB
Date: 3/28/2022
Job No.: 21-004-0008

Revised: 3/31/2022

TABLE 2 - LIFT STATION DESIGN - LS 3-1

PUMP DATA

MANUFACTURER	Pentair	MODEL	Hydromatic-S4K
PUMP CURVE	SUB_S_E_AH_00011_E_4 Rev 2012-03-23	IMPELLER SIZE	10.13 IN, rated
PUMP HORSEPOWER	10.19 HP, rated	DESIGN SPEED	1750 RPM, rated

DESIGN FLOWS

ADF QIN 15.2 GPM

PDF QIN 38.0 GPM

HYDRAULIC MODEL RESULTS


MAX PRESSURE	38.0 GPM OUTFLOW @	98.9 FT TDH
MIN PRESSURE	16 GPM OUTFLOW @	106.2 FT TDH

WET WELL STORAGE

Q	38 (GPM) FLOW OUT OF WET WELL PUMP DISCHARGE, ONE RUNNING
S	38 (GPM) WASTEWATER FLOW INTO WET WELL - PDF IN
T	20 (MIN) ASSUMED CYCLE TIME
V	-0.4 (GAL) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
	-0.1 (FT ³) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
STORAGE DEPTH	2.00 FT

WET WELL DESIGN

ELEVATION	58.00 SLAB TOP (WW INVERT)
ELEVATION	58.25 PUMP VOLUTE
ELEVATION	60.00 BOTH PUMPS OFF
ELEVATION	62.00 START LEAD
ELEVATION	63.00 START LAG
ELEVATION	64.00 HIGH LEVEL ALARM
ELEVATION	85.00 TOP OF WET WELL
ELEVATION	65 INFLUENT INVERT
TOTAL LIFT STATION DEPTH	27.00 FT



ID - INSIDE DIAMETER	8 FT	FS - FLOOR SLAB THICKNESS	12 IN
W - WALL THICKNESS	8 IN	AD - ADD SLAB DIAMETER	16 IN
TS - TOP SLAB THICKNESS	0 IN	OD - TOTAL SLAB DIAMETER	12.0 FT

CYCLE TIME EVALUATION

AVERAGE DAILY FLOW

TIME ON	-0.02 MIN
TIME OFF	-0.03 MIN
TOTAL CYCLE TIME	-0.05 MIN
STARTS PER HOUR	-1313

PEAK DAILY FLOW

TIME ON	20.01 MIN
TIME OFF	-0.01 MIN
TOTAL CYCLE TIME	20.00 MIN
STARTS PER HOUR	3.0

DESIGN CHECKS

DEPTH FROM INFLUENT INVERT TO TOP OF SLAB (WET WELL INVERT)

REQUIRED	5 FT	PROVIDED	7.00 FT
TOTAL CYCLE TIME MINIMUM			
REQUIRED	10 MIN	PROVIDED	(0.05) MIN

DEPTH FROM HIGH LEVEL ALARM TO ALL PUMPS OFF

REQUIRED

3 FT

PROVIDED

4.00 FT

WET WELL FLOATATION**ASSUMPTIONS**

- 1) WEIGHT OF PUMPS, FITTINGS, ETC. NOT INCLUDED.
- 2) WET WELL IS EMPTY - FLUID WEIGHT WITHIN STRUCTURE IS NOT CONSIDERED
- 3) GROUNDWATER LEVEL IS AT TOP OF WET WELL
- 4) SOIL FRICTION FORCE IS EXCLUDED, ONLY THE WEIGHT OF SOIL ON TOP OF BOTTON OF SLAB IS CONSIDERED

DOWNWARD FORCES

CONCRETE WALLS

CONCRETE WALLS 18.2 FT²
 27.00 FT (DEPTH OF WALLS)
 490.1 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.1 FT³

CONCRETE WEIGHT **0.0** CY - ADDITIONAL BALLAST
 603.2 FT³
 150 LB/FT³ (UNIT WEIGHT OF REENFORCED CONCRETE)
 90,478 LBS

SOIL WEIGHT 44.7 FT²
 27.00 FT (DEPTH OF WALLS)
 47.6 LB/FT³ (110 LB/FT³ - 62.4 LB/FT³ = WEIGHT OF SOIL - WEIGHT OF WATER)
 57,423 LBS

UPWARD FORCES (HYDROSTATIC)

CONCRETE WALLS

 68.4 FT²
 27.00 FT (DEPTH OF WALLS)
 1847.3 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.10 FT³

WEIGHT OF WATER

 1960.4 FT³
 62.4 LB/FT³
 122,326 LBS

TOTAL FORCES SUMMARY

DOWNWARD FORCE **147,901** LBS
UPWARD FORCE **122,326** LBS
SAFETY FACTOR **1.21**



Project: Howey
Table: 3 - Lift Station System Curve
Engineer(s): SC/RB
Date: 3/28/2022 Revised: 3/31/2022
Job No.: 21-004-0008

TABLE 3 - LIFT STATION SYSTEM CURVE - LS 3-1

STATIC/ELEVATION HEAD		
BOTH PUMPS OFF	60.00	FT
HIGHPOINT ALONG FM	95.00	FT
CONNECTION ELEVATION	95.00	FT
INVERT ELEVATION OF EXISTING FORCEMAIN		
TOTAL STATIC LOSS	35.0	FT
TOTAL STATIC LOSS	35.0	FT

FRICTION HEAD		
	LIFT STATION RISER PIPES	LIFT STATION TO CONNECTION
DESIGN FLOW (Q)	38 GPM	38 GPM
PIPE DIAMETER (D)	4 IN	4 IN
PIPE LENGTH (L)	20 FT	1285 FT
HAZEN WILLIAMS COEFF (C)	120	120
VELOCITY (V)	0.97 FT/S	0.97 FT/S
FLOW AREA (A)	0.09 FT ²	0.09 FT ²
FRICTION LOSS (HF)	0.03 FT	1.87 FT
TOTAL FRICTION LOSS	2.2	FT

CONNECTION/PRESSURE HEAD		
CONNECTION PRESSURE (max)	30	PSI
CONNECTION PRESSURE (min)	10	PSI
TOTAL PRESSURE LOSS	69.3	FT
TOTAL PRESSURE LOSS	23.1	FT

MINOR HEAD LOSS		
	0	
FITTING TYPE	K - VALUE	COUNT
DISCHARGE	0.6	1
90° BEND	0.3	2
VALVES	1.5	1
CHECK VALVES	2.0	2
TEE CONNECTION	0.4	1
OUTLET	1.0	1
USER DEFINED	0.0	0
TOTAL		8.1
TOTAL MINOR LOSS	0.1	FT

SYSTEM CURVE		
Min Pressure		
FLOW RATE	TDH	INCREMENT
GPM	FT	8.00
0	58.1	
8	58.2	
16	58.5	← SYSTEM PT
24	58.9	
32	59.5	
85	66.5	
93	68.1	
101	69.7	
109	71.5	
117	73.3	
125	75.3	
133	77.4	
Max Pressure		
FLOW RATE	TDH	INCREMENT
GPM	FT	8.00
0	104.3	
8	104.4	
16	104.7	
24	105.1	
32	105.7	
38	106.2	← SYSTEM PT
46	107.0	
54	107.9	
62	109.0	
70	110.2	
78	111.5	
86	112.9	

Item number	: Default	Size	: Hydromatic - S4K
Service	:	Stages	: 1
Quantity	: 1	Based on curve number	: SUB_S_E_AH_00011_E_4 Rev
Quote number	:		2012-03-23
		Date last saved	: 31 Mar 2022 8:28 AM

Operating Conditions

Flow, rated	: 80.00 USgpm
Differential head / pressure, rated (requested)	: 112.0 ft
Differential head / pressure, rated (actual)	: 113.2 ft
Suction pressure, rated / max	: 0.00 / 0.00 psi.g
NPSH available, rated	: Ample
Site Supply Frequency	: 60 Hz

Performance

Speed criteria	: Synchronous
Speed, rated	: 1750 rpm
Impeller diameter, rated	: 10.13 in
Impeller diameter, maximum	: 12.00 in
Impeller diameter, minimum	: 8.50 in
Efficiency	: 22.20 %
NPSH required / margin required	: - / 0.00 ft
nq (imp. eye flow) / S (imp. eye flow)	: 28 / - Metric units
Minimum Continuous Stable Flow	: 145.2 USgpm
Head, maximum, rated diameter	: 118.8 ft
Head rise to shutoff	: 6.03 %
Flow, best eff. point	: 671.2 USgpm
Flow ratio, rated / BEP	: 11.92 %
Diameter ratio (rated / max)	: 84.38 %
Head ratio (rated dia / max dia)	: 67.34 %
Cq/Ch/Ce/Cn [ANSI/HI 9.6.7-2010]	: 1.00 / 1.00 / 1.00 / 1.00

Liquid

Liquid type	: Water
Additional liquid description	:
Solids diameter, max	: 0.00 in
Solids diameter limit	: 3.00 in
Solids concentration, by volume	: 0.00 %
Temperature, max	: 68.00 deg F
Fluid density, rated / max	: 1.000 / 1.000 SG
Viscosity, rated	: 1.00 cP
Vapor pressure, rated	: 0.34 psi.a

Material


Material selected	: Standard
-------------------	------------

Pressure Data

Maximum working pressure	: 51.40 psi.g
Maximum allowable working pressure	: N/A
Maximum allowable suction pressure	: N/A
Hydrostatic test pressure	: N/A

Driver & Power Data (@Max density)

Driver sizing specification	: Maximum power
Margin over specification	: 0.00 %
Service factor	: 1.00
Power, hydraulic	: 2.26 hp
Power, rated	: 10.19 hp
Power, maximum, rated diameter	: 24.81 hp
Minimum recommended motor rating	: 25.00 hp / 18.64 kW



Tab 6: Lift Station 4-1 Design



Connelly & Wicker Inc.

Planning • Engineering • Landscape Architecture

1560 North Orange Ave. | Suite 210 | Winter Park, Florida 32789

P: 407.261.3100 www.cwleag.com



Project: Howey

Table: 1 - Summary of Wastewater Demands

Engineer(s): SC\RB

Date: 3/28/2022 Revised: 3/31/2022

Job No.: 21-004-0008

TABLE 1 - SUMMARY OF WASTEWATER DEMANDS - LS 4-1

PHASE	LAND USE	QUANTITY	UNITS	DEMAND	UNITS	ADF		PEAK FACTOR	MDF	
						(gpd)	(gpm)		(gpd)	(gpm)
ER	SF Homes (actual)	177	UNITS	300	GPD/UNIT	53,100	36.9	2.5	132,750	92.2
ER	SF Homes (additional)		UNITS	300	GPD/UNIT	0	0.0	2.5	0	0.0
TOTAL		177				53,100	36.9		132,750	92.2



Project: Howey
 Table: 2 - Lift Station Design
 Engineer(s): SC/RB
 Date: 3/28/2022
 Job No.: 21-004-0008

Revised: 3/31/2022

TABLE 2 - LIFT STATION DESIGN - LS 4-1

PUMP DATA

MANUFACTURER	Pentair	MODEL	Hydromatic-S4NRC/S4NVX
PUMP CURVE	SUB_S_V_AH_00003_B_4 Rev 2012-03-23		IMPELLER SIZE
PUMP HORSEPOWER	2.77 HP, rated	DESIGN SPEED	1750 RPM, rated

DESIGN FLOWS

ADF QIN	36.9 GPM	PDF QIN	92.2 GPM
---------	----------	---------	----------

HYDRAULIC MODEL RESULTS


MAX PRESSURE	95.0 GPM OUTFLOW @	98.9 FT TDH
--------------	--------------------	-------------

WET WELL STORAGE

Q	95 (GPM) FLOW OUT OF WET WELL PUMP DISCHARGE, ONE RUNNING
S	92 (GPM) WASTEWATER FLOW INTO WET WELL - PDF IN
T	20 (MIN) ASSUMED CYCLE TIME
V	54.6 (GAL) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
	7.3 (FT ³) VOLUME REQUIRED BETWEEN LEAD PUMP ON AND BOTH PUMPS OFF
STORAGE DEPTH	2.00 FT

WET WELL DESIGN

ELEVATION	63.00 SLAB TOP (WW INVERT)
ELEVATION	63.25 PUMP VOLUTE
ELEVATION	65.00 BOTH PUMPS OFF
ELEVATION	67.00 START LEAD
ELEVATION	68.00 START LAG
ELEVATION	69.00 HIGH LEVEL ALARM
ELEVATION	90.00 TOP OF WET WELL
ELEVATION	70 INFLUENT INVERT
TOTAL LIFT STATION DEPTH	27.00 FT



ID - INSIDE DIAMETER	8 FT	FS - FLOOR SLAB THICKNESS	12 IN
W - WALL THICKNESS	8 IN	AD - ADD SLAB DIAMETER	16 IN
TS - TOP SLAB THICKNESS	0 IN	OD - TOTAL SLAB DIAMETER	12.0 FT

CYCLE TIME EVALUATION

AVERAGE DAILY FLOW

TIME ON	0.94 MIN
TIME OFF	1.48 MIN
TOTAL CYCLE TIME	2.42 MIN
STARTS PER HOUR	25

PEAK DAILY FLOW

TIME ON	19.41 MIN
TIME OFF	0.59 MIN
TOTAL CYCLE TIME	20.00 MIN
STARTS PER HOUR	3.0

DESIGN CHECKS

DEPTH FROM INFLUENT INVERT TO TOP OF SLAB (WET WELL INVERT)

REQUIRED	5 FT	PROVIDED	7.00 FT
TOTAL CYCLE TIME MINIMUM			
REQUIRED	10 MIN	PROVIDED	2.42 MIN

DEPTH FROM HIGH LEVEL ALARM TO ALL PUMPS OFF

REQUIRED

3 FT

PROVIDED

4.00 FT

WET WELL FLOATATION**ASSUMPTIONS**

- 1) WEIGHT OF PUMPS, FITTINGS, ETC. NOT INCLUDED.
- 2) WET WELL IS EMPTY - FLUID WEIGHT WITHIN STRUCTURE IS NOT CONSIDERED
- 3) GROUNDWATER LEVEL IS AT TOP OF WET WELL
- 4) SOIL FRICTION FORCE IS EXCLUDED, ONLY THE WEIGHT OF SOIL ON TOP OF BOTTON OF SLAB IS CONSIDERED

DOWNWARD FORCES

CONCRETE WALLS

CONCRETE WALLS 18.2 FT²
 27.00 FT (DEPTH OF WALLS)
 490.1 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.1 FT³

CONCRETE WEIGHT **0.0** CY - ADDITIONAL BALLAST
 603.2 FT³
 150 LB/FT³ (UNIT WEIGHT OF REENFORCED CONCRETE)
 90,478 LBS

SOIL WEIGHT 44.7 FT²
 27.00 FT (DEPTH OF WALLS)
 47.6 LB/FT³ (110 LB/FT³ - 62.4 LB/FT³ = WEIGHT OF SOIL - WEIGHT OF WATER)
 57,423 LBS

UPWARD FORCES (HYDROSTATIC)

CONCRETE WALLS

 68.4 FT²
 27.00 FT (DEPTH OF WALLS)
 1847.3 FT³

SLAB 113.1 FT²
 1.0 FT (THICKNESS)
 113.10 FT³

WEIGHT OF WATER

 1960.4 FT³
 62.4 LB/FT³
 122,326 LBS

TOTAL FORCES SUMMARY

DOWNWARD FORCE **147,901** LBS
UPWARD FORCE **122,326** LBS
SAFETY FACTOR **1.21**



Project: Howey
Table: 3 - Lift Station System Curve (4-1)
Engineer(s): SC/RB
Date: 3/28/2022 Revised: 3/31/2022
Job No.: 21-004-0008

TABLE 3 - LIFT STATION SYSTEM CURVE - LS 4-1

STATIC/ELEVATION HEAD

BOTH PUMPS OFF	65.00	FT
HIGHPOINT ALONG FM	91.00	FT
CONNECTION ELEVATION	90.00	FT
INVERT ELEVATION OF MANHOLE		
TOTAL STATIC LOSS	26.0	FT
TOTAL STATIC LOSS	26.0	FT

FRICTION HEAD

	LIFT STATION RISER PIPES	LIFT STATION TO CONNECTION
DESIGN FLOW (Q)	95 GPM	95 GPM
PIPE DIAMETER (D)	4 IN	4 IN
PIPE LENGTH (L)	20 FT	769 FT
HAZEN WILLIAMS COEFF (C)	120	120
VELOCITY (V)	2.43 FT/S	2.43 FT/S
FLOW AREA (A)	0.09 FT ²	0.09 FT ²
FRICTION LOSS (HF)	0.16 FT	6.09 FT
TOTAL FRICTION LOSS	7.9	FT

CONNECTION/PRESSURE HEAD

CONNECTION PRESSURE (max)	0	PSI	CONNECTION PRESSURE (min)	0	PSI
TOTAL PRESSURE LOSS	0.0	FT	TOTAL PRESSURE LOSS	0.0	FT

MINOR HEAD LOSS

FITTING TYPE	K - VALUE	COUNT
DISCHARGE	0.6	1
90° BEND	0.3	2
VALVES	1.5	1
CHECK VALVES	2.0	2
TEE CONNECTION	0.4	1
OUTLET	1.0	1
USER DEFINED	0.0	0
TOTAL		8.1
TOTAL MINOR LOSS	0.7	FT

SYSTEM CURVE

Min Pressure		
FLOW RATE	TDH	INCREMENT
GPM	FT	20.00
0	26.0	
20	26.4	
40	27.3	
60	28.7	
80	30.6	
95	32.3	← SYSTEM PT
112	34.6	
129	37.1	
146	40.0	
163	43.2	
180	46.6	
197	50.4	

Item number	: Default	Size	: Hydromatic - S4NRC/S4NVX
Service	:	Stages	: 1
Quantity	: 1	Based on curve number	: SUB_S_V_AH_00003_B_4 Rev
Quote number	:		2012-03-23
		Date last saved	: 31 Mar 2022 8:33 AM

Operating Conditions

Flow, rated	: 95.00 USgpm
Differential head / pressure, rated (requested)	: 32.30 ft
Differential head / pressure, rated (actual)	: 34.45 ft
Suction pressure, rated / max	: 0.00 / 0.00 psi.g
NPSH available, rated	: Ample
Site Supply Frequency	: 60 Hz

Performance

Speed criteria	: Synchronous
Speed, rated	: 1750 rpm
Impeller diameter, rated	: 6.50 in
Impeller diameter, maximum	: 8.00 in
Impeller diameter, minimum	: 5.50 in
Efficiency	: 29.88 %
NPSH required / margin required	: - / 0.00 ft
nq (imp. eye flow) / S (imp. eye flow)	: 30 / - Metric units
Minimum Continuous Stable Flow	: 52.80 USgpm
Head, maximum, rated diameter	: 39.60 ft
Head rise to shutoff	: 14.96 %
Flow, best eff. point	: 179.7 USgpm
Flow ratio, rated / BEP	: 52.86 %
Diameter ratio (rated / max)	: 81.25 %
Head ratio (rated dia / max dia)	: 66.24 %
Cq/Ch/Ce/Cn [ANSI/HI 9.6.7-2010]	: 1.00 / 1.00 / 1.00 / 1.00
Selection status	: Acceptable

Liquid

Liquid type	: Water
Additional liquid description	:
Solids diameter, max	: 0.00 in
Solids diameter limit	: 3.00 in
Solids concentration, by volume	: 0.00 %
Temperature, max	: 68.00 deg F
Fluid density, rated / max	: 1.000 / 1.000 SG
Viscosity, rated	: 1.00 cP
Vapor pressure, rated	: 0.34 psi.a

Material


Material selected	: Standard
-------------------	------------

Pressure Data

Maximum working pressure	: 17.14 psi.g
Maximum allowable working pressure	: N/A
Maximum allowable suction pressure	: N/A
Hydrostatic test pressure	: N/A

Driver & Power Data (@Max density)

Driver sizing specification	: Maximum power
Margin over specification	: 0.00 %
Service factor	: 1.00
Power, hydraulic	: 0.83 hp
Power, rated	: 2.77 hp
Power, maximum, rated diameter	: 4.25 hp
Minimum recommended motor rating	: 5.00 hp / 3.73 kW



Tab 7: Hydraulic Model of Manifolded System




Connelly & Wicker Inc.

Planning • Engineering • Landscape Architecture

1560 North Orange Ave. | Suite 210 | Winter Park, Florida 32789

P: 407.261.3100 www.cwlang.com

Scenario: Base



FlexTable: Reservoir Table

FlexTable: Reservoir Table

ID	Label	Elevation (ft)	Zone	Flow (Out net) (gpm)	Hydraulic Grade (ft)
31	LS-1-1	70.00	<None>	180	70.00
40	R-2	120.00	<None>	-1,248	120.00
42	LS-1-2	70.00	<None>	391	70.00
47	LS-2-1	70.00	<None>	677	70.00

FlexTable: Pump Table

FlexTable: Pump Table

ID	Label	Elevation (ft)	Pump Definition	Status (Initial)	Hydraulic Grade (Suction) (ft)	Hydraulic Grade (Discharge) (ft)	Flow (Total) (gpm)	Pump Head (ft)
32	PMP-1-1	70.00	Pump Definition - 1-1	On	69.97	139.58	180	69.61
44	PMP-1-2	70.00	Pump Definition - 1-2	On	69.89	152.49	391	82.60
49	PMP-2-1	70.00	Pump Definition - 2-1	On	69.70	140.95	677	71.25

FlexTable: Pipe Table

FlexTable: Pipe Table

ID	Label	Length (Scaled) (ft)	Start Node	Stop Node	Diameter (in)	Material	Hazen-Williams C	Has Check Valve?	Minor Loss Coefficient (Local)	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)	Has User Defined Length?	Length (User Defined) (ft)
33	P-1	55	LS-1-1	PMP-1-1	4.0	PVC	120.0	False	0.000	180	4.60	0.026	True	1
37	P-3	73	J-2	J-3	10.0	PVC	120.0	False	0.000	180	0.74	0.000	True	1,100
39	P-4	90	J-3	J-4	10.0	PVC	120.0	False	0.000	571	2.33	0.003	True	1,000
41	P-5	63	J-4	R-2	10.0	PVC	120.0	False	0.000	1,248	5.10	0.011	True	1,000
45	P-7	33	LS-1-2	PMP-1-2	4.0	PVC	120.0	False	0.000	391	9.98	0.109	True	1
51	P-8	34	PMP-2-1	LS-2-1	4.0	PVC	120.0	False	0.000	-677	17.27	0.301	True	1
55	P-2(1)	20	PMP-1-1	J-5	4.0	PVC	120.0	False	0.000	180	4.60	0.026	True	20
56	P-2(2)	57	J-5	J-2	6.0	PVC	120.0	False	0.000	180	2.05	0.004	True	1,510
58	P-6(1)	18	PMP-1-2	J-6	4.0	PVC	120.0	False	0.000	391	9.98	0.109	True	20
59	P-6(2)	94	J-6	J-3	6.0	PVC	120.0	False	0.000	391	4.43	0.015	True	1,128
61	P-8(1)	67	J-4	J-7	6.0	PVC	120.0	False	0.000	-677	7.68	0.042	True	100
62	P-8(2)	19	J-7	PMP-2-1	4.0	PVC	120.0	False	0.000	-677	17.27	0.301	True	20

FlexTable: Junction Table

FlexTable: Junction Table

ID	Label	Elevation (ft)	Demand (gpm)	Hydraulic Grade (ft)	Pressure (psi)
34	J-2	90.00	0	133.62	19
36	J-3	90.00	0	133.29	19
38	J-4	88.00	0	130.76	19
54	J-5	90.00	0	139.06	21
57	J-6	90.00	0	150.31	26
60	J-7	90.00	0	134.93	19