

WATER MASTER PLAN

TOWN OF HOWEY-IN-THE-HILLS

Prepared For:



Prepared By:



902 North Sinclair Avenue + Tavares, Florida 32778
Phone (352) 343-8481 + Fax (352) 343-8495

December 2024

TOWN OF HOWEY-IN-THE-HILLS

WATER MASTER PLAN

Prepared for:

TOWN OF HOWEY-IN-THE-HILLS
101 N. Palm Avenue • Howey-in-the-Hills, Florida 34737

Prepared by:

HALFF ASSOCIATES, INC.
902 N. Sinclair Avenue • Tavares, Florida 32778



Digitally signed by
Troy Mitchell
DN: cn=Troy
Mitchell,
ou=Tavares
Date: 2024.12.16
10:49:14 -05'00'

Troy Mitchell, P.E. #60190

Date: December 16, 2024

TABLE OF CONTENTS

SECTION 1	Introduction	
1.0	General	1
1.1	Master Plan Objectives	1
1.2	Data Collection	2
1.3	Content and Organization	2
SECTION 2	Existing Potable Water System	
2.0	Background	3
2.1	Water Treatment Facilities	4
2.2	Existing Water Distribution System	8
SECTION 3	Potable Water Demand Projections	
3.0	General	10
3.1	Existing Population	10
3.2	Existing Water Usage Rate	11
3.3	Projected Growth and Water Usage Rates	14
3.4	Alternative Water Supply	20
SECTION 4	Regulatory Compliance	
4.1	SJRWMD Consumptive Use Permit	21
4.2	FDEP Water Treatment Plant Permit	22
SECTION 5	Potable Water System Evaluation	
5.0	General	25
5.1	Evaluation of Existing System	25
5.2	Summary of Recommended Improvements	27
5.3	Summary of Remaining Capital Improvement Costs	39
SECTION 6	Construction Cost Estimation Methodology	
6.0	Introduction	40
6.1	Level of Contingency	40
6.2	Engineering Services Costs	40
SECTION 7	Summary and Recommendations	
7.0	General	41
7.1	Summary	41
7.2	Recommendations	41
7.3	Updates to the Water Master Plan Report	43

TABLE OF CONTENTS **(continued)**

Figures

Figure 1	Water Service Area Map
Figure 2	Future Planned Residential Developments
Figure 3	WTP No. 3 Capital Improvements
Figure 4	Proposed Capital Water Distribution System Key Map
Sheet 1	Proposed Capital Water Distribution System Map
Sheet 2	Proposed Capital Water Distribution System Map
Sheet 3	Proposed Capital Water Distribution System Map
Sheet 4	Proposed Capital Water Distribution System Map
Sheet 5	Proposed Capital Water Distribution System Map
Sheet 6	Proposed Capital Water Distribution System Map
Sheet 7	Proposed Capital Water Distribution System Map
Sheet 8	Proposed Capital Water Distribution System Map
Sheet 9	Proposed Capital Water Distribution System Map
Sheet 10	Proposed Capital Water Distribution System Map
Sheet 11	Proposed Capital Water Distribution System Map
Sheet 12	Proposed Capital Water Distribution System Map
Sheet 13	Proposed Capital Water Distribution System Map
Sheet 14	Proposed Capital Water Distribution System Map

Tables

Table A	Estimated Historical Service Connections and Water Demand
Table B	Historic Water Usage Per Service Connection Type
Table C	WTP MOR's 2018-2023
Table D	Future Residential Developments and Demands
Table E	Future Non-Residential Developments and Demands
Table F	Future Planned Developments
Table G	Projected Water Demands
Table H	WaterCAD Analysis - Summary of Results
Table I	WTP No. 3 - Engineer's Opinion of Probable Construction Cost
Table J	Distribution - Engineer's Opinion of Probable Construction Cost
Table K	Total Estimated Capital Cost by Year

Appendices

- Appendix A Service Area Map
- Appendix B Future Land Use Map
- Appendix C Consumptive Use Permit
- Appendix D 2020 Water Audit
- Appendix E Sanitary Survey Reports
- Appendix F Water Treatment System Calculations
- Appendix G WaterCAD Analyses

Section 1

Introduction

1.0 General

The Town of Howey-in-the-Hills' water treatment and distribution system consists of three (3) potable supply wells, two (2) water treatment plants, and approximately 20 miles of distribution piping networked throughout the Town. The water treatment plants have an average annual combined consumptive use permitted capacity of 0.90 million gallons per day (MGD) for household, commercial/industrial, urban landscape irrigation, water utility, and unaccounted for water use until March 12, 2029. The Florida Department of Environmental Protection (FDEP) has assigned WTP No. 1 and WTP No. 2 permitted capacities of 1.80 MGD and 0.72 MGD, respectively.

The purpose of this report is to provide a planning tool for the Town of Howey-in-the-Hills to utilize in planning future capital needs of the potable water system as well as expansions and upgrades to the water system.

1.1 Master Plan Objectives

This Potable Water Master Plan was undertaken with the following objectives:

- Provide an overview of the Town's existing potable water treatment assets.
- Review the Town's potable water service area and areas targeted for expansion.
- Establish a potable water level of service based upon historical potable water demand data.
- Project the number of future connections and potable water demands within the service area.
- Evaluate compliance with regulatory requirements related to water treatment plant capacity and groundwater withdrawals.
- Develop recommendations for improvements to the potable water treatment system to maintain compliance with existing and proposed future regulatory requirements and to accommodate new growth.
- Prepare a conceptual opinion of probable construction cost for the recommended improvements.
- Prioritize recommended improvements into an implementation plan with triggers based upon growth in the number of new service connections.

1.2 Data Collection

The recommendations in this Potable Water Master Plan were developed based upon a review of data found within the Town's FDEP Permits, St. John's Water Management District (SJRWMD) Consumptive Use Permit, Water Treatment Plant Monthly Operating Reports, EN-50 groundwater withdrawal forms, historical utility billing data, and discussions with Town staff.

1.3 Content and Organization

This Potable Water Master Plan presents the data and methods used to evaluate the Town's potable water treatment and distribution systems, and recommendations for improvements to continue to maintain the same high level of service currently provided to the Town's customers while accommodating future growth. The remainder of the Potable Water Master Plan is organized as described below:

- **Section 2 – Existing Potable Water System:** Review of the potable water system including service area, water treatment plants, and distribution system.
- **Section 3 – Potable Water Demand Projections:** Analysis of historical potable water demand data in order to develop a level of service standard and preparation of future demand projections.
- **Section 4 – Regulatory Compliance:** Evaluation of compliance with all current FDEP and SJRWMD permit requirements.
- **Section 5 – Potable Water System Evaluation:** Evaluation of current potable water system assets with their respect to meet permit limitations at future projected flows and recommendations for improvements.
- **Section 6 – Construction Cost Estimation Methodology:** Methodology for estimating capital costs of project implementation and estimated unit costs.
- **Section 7 – Summary and Recommendations:** Summary of the recommendations of the master plan.

Section 2

Existing Potable Water System

2.0 Background

The Town of Howey in the Hills (Town) established a Chapter 180 Utility Reserve Area (URA) by Ordinance No. 2003-307 in 2003 and revised under Ordinance No. 2013-006. Prior to the URA, the Town's water service area had been limited to its municipal boundaries which encompassed approximately 820 acres. The URA extended the service area to approximately 13,600 acres which consists mainly of agricultural tracts and rural residential use properties. The Town's Utility Service Area Map, as prepared by B&H Consultants, Inc., is attached as Appendix A.

The Town owns and maintains a public water system identified by the state as PWS I.D. No. 3350573. The Town's current water treatment and distribution system consists of three (3) potable supply wells, two (2) water treatment facilities, and approximately 20 miles of distribution piping networked throughout the town. The existing water treatment facilities have a combined maximum day design capacity of 2.52 million gallons per day (MGD). The system currently has approximately 1,284 service connections. The majority of the connections within the Town's service area are residential (1,226) with an estimated population of 2,624. The Town's service area also includes non-residential service connections consisting of commercial, institutional and municipal usage.

The Town's water system is currently operated as two separate systems (north and south) due to elevation differences. The north system is served by Water Treatment Plant (WTP) No. 2 which is located at the intersection of State Road 19 and County Road 48. WTP No. 2 is located on property owned by the FDOT and is leased to the Town. The lease agreement between the Town and the FDOT expires on October 29, 2028. The lease will not be renewed due to the FDOT's plans to expand the intersection with the construction of a roundabout. Property for a new water treatment plant (WTP No. 3) was purchased by the Town from the Lake Hills development. WTP No. 3 will be located on a parcel north and adjacent to the existing WTP No. 2 site. WTP No. 3 is currently in design and its two (2) lower floridan wells have been drilled. WTP No. 2 will be decommissioned when the new water treatment plant is placed in operation. The south system is served by WTP No. 1 which is located at the Public Works Complex on Central Avenue.

The systems are isolated via a pressure regulating valve (PRV) and control system located at the intersection of Magnolia Avenue and SR 19. Currently the system pressures on the north and south sides of the pressure regulating valve are 34 psi

and 55 psi, respectively. The PRV is intended to open when plant pressure at either facility drops below their respective operating pressure set point. Current setpoints are 52 psi on the WTP No. 1 side of the valve and 32 psi on the WTP No. 2 side of the valve.

The Town's current Consumptive Use Permit (CUP No. 2596-9) was issued on March 12, 2024 by the St Johns River Water Management District (SJRWMD). The CUP permits a maximum annual combined groundwater withdraw of 328.5 million gallons per year (MGY) – 0.90 million gallons per day (MGD) annual average. The Town's CUP expires on March 12, 2029. A copy of the CUP is attached in Appendix C. A summary of the groundwater supply wells for each water treatment facility is shown in Table 2.1.

Table 2.1
Summary of Water Supply System

Treatment Facility	Well No.	Well Pump Capacity (gpm)	FDEP Plant Capacity (MGD)	Type of Use
WTP No. 1	2	1,200	1.80	Potable
	4	1,000		Potable
WTP No. 2 ⁽¹⁾	3	1,000	0.72	Potable
WTP No. 3 ⁽²⁾	5	1,500	2.58 ⁽³⁾	Potable
	6	1,500		Potable
Total Well Capacity		5,200⁽⁴⁾	4.38	

- Notes:
1. WTP No. 2 will be abandoned when WTP No. 3 is on-line.
 2. WTP No. 3 is currently in the design/permitting phase.
 3. Estimated permitted capacity.
 4. Excludes well capacity from WTP No. 2.

The Florida Department of Environmental Protection (FDEP) updated the Sanitary Survey Report for both treatment facilities in June 2023. A copy of both reports is provided in Appendix E.

2.1 Water Treatment Facilities

The following is a description of the City's existing water treatment plants and proposed water treatment plant:

2.1.1 WTP No. 1

WTP No. 1 is located at the Public Works Complex on Central Avenue and consists of the following components.

- Two (2) Raw Water Wells
 - Well No. 2 (1,000 gpm capacity)
 - Well No. 4 (1,200 gpm capacity)
- One (1) Chlorine Gas system
- One (1) Aquamag Iron Sequestration system
- One (1) 0.25 MG CROM Ground Storage Tank with a cascade tray aerator
- Two (2) 150 hp Horizontal Split-Case High Service Pumps (2,800 gpm capacity, each)
- One (1) 60 hp Horizontal Split-Case High Service Pump (1,000 gpm capacity)
- One (1) 50 hp Horizontal Split-Case High Service Pump (360 gpm capacity)
- One (1) Auxiliary Power 500 kW generator

Well No. 2 is permitted with the St Johns River Water Management District (SJRWMD) and has the well identification number GRS ID No. 9557. Well No. 2 consists of a 12" casing to a depth of 191' below ground surface, and a total well depth of 334'. The well was drilled in 1964. The water is withdrawn from the Upper Floridan Aquifer. Water is pumped from the well by a *Jacuzzi* 12MSB4 vertical turbine pump powered by a 75 HP motor. The pump is rated at 1,200 gpm.

Well No. 4 is permitted with the St Johns River Water Management District (SJRWMD) and has the well identification number GRS ID No. 421002. Well No. 4 consists of a 12" casing to a depth of 303' below ground surface, and a total well depth of 450'. The well was drilled in 2012. The water is withdrawn from the Upper Floridan Aquifer. Water is pumped from the well by a *Demming* 4700 Series vertical turbine pump powered by a 60 HP motor. The pump is rated at 1,000 gpm.

Water is pumped from these wells to the 0.25-MG CROM ground storage tank which is equipped with a natural draft cascade tray aerator for the removal of hydrogen sulfide. The cascade tray aerator has a capacity of 2,600 gpm. The influent header piping from the ground storage tank (GST) to the horizontal split-case high service pumps is installed above grade at the side of the GST. It should be noted that a portion of the storage volume of the GST is not usable due to the elevations of the GST and high service pumps. The high service pumps are horizontal split-case high service

pumps which require a flooded suction condition on the influent header piping. Because of this condition, water level the GST cannot be pumped below the intake elevation of the header pipe. Therefore, the overall storage capacity of the GST is reduced.

Disinfection of the raw water is accomplished via chlorine gas. The chlorine gas is transferred into the system by a *Hydro Instruments*, 150 lb cylinder feed, simple rotameter system and a 1.5 hp Goulds booster pump. The 150 lb cylinders are stored in a chlorine storage room as well as two scales capable of holding one cylinder each. The system has a 250 ppd capacity. The current chlorine feed rate is 52 ppd.

Dissolved iron is inhibited within the ground water via an Aquamag Iron Sequestration system using a blended phosphate solution. The solution is injected into the finished water distribution piping via Strenner chemical feed pump, Model 45MHP2, at a feed rate of 3 gallons per day. The phosphate solution is stored in 55-gallon storage drum.

Finished water is pumped into the distribution system via four variable speed, horizontal split-case centrifugal high service pumps. The high service pumps are *Crane-Deming* Series 5060 pumps. Two (2) of the high service pumps are rated for 2,800 gpm with a 150 hp motor. The third high service pump is rated for 1,000 gpm with a 60 hp motor. The fourth high service pump, or jockey pump, is rated for 360 gpm with a 60 hp motor.

Water pumping rates are controlled by system pressure. As system pressure decreases, pump output increases in order to maintain constant system pressure. Normal operating pressure at this facility is 65 psi.

Plant flows are monitored and recorded with a chart recorder, totalizer and flow indicator. The plant's discharge meter is a 12" Badger Magmeter.

Backup power is provided to the well pumps and high service pump station via a 500 kW emergency generator and automatic transfer switch. The generator is equipped with a 500-gallon, dual wall fuel tank.

The entire facility is connected to a Supervisory Control And Data Acquisition (SCADA) system.

2.1.2 WTP No. 2

WTP No. 2 which is located at the intersection of State Road 19 and County Road 48 and consists of the following components.

- One (1) Raw Water Well
 - Well No. 3 (1,000 gpm capacity)
- One (1) Chlorine Gas system
- One (1) Aquamag Iron Sequestration system
- One (1) 15,000-gallon Hydropneumatic Tank
- One (1) Auxiliary Power 150 kW generator

Well No. 3 is permitted with the St Johns River Water Management District (SJRWMD) and has the well identification number GRS ID No. 9558. Well No. 3 consists of a 14" casing to a depth of 162' below ground surface, and a total well depth of 350'. The well was drilled in 1990. The water is withdrawn from the Upper Floridan Aquifer. Water is pumped from the well by a *Peerless* NB-4 vertical turbine pump powered by a 75 HP motor. The pump is rated at 1,000 gpm.

Disinfection of the raw water is accomplished via chlorine gas. The chlorine gas is transferred into the system by a *Hydro Instruments*, 150 lb cylinder feed, simple rotameter system and a 1.5 hp Goulds centrifugal booster pump. The 150 lb cylinders are stored in a chlorine storage room as well as two scales capable of holding one cylinder each. The system has a 100 ppd capacity. The current chlorine feed rate is 40 ppd.

Dissolved iron is inhibited within the ground water via an Aquamag Iron Sequestration system using a blended phosphate solution. The solution is injected into the finished water distribution piping via Strenner chemical feed pump, Model 45MHP2, at a feed rate of 3 gallons per day. The phosphate solution is stored in 55-gallon storage drum.

Water is pumped from this well to the 15,000-gallon ASME certified hydropneumatic tank. The hydro tank has ON and OFF setpoints of 50 psi and 65 psi, respectively.

Backup power is provided to the well pumps and high service pump station via a 150-kW emergency generator and automatic transfer switch. The generator is equipped with a 500-gallon, dual wall fuel tank.

2.1.3 WTP No. 3

WTP No. 3 will be located on a parcel north and adjacent to the existing WTP No. 2 site. Property for WTP No. 3 was dedicated to the Town by the Lake Hills development. WTP No.2 will be abandoned when WTP No. 3 is placed into operation.

WTP No. 3 is currently in the design phase and is anticipated to consist of the following components.

- Two (2) Raw Water Wells
 - Well No. 5 (1,500 gpm capacity)
 - Well No. 6 (1,500 gpm capacity)
- One (1) Chlorine Gas system
- One (1) Aquamag Iron Sequestration system (if required)
- Two (2) 0.60 MG CROM Ground Storage Tanks with a cascade tray aerator. One (1) tank will be built with the initial plant construction and the second tank will be constructed at a future date.
- Three (3) 75 hp Vertical Turbine High Service Pumps (1,000 gpm capacity, each)
- One (1) 40 hp Vertical Turbine High Service Pump (600 gpm capacity)
- One (1) Auxiliary Power generator

Well No. 5 is permitted with the St Johns River Water Management District (SJRWMD) and has the well identification number GRS ID No. 39899. Well No. 5 consists of a 12" casing to a depth of 750' below ground surface, and a total well depth of 1,061'. The well was drilled in 2024. The water is withdrawn from the Lower Floridan Aquifer. Water will be pumped from the well with a vertical turbine pump powered by a 75 HP motor. The pump will be rated at 1,500 gpm.

Well No. 6 is permitted with the St Johns River Water Management District (SJRWMD) and has the well identification number GRS ID No. 540961. Well No. 6 consists of a 12" casing to a depth of 750' below ground surface, and a total well depth of 1,087'. The well was drilled in 2024. The water will be withdrawn from the Lower Floridan Aquifer. Water will be pumped from the well by a vertical turbine pump powered by a 75 HP motor. The pump will be rated at 1,500 gpm.

2.2 Existing Water Distribution System

The existing potable water distribution system consists of a network of various sizes and materials of pipe ranging from 2-inches diameter to 12-inches diameter. The Town's water system is very limited in capital water mains (i.e. 10 inches in diameter and greater) throughout the distribution system. The majority of the existing network is +40 years old. There are areas where thin-walled PVC pipe was used and subsequently there have been issues with pipe failures in those areas. There is also an area in the northern section of Town that cannot be isolated from the system with valves. Most of the 8-inch and 12-inch piping is relatively new as it was installed in the early and mid-2000's.

Based upon information received from the Town's Utility Department, there are approximately 20 miles of potable water lines within the Town's service area. Table 2.2 illustrates the approximate lengths of each diameter water line existing in the Town system as of March, 2024.

Table 2.2 Estimated Lengths of Potable Water Piping (Linear Feet)						
2"	4"	6"	8"	10"	12"	Total
1,675	3,770	70,065	29,230	---	740	105,513

A hydraulic model of the Town's existing, potable water distribution system was created using the Bentley WaterCAD computer program. System pressures in the model were verified by field conditions of dynamic pressures at the pressure regulating valve (PRV) and control system located at the intersection of Magnolia Avenue and SR 19. Currently the system pressures on the north and south sides of the PRV are 34 psi and 55 psi, respectively.

According to Section 7.3.1 of the Recommended Standards for Water Works, the minimum working pressure in the distribution system should be 35 psi and the normal working pressure should be approximately 60 psi to 80 psi. The model indicates that the average daily operating pressure in the existing system ranges from 23 psi to 84 psi. The lowest pressure in the system is located within the Mission Inn development which is in the northern section of town that is served by WTP No. 2. This is also the highest elevation in the existing system. The highest pressure observed in the model is located near the Boondocks restaurant which is in the southern section of town on Lake Shore Boulevard that is served by WTP No. 1. The WaterCAD analyses for the distribution system is attached as Appendix G.

Section 3

Potable Water Demand Projections

3.0 General

The recommendations contained within this report are based predominantly on the anticipated population growth and subsequent increase in water demand within the Town's Projected Utility Service Area. Water demand projections for the Town of Howey in the Hills were based on the historic water use and an average population per capita.

The existing number of residential, commercial, institutional and municipal connections were obtained from the Town Utility Billing Department. Table 3.1 lists the annual water service connections from 2018 through 2023. A map of the Town's existing Utility Service Area can be found in Figure 1, attached herein. Historically, the residential demand is approximately 36.8% and the combined commercial, institutional and municipal demands are 8.6% of the total average daily demand. Historic irrigation demand, construction and utility usage and unaccounted water are 40.2%, 8.8% and 5.6%, respectively. These ratios have been utilized in the attached projections. There has been no recent growth in commercial, institutional and municipal connections.

**Table 3.1
Historic Water Service Connections**

Year	Residential	Non-Residential			
		Irrigation	Commercial	Institutional	Municipal
2018	811	26	25	5	4
2019	879	26	25	5	4
2020	938	17	25	5	4
2021	1,088	17	25	5	4
2022	1,146	22	25	5	4
2023	1,226	24	25	5	4

3.1 Existing Population

Historic population of the Town as reported by the US Census Bureau is presented in Table 3.2. Based on the US Census information over the past 50 years, the average persons per residential unit is 2.11.

Table 3.2
Historic Population per Housing Unit

	2020	2010	2000	1990	1980	1970
Population	1,643	1,098	956	724	626	466
Housing Units	715	484	450	351	320	239
Population per Housing Unit	2.30	2.27	2.12	2.06	1.96	1.95

Since the Town's total population and the population served with water are not the same, Table A, attached in the Tables section of this report, illustrates the historic residential and non-residential service connections, population and water demands as indicated by the Town Utility Billing Department and the Town's WTP Monthly Operating Reports (MOR) for the years 2018-2023. Existing population per housing unit (2.30) was based on the 2020 US Census Bureau information. A summary of the total residential and non-residential service connections and population for 2018 through 2023 is presented in Table 3.3 below.

Table 3.3
Historic Service Connections and Population

	2023	2022	2021	2020	2019	2018
Population	2,820	2,636	2,502	2,157	2,022	1,865
Residential Connections	1,226	1,146	1,088	938	879	811
Non-Residential Connections	58	56	51	51	60	60

The historic rate of growth between 2018 and 2023 is approximately 51% with an average annual growth rate of 7.2%.

3.2 Existing Water Usage Rate

Table A illustrates the historic annual water demands for residential and non-residential service connections. Based on billing information provided by the Town's billing department, the five-year average percentage of water demand for residential connections is 36.8% of the total system demand. Irrigation connections account for 40.2% of the system demand. The percentage for the combined commercial, institutional, and municipal connections is 8.6%. Builder construction and utility usage are approximately 8.8% and unaccounted water

losses (average of 2021 and 2022) is approximately 5.6% of the total system demand. A summary of historic annual average demands is presented in Table 3.4 below.

Table 3.4
Historic Annual Average Demands

Year	Residential (MGD)	Commercial (MGD)	Irrigation (MGD)	Builder (MGD)	Unaccounted (MGD)	Total (MGD)
2018	0.114	0.027	0.125	0.027	0.017	0.311
2019	0.165	0.039	0.180	0.039	0.025	0.448
2020	0.152	0.036	0.166	0.036	0.023	0.415
2021	0.142	0.033	0.155	0.034	0.022	0.386
2022	0.161	0.038	0.176	0.039	0.025	0.438
2023	0.169	0.040	0.185	0.041	0.026	0.461

Chapter 4 of the Town's Comprehensive Plan lists an overall system demand per capita of 242 gallons per capita per day (gpcd) and a residential use demand of 150.8 gpcd. The Towns, *Water Impact Fee Study*, prepared by B&H Consultants, Inc., and adopted as part of Ordinance No. 2006-003, indicates that the average household consists of 2.48 persons and that the per capita demand is 150 gpcd. This equates to an average daily water demand of 372 gpd per single-family home which is referred to as an Equivalent Residential Unit (ERU).

The historic residential demands per ERU and per capita are presented in Table 3.5 below. A population per ERU of 2.30 (2020 US Census) was used to determine the existing per capita demand. The historic six-year average demand per ERU was determined to be 150 gpd/ERU. The historic six-year average demand per capita was calculated to be 68 gpcd, which is approximately 55% less than the per capita demand of 150 gpcd presented in Ordinance No. 2006-003. The six-year average for overall system demand capacity per ERU was calculated to be 408 gpd/ERU. The average for overall system demand capacity per capita was calculated to be 184 gpcd. This is approximately 24% less than the overall system demand per capita of 242 gpcd listed in the Town's Comprehensive Plan. The reduction in demand could be attributed to new home construction with low-flow fixtures as well conservation efforts established by the Town. Future system demand projections will include a residential demand of 408 gpd/ERU for all existing residential connections.

Table 3.5
Historic Residential Demand per ERU

Year	Residential				Demand	
	Demand (MGY)	Demand (MGD)	Connections	Population	Per ERU (gpd/ERU)	Per Capita (gpcd)
2018	41.737	0.114	811	1,865	141	61
2019	60.137	0.165	879	2,022	187	81
2020	55.754	0.152	938	2,157	162	71
2021	51.887	0.142	1,088	2,502	131	57
2022	58.791	0.161	1,146	2,636	141	61
2023	61.856	0.169	1,226	2,820	138	60
Average				150	68	

Table B presents the historic water usage billed per service connection type, which were obtained from the Town Utility Billing Department. A summary of Table B is presented in Table 3.6 below.

Table 3.6
Historic Demand Per Service Connection Type

Year	Total Billed (MG)	Usage Billed				Annual Average Billed Demand (MGD)
		Residential (MG)	Commercial (MG)	Irrigation (MG)	Builder (MG)	
2019	132.652	58.440	27.902	38.676	7.634	0.363
2020	258.582	100.442	33.190	119.365	5.585	0.708
2021	161.448	74.586	13.924	66.987	5.952	0.442
2022	149.084	58.605	3.534	72.712	14.233	0.408
2023	160.643	60.238	4.327	87.727	8.351	0.440

Table C presents the monthly average daily and monthly maximum daily demands as listed on the Town's MOR's for the years 2019-2023. A summary of the annual average daily demand (AADD) and maximum month daily demand (MMDD) for each well is presented in Table 3.7 below.

Table 3.7
Historic Annual Average Demands

Year	AADD			MMDD		
	Well No. 2 (MGD)	Well No. 3 (MGD)	Well No. 4 (MGD)	Well No. 2 (MGD)	Well No. 3 (MGD)	Well No. 4 (MGD)
2019	0.207	0.118	0.123	0.671	0.357	0.367
2020	0.151	0.146	0.117	0.615	0.389	0.335
2021	0.119	0.119	0.148	0.419	0.419	0.580
2022	0.157	0.132	0.149	0.483	0.394	0.458
2023	0.168	0.134	0.158	0.593	0.261	0.350

Table 3.8 below presents the historic annual average daily demands and maximum month daily demands of the Town's water system. The five-year ratio of maximum month daily demand to annual average daily demand is calculated to be approximately 2.0.

Table 3.8
Historic Annual Average and Maximum Month Daily Demands

Year	Annual Average Daily Demand (MGD)	Maximum Month Daily Demand (MGD)	Maximum Month Ratio
2019	0.447	0.924	2.10
2020	0.414	0.812	1.95
2021	0.386	0.749	1.94
2022	0.437	0.859	1.97
2023	0.460	0.856	1.85
Total Average			1.96

3.3 Projected Population Growth and Water Usage Demands

A map of the Town's existing Utility Service Area can be found in Figure 1, attached herein. It is anticipated that the majority of the Town's growth within the service area boundary will occur southward to serve properties along the State Road 19 corridor and westward. Growth is also expected northward along the State Road 19 and County Road 48 corridor. Figure 2 shows the proposed residential developments within the Town's service area. The Town's Future Land Use Map is attached as Appendix B.

The following recommendations are based predominantly on the anticipated population growth and subsequent increase in water demand within the Town's Projected Utility Service Area. Water demand projections for the Town of Howey

in the Hills were based on the historic water use and an average population per capita.

3.3.1 Projected Population Growth

US Census data included on the current 2024 CUP list an average household size of 2.46 persons. This is similar to the Towns *Water Impact Fee Study*, prepared by B&H Consultants, Inc., and adopted as part of Ordinance No. 2006-003, indicates that the average household consists of 2.48 persons. Population projections for future growth will be based on the 2.46 persons per household. Figure 2 shows the future residential developments listed in Table D. A summary of the future residential developments and associated population growth as outlined in Table D is presented in Table 3.9 below.

Table 3.9 Planned Future Residential Developments and Population		
Development Name	Equivalent Residential Units	Population
Approved Developments		
Venezia South Townhomes	113	278
Venezia Talichet Phase II (<i>completed</i>)	21	52
Whispering Hills	156	384
Lake Hills (Four Seasons)	571	1,405
The Reserve	728	1,791
Watermark (Simpson Parcel)	225	554
Subtotal	1,814	4,464
Future Developments		
Mission Rise	499	1,228
Thompson Grove (Bouis Property)	272	669
Westminster (Marina)	350	861
Cedar Creek (Daryl Carter)	171	421
Golden Hills (J-5 Equities)	607	1,493
Cypress Point	110	271
Drake Point	530	1,304
Subtotal	2,539	6,247
Total Proposed Residential	4,353	10,708
Total Existing Residential	1,226	2,820
Total Residential	5,579	13,528

There are currently six (6) approved developments within the Town's service area. Talichet Phase II is recently completed. It is expected that

these developments will bring an additional 1,814 residential units with an estimated population of 4,464 into the Town's service area. There are seven (7) other areas scheduled for future developments within the Town's service area. It is expected that these developments will bring an additional 2,539 residential units with an estimated population of 6,247 into the Town's service area. Based on approved and anticipated future growth, it is anticipated that 4,353 residential units with a population of 10,708 will be added to the Town's service area. It should be noted that the Cedar Creek PUD and the Drake Point PUD properties are not contiguous to the Town limits and will be approved and built under the Lake County jurisdiction, but are anticipated to be provided service by the Town's potable water system.

It is anticipated that the Town will also have non-residential growth within its service area. Table E lists the anticipated non-residential developments. There are currently three (3) approved commercial and two (2) approved institutional developments within the Town's service area. A summary of the future non-residential development growth as outlined in Table E is presented in Table 3.10 below.

Table 3.10 Planned Future Residential Developments and Population	
Development Name	Gross Floor Area (ft ²)
Approved Commercial Developments	
Venezia South	85,000
Lake Hills (Four Seasons)	150,000
The Reserve	300,000
Total Commercial	535,000
Approved Institutional Developments	
Lake Hills (Four Seasons)	176,000
The Reserve	205,000
Total Institutional	381,000

3.3.2 Projected Water Usage Demands

Chapter 4 of the Town's Comprehensive Plan lists an overall system demand per capita of 242 gpcd and a residential use demand of 150.8 gpcd. However, Land Development Code (LDC) Section 171.25 establishes irrigation design standards for new residential, commercial and industrial systems. The LDC also imposes regulations for landscape irrigation systems in order to limit the use of potable water for irrigation. All future developments will have to find and alternative means of providing irrigation water with the Town only providing potable water for indoor uses.

The projected water demands for the Town's service area is presented in Tables D and E. Historic annual demand from 2018 through 2023 showed an overall system demand per capita of 184 gpcd (403 gpd per ERU) and an average residential daily demand of 150 gpd per ERU. Average daily water demand for future residential connections is projected forward at 150 gpd/ERU (61 gpcd based on 2.46 persons per household). Water demands for commercial and recreational uses are based on 0.15 gpd/ft² of floor area. Civic and institutional uses are based on 0.25 gpd/ft² of floor area. The maximum daily demand (MDD) condition was calculated using a historic ratio to the average daily demand (ADD) of 2:1. The peak hour demand (PHD) condition was based on an FDEP standard ratio to the average daily demand (ADD) of 4:1. A summary of Tables D and E is presented in Table 3.11 below.

Table 3.11
Planned Future Developments and Demands

Development	ERUs	Gross Floor Area (ft ²)	Demand		
			ADD (MGD)	MDD (MGD)	PHD (MGD)
Approved Residential Developments					
Venezia South Townhomes	113		0.017	0.034	0.068
Venezia – Talichet Phase II	21		0.003	0.006	0.013
Whispering Hills	156		0.023	0.047	0.094
Lake Hills (Four Seasons)	571		0.086	0.171	0.343
The Reserve	728		0.109	0.218	0.437
Watermark (Simpson Parcel)	225		0.034	0.068	0.135
Subtotal	1,814				
Future Residential Developments					
Mission Rise	499		0.075	0.150	0.299
Thompson Grove (Bouis)	272		0.041	0.082	0.163
Westminster (Marina)	350		0.053	0.105	0.210
Cedar Creek (Daryl Carter)	171		0.026	0.051	0.103
Golden Hills (J-5 Equities)	607		0.091	0.182	0.364
Cypress Point	110		0.017	0.033	0.066
Drake Point	530		0.080	0.159	0.318
Subtotal	2,539				
Total Proposed Residential	4,353		0.653	1.306	2.612
Total Existing Residential	1,226		0.500	1.000	2.001
Total Residential	5,579		1.153	2.306	4.613
Approved Non-Residential Commercial Developments					
Venezia South		85,000	0.013	0.026	0.051
Lake Hills (Four Seasons)		150,000	0.023	0.045	0.090
The Reserve		300,000	0.045	0.090	0.180
Approved Non-Residential Institutional Developments					
Lake Hills (Four Seasons)		176,000	0.044	0.088	0.176
The Reserve		205,000	0.051	0.103	0.205
Total Proposed Non-Residential		916,000	0.176	0.351	0.702
Total Existing Non-Residential			0.040	0.080	0.160
Total Non-Residential			0.216	0.431	0.862
Total			1.369	2.737	5.475

Note: Does not include builder or irrigation demands or unaccounted losses.

Projected residential, commercial and institutional water demands for the City's service area can be seen in Table F for the years 2024 to 2043. The total projected water demands - including irrigation, construction, and unaccounted losses - for the City's service area can be seen in Table G for the years 2024 to 2043. Unaccounted losses were project forwarded at 10% which is the maximum allowable per the Consumptive Use Permit. The projections are based on the assumption that the housing market remains stable and continues to grow and the proposed developments will

reach build-out. A summary of Table F and Table G is presented in Table 3.12 below.

Year	Residential	Commercial	Irrigation	Builder	Losses	Total	
						ADD	MDD
2024	0.503	0.040	0.185	0.072	0.082	0.883	1.765
2025	0.512	0.040	0.185	0.073	0.083	0.893	1.786
2026	0.528	0.052	0.185	0.076	0.087	0.928	1.857
2027	0.567	0.064	0.185	0.081	0.092	0.989	1.978
2028	0.623	0.119	0.185	0.092	0.105	1.124	2.247
2029	0.696	0.164	0.185	0.104	0.118	1.267	2.533
2030	0.788	0.164	0.185	0.113	0.128	1.379	2.757
2031	0.883	0.215	0.185	0.128	0.145	1.556	3.111
2032	0.955	0.215	0.185	0.135	0.153	1.643	3.286
2033	1.038	0.215	0.185	0.143	0.162	1.743	3.486
2034	1.080	0.215	0.185	0.147	0.167	1.794	3.589
2035	1.112	0.215	0.185	0.150	0.171	1.834	3.667
2036	1.138	0.215	0.185	0.153	0.174	1.865	3.731
2037	1.153	0.215	0.185	0.154	0.176	1.833	3.766
2038	1.153	0.215	0.185	0.000	0.176	1.729	3.458
2039	1.153	0.215	0.185	0.000	0.176	1.729	3.458
2040	1.153	0.215	0.185	0.000	0.176	1.729	3.458
2041	1.153	0.215	0.185	0.000	0.176	1.729	3.458
2042	1.153	0.215	0.185	0.000	0.176	1.729	3.458
2043	1.153	0.215	0.185	0.000	0.176	1.729	3.458
Total	1.153	0.215	0.185		0.176	1.729	3.458

Based on approved and anticipated future growth, it is anticipated that 4,353 residential units with a population of 10,708 will be added to the Town's service area. The projected total system water demand is 1.729 MGD based on an annual average daily demand (AAD) and 3.458 MGD based on a maximum daily demand (MDD). It is anticipated that the service area will reach build out by 2038.

Due to the ever-changing nature of the economy and its impact on growth rates and costs of construction, it is recommended that this report be updated approximately every five years in order to ensure that sufficient funds are being collected to pay for water system improvements.

3.4 Alternative Water Supply

The Town does not own or operate a wastewater treatment facility. Wastewater treatment throughout the older section of town is accomplished via individual, on-site septic systems. The Town currently has an interlocal agreement with the Central Lake Community Development District (CDD) [Mission Inn] for wastewater treatment. However, the treatment facility has limited capacity and only serves the *Lake Hills School*, the *Venezia South* development and the future *The Reserve* development. The CDD's Mission Inn Wastewater Treatment Plant (WWTP) is not capable of producing reclaimed water and the Town currently does not have the infrastructure available for a reclaimed water system.

There are five proposed developments whose property currently has an active CUP for citrus grove irrigation. There is a potential to modify the CUPs for residential and non-residential irrigation systems for their respective development. The CUPs are outlined in Table 3.13 below.

**Table 3.13
Existing CUPs for Development Irrigation**

Development	CUP No.	Exp. Date	Source	Permitted Withdraw (MGY)	Withdraw (MGD)
Lake Hills	2664-7	05/24/2041	Lake Harris	60.30	0.165
Thompson Grove	135453-2	06/09/2026	Ltl Lake Harris	30.02	0.082
Drake Point	2666-4	11/24/2040	Lake Harris	38.41	0.105
			Upper Floridan	9.6	0.026
The Reserve	2791-5	03/07/2027	Upper Floridan	59.43	0.163
Watermark	2571-5	01/27/41	Upper Floridan	45.61	0.125

According to the current CUP, the Town is proposing a requirement for stormwater reuse to the extent economically, technically, and environmentally feasible for all new developments. The generated surface water will be available for landscape irrigation purposes for the new construction and proposed developments.

Section 4

Regulatory Compliance

4.1 SJRWMD Consumptive Use Permit

Raw groundwater withdrawals for the production of potable water are regulated by the St. John's River Water Management District through the issuance of a Consumptive Use Permit (CUP). The Town of Howey in the Hills was issued CUP Number 2596-9 on March 12, 2024, with an expiration date of March 12, 2029. The CUP is attached herein as Appendix B.

4.1.1 Ground Water Withdrawals

Maximum annual groundwater withdrawals for potable water from the Town's five (5) production wells as a combined total are stated within the CUP. The combined total includes water usage for households, commercial/industrial, urban landscape irrigation, water utility and unaccounted water. Total allowable ground water withdrawals must not exceed either 328.5 million gallons per year or 0.90 million gallons per day based on an annual average. A summary of the Town's historic withdraws and the CUP limitations is presented in the Table 4.1 below.

**Table 4.1
Historic Water Withdraws (2018-2023)**

Year	Annual Withdraw (MGY)	CUP Limit (MGY)	Annual Average Daily Withdraw (MGD)	CUP Limit (MGD)
2018	113.4	328.5	0.311	0.900
2019	163.4	328.5	0.447	0.900
2020	151.5	328.5	0.414	0.900
2021	141.0	328.5	0.386	0.900
2022	159.8	328.5	0.437	0.900
2023	168.1	328.5	0.460	0.900

Based on the historic maximum water withdraw, the Town's is operating at approximately 51.2% of its CUP limit for annual withdraw and its CUP limit for annual average daily flow. It is anticipated that the Town will reach its CUP withdraw limits by year 2029, based the future projections shown on Table G.

4.1.2 Water Loss

As a condition of the CUP a water loss audit is required every three years to show that water loss in the distribution system is less than 10 percent of the groundwater withdrawal for the previous year. Observed water loss greater than the 10 percent limit requires the completion of a meter survey to ensure water is being properly metered. Unmetered water uses including fire hydrant flushing, water main breaks, allowable water main losses, and water used in firefighting are not considered water loss. The most recent water loss audit completed by the Town for the SJRWMD in 2020, attached herein as Appendix D, showed water loss of approximately 12.9 percent, which exceeds the allowable water loss requirements of the permit. In order to remain in compliance with the requirements of the CUP, the Town began an investigation into the excessive water loss. As a result of the investigation, the Town's water audits for 2021 and 2022 showed a loss of 6.4 percent and 4.9 percent, respectively. The Town's water audit for 2023 is currently in process.

4.2 FDEP Water Treatment Plant Permit

The Florida Department of Environmental Protection is responsible for issuing permits related to the construction of water treatment facilities and distribution systems. Unlike the CUP issued by the SJRWMD, these permits do not expire. Also, while the SJRWMD CUP limits are based on annual average groundwater withdrawals, FDEP Operating Permits for Water Treatment Facilities provide limits on the amount of potable water that may be produced in a single day, providing a capacity in terms of maximum day demand.

4.2.1 Water Treatment Plant No. 1

WTP No. 1 has a permitted capacity of 1.80 MGD. The plant consists of two ground water wells with a combined capacity of 3.168 MGD and one 0.25 MG ground storage tank equipped with cascade tray aeration. The plant also includes four horizontal split-case high service pumps with a combined capacity of 10.022 MGD, Aquamag iron sequestration system, chlorine gas injection system, and a 500-kW auxiliary generator. The permitted capacity of this plant is limited by its storage capacity.

4.2.2 Water Treatment Plant No. 2

WTP No. 2 has a permitted capacity of 0.72 MGD. The plant consists of a 1.440 MGD capacity ground water well, a 15,000-gallon hydro-pneumatic tank, Aquamag iron sequestration system, chlorine injection system, and a 150-kW auxiliary generator. The 15,000-gallon hydro-pneumatic tank which is not permitted to be counted towards the required system storage

for larger system. The permitted capacity of this plant is limited by its storage capacity. It is noted that WTP No. 2 will be decommissioned when the new WTP No. 3 is placed into service.

4.2.3 Water Treatment Plant No. 3

WTP No. 3 is currently in design phase and has not yet been permitted by the FDEP. It is anticipated that WTP No. 3 will have at a minimum, a permitted capacity of 2.58 MGD.

4.2.4 Total FDEP Permitted WTP Capacity

The current, combined permitted capacity of WTP No. 1 and WTP No. 2 is 2.52 MGD. The permitted capacity of the combined water treatment plants is limited by its storage capacity. Chapter 62-555.320, F.A.C., states that the total finished-water storage capacity connected to a water system shall at least equal 25% of the system's maximum-day water demand, excluding any design fire-flow demand. Currently, the finished-water storage for the entire system is currently being accomplished with one 0.25-million-gallon ground storage tank and one 15,000-gallon hydro-pneumatic tank. The 15,000-gallon hydro-pneumatic tank at WTP No. 2 may not be counted as finished water storage for large water systems only ground or elevated storage may be counted. This provides a total storage capacity for the system of 250,000 gallons and equates to a maximum-day demand of 1.0 MGD. A summary of the Town's historic maximum daily demands and the FDEP permit limitations is presented in the Table 4.2 below.

**Table 4.2
Historic Maximum Daily Demands (2018-2023)**

Year	Maximum Daily Demand (MGD)	FDEP Permit Capacity (MGD)	Rated Capacity Based on Storage (MGD)
2018	0.631	2.52	1.00
2019	0.924	2.52	1.00
2020	0.812	2.52	1.00
2021	0.749	2.52	1.00
2022	0.859	2.52	1.00
2023	0.856	2.52	1.00

It is anticipated that the Town will reach its rated capacity based on finished water storage limitations by year 2026, based the future projections shown on Table G.

The permitted capacity of WTP No. 3 will be 2.58 MGD. The combination of the rated capacities of WTP No. 1 and WTP No. 3 will be 4.38 MGD, which is approximately 25% more than the projected maximum daily demand of 3.458 MGD anticipated for year 2038. The initial phase of WTP No. 3 will include the construction of one (1) 600,000-gallon ground storage tank. A second 600,000-gallon tank will be constructed at a future date. The Town's potable water system will no longer be limited by storage capacity with the addition of WTP No. 3.

Section 5

Potable Water System Evaluation

5.0 General

The Town of Howey in the Hills water system consists of two water treatment plants, WTP No. 1, WTP No. 2, and approximately 20 miles of potable water lines. As of December 2023, the water treatment plants and distribution system served 2,555 metered connections which consisted of 1,226 residential, 34 commercial and institutional, and 26 irrigation connections.

5.1 Evaluation of Existing System

Evaluations of the Town's existing water treatment plant and distribution system are presented below. The evaluations are based on plant flow rates, system demands, and field observations.

5.1.1 WTP No. 1

The rated design capacity of this facility is 1.80 MGD. The permitted capacity of this plant is limited by its storage capacity. The plant consists of the following:

- One (1) 1,000 gpm production well - Well No. 2
- One (1) 1,200 gpm production well - Well No. 4
- One (1) Aquamag iron sequestration system
- One (1) Gas Chlorination system
- One (1) 250,000-gallon Ground Storage Tank with a 2,600 gpm Cascade Tray Aerator
- Two (2) 2,800 gpm, 150-hp Horizontal Split-Case High Service Pumps with variable speed drives
- One (1) 1,000 gpm, 60-hp Horizontal Split-Case High Service Pump with variable speed drive
- One (1) 360 gpm, 50-hp *jockey* Horizontal Split-Case High Service Pump with a variable speed drive
- One (1) 500 kVA auxiliary power generator
- One (1) SCADA monitoring and control system

The influent header piping from the ground storage tank (GST) to the horizontal split-case high service pumps is installed above grade at the side of the GST. The horizontal split-case high service pumps require a flooded suction condition on the influent header piping. Because of this condition,

water level the GST cannot be pumped below the intake elevation of the header pipe. Therefore, the overall storage capacity of the GST is reduced.

5.1.2 WTP No. 2

The rated design capacity of this facility is 0.72 MGD. The permitted capacity of this plant is limited by its storage capacity. The plant consists of the following:

- One (1) 1,000 gpm production well - Well No. 3
- One (1) Aquamag iron sequestration system
- One (1) Gas Chlorination system
- One (1) 15,000-gallon Hydro-pneumatic Tank
- One (1) 150 kW auxiliary power generator

The design of Water Treatment Plant No. 2 included a hydro-pneumatic tank. Chapter 62-555.320(20), F.A.C., states that new hydro-pneumatic tanks shall be designed and constructed in accordance with Section 7.2 in *Recommended Standards for Water Works* (RSWW). Section 7.2 in RSWW states, “*Hydro-pneumatic tanks, when provided as the only storage facility, are acceptable only in very small water systems. When serving more than 150 living units, ground or elevated storage designed in accordance with Section 7.0.1 should be provided. Pressure tank storage is not to be considered for fire protection purposes.*”

Chapter 62-555.320, F.A.C., states that the total finished-water storage capacity connected to a water system shall at least equal 25% of the system’s maximum-day water demand, excluding any design fire-flow demand. Currently, the finished-water storage for the entire system is currently being accomplished with one 0.25-million-gallon ground storage tank and one 15,000-gallon hydro-pneumatic tank. The 15,000-gallon hydro-pneumatic tank at WTP No. 2 may not be counted as finished water storage for large water systems only ground or elevated storage may be counted. This provides a total storage capacity for the system of 250,000 gallons and equates to a maximum-day demand of 1.0 MGD.

WTP No. 2 is located on property owned by the FDOT and is leased to the Town. The lease agreement between the Town and the FDOT expires on October 29, 2028. The least extension is anticipated to expire and will not be renewed due to the FDOT’s plans to expand the intersection of State Road 19 and County Road 48 with the construction of a round-about.

5.1.3 Potable Water Distribution System

There are approximately 20 miles of potable water lines within the Town's service area. The existing potable water distribution system consists of various sizes and materials of pipe ranging from 2-inches diameter to 12-inches diameter. The Town's water system is very limited in capital water mains (i.e. 10 inches in diameter and greater) throughout the distribution system. Most of the 8-inch and 12-inch piping is relatively new as it was installed in the early and mid-2000's. The majority of the existing network is +40 years old. There are areas where thin-walled PVC pipe was used and subsequently there have been issues with pipe failures in those areas. There is also an area in the northern section of Town that cannot be isolated from the system with valves.

The Town's water system is currently operated as two separate systems (north and south) due to elevation differences. The north system is served by Water Treatment Plant (WTP) No. 2 and the south system is served by WTP No. 1. The systems are isolated via a pressure regulating valve (PRV) and control system located at the intersection of Magnolia Avenue and SR 19. Currently the system pressures on the north and south sides of the pressure regulating valve are 34 psi and 55 psi, respectively. The PRV is intended to open when plant pressure at either facility drops below their respective operating pressure set point. Current setpoints are 52 psi on the WTP No. 1 side of the valve and 32 psi on the WTP No. 2 side of the valve.

5.2 Summary of Recommended Improvements

Several upgrades to the Town's Capital Water System are necessary in order to ensure the ability to provide adequate water service and fire protection through buildup of the projected Utility Service Area. Additions to the Town's distribution system will be necessary to further loop the system and to provide water service to areas located at the periphery of the existing distribution system.

It should be noted that material and labor costs have increased significantly since the previous Water Master Plan was completed in 2018. It is recommended that the improvements listed here in be used by the Town's rate consultant to update the Water Impact Fee Report and assess increasing impact fees in order to ensure that sufficient funding is available for future improvements.

A summary of these improvements is provided below.

5.2.1 WTP No. 1

Recommendations to the Town's existing water treatment plant are presented below.

Replace the existing horizontal split-case high service pump station with a vertical turbine high service pump station. The proposed vertical turbine pumps will be can-mounted with an intake header pipe install below the ground storage tank floor in order to have full use of the tank's storage capacity. The estimated construction cost for recommended WTP No. 1 improvements is presented in Table 5.1 below.

Table 5.1 Estimated Construction Cost for WTP No. 1 Improvements	
Vertical Turbine Pumps and Cans	\$ 340,000.00
Yard Piping	\$ 85,000.00
Electrical, I&C and SCADA Improvements	\$ 150,000.00
Demolish Existing HSP Pump Station	\$ 100,000.00
Subtotal	\$ 675,000.00
Payment/Performance Bond (5%)	\$ 28,750.00
Contract Administration (3%)	\$ 17,250.00
Engineering/Surveying/Construction Admin. (15%)	\$ 86,250.00
Contingency (15%)	\$ 86,250.00
Total	\$ 931,500.00

5.2.2 WTP No. 2

Recommendations to the Town's existing water treatment plant are presented below. The estimated construction cost for recommended WTP No. 2 demolition is presented in Table 5.2 below.

- No recommendations to this plant are proposed as this facility is schedule to be decommissioned.

:

Table 5.2
Estimated Construction Cost for WTP No. 2 Demolition

Well No. 3 Abandonment	\$ 60,000.00
Geotechnical Engineer Support	\$ 10,000.00
Building, Tank and Equipment Removal	\$ 25,000.00
Subtotal	\$ 95,000.00
Contingency (15%)	\$ 14,250.00
Total	\$ 109,250.00

5.2.3 WTP No. 3

WTP No. 3 is currently in design phase and has not yet been permitted by the FDEP. It is anticipated that WTP No. 3 will have at a minimum, a permitted capacity of 2.58 MGD. This facility will replace WTP No. 2. WTP No. 3 is anticipated to consist of the following components.

- Two (2) Raw Water Wells
 - Well No. 5 (1,500 gpm capacity)
 - Well No. 6 (1,500 gpm capacity)
- One (1) Chlorine Gas system
- Two (2) 0.60 MG CROM Ground Storage Tank with a cascade tray aerator
- Three (3) 75 hp Vertical Turbine High Service Pumps (1,000 gpm capacity, each)
- One (1) 40 hp Vertical Turbine High Service Pump (600 gpm capacity)
- One (1) Auxiliary Power generator

Construction of the treatment plant is to occur in two (2) phases. The first phase will consist of the two well pumps, high service pumps, chlorination system, pump house building, auxiliary generator and one ground storage tank. Phase II will consist of the construction of the second ground storage tank. It should be noted that the tank foundation earthwork and piping to the second tank will be installed during the Phase I construction. The total projected cost for WTP No. 3 is listed in Table I. The estimated construction cost for each phase of the recommended WTP No. 3 improvements is presented in Table 5.3 below.

Table 5.3
Estimated Construction Cost for WTP No. 3

Phase I	\$ 7,249,000.00
Phase II	\$ 1,254,000.00
Total	\$ 8,503,000.00

5.2.4 Water Distribution System

The Town's water system is currently operated as two separate systems (north and south) due to elevation differences. Much of the future growth into the Town is anticipated in the southern and western section of the service area. WTP No. 1 does not have the storage supply capacity required to accommodate the future growth. The main water distribution piping between the existing treatment plants is 8-inch piping. The systems are isolated via a pressure regulating valve (PRV) and control system located at the intersection of Magnolia Avenue and SR 19. The 8-inch piping and PRV and referred to herein as the "existing interconnect", for purposes of this report and hydraulic modeling. The existing interconnect limits the Town's ability to provide redundancy for treatment, pumping and storage supply.

The Town's hydraulic model was modified to include potential scenarios that expand the Town's capital distribution system in order to accommodate future growth and associated demands. The WaterCAD scenarios for the future growth were created using maximum daily demands. The results of the WaterCAD analysis are attached as Appendix G. Fire flow demands were based on 1,000 gpm for single-family residential and 1,500 gpm for multi-family residential per the Town's land development code. The fire flow demands for the system model were set up in the high elevation points of the northern section and southern section of the service area. The Mission Inn CDD (1,500 gpd) was selected for the northern region and the proposed Watermark PUD (1,000 gpd) for the southern section. The hydraulic model also established a 50-psi set point for the PRV. A summary of results is presented in Table H.

Multiple scenarios were created with the existing 8-inch interconnect piping and a proposed 12-inch interconnect piping. The goal was to determine minimum and maximum system pressures at service area build-out under the following conditions.

- Average Daily Demand
- Maximum Daily Demand
- Maximum Daily Demand with fire flow demand in the north
- Maximum Daily Demand with fire flow demand in the south
- Maximum Daily Demand with WTP No. 1 Offline
- Maximum Daily Demand with WTP No. 1 Offline and fire flow demand in the north
- Maximum Daily Demand with WTP No. 1 Offline and fire flow demand in the south
- Maximum Daily Demand with WTP No. 3 Offline
- Maximum Daily Demand with WTP No. 3 Offline and fire flow demand in the north
- Maximum Daily Demand with WTP No. 3 Offline and fire flow demand in the south

Based on the WaterCAD hydraulic modeling, under the existing 8-inch interconnection the Town will have adverse issues with their distribution system in the event WTP No. 1 is offline during a fire situation in either the northern or southern section of Town. This will create negative (vacuum) pressures potentially collapsing the distribution piping. There were also instances with scenario results higher than the recommended 85 psi. This would require the installation of in-line pressure reducing valves (PRVs) in the system of individual residential lot PRVs. Based upon these results, it will be necessary to install a larger 12-inch interconnect from the new WTP No. 3 south through town to Central Avenue in order to satisfy future demands.

Based on the WaterCAD hydraulic modeling, the proposed 12-inch interconnection will provide the Town the ability to balance the “two” systems and operate the two systems as one system with both WTP No. 1 and WTP No. 3 providing the pump flows from its HSPs. The proposed interconnect will allow the system to meet system demand and pressure requirements with fire flow demands and either treatment plant offline.

A summary of scenarios and pressure results is presented in Table 5.4 below.

Table 5.4
Summary of WaterCAD Analysis

Scenario Title	Fire Flow Demand (gpm)	System Minimum (psi)	Pressure Maximum (psi)
Existing Interconnect			
Ave Day – Existing Interconnect	N/A	37	79
Max Day – Existing Interconnect	N/A	37	79
Max Day – Ex Interconnect + Fire (North)	1,500	36	97
Max Day – Ex Interconnect + Fire (South)	1,000	34	79
Max Day – Ex Interconnect – WTP No.1 offline	N/A	28	103
Max Day – Ex Inter – WTP No.1 offline + Fire (N)	1,500	(-63)	77
Max Day – Ex Inter – WTP No.1 offline + Fire (S)	1,500	(-100)	77
Max Day – Ex Inter – WTP No.1 offline + Fire (S)	1,000	(-43)	93
Max Day – Ex Interconnect – WTP No.3 offline	N/A	39	82
Max Day – Ex Inter – WTP No.3 offline + Fire (N)	1,500	16	85
Max Day – Ex Inter – WTP No.3 offline + Fire (S)	1,000	38	81
Proposed Interconnect			
Max Day – Proposed Interconnect	N/A	37	79
Max Day – Prop Inter – Ex Demand Condition	N/A	40	79
Max Day – Prop Interconnect + Fire (North)	1,500	37	79
Max Day – Prop Interconnect + Fire (South)	1,000	34	79
Max Day – Prop Inter – WTP No.1 offline	N/A	35	78
Max Day – Prop Inter – WTP No.1 offline + Fire (N)	1,500	29	77
Max Day – Prop Inter – WTP No.1 offline + Fire (S)	1,000	28	82
Max Day – Prop Inter – WTP No.3 offline	N/A	38	80
Max Day – Prop Inter – WTP No.3 offline + Fire (N)	1,500	36	84
Max Day – Prop Inter – WTP No.3 offline + Fire (S)	1,000	35	79

It is anticipated that the capital improvements to the Town's water distribution system will be constructed in phases to meet the demand needs of planned future developments throughout the service area. Table F provides an estimate of the annual growth projections within the Town's service area over the next 20 years. It should be noted that the annual projections are subject to change due to developers' construction scheduling. This will have an impact on the schedule, and/or order of the proposed capital distribution system improvements phasing. The first phase which consists of the upsized interconnect between the two water treatment plants will be funded by the Town. It is anticipated that additional phases to extend the Town's capital water system "trunklines" to developments will be developer funded through impact fee credits. It is expected that developers will extend capital pipelines from the point of connection to the extents of the development's furthest property boundary along the public right-of-way route.

Phase I (Town Funded)

The first phase includes installing approximately 5,650 linear feet of new 12-inch capital main from the new WTP No. 3 to the existing 12-inch main at the intersection of West Central Avenue and South Florida Avenue. This is referred to herein as the “proposed interconnect.” The route of the proposed capital water main will begin at the proposed commercial roadway accessing the new WTP No. 3 southward along SR 19 to West Cypress Avenue then westward to North Dixie Drive. The route will continue southward along North Dixie Drive to West Central Avenue then westward to the point of connection at South Florida Avenue. This phase will also include replacing the existing 8-inch pressure sustaining valve (PSV) at the intersection of West Magnolia Avenue and SR 19 with a 12-inch PSV and SCADA control upgrades for VFDs of the high service pumps at the water treatment plants. The purpose of this phase is to ensure fire flow demands and associated pressure requirements are maintained within the system. The proposed interconnect will also provide the Town the ability to balance the “two” systems and operate the two systems as one system with both WTP No. 1 and WTP No. 3 providing the pump flows from its HSPs. It is recommended that this phase be constructed concurrently with the construction of WTP No. 3.

The WaterCAD model for this phase was run with the two scenario conditions listed below.

- Current Maximum Daily Demand at current system conditions with WTP No. 3 on-line
- Future Maximum Daily Demand at system build-out conditions with WTP No. 3 on-line

The WaterCAD results for this phase are presented in the Table 5.5 below.

**Table 5.5
WaterCAD Analysis Results – Phase I**

High Pressure (psi)	Low Pressure (psi)	Interconnect Pressure (psi)	WTP No.1 (psi)	WTP No. 3 (psi)	MDD (gpm)
Current Condition with WTP No. 3 On-Line					
79	40	50	69	46	720
Buildout Condition					
79	37	50	69	46	2,165

The estimated construction cost for recommended distribution system Phase I improvements is presented in Table 5.6 below.

Table 5.6 Estimated Construction Cost for Phase I	
5,650 LF 12" C900 PVC	\$ 1,130,000.00
12" PSV Interconnect	\$ 45,000.00
SCADA Improvements	\$ 50,000.00
Subtotal	\$ 1,225,000.00
Payment/Performance Bond (5%)	\$ 61,250.00
Contract Administration (3%)	\$ 36,750.00
Engineering/Surveying/Construction Admin. (15%)	\$ 183,750.00
Contingency (15%)	\$ 183,750.00
Total	\$ 1,690,500.00

Phase II

The second phase includes installing approximately 5,350 linear feet of new 12-inch capital main along SR 19 southward from S. Florida Avenue to the proposed entrance of the Watermark Development. This will provide water service to the south side of the Town's service area and will improve service in the existing Venezia development as well as provide service for the proposed commercial developments within the Venezia development. This phase will also provide initial service to the proposed Mission Rise, The Reserve and Watermark PUDs. The estimated construction cost for recommended distribution system Phase II improvements is presented in Table 5.7 below.

Table 5.7
Estimated Construction Cost for Phase II

5,350 LF 12" C900 PVC	\$ 1,070,000.00
Subtotal	\$ 1,070,000.00
Payment/Performance Bond (5%)	\$ 53,500.00
Contract Administration (3%)	\$ 32,000.00
Engineering/Surveying/Construction Admin. (15%)	\$ 160,500.00
Contingency (15%)	\$ 160,500.00
Total	\$ 1,476,500.00

Phase III

The third phase includes installing approximately 2,300 linear feet of new 12-inch capital main from proposed commercial roadway accessing the new WTP No. 3 northward along CR 48 to San Luis Boulevard. This phase is intended to provide the Lake Hills PUD with a secondary connection point which will provide a redundant loop of their internal distribution system. The estimated construction cost for recommended distribution system Phase III improvements is presented in Table 5.8 below.

Table 5.8
Estimated Construction Cost for Phase III

2,300 LF 12" C900 PVC	\$ 460,000.00
Subtotal	\$ 460,000.00
Payment/Performance Bond (5%)	\$ 23,000.00
Contract Administration (3%)	\$ 13,750.00
Engineering/Surveying/Construction Admin. (15%)	\$ 69,000.00
Contingency (15%)	\$ 69,000.00
Total	\$ 634,750.00

Phase IV

The Phase IV includes installing approximately 5,320 linear feet of new 12-inch capital main along W. Central Avenue/No. 2 Road westward from WTP No. 1 to Silverwood Road. This phase is intended to provide the Mission Rise PUD and The Reserve PUD with a secondary connection point which will provide a redundant loop of their internal distribution system. The estimated construction cost for recommended distribution system Phase IV improvements is presented in Table 5.9 below.

**Table 5.9
Estimated Construction Cost for Phase IV**

5,350 LF 12" C900 PVC	\$ 1,064,000.00
Subtotal	\$ 1,064,000.00
Payment/Performance Bond (5%)	\$ 53,250.00
Contract Administration (3%)	\$ 32,000.00
Engineering/Surveying/Construction Admin. (15%)	\$ 159,500.00
Contingency (15%)	\$ 159,500.00
Total	\$ 1,468,250.00

Phase V

The fifth phase includes installing approximately 4,170 linear feet of new 12-inch capital main along SR 19 eastward from CR 48 to the eastern most intersection of Savage Circle. This phase is intended to provide the Lake Hills PUD with a third connection point which will provide additional redundancy looping of their internal distribution system. This phase will also provide service to the proposed Thompson Grove PUD, Westminster PUD and the existing Cypress Point development. The estimated construction cost for recommended distribution system Phase V improvements is presented in Table 5.10 below.

Table 5.10
Estimated Construction Cost for Phase V

4,170 LF 12" C900 PVC	\$ 834,000.00
Subtotal	\$ 834,000.00
Payment/Performance Bond (5%)	\$ 41,750.00
Contract Administration (3%)	\$ 25,000.00
Engineering/Surveying/Construction Admin. (15%)	\$ 125,000.00
Contingency (15%)	\$ 125,000.00
Total	\$ 1,150,750.00

Phase VI

Phase VI includes installing approximately 3,280 linear feet of new 12-inch capital main along W. Central Avenue/No. 2 Road westward from Silverwood Road to the proposed entrance of the Cedar Creek PUD. This phase is intended to provide service to the Cedar Creek. The estimated construction cost for recommended distribution system Phase VI improvements is presented in Table 5.11 below.

Table 5.11
Estimated Construction Cost for Phase VI

3,820 LF 12" C900 PVC	\$ 764,000.00
Subtotal	\$ 764,000.00
Payment/Performance Bond (5%)	\$ 38,250.00
Contract Administration (3%)	\$ 23,000.00
Engineering/Surveying/Construction Admin. (15%)	\$ 114,500.00
Contingency (15%)	\$ 114,500.00
Total	\$ 1,054,250.00

Phase VII

The seventh phase includes installing approximately 7,450 linear feet of new 12-inch capital main from San Luis Boulevard northward along CR 48 to Lime Avenue. This phase is intended to provide service to the Drake Point PUD. The estimated construction cost for recommended distribution system Phase VII improvements is presented in Table 5.12 below.

**Table 5.12
Estimated Construction Cost for Phase VII**

7,450 LF 12" C900 PVC	\$ 1,490,000.00
Subtotal	\$ 1,490,000.00
Payment/Performance Bond (5%)	\$ 74,500.00
Contract Administration (3%)	\$ 44,750.00
Engineering/Surveying/Construction Admin. (15%)	\$ 223,500.00
Contingency (15%)	\$ 223,500.00
Total	\$ 2,056,250.00

Developer Driven (Internal to Development)

The WaterCAD model included sections of the water distribution system within the proposed PUDs to further loop the Town's capital water system. These water mains will be installed along the main boulevard and serve as the main "truckline" for each PUD's water distribution system and will provide additional redundancy looping of their internal distribution system. It is anticipated that these sections of the water system will be developer driven costs.

- *Lake Hills PUD.* It is expected that the Lake Hills PUD will install a 10-inch water main along its internal boulevard from the access points at SR 19 and CR 48. The proposed 10-inch water main will connect to the Town's capital water system at both SR 19 and CR 48.
- *Watermark PUD.* It is expected that the Watermark PUD will install a 10-inch water main along its internal boulevard from the access points at SR 19 and E. Revels Road. The proposed 10-inch water main will connect to the Town's capital water system at both SR 19 and E. Revels Road.
- *Mission Rise PUD.* It is expected that the Mission Rise PUD will install a 10-inch water main along its internal boulevard from the access points

- at No. 2 Road and SR 19. The proposed 10-inch water main will connect to the Town's capital water system at both No. 2 Road and SR 19.
- *The Reserve PUD.* It is expected that The Reserve PUD will install a 12-inch water main along its internal boulevard from the access points at No. 2 Road and SR 19. The proposed 12-inch water main will connect to the Town's capital water system at both No. 2 Road and SR 19.

5.3 Summary of Capital Improvement Costs

The estimated cost for the WTP No. 1 improvements is **\$931,500** (Year 2024 dollars). The estimated cost for the WTP No. 3 is **\$8,503,000** (Year 2024 dollars). The estimated cost for the WTP No. 2 decommissioning is **\$109,250** (Year 2024 dollars). The total projected cost for the remaining capital water line improvements to the Town water system is listed in Table J. The estimated cost for the capital water line improvements is **\$9,531,250** (includes PSV interconnect improvements - Year 2024 dollars).

The total projected cost for the Capital Water System improvements is **\$19,075,000**.

Section 6

Construction Cost Estimation Methodology

6.0 Introduction

This section focuses on presenting unit cost data that can aid the Town in preparing cost estimates in the future. The sections below focus on the types of projects that are expected to represent the majority of projects undertaken by the Town during the upcoming five-year capital planning period. Future costs are represented as 2024 dollars. A cost escalation factor to account for inflation and market conditions should be considered in future evaluations.

6.1 Level of Contingency

The planning level unit costs presented in this section are conceptual in nature, and do not account for actual field conditions. These costs may be impacted by factors such as:

- Bypass pumping requirements or limitations in taking equipment out of service;
- Directional drilling or jack and bore construction of pipelines;
- Difficult installation conditions such as tight site constraints high groundwater tables, or the presence of rock;
- Easement, right of way, or land acquisition requirements; and,
- Ecological issues.

It is recommended that a minimum fifteen (15%) percent contingency be applied to all planning level construction cost estimates generated from this evaluation.

6.2 Engineering Services Costs

Engineering services related to the implementation of capital projects were estimated to be fifteen (15%) percent of the total construction cost. General services during construction, including bidding assistance, review of shop drawings, response to requests for information (RFIs), production of record drawings, and general coordination with the contractor were assumed to be five (5%) percent of the total construction cost. The cost estimates for the recommended projects include costs associated with both construction and engineering.

Section 7

Summary and Recommendations

7.0 General

The Town of Howey-in-the-Hills' potable water system includes two water treatment plants, and 20 miles of water main ranging in size from 1-inch to 12-inch. Both water treatment plants are currently in compliance with all FDEP and SJRWMD permit requirements. It should be noted that the planned Lake Hills PUD development will be located adjacent to the CR 48 and SR 19 intersection and would be served primarily by WTP No. 2. However, WTP No. 2 does not currently have the pumping ability or storage capacity to meet the fire flow demand requirements of the proposed PUD. Also, WTP No. 2 was constructed on property leased to the Town by the Florida Department of Transportation (FDOT). The lease agreement between the Town and the FDOT expires on October 29, 2028. There does not appear to be any provisions to extend or renew the lease and, as such, the Lake Hills PUD has provided the Town property for a new WTP No. 3 which is currently in the design phase. It is anticipated that the new WTP No. 3 combined with the existing WTP No. 1 will provide sufficient capacity to meet future growth in the service area for the next twenty years. A summary of the projected future growth in the service area, as well as its impact on potable water demand is presented in Tables F and G.

7.1 Summary

Projected growth for the Town of Howey-in-the-Hills water system is estimated to add 4,353 residential connections, 535,000 square footage of commercial, and 381,000 square footage of institutional. Therefore, as projected for 2044 year-end, the water treatment plants and distribution system are anticipated to provide service for 5,579 metered residential connections. It will be necessary to provide improvements to the Town of Howey-in-the-Hills' Capital Water System in order to sufficiently serve water to this future population. It is estimated that these improvements will have a total cost of approximately **\$19,075,000** in Year 2024 dollars. The total estimated capital cost per year is shown in Table K.

The information found in this report should be utilized by the Town of Howey-in-the-Hills in preparation of an updated Water Impact Fee Report in order to ensure that sufficient funding is available for future improvements.

7.2 Recommendations

Capital Improvements are recommended to enable the Town to continue to provide a reliable supply of potable water as demand accelerates due to future growth. A

total of 10 capital improvements projects with an opinion of probable construction cost of \$23.59 million are recommended to be undertaken over the next 10 years. Implementation of these projects will:

WTP No. 1

- Replace the existing horizontal split-case high service pump station with a can-mounted, VFD driven, vertical turbine high service pump station and associated piping and controls.

WTP No. 2

- Decommission and demolish treatment plant.

WTP No. 3

- Construct a new treatment plant which will consist of the following components.
 - Two (2) Raw Water Wells
 - Well No. 5 (1,500 gpm capacity)
 - Well No. 6 (1,500 gpm capacity)
 - One (1) Chlorine Gas system
 - Two (2) 0.60 MG CROM Ground Storage Tanks each equipped with a cascade tray aerator
 - Three (3) 75 hp Vertical Turbine High Service Pumps (1,000 gpm capacity, each)
 - One (1) 40 hp Vertical Turbine High Service Pump (600 gpm capacity)
 - One (1) Auxiliary Power generator


Distribution System


- Install approximately 5,650 linear feet of new 12-inch capital main from the new WTP No. 3 to the existing 12-inch main at the intersection of West Central Avenue and South Florida Avenue.
- Install approximately 5,350 linear feet of new 12-inch capital main along SR 19 southward from S. Florida Avenue to the proposed entrance of the Watermark Development.
- Install approximately 2,300 linear feet of new 12-inch capital main from proposed commercial roadway accessing the new WTP No. 3 northward along CR 48 to San Luis Boulevard.
- Install approximately 5,320 linear feet of new 12-inch capital main along W. Central Avenue/No. 2 Road westward from WTP No. 1 to Silverwood Road.
- Install approximately 4,170 linear feet of new 12-inch capital main along SR 19 eastward from CR 48 to the eastern most intersection of Savage Circle.
- Installing approximately 3,280 linear feet of new 12-inch capital main along W. Central Avenue/No. 2 Road westward from Silverwood Road to the proposed entrance of the Cedar Creek PUD.
- Install approximately 7,450 linear feet of new 12-inch capital main from San Luis Boulevard northward along CR 48 to Lime Avenue.


7.3 Updates to the Water Master Plan Report


Due to the ever-changing nature of the economy and its impact on growth rates and costs of construction, it is recommended that this report be updated approximately every five years in order to ensure that sufficient funds are being collected to pay for water system improvements.


FIGURES












SEE SHEET 1

SEE SHEET 4



**HOWEY-IN-THE-HILLS
WATER MASTER PLAN UPDATE
HOWEY-IN-THE-HILLS, FLORIDA**



half
902 NORTH SINCLAIR AVE.
TAVARES FLORIDA 32778
TEL. (352) 343-9481

THE SEAL ORIGINALLY APPEARING ON THIS
DOCUMENT WAS AUTHORIZED BY:
TROY E. MITCHELL
NAME **PE** LICENSE NO.
OCTOBER 2024
DATE

THE RECORD COPY OF THIS DRAWING IS ON
FILE AT THE OFFICES OF:

HALFF ASSOCIATES, INC.

FIRM OR BUSINESS NO.	STATE
PROJECT NO.: 055783.001	
ISSUED: OCTOBER 2024	
DRAWN BY:	--
CHECKED BY:	--
SCALE:	1" = 200'
SHEET TITLE:	
PROPOSED CAPITAL WATER DISTRIBUTION SYSTEM MAP	

SHEET 2



HOWEY-IN-THE-HILLS
WATER MASTER PLAN UPDATE
HOWEY-IN-THE-HILLS, FLORIDA




halff
902 NORTH BINGER AVENUE
TAVARES, FLORIDA 32778
TEL: (352) 343-8181

SEE SHEET 2

LEGEND

- SERVICE AREA BOUNDARY
- TOWN LIMITS
- PLANNED RESIDENTIAL DEVELOPMENTS
- PROPOSED 12' WATER MAIN
- PROPOSED 10' WATER MAIN



WESTMINS

SEE SHEET 3

SEE SHEET 5

LAKE HILLS

Mission Inn


SEE SHEET 7



half
902 NORTH SINCLAIR AVE.
TAVARES, FLORIDA 32778
TEL. (321) 345-8481

THE SEAL ORIGINALLY APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY	
TROY E. MITCHELL NAME	PE LICENSE NO.
OCTOBER 2024 DATE	
THE RECORD COPY OF THIS DRAWING IS ON FILE AT THE OFFICES OF:	
HALFF ASSOCIATES, INC.	
FLA CA 33380 & FL LC 26000645	FL

PROJECT NO.:	055783.001
ISSUED:	OCTOBER 2024
DRAWN BY:	--
CHECKED BY:	--
SCALE:	1" = 200'
SHEET TITLE:	
PROPOSED CAPITAL WATER DISTRIBUTION SYSTEM MAP	
SHEET 4	



CEDAR CREEK

SEE SHEET 3

0 100 200 400
SCALE IN FEET

HOWEY-IN-THE-HILLS
WATER MASTER PLAN UPDATE
HOWEY-IN-THE-HILLS, FLORIDA



halff
902 NORTH BINGLAR AVE.
TAVARES, FLORIDA 32778
TEL: (863) 343-1818

SEE SHEET 7

- LEGEND**
- SERVICE AREA BOUNDARY
 - TOWN LIMITS
 - PLANNED RESIDENTIAL DEVELOPMENTS
 - (12) PROPOSED 12" WATER MAIN

SEE SHEET 9

THE SEAL ORIGINALLY APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY:
TROY E. MITCHELL PE LICENSE NO.:
NAME: _____ DATE: _____
OCTOBER 2024
FIRM OR BUSINESS OF:
HALFF ASSOCIATES, INC.
FLA CA 33380 & FL LC 26000645 STATE: FL
PROJECT NO.: 055783.001
ISSUED: OCTOBER 2024
DRAWN BY: --
CHECKED BY: --
SCALE: 1" = 200'
SHEET TITLE:
**PROPOSED CAPITAL
WATER DISTRIBUTION
SYSTEM MAP**
SHEET 6






SEE SHEET 5

SEE SHEET 11

Little Lake Ha



LEGEND

- SERVICE AREA BOUNDARY
- TOWN LIMITS
- PLANNED RESIDENTIAL DEVELOPMENTS

HOWEY-IN-THE-HILLS
WATER MASTER PLAN UPDATE
HOWEY-IN-THE-HILLS, FLORIDA




REVISION NO.	DATE	DESCRIPTION

THE SEAL ORIGINALLY APPEARING ON THIS DOCUMENT WAS AUTHORIZED BY:
TROY E. MITCHELL
NAME _____ PE LICENSE NO. _____
OCTOBER 2024
DATE
THE RECORD COPY OF THIS DRAWING IS ON FILE AT THE OFFICES OF:
HALFF ASSOCIATES, INC.
FLA CA 33380 & FL LC 26000645
FIRM OR BUSINESS NO. _____ STATE _____

PROJECT NO.: 055783.001
ISSUED: OCTOBER 2024
DRAWN BY: --
CHECKED BY: --
SCALE: 1" = 200'

SHEET TITLE:
**PROPOSED CAPITAL
WATER DISTRIBUTION
SYSTEM MAP**

SHEET 8



SESSION 9

SEE SHEET 9

RISE

THE RESERVE

SEE SHEET

SEE SHI

LEGEND

- SERVICE AREA BOUNDARY
- TOWN LIMITS
- PLANNED RESIDENTIAL DEVELOPMENT
- PROPOSED 12" WATER MAIN
- PROPOSED 10" WATER MAIN

SEE SHEET 9

SEE SHEET 11



halff
902 NORTH SIRIUS AVE.
TAVARES, FLORIDA 32778
TEL. (352) 343-8411

THE SEAL ORIGINALLY APPEARING ON THIS
DOCUMENT WAS AUTHORIZED BY:


TROY E. MITCHELL
NAME **PE LICENSE NO.**
OCTOBER 2024
DATE



THE RECORD COPY OF THIS DRAWING IS ON FILE AT THE OFFICES OF:
HALFF ASSOCIATES, INC.


FLA CA 33380 & FL LC 26000645 **FL**

PROJECT NO.: 055783.001
ISSUED: OCTOBER 2024
DRAWN BY: --
CHECKED BY: --
SCALE: 1" = 200'
SHEET TITLE:
**PROPOSED CAPITAL
WATER DISTRIBUTION
SYSTEM MAP**

SHEET 10









TABLES

TABLE A
Town of Howey in the Hills
Estimated Historical Service Connections and Water Demand

Year	Annual Water Demand						Total Residential Connections ²	Population ¹	per Capita	Percent Increase (%)	Residential Demand		Overall System Demand	
	Total (MGY)	Unaccounted (MGY) ⁷	Construction (MGY) ⁶	Irrigation (MGY) ⁵	Commercial (MGY) ⁴	Residential (MGY) ³					per ERU (gpd/ERU)	per Capita (gpd)	per ERU (gpd/ERU)	per Capita (gpd)
2018	113.417	6.351	9.981	45.593	9.754	41.737	811	1,865	2.30	141	61	383	167	
2019	163.409	9.151	14.380	65.690	14.053	60.134	879	2,022	2.30	8.4%	187	81	509	221
2020	151.506	8.484	13.333	60.905	13.030	55.754	938	2,157	2.30	6.7%	162	71	441	192
2021	140.996	7.896	12.408	56.680	12.126	51.887	1,088	2,502	2.30	16.0%	131	57	355	154
2022	159.757	8.946	14.059	64.222	13.739	58.791	1,146	2,636	2.30	5.3%	141	61	382	166
2023	168.087	9.413	14.792	67.571	14.455	61.856	1,226	2,820	2.30	7.0%	138	60	376	163
Average									2.30	8.7%	150	68	408	184

Year	Annual Average Water Demand						Non-Residential - Irrigation			Non-Residential - Commercial ⁹		
	Total (MGY)	Unaccounted (MGY) ⁷	Construction (MGY) ⁶	Irrigation (MGY) ⁵	Commercial (MGY) ⁴	Residential (MGY) ³	Connections	Demand (gpd/cu)	ERU ⁸	Connections	Demand (gpd/cu)	ERU ⁸
2018	113.417	6.351	9.981	45.593	9.754	41.737	26	4,804	306	34	786	65
2019	163.409	9.151	14.380	65.690	14.053	60.134	26	6,922	441	34	1,132	94
2020	151.506	8.484	13.333	60.905	13.030	55.754	17	9,789	408	34	1,047	87
2021	140.996	7.896	12.408	56.680	12.126	51.887	17	9,135	381	34	977	81
2022	159.757	8.946	14.059	64.222	13.739	58.791	22	7,998	431	34	1,107	92
2023	168.087	9.413	14.792	67.571	14.455	61.856	24	7,714	454	34	1,165	97
Average							7,727		403		1,036	86

NOTES:

1. Estimated population per home

2.30

based on the 2020 Decennial Census

Comprehensive Plan - Chapter 4: 242.0 gpcd Overall System Demand

Residential Use: 150.8 gpd per resident

2. Service connections were provided by the Town's Billing Department

3. Average Residential Demand:

36.8%

based on data provided by Town's billing

4. Average Commercial Demand:

8.6%

based on data provided by Town's billing

5. Average Irrigation Demand:

40.2%

based on data provided by Town's billing

6. Average Construction Demand:

8.8%

based on data provided by Town's billing

7. Average Unaccounted Demand:

5.6%

based on average of 2021 & 2022 Water Audits

8. Residential ERU:

408

GPD/ERU

9. Connections include commercial, institutional and municipal.

10. Demand is based on Total Usage per Residential Connections

TABLE B
Town of Howey in the Hills
Historic Water Usage Per Service Connection Type

Fiscal Year	Total Billed Usage (Gallons)	Total Residential Usage (Gallons)		Total Commercial Usage (Gallons)		Total Irrigation Usage (Gallons)		Total Builder Usage (Gallons)	
		Usage (Gallons)	Percent (%)	Usage (Gallons)	Percent (%)	Usage (Gallons)	Percent (%)	Usage (Gallons)	Percent (%)
2019	132,652,000	58,440,000	44.06%	27,902,000	21.03%	38,676,000	29.16%	7,634,000	5.75%
2020	258,582,000	100,442,000	38.84%	33,190,000	12.84%	119,365,000	46.16%	5,585,000	2.16%
2021	161,448,797	74,586,000	46.20%	13,924,000	8.62%	66,987,000	41.49%	5,951,797	3.69%
2022	149,084,474	58,605,000	39.31%	3,534,000	2.37%	72,712,000	48.77%	14,233,474	9.55%
2023	160,643,068	60,238,000	37.50%	4,327,000	2.69%	87,727,000	54.61%	8,351,068	5.20%
5-year Total	862,410,339	352,311,000		82,877,000		385,467,000		41,755,339	
5-year Percentage			40.85%		9.61%		44.70%		4.84%

NOTES:

1. Billed Water Usage provided by the Town's Billing Department
2. Unaccounted flows and percentages are not represented.
3. Total Builder Usage for 2023 is estimated.

TABLE C
Town of Howey in the Hills
WTP MOR's 2018-2023

TABLE D
Town of Howey in the Hills
Future Residential Developments and Demands

Development Name	ERUs	Population	ADD (MGD)	MDD (MGD)	PHD (MGD)
Approved Developments					
Venezia South Townhomes	113	278	0.017	0.034	0.068
Venezia North - Talichet Phase II	21	52	0.003	0.006	0.013
Whispering Hills	156	384	0.023	0.047	0.094
Lake Hills (Four Seasons)	571	1,405	0.086	0.171	0.343
The Reserve	728	1,791	0.109	0.218	0.437
Watermark (Simpson Parcel)	225	554	0.034	0.068	0.135
Future Developments					
Mission Rise	499	1,228	0.075	0.150	0.299
Thompson Grove (Bouis Property)	272	669	0.041	0.082	0.163
Westminster (Marina)	350	861	0.053	0.105	0.210
Cedar Creek (Daryl Carter)	171	421	0.026	0.051	0.103
Golden Hills (J-5 Equities)	607	1,493	0.091	0.182	0.364
Cypress Point	110	271	0.017	0.033	0.066
Drake Point	530	1,304	0.080	0.159	0.318
Total Proposed Residential	4,353	10,708	0.653	1.306	2.612
Total Existing Residential	1,226	2,820	0.500	1.000	2.001
Total Residential	5,579	13,528	1.153	2.306	4.613

Notes:

1. Proposed Residential Average Daily Demand 150 gpd/ERU
2. Existing Residential Average Daily Demand 408 gpd/ERU
3. Proposed capita per ERU 2.46 persons/ERU
4. Maximum Daily Demand peaking factor 2.00
5. Peak Hour Demand peaking factor 4.00

TABLE E
Town of Howey in the Hills
Future Non-Residential Developments and Demands

Development Name	ERUs	Gross Floor Area (ft ²)	ADD (MGD)	Demand MDD (MGD)	Demand PHD (MGD)
Approved Commercial Developments					
Venezia South	85	85,000	0.013	0.026	0.051
Lake Hills (Four Seasons)	150	150,000	0.023	0.045	0.090
The Reserve	300	300,000	0.045	0.090	0.180
Approved Institutional Developments					
Lake Hills (Four Seasons)	293	176,000	0.044	0.088	0.176
The Reserve	342	205,000	0.051	0.103	0.205
Total Proposed Non-Residential	1,170	916,000	0.176	0.351	0.702
Total Existing Non-Residential			0.040	0.080	0.160
Total Non-Residential			0.216	0.431	0.862

Notes:

1. Proposed Commercial Average Daily Demand 0.15 gpd/sf
2. Proposed Institutional Average Daily Demand 0.25 gpd/sf
3. Proposed Residential ERU 150 GPD/ERU
4. Maximum Daily Demand peaking factor 2.00
5. Peak Hour Demand peaking factor 4.00

TABLE F
Town of Howey in the Hills
Future Planned Developments

Year	Existing Residential Connections	Proposed Residential Connections	Proposed Residential Connections Approved						Proposed Residential Connections Future						Proposed Non-Residential					
			Venezia Townhomes 113	Venezia North Phase II 21	Whispering Hills 156	Lake Hills 571	The Reserve 728	Watermark 225	Mission Rise 499	Thompson Grove 272	Westminster 350	Cedar Creek 171	Golden Hills 607	Cypress Point 110	Drake Point 530	Venezia 85,000	Commercial Lake Hills 150,000	The Reserve 300,000	Institutional Lake Hills 176,000	The Reserve 205,000
2018	811																			
2019	879																			
2020	938																			
2021	1,088																			
2022	1,146																			
2023	1,226																			
2024	1,226	21		21																
2025	1,226	78	57																	
2026	1,226	188	56		54											85,000				
2027	1,226	446		36	108	54	60										75,000			
2028	1,226	818		36	108	108	60			60							75,000	176,000		
2029	1,226	1,304		36	108	108	60	54	60	60								300,000		
2030	1,226	1,920		36	108	108	45	108	60	60	36		55							
2031	1,226	2,552		12	85	108		108	60	60	36	108	55					205,000		
2032	1,226	3,032			108			108	60	60	36	108								
2033	1,226	3,582				108		108	32	50	36	108		108						
2034	1,226	3,864				26		13			27	108		108						
2035	1,226	4,080										108		108						
2036	1,226	4,255										67		108						
2037	1,226	4,353												98						
2038	1,226	4,353																		
2039	1,226	4,353																		
2040	1,226	4,353																		
2041	1,226	4,353																		
2042	1,226	4,353																		
2043	1,226	4,353																		
Total	1,226	4,353	113	21	156	571	728	225	499	272	350	171	607	110	530	85,000	150,000	300,000	176,000	205,000

Notes

1. Small development (< 200 dwelling units) average construction rate: 3 per month
2. Medium development (200 - 400 dwelling units) average construction rate: 5 per month
3. Large development (> 400 dwelling units) average construction rate: 9 per month

TABLE G
Town of Howey in the Hills
Projected Water Demands

Year	Existing Residential Connections	Proposed Residential Connections	Average Demand							Maximum Demand (MGD)	Peak Hour Demand (MGD)
			Residential (MGD)	Commercial (MGD)	Irrigation (MGD)	Subtotal (MGD)	Construction (MGD)	Unaccounted (MGD)	Total (MGD)		
2018	811	0	0.114	0.027	0.125	0.266	0.027	0.017	0.311	0.621	1.243
2019	879	0	0.165	0.039	0.180	0.383	0.039	0.025	0.448	0.895	1.791
2020	938	0	0.152	0.036	0.166	0.354	0.036	0.023	0.414	0.828	1.656
2021	1,088	0	0.142	0.033	0.155	0.331	0.034	0.022	0.386	0.773	1.545
2022	1,146	0	0.161	0.038	0.176	0.375	0.039	0.025	0.438	0.875	1.751
2023	1,226	0	0.169	0.040	0.185	0.394	0.041	0.026	0.461	0.921	1.842
2024	1,226	21	0.503	0.040	0.185	0.728	0.072	0.082	0.883	1.765	3.530
2025	1,226	78	0.512	0.040	0.185	0.737	0.073	0.083	0.893	1.786	3.572
2026	1,226	188	0.528	0.052	0.185	0.766	0.076	0.087	0.928	1.857	3.714
2027	1,226	446	0.567	0.064	0.185	0.816	0.081	0.092	0.989	1.978	3.956
2028	1,226	818	0.623	0.119	0.185	0.927	0.092	0.105	1.124	2.247	4.495
2029	1,226	1,304	0.696	0.164	0.185	1.045	0.104	0.118	1.267	2.533	5.066
2030	1,226	1,920	0.788	0.164	0.185	1.137	0.113	0.128	1.379	2.757	5.514
2031	1,226	2,552	0.883	0.215	0.185	1.283	0.128	0.145	1.556	3.111	6.223
2032	1,226	3,032	0.955	0.215	0.185	1.355	0.135	0.153	1.643	3.286	6.572
2033	1,226	3,582	1.038	0.215	0.185	1.438	0.143	0.162	1.743	3.486	6.972
2034	1,226	3,864	1.080	0.215	0.185	1.480	0.147	0.167	1.794	3.589	7.177
2035	1,226	4,080	1.112	0.215	0.185	1.512	0.150	0.171	1.834	3.667	7.334
2036	1,226	4,255	1.138	0.215	0.185	1.539	0.153	0.174	1.865	3.731	7.462
2037	1,226	4,353	1.153	0.215	0.185	1.553	0.154	0.176	1.883	3.766	7.533
2038	1,226	4,353	1.153	0.215	0.185	1.553	0.000	0.176	1.729	3.458	6.915
2039	1,226	4,353	1.153	0.215	0.185	1.553	0.000	0.176	1.729	3.458	6.915
2040	1,226	4,353	1.153	0.215	0.185	1.553	0.000	0.176	1.729	3.458	6.915
2041	1,226	4,353	1.153	0.215	0.185	1.553	0.000	0.176	1.729	3.458	6.915
2042	1,226	4,353	1.153	0.215	0.185	1.553	0.000	0.176	1.729	3.458	6.915
2043	1,226	4,353	1.153	0.215	0.185	1.553	0.000	0.176	1.729	3.458	6.915
Total	1,226	4,353									

Notes:

1. Average Construction Demand: 8.8% based on data provided by Town's billing
2. Average Unaccounted Loss Demand: 10.0% based on Max allowable by SJRWMD CUP
3. Maximum Daily Demand peaking factor 2.00
4. Peak Hour Demand peaking factor 4.00
5. CUP Max. Withdraw through 2029 0.90 MGD (annual average)

TABLE H Town of Howey in the Hills WaterCAD Analysis - Summary of Results								
Scenario Title	System Demand Type	Demand (MGD)	Fire Flow (gpm)	Fire Location	Interconnect Pressure (psi)	System Pressure Minimum (psi)	System Pressure Maximum (psi)	System Modeling Notes
Ave Day - Existing Interconnect	Average Day	1.215	N/A		50	37	79	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Existing Interconnect	Maximum Day	3.177	N/A		50	37	79	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect + Fire (North)	Maximum Day	3.177	1,500	Mission Inn	50	36	97	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect + Fire (South)	Maximum Day	3.177	1,000	Watermark	50	34	79	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect - WTP No. 1 Off-Line	Maximum Day	3.177	N/A		50	28	103	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (North)	Maximum Day	3.177	1,500	Mission Inn	50	(-63)	77	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (South)	Maximum Day	3.177	1,500	Watermark	50	(-100)	77	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (South)	Maximum Day	3.177	1,000	Watermark	50	(-43)	93	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect - WTP No. 3 Off-Line	Maximum Day	3.177	N/A		50	39	82	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (North)	Maximum Day	3.177	1,500	Mission Inn	50	16	85	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (South)	Maximum Day	3.177	1,500	Watermark	50	35	81	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (South)	Maximum Day	3.177	1,000	Watermark	50	38	81	Uses a 50 psi setpoint at the interconnect to control the plants VFD pumps
Max Day - Proposed Interconnect	Maximum Day	3.177	N/A		50	37	79	Uses a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Proposed Interconnect - Existing Demand Conditions	Maximum Day	3.177	N/A		50	40	79	Uses a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect + Fire (North)	Maximum Day	3.177	1,500	Mission Inn	50	37	79	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect + Fire (South)	Maximum Day	3.177	1,000	Watermark	50	34	79	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect - WTP No. 1 Off-Line	Maximum Day	3.177	N/A		50	35	78	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (North)	Maximum Day	3.177	1,500	Mission Inn	50	29	77	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (South)	Maximum Day	3.177	1,500	Watermark	50	16	77	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (South)	Maximum Day	3.177	1,000	Watermark	50	28	82	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect - WTP No. 3 Off-Line	Maximum Day	3.177	N/A		50	38	80	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (North)	Maximum Day	3.177	1,500	Mission Inn	50	36	84	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (South)	Maximum Day	3.177	1,500	Watermark	50	32	79	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open
Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (South)	Maximum Day	3.177	1,000	Watermark	50	35	79	Required a 12" main from WTP No. 3 to WTP No. 1 and all SR 19 crossings open

TABLE I
Town of Howey in the Hills Capital Water System Improvements - WTP No. 3
Engineer's Opinion of Probable Construction Cost

Item #	Description	Quantity	Unit	Unit Price	Total Price
Phase I					
1	Mobilization/Demobilization/General Conditions	1	LS	\$150,000.00	\$150,000.00
2	Building Permit	1	LS	\$7,000.00	\$7,000.00
3	NPDES and Erosion Control	1	LS	\$8,000.00	\$8,000.00
4	Temp Fence and Permanent Fence	1	LS	\$15,000.00	\$15,000.00
5	Sitework, Earthwork and Tank Pads	1	LS	\$375,000.00	\$375,000.00
6	Two Well Pumps Equipment Installed	1	LS	\$196,000.00	\$196,000.00
7	Disinfect, Samples and Test of Wells	1	LS	\$12,000.00	\$12,000.00
8	Pumps Discharge Piping and Valves	1	LS	\$306,000.00	\$306,000.00
9	0.6 MG Ground Storage Tank with Aerator	1	LS	\$850,000.00	\$850,000.00
10	Under Slab Pipe from Tank to Pump Cans	1	LS	\$141,000.00	\$141,000.00
11	Vertical Turbine Pumps and Cans	1	LS	\$340,000.00	\$340,000.00
12	Yard Piping and Valves	1	LS	\$525,000.00	\$525,000.00
13	Chlorine Gas Equipment	1	LS	\$67,000.00	\$67,000.00
14	Auxiliary Generator	1	LS	\$202,000.00	\$202,000.00
15	Electrical	1	LS	\$900,000.00	\$900,000.00
16	SCADA control/monitoring system	1	LS	\$215,000.00	\$215,000.00
17	Building (3,648 sqft)	1	LS	\$729,000.00	\$729,000.00
18	HVAC	1	LS	\$40,000.00	\$40,000.00
19	Lab Equipment	1	LS	\$12,000.00	\$12,000.00
20	Lab Counters and Cabinets	1	LS	\$10,000.00	\$10,000.00
21	2" Water Service & Eyewash Station	1	LS	\$12,000.00	\$12,000.00
22	Painting, Coating & Misc	1	LS	\$64,000.00	\$64,000.00
23	Materials Testing	1	LS	\$10,000.00	\$10,000.00
24	Restoration	1	LS	\$20,000.00	\$20,000.00
25	Onsite Wastewater Treatment System	1	LS	\$25,000.00	\$25,000.00
26	As-Builts and Survey	1	LS	\$15,000.00	\$15,000.00
27	Close Out Doc & Manuals	1	LS	\$3,000.00	\$3,000.00
28	Indemnification (1%)	1	LS	\$52,000.00	\$52,000.00
Phase I Sub-Total					\$5,301,000.00
Payment/Performance Bond (5%)					\$265,000.00
Contract Administration (3%)					\$159,000.00
Engineering/Surveying/Construction Administration (15%)					\$729,000.00
Contingency (15%)					\$795,000.00
Phase I Construction Total					\$7,249,000.00
Item #	Description	Quantity	Unit	Unit Price	Total Price
Phase II					
1	Mobilization/Demobilization/General Conditions	1	LS	\$50,000.00	\$50,000.00
2	NPDES and Erosion Control	1	LS	\$3,000.00	\$3,000.00
3	0.6 MG Ground Storage Tank with Aerator	1	LS	\$909,000.00	\$909,000.00
4	As-Builts and Survey	1	LS	\$3,000.00	\$3,000.00
5	Restoration	1	LS	\$5,000.00	\$5,000.00
6	Indemnification (1%)	1	LS	\$10,000.00	\$10,000.00
Phase II Sub-Total					\$980,000.00
Payment/Performance Bond (5%)					\$49,000.00
Contract Administration (3%)					\$29,000.00
Engineering/Surveying/Construction Administration (5%)					\$49,000.00
Contingency (15%)					\$147,000.00
Phase II Construction Total					\$1,254,000.00
Construction Total					\$8,503,000.00

Please note that any opinion of the construction cost estimate prepared by Halff represents its judgement as a design professional and is supplied solely for the general guidance of the client. Since Halff has no control over the actual cost of labor and materials, or over competitive bidding, or market conditions, Halff does not guarantee the accuracy of such opinion as compared to contractor bids or actual costs to the client.

TABLE J
Town of Howey in the Hills Capital Water System Improvements - Distribution System
Engineer's Opinion of Probable Construction Cost

Phase	Description	Quantity	Unit	Unit Price	Total Price
1	12" WM: WTP No.3 to W. Central Ave. - Complete	5650	LF	\$200.00	\$1,130,000.00
2	12" WM: SR19 - Venezia to Watermark - Complete	5350	LF	\$200.00	\$1,070,000.00
3	12" WM: CR48 - WTP No.3 to San Luis Blvd - Complete	2300	LF	\$200.00	\$460,000.00
4	12" WM: W. Central Ave. to Silverwood Ln. - Complete	5320	LF	\$200.00	\$1,064,000.00
5	12" WM: SR19 - CR48 to Savage Circle - Complete	4170	LF	\$200.00	\$834,000.00
6	12" WM: No. 2 Rd - Silverwood Ln. to Cedar Creek - Complete	3820	LF	\$200.00	\$764,000.00
7	12" WM: CR48 - San Luis Blvd to Lime Ave. - Complete	7450	LF	\$200.00	\$1,490,000.00
Sub-Total					\$6,812,000.00
Payment/Performance Bond (5%)					\$340,600.00
Contract Administration (3%)					\$204,360.00
Engineering/Surveying/Construction Administration (15%)					\$1,021,800.00
Contingency (15%)					\$1,021,800.00
Construction Total					\$9,400,560.00

Please note that any opinion of the construction cost estimate prepared by Halff represents its judgement as a design professional and is supplied solely for the general guidance of the client. Since Halff has no control over the actual cost of labor and materials, or over competitive bidding, or market conditions, Halff does not guarantee the accuracy of such opinion as compared to contractor bids or actual costs to the client.

TABLE K
Town of Howey in the Hills
Total Estimated Capital Cost by Year

Year	WTP No. 1 Improvements	WTP No. 2 Decommission	WTP No. 3 Construction	Water Main Expansion - Phase 1	Water Main Expansion - Phase 2	Water Main Expansion - Phase 3	Water Main Expansion - Phase 4	Water Main Expansion - Phase 5	Water Main Expansion - Phase 6	Water Main Expansion - Phase 7	Total
2024	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2025	\$0	\$0	\$3,624,500	\$845,250	\$0	\$0	\$0	\$0	\$0	\$0	\$4,469,750
2026	\$0	\$109,250	\$3,624,500	\$845,250	\$369,125	\$0	\$0	\$0	\$0	\$0	\$4,948,125
2027	\$0	\$0	\$0	\$0	\$1,107,375	\$158,688	\$0	\$0	\$0	\$0	\$1,266,063
2028	\$465,750	\$0	\$0	\$0	\$0	\$476,063	\$734,125	\$287,688	\$0	\$0	\$1,963,625
2029	\$465,750	\$0	\$0	\$0	\$0	\$0	\$734,125	\$863,063	\$263,563	\$0	\$2,326,500
2030	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$790,688	\$514,063	\$1,304,750
2031	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,542,188	\$1,542,188
2032	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2033	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2034	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2035	\$0	\$0	\$125,400.00	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$125,400
2036	\$0	\$0	\$1,128,600.00	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,128,600
2037	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2038	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2039	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2040	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2041	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2042	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2043	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
2044	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
TOTAL	\$931,500	\$109,250	\$8,503,000	\$1,690,500	\$1,476,500	\$634,750	\$1,468,250	\$1,150,750	\$1,054,250	\$2,056,250	\$19,075,000

Note: All figures are based upon 2024 dollars.

APPENDIX A


Service Area Map



TOWN OF HOWEY-IN-THE-HILLS UTILITY SERVICE AREA MAP




LEGEND



- MAJOR ROADS
- INCORPORATED AREAS
- SECTION, TOWNSHIP, RANGE
- LAKES OR PONDS
- TOWN OF HOWEY-IN-THE-HILLS
- HOWEY-IN-THE-HILLS UTILITY SERVICE AREA

SOURCES: LAKE COUNTY AND TOWN OF HOWEY-IN-THE-HILLS



APPENDIX B

Future Land Use Map



N
0 500 1,000 2,000
FEET

LEGEND

- LOCAL ROADS
- POTABLE WATER
- ★ WELLHEAD
- WELLHEAD PROTECTION AREA (500 FT RADIUS)
- LAKES OR PONDS
- PARCELS
- TOWN LIMITS

TOWN OF HOWEY-IN-THE-HILLS 2025 FUTURE LAND USE MAP

- FUTURE LAND USE
- CON - CONSERVATION
- INST - INSTITUTIONAL
- LDR - LOW DENSITY RESIDENTIAL
- RESIDENTIAL
- LI - LIGHT INDUSTRIAL
- MDR - MEDIUM DENSITY RESIDENTIAL
- RECREATION


- NC - NEIGHBORHOOD COMMERCIAL
- PUB - PUBLIC/UTILITY
- REC - RECREATION
- VMU - VILLAGE MIXED USE
- TCMU - TOWN CENTER
- MIXED USE OVERLAY



PLANNING • ENGINEERING
GIS SERVICES

SOURCES: HOWEY-IN-THE-HILLS AND LAKE COUNTY.

***NOTE - THIS MAP AND DIGITAL DATA IS FOR PLANNING PURPOSES ONLY AND SHOULD NOT BE USED TO DETERMINE THE PRECISE LOCATION OF A FEATURE. ACREAGE ARE APPROXIMATE AND GIS DERIVED.



APPENDIX C

Consumptive Use Permit



St. Johns River Water Management District

Michael A. Register, P.E., Executive Director

4049 Reid Street • P.O. Box 1429 • Palatka, FL 32178-1429 • 386-329-4500 • www.sjrwmd.com

March 12, 2024

Town of Howey-in-the-Hills
101 N. Palm Avenue
Howey In Hills, FL 34737-3418

SUBJECT: Town of Howey-In-The-Hills, Consumptive Use Permit Number 2596-9
Lake County, Florida

Dear Sir/Madam:

Enclosed is the permit authorized by the District on March 12, 2024. The enclosed permit is a legal document and should be kept with other important records. Please read the permit and conditions carefully because the referenced conditions may require submittal of additional information. Where possible, please submit all information required to comply with permit conditions electronically at www.sjrwmd.com/permitting via the District's e-Permitting portal.

Please be advised that the period of time within which a third party may request an administrative hearing on this permit may not have expired by the date of issuance. A potential petitioner has 26 days from the date on which the actual notice is deposited in the mail, or 21 days from publication of this notice when actual notice is not provided, within which to file a petition for an administrative hearing pursuant to Sections 120.569 and 120.57, Florida Statutes. Receipt of such a petition by the District may result in this permit becoming null and void.

If you have any questions concerning the permit, please contact Douglas Hearn in the Apopka Service Center at (407) 215-1465 or Kristian Holmberg in the Palm Bay Service Center at (321) 409-2121 or Clint Brown in the Apopka Service Center at (407) 215-1477

Sincerely,

Richard Burkew, Bureau Chief
Water Use Regulation

GOVERNING BOARD

Rob Bradley, CHAIR
FLEMING ISLAND

Maryam H. Ghyabi-White, VICE CHAIR
ORMOND BEACH

J. Chris Peterson, SECRETARY
WINTER PARK

Ron Howse, TREASURER
COCOA

Ryan Atwood
MOUNT DORA

Doug Bourquin
VERO BEACH

Douglas Burnett
ST. AUGUSTINE

Cole Oliver
MERRITT ISLAND

Janet Price
FERNANDINA BEACH

ST. JOHNS RIVER WATER MANAGEMENT DISTRICT
Post Office Box 1429
Palatka, Florida 32178-1429

PERMIT NO: 2596-9

DATE ISSUED: March 12, 2024

PROJECT NAME: Town of Howey-In-The-Hills

A PERMIT AUTHORIZING:

The District authorizes, as limited by the attached conditions, the use of 0.90 million gallons per day (mgd) annual average of groundwater from the Upper and Lower Floridan aquifers through 2029 for public supply use.

LOCATION: Lake County; Town of Howey-In-The-Hills
Sections 23, 26, 35 & 36; Township 20 South; Range 25 East

ISSUED TO:

Town of Howey-in-the-Hills
101 N. Palm Avenue
Howey In Hills, FL 34737-3418

The permittee agrees to hold and save the St. Johns River Water Management District and its successors harmless from any and all damages, claims, or liabilities which may arise from permit issuance. Said application, including all plans and specifications attached thereto, is by reference made a part hereof.

This permit does not convey to the permittee any property rights nor any rights or privileges other than those specified herein, nor relieve the permittee from complying with any applicable local government, state, or federal, rule, or ordinance.

This permit may be revoked, modified or transferred at any time pursuant to the appropriate provisions of Chapter 373, Florida Statutes and 40C-1, Florida Administrative Code.

PERMIT IS CONDITIONED UPON:

See conditions on attached "Exhibit A", dated March 12, 2024

AUTHORIZED BY: St. Johns River Water Management District
Division of Water Supply Planning and Assessment

By:



Michael A. Register
Executive Director

"EXHIBIT A"
CONDITIONS FOR ISSUANCE OF PERMIT NUMBER 2596-9
Town of Howey-In-The-Hills
Date Issued March 12, 2024

1. With advance notice to the permittee, District staff with proper identification shall have permission to enter, inspect, observe, collect samples, and take measurements of permitted facilities to determine compliance with the permit conditions and permitted plans and specifications. The permittee shall either accompany District staff onto the property or make provision for access onto the property.
2. Nothing in this permit should be construed to limit the authority of the St. Johns River Water Management District to declare a water shortage and issue orders pursuant to Chapter 373, F.S. In the event of a declared water shortage, the permittee must adhere to the water shortage restrictions, as specified by the District. The permittee is advised that during a water shortage, reports shall be submitted as required by District rule or order.
3. Prior to the construction, modification or abandonment of a well, the permittee must obtain a water well permit from the St. Johns River Water Management District or the appropriate local government pursuant to Chapter 40C-3, F.A.C. Construction, modification, or abandonment of a well will require modification of the consumptive use permit when such construction, modification, or abandonment is other than that specified and described on the consumptive use permit application form.
4. Leaking or inoperative well casings, valves, or controls must be repaired or replaced as required to eliminate the leak or make the system fully operational.
5. The permittee's consumptive use of water as authorized by this permit shall not interfere with legal uses of water existing at the time of permit application. If interference occurs, the District shall revoke the permit, in whole or in part, to curtail or abate the interference, unless the interference associated with the permittee's consumptive use of water is mitigated by the permittee pursuant to a District-approved plan.
6. The permittee's consumptive use of water as authorized by this permit shall not have significant adverse hydrologic impacts to off-site land uses existing at the time of permit application. If significant adverse hydrologic impacts occur, the District shall revoke the permit, in whole or in part, to curtail or abate the adverse impacts, unless the impacts associated with the permittee's consumptive use of water are mitigated by the permittee pursuant to a District-approved plan.
7. The permittee shall notify the District in writing within 30 days of any sale, transfer, or conveyance of ownership or any other loss of permitted legal control of the Project and/or related facilities from which the permitted consumptive use is made. Where permittee's control of the land subject to the permit was demonstrated through a lease, the permittee must either submit documentation showing that it continues to have legal control or transfer control of the permitted system/project to the new landowner or new lessee. All transfers of ownership are subject to the requirements of Rule 40C-1.612, F.A.C. Alternatively, the permittee may surrender the consumptive use permit to the District, thereby relinquishing the right to conduct any activities under the permit.
8. A District-issued identification tag shall be prominently displayed at each withdrawal site by permanently affixing such tag to the pump, headgate, valve, or other withdrawal facility as provided by Rule 40C-2.401, F.A.C. The permittee shall notify the District in the event that a replacement tag is needed.

9. The permittee's consumptive use of water as authorized by this permit shall not adversely impact wetlands, lakes, rivers, or springs. If adverse impacts occur, the District shall revoke the permit, in whole or in part, to curtail or abate the adverse impacts, unless the impacts associated with the permittee's consumptive use of water are mitigated by the permittee pursuant to a District-approved plan.
10. The permittee's consumptive use of water as authorized by this permit shall not reduce a flow or level below any minimum flow or level established by the District or the Department of Environmental Protection pursuant to Section 373.042 and 373.0421, F.S. If the permittee's use of water causes or contributes to such a reduction, then the District shall revoke the permit, in whole or in part, unless the permittee implements all provisions applicable to the permittee's use in a District-approved recovery or prevention strategy.
11. The permittee's consumptive use of water as authorized by the permit shall not cause or contribute to significant saline water intrusion. If significant saline water intrusion occurs, the District shall revoke the permit, in whole or in part, to curtail or abate the saline water intrusion, unless the saline water intrusion associated with the permittee's consumptive use of water is mitigated by the permittee pursuant to a District-approved plan.
12. The permittee's consumptive use of water as authorized by the permit shall not cause or contribute to flood damage. If the permittee's consumptive use causes or contributes to flood damage, the District shall revoke the permit, in whole or in part, to curtail or abate the flood damage, unless the flood damage associated with the permittee's consumptive use of water is mitigated by the permittee pursuant to a District-approved plan.
13. All consumptive uses authorized by this permit shall be implemented as conditioned by this permit, including any documents incorporated by reference in a permit condition. The District may revoke this permit, in whole or in part, or take enforcement action, pursuant to Section 373.136 or 373.243, F.S., unless a permit modification has been obtained to address the noncompliance. The permittee shall immediately notify the District in writing of any previously submitted information that is later discovered to be inaccurate.
14. This permit does not convey to the permittee any property rights or privileges other than those specified herein, nor relieve the permittee from complying with any applicable local government, state, or federal law, rule, or ordinance.
15. A permittee may seek modification of any term of an unexpired permit. The permittee is advised that Section 373.239, F.S., and Rule 40C-2.331, F.A.C., are applicable to permit modifications.
16. Following the effective date of the re-evaluated Minimum Flows and Levels (MFL), adopted pursuant to 373.042, F.S., for Lake Apshawa South this permit is subject to modification during the term of the permit, upon reasonable notice by the District to the permittee, to achieve compliance with any approved MFL recovery or prevention strategy for Lake Apshawa South. The permittee's participation in implementing an approved MFL prevention/recovery strategy shall be limited to offsetting or mitigating the impact of the permittee's groundwater allocation on these MFLs. The District shall revoke the permit in whole or in part, if the permittee fails to implement its portion of any approved prevention/recovery strategy for any of these MFLs in accordance with the schedule included in the strategy. Nothing herein shall be construed to alter the District's authority to modify a permit under circumstances not addressed in this condition.
17. All irrigation shall be in conformity with the requirements set forth in subsection 40C-2.042(2), F.A.C.

18. All submittals made to demonstrate compliance with this permit must include CUP number 2596-9 labeled on the submittal. Submittals should be made on-line at www.sjrwmd.com/permitting whenever possible.
19. This permit will expire on March 12, 2029.
20. Maximum annual combined groundwater withdrawals from the Upper Floridan aquifer and Lower Floridan aquifer for public supply use must not exceed 328.5 million gallons (0.90 mgd annual average).
21. Prior to use, all existing and proposed wells must be equipped with totalizing flow meters. All flow meters must measure within +/- 5% of actual flow, be verifiable and be installed according to the manufacturer's specifications.
22. The permittee shall meter all service connections.
23. The permittee must maintain all flowmeters and alternative methods for measuring flow. In case of failure or breakdown of any meter, the District must be notified in writing within 5 days of its discovery. A defective meter must be repaired or replaced within 30 days of its discovery.
24. The permittee must have all flow meters checked for accuracy at least once every 10 years, specifically before March 31, 2026, and recalibrated if the difference between the actual flow and the meter reading is greater than 5%. Flow Meter Accuracy Report Form (EN-51) must be submitted to the District within 30 days of the inspection/calibration.
25. Total withdrawal from the following stations must be recorded continuously, totaled monthly, and reported to the District at least every six months for the duration of this permit using Water Use Pumpage Report Form (EN-50). Reporting is required, even if there is no use.

Station Name	Station ID	Source
2 (WTP No. 1)	9557	Upper Floridan aquifer
3 (WTP No. 2)	9558	Upper Floridan aquifer
4A (WTP No. 1)	421002	Upper Floridan aquifer
5 (WTP No. 3)	39899	Lower Floridan aquifer
6 (WTP No. 3)	540961	Lower Floridan aquifer

The reporting dates each year will be as follows:

<u>Reporting Period</u>	<u>Report Due Date</u>
January - June	July 31
July - December	January 31

26. By December 31, 2024, the permittee shall provide documentation for District approval of the process implemented for recording and reducing or eliminating unmetered water uses including, but not limited to, main breaks, sewer cleaning, and water quality flushing.
27. The permittee must implement the water conservation plan finalized on January 16, 2024, in accordance with the schedule contained therein.

28. The Town shall provide documentation by December 31, 2024, demonstrating that it has amended its land use code and adopted an ordinance that is in substantial conformance with the one proposed by the Town and provided as Attachment D of the water conservation plan finalized on January 16, 2024. In addition, the Town's website will be updated to include the ordinance and current water conservation plan.□
29. The Town is proposing a requirement for stormwater reuse to the extent economically, technically, and environmentally feasible for all new developments. The generated surface water will be available for landscape irrigation purposes for the new construction and proposed developments. The Town will provide an annual summary report listing all new developments approved and/or under construction, and the quantity of stormwater reuse that will be used within each for landscape irrigation. The report is due January 31, 2025.
30. The permittee must continue monitoring of wetlands and/or surface waters for each of the areas listed below, including monitoring surficial, intermediate and/or Floridan aquifer groundwater levels associated with each wetland and/or surface water monitoring site, as needed:

Monitoring Site:

1. Unnamed marsh located north of W. Central Ave, (Section 26, Township 20 South, Range 25 East).
31. Groundwater level data associated with the wetland and/or surface water monitoring must be collected for the site listed in the following table and submitted electronically every six months to the District utilizing the Water Level Data-Wetland Monitoring Template, for the wetland monitoring site. The template is available through the District's e-Permitting website. Alternative submittal formats must be approved by the District. Data collected January through June must be submitted on or before July 31st of each year. Data collected July through December must be submitted on or before January 31st of each year.

Data collection must include water levels (weekly without data loggers, daily with data loggers) from wetland surficial aquifer monitoring wells. Data must be reported as elevation relative to North American Vertical Datum (NAVD) of 1988.

Wetland Monitoring Sites

Station ID	Station Name (wetland/surface water)	Source	Location
427180	LI-MW 1	SA	(28.712158° N, -81.77749° W)

32. On or before March 31st, the permittee must submit an annual report summarizing the monitoring efforts and comparing all of the wetland monitoring data recorded for the last calendar year and previous years. The report must include panoramic photographs taken in September at the established photo stations, and a summary of wetland monitoring data. In addition, the report will include a brief analysis of any data trends.
33. If the permittee is unable to obtain or maintain legal access to the monitoring site referenced above, the permittee must notify the District in writing within 15 days of concluding that access to any specific site is not possible. Within 45 days of this notification, the permittee must submit an alternative site to modify the monitoring network. Within six months of District approval of the monitoring network modification, the permittee must implement the approved change(s).

34. The construction of proposed wells 5 (Station ID #39899) and well 6 (Station ID #540961) shall be completed by December 31, 2024. The installation of observation wells and completion of the APT and any associated reports shall be completed as specified in Limiting Conditions 36 and 37. Additionally, the installation of permanent pumps and piping will be completed when the new water treatment plant is constructed.

35. During the construction of proposed well 5 (Station ID #39899) and well 6 (Station ID #540961) the permittee must conduct the following tests and submit the testing results to the District within 90 days of completion of the testing:

(a) Downhole field water quality testing for chlorides, sulfates and specific conductivity taken during drilling, at the end of each drill rod or 30-foot intervals, upon penetration of the Floridan aquifer, or when the drilling method changes from mud-rotary to the reverse-air/direct-air drilling technique. Any change in these parameters of 20% or greater between consecutive samples will require that the permittee collect a sample for laboratory analysis for those major anions and cations listed in Appendix F of the Applicant's Handbook.

All major ion analyses must be checked for anion-cation balance and must balance within 10%. It is recommended that duplicates be taken to allow for laboratory errors or data loss.

(b) A suite of geophysical logs (gamma, electrical resistivity, caliper, flow, and fluid resistivity) and a video log of the well. All logs must be submitted to the District in hard copy and electronically in LAS format.

(c) GPS (latitude, longitude) and a site map location of the well.

(d) Water quality testing upon completion of the well for:

Field

- Field temperature (oC)
- Field pH
- Field specific conductance (umhos/cm)
- Field turbidity (NTU)

Laboratory

Calcium (mg/L), Magnesium (mg/L), Potassium (mg/L), Sodium (mg/L), Total iron (mg/L), Chloride (mg/L), Sulfate (mg/L), Strontium (mg/L), Bicarbonate Alkalinity (as mg/L CaCO₃), Carbonate Alkalinity (as mg/L CaCO₃), Total Dissolved Solids (mg/L), Specific Conductance (umhos/cm or uS/cm)

Sample Collection

Groundwater samples must be collected in accordance with the Florida Department of Environmental Protection's (FDEP) standard operating procedures (SOP), DEP-SOP-001/01, DEP Quality Assurance Rule, 62-160, F.A.C.

The well must be purged in accordance with the appropriate procedure in DEP-SOP-001/01, as necessary to evacuate water from the well column and induce groundwater representative of the hydrogeologic formation into the well prior to sampling. Purged water must be sampled and analyzed in the field for the following parameters:

- Water Temperature (oC)
- pH (SU)
- Specific Conductance (umhos/cm or uS/cm)
- Turbidity (NTU)

Purging must be documented using the Groundwater Sampling Log form referenced in the FDEP SOP or equivalent.

Water samples must be stored on ice immediately after collection and remain on ice until received by the laboratory. It is recommended that sample duplicates be taken to allow for laboratory errors or data loss, and these samples be stored by the laboratory for a minimum of 60 days to ensure backup sample availability should re-analyses be required.

Quality Assurance

The permittee must provide documentation that field instruments were properly calibrated prior to obtaining field measurements during purging and sampling.

All water quality analyses must be performed by a laboratory certified by the Florida Department of Health (FDOH) and the National Environmental Laboratory Accreditation Program (NELAP). All laboratory analyses must be by methods for which the laboratory has FDOH certification. All laboratory analyses must be completed within EPA holding times. If data is lost or a laboratory error occurs and the EPA holding time for an analysis has expired, the permittee must have the well re-sampled within 15 days of notification from the laboratory that a loss or laboratory error has occurred. The resample shall be collected according to the procedures described above and analyzed for the field parameters and the major ion suite listed above.

With the exception of pH, laboratory analyses utilizing selective ion electrodes are not acceptable due to the inadequate sensitivity of these methods. Analyses utilizing test kits typically used for field screening (e.g., Hach and LaMotte) are also not acceptable for the same reason.

All major ion analyses must be checked for anion-cation balance (equivalent concentration in meq/L) and must not exceed 10% difference. If the ion balance exceeds 10% difference, the permittee must review the data and include in the report submitted to the District, a discussion of the cause or explanation of the imbalance. The permittee may also be required to have the sample re-analyzed if it is within acceptable holding times or have the well re-sampled. The resample shall be collected according to the procedures described above and analyzed for the four field parameters and the major ion suite.

Reports

A report must be submitted to the District within 30 days of receipt of data analysis from the laboratory. The report must include the following:

- Table summarizing results for field measurements and laboratory chemical analyses
- Well sampling log
- Field instrument calibration verification
- Chain of custody forms (if outsourced)
- Laboratory analytical report (if outsourced)

All data must be submitted to the District in a District-approved electronic format readable by the District's computerized database.

36. At least 60 days prior to the construction of proposed wells 5 (Station ID #39899) and 6 (Station ID #540961), an aquifer testing plan must be submitted for District approval, in accordance with the Guidelines for Developing and Conducting an Aquifer Performance Testing Program outlined in Appendix D of the Applicant's Handbook, Consumptive Uses of Water. If the APT test results indicate a significant difference from the previously modeled groundwater parameters, the permittee may be required to conduct a revised impact assessment as part of the hydrogeological report and evaluation utilizing the new data.
37. No later than 90 days after the APT is completed, the permittee shall provide an APT final report ("APT Report") documenting well construction, APT procedures, data analysis, and APT results to the District for review and approval. The APT report shall be signed and sealed by a Florida Registered Professional Geologist.
38. The permittee must conduct a detailed annual water audit and submit it to the District by February 28th of each year. All water uses given in the audit must be for the previous calendar year and documentation provided on how the amounts were metered or determined. If the water audit shows that the system losses and unaccounted for water utility uses exceed 10%, a corrective action plan and annual water audit must be submitted together until the unaccounted for water losses do not exceed 10%. After two consecutive years of water audits that do not exceed 10%, the permittee may reduce the water audit frequency to no more than two years.
39. The permittee must provide an annual water conservation and alternative water source status report to the District, by February 28th of each year. At a minimum, the report must include:
 - (a) an update on implementation of water conservation activities designed to reduce per capita water use;
 - (b) details on new potential water conserving projects or activities, including type of projects and projected implementation dates; and
 - (c) an update on the progress made toward utilizing or participating in alternative water source projects, including but not limited to reclaimed water, surface water or other alternative sources of water, that would result in offsetting groundwater withdrawals.
40. The permittee shall use the lowest quality water source, such as reclaimed water, surface/storm water, or alternative water supply, to supply the needs of the project when deemed feasible pursuant to District rules and applicable state law.
41. When determined to be economically, environmentally, and technically feasible by the District, based on well construction and aquifer performance testing, the Lower Floridan aquifer must be maximized to the extent possible as a source of water.

APPENDIX D

2020 Water Audit

Bolling Engineering, LLC

PO Box 540576
Orlando, FL 32854
(407) 900-9835
www.bollingengineering.com

May 10, 2021

TO: Mayor Martha MacFarlane
Town of Howey-in-the-Hills, FL
101 N Palm Ave
Howey-In-The-Hills, FL 34737

SUBJECT: **2020 Potable Water Audit**
Consumptive Use Permit 2596

Dear Mayor MacFarlane,

Attached find the 2020 potable water audit and supporting documentation for the Town of Howey-in-the-Hills Consumptive Use Permit (CUP) 2596. The 2020 unaccounted-for water loss from the treatment and distribution systems was calculated to be **14.2%** based on the following information provided by the Town:

- Raw water and finished water produced
- Consumption data (billing)
- Estimated utility uses
- Estimated leaks and breaks

An unaccounted-for water loss value greater than 10% is considered a significant amount to the SJRWMD and identifying the cause of the high unaccounted-for water loss will be crucial during the CUP application review process. The result of this audit is anticipated to generate a Request for Additional Information for a corrective action plan which could ultimately involve a costly meter survey and a leak detection evaluation as required by the SJRWMD Consumptive Uses of Water Applicant's Handbook (A.H.) Section 2.2.2.5.1.A.4.

A water loss corrective action plan typically begins with data validation since audit results are only as good as the data inputs. Considering that the Town is nearing completion of its meter inventory and staff are confident that all consumption is accounted for and meters are functioning within acceptable limits, Bolling Engineering recommends implementing a program to better estimate and record utility uses such as leaks and main breaks. The 2020 water audit includes numerous assumptions for utility uses and these assumptions should be verified by performing additional audits. A mid-year and annual water audit for the 2021 calendar year use is also recommended to measure water loss reduction progress. Additional corrective actions may be needed if water loss remains above 10%.

Should you have any questions, please do not hesitate to contact the undersigned.

Sincerely,
Bolling Engineering, LLC.



Jennifer Bolling, P.E.

President

c: John Earnest, Town of Howey
JJ Southall, Town of Howey
Sarah M. Whitaker, P.G./SMW GeoSciences, Inc.

SJRWMD AUDIT FORM



St. Johns River Water Management District Water Audit Form



GENERAL AUDIT INFORMATION	
Utility Name:	Town of Howey-in-theHills
CUP Number:	2596
Audit Study Period (beginning and ending mo/dy/yr):	January 1, 2020 to December 21, 2020

The water audit is designed to provide assurances of water accountability within the treatment and water distribution systems.

The information provided below must reflect volumes covering a period of at least 12 consecutive months.

TASK 1: TREATMENT SYSTEM		
Line	Treatment System	Million Gallons
1A	Raw water produced	151.51
1B	Raw water purchased	
1C	Finished water purchased	
1D	Total water produced and purchased (sum of lines 1A – 1C)	151.51
1E	Metered uses in treatment	
1F	Unmetered but known uses in treatment	
1G	Total water used in treatment (line 1E plus line 1F)	
1H	Total water produced and purchased for distribution (line 1D minus line 1G)	151.51
1I	Metered finished water entering the distribution system	151.51
1J	Change in reservoir and tank storage (If increase, subtract) (If decrease, add)	
1K	Total water unaccounted for in the treatment process (line 1H minus line 1I, plus or minus line 1J)	0.00

TASK 2: DISTRIBUTION SYSTEM – METERED USES ¹		
Line	Metered Use	Million Gallons
2A	Small and medium meter use (5/8 inch – 3 inches)	120.783
2B	Large meter use (greater than 3 inches)	
2C	Adjustment due to meter lag time	
2D	Sum of lines 2A – 2C	120.78

¹The applicant must perform a meter survey (see instructions and the attached survey form) if the initial unaccounted for water loss is 10% or greater (as listed in line 4F). When a meter survey is performed, the information submitted in Task 2 must be corrected pursuant to the meter survey.

TASK 3: DISTRIBUTION SYSTEM – METERED USES NOT COVERED IN TASK 2 AND UNMETERED USES				
Line	Unmetered or Other Use	Million Gallons	Documented ¹	Undocumented/ Negligible ²
3A	Irrigation		<input type="checkbox"/>	
3B	Swimming pools		<input type="checkbox"/>	
3C	Sewer cleaning		<input type="checkbox"/>	
3D	Water quality flushing	0.10	<input checked="" type="checkbox"/>	
3E	Firefighting		<input type="checkbox"/>	
3F	Construction flushing		<input type="checkbox"/>	
3G	Main breaks	6.99	<input checked="" type="checkbox"/>	
3H	Schools		<input type="checkbox"/>	
3I	Decorative fountains		<input type="checkbox"/>	
3J	Allowable line loss	0.29	<input checked="" type="checkbox"/>	
3K	Other Uses			
	Tank wq flushing	0.21	<input checked="" type="checkbox"/>	
	Drained tanks twice	0.78	<input checked="" type="checkbox"/>	
	Register replacement	0.79	<input checked="" type="checkbox"/>	
3L	Total (sum of lines 3A-3K)	9.16		

¹Check if the water use estimate is documented. Only documented use estimates will be accepted for items 3A-3K. Documentation must take the form of metered reports, journal entries or other records. Attach all documentation for these uses.

²Check if the amount represents a very small part of the overall total water use or if the amount is not documented.

Documentation provided by the Town for unmetered uses listed above are attached.

TASK 4 – SUMMARY OF WATER USE		
Line	Water Use	Million Gallons
4A	Total water from distribution system (line 2D plus line 3L)	129.94
4B	Total finished water pumped into distribution system (line 11)	151.51
4C	Finished water purchased after WTP master meter (not previously accounted for in TASK 1)	
4D	Sum of finished water going into the distribution system (sum line 4B and 4C)	151.51
4E	Total unaccounted for water loss from distribution (line 4D minus line 4A)	21.57
4F	Total unaccounted for water from treatment and distribution systems (sum line 1K and line 4E)	21.57
4G	Percent total unaccounted for loss from treatment and distribution systems (divide line 4F by the sum of lines 4C plus 1H, then multiply by 100)	14.24%

TASK 1:

TREATMENT SYSTEM DOCUMENTATION

Town of Howey EN50 & MOR Total

Month	2020 Corrected EN50s (Gallons)			
	Well 2	Well 3	Well 4	Total
Jan	5,741,700	4,475,000	2,244,000	12,460,700
Feb	7,251,400	3,450,000	1,507,000	12,208,400
Mar	5,436,500	4,623,000	4,795,000	14,854,500
Apr	4,679,200	4,119,100	4,169,000	12,967,300
May	5,355,550	4,966,000	4,882,500	15,204,050
June	4,431,100	5,500,000	4,247,000	14,178,100
Jul	4,265,000	5,616,000	4,062,000	13,943,000
Aug	3,858,100	3,800,000	3,635,000	11,293,100
Sept	3,516,900	4,805,000	3,176,000	11,497,900
Oct	3,797,500	4,593,000	3,347,000	11,737,500
Nov	3,670,600	3,468,000	3,458,000	10,596,600
Dec	3,359,300	4,075,000	3,131,000	10,565,300
Total By Well	55,362,850	53,490,100	42,653,500	151,506,450

The Town reports the same data for EN50s and MORs

**TASK 2:
DISTRIBUTION SYSTEM – METERED USES
DOCUMENTATION**

Town of Howey 2020 Billing Data Summary

USER TYPE	GALLONS
BUILDER	4,067,000
COMMERCIAL	5,114,000
COMMERCIAL RENTER	140,000
IRRIGATION	50,310,000
RESIDENTIAL	58,853,000
RESIDENTIAL RENTER	2,299,000
TOTAL	120,783,000

**TASK 3:
DISTRIBUTION SYSTEM –
METERED USES NOT COVERED IN TASK 2 AND
UNMETERED USES DOCUMENTATION**

TOWN OF HOWEY LINE FLUSHING

Line Flushing = 100,000 gal

Water Loss Report for 2020

- 19 Leaks repaired
- 2 Main Breaks
- **Flushed** approximately 100,000 gallons

Thanks,

Steve Guba, **JJ** Southall

TOWN OF HOWEY BREAK AND LEAK ESTIMATES

Leak and Break Total : 6,987,180 Gal

(Estimated per emails and discussions with the Town and URE)

4" Break for 4 hours 1,243,000 gal
assume break width = 2"; 4 hours to detect

6" Break for 4 hours 3,729,000 gal
assume break width = 4"; 4 hours to detect
complete separation

Circular Break Around Pipe

Dia of Pipe, in inches:
Width of Break, in inches:
Pressure in Pipe, in PSI:
Leak Time, in hours:
GPM Flow lost from leak: 5179.17
Total Water Lost, in gallons: 1,243,000.8

[Click Here To Close Window!](#)
[Print This Window!](#)



Circular Break Around Pipe

Dia of Pipe, in inches:
Width of Break, in inches:
Pressure in Pipe, in PSI:
Leak Time, in hours:
GPM Flow lost from leak: 15537.5
Total Water Lost, in gallons: 3,729,000

[Click Here To Close Window!](#)
[Print This Window!](#)



19 leaks x 59,270 1,126,130 gallons
assume length of break = 1" and width of crack - 0.1
48 hours to detect

15 curb stop leaks x 59,270 889,050 gallons
assume length of break = 1" and width of crack - 0.1
2 days to detect

Rectangular Break Along Pipe

Length of Break, in inches:
Width of Break, in inches:
Water Pressure, in PSI:
Leak Time, in hours:
GPM Flow lost from leak: 20.58
Total Water Lost, in gallons: 59,270.4

[Click Here To Close Window!](#)
[Print This Window!](#)



Rectangular Break Along Pipe

Length of Break, in inches:
Width of Break, in inches:
Water Pressure, in PSI:
Leak Time, in hours:
GPM Flow lost from leak: 20.58
Total Water Lost, in gallons: 59,270.4

[Click Here To Close Window!](#)
[Print This Window!](#)



TOWN OF HOWEY BREAKS AND LEAKS

 Steven guba Mon, Mar 22, 7:05 PM (13 days ago)   
to me ▾

Hi Jen,

Here are the main breaks and pipe sizes.

3/21/20- 4" Main Break on Mission Lane
8/21/20- 6" Main Break on Central Ave

The 15 curb stops are additional to the 19 service line leaks.

I hope this is helpful. Please let me know if you have any questions

Thanks,

Steve

--
Steve Guba



Water Loss Report for 2020

- 19 Leaks repaired
- 2 Main Breaks
- Flushed approximately 100,000 gallons

Thanks,

Steve Guba, JJ Southall

Howey water loss 

 James Southall <jsouthall@howey.org> Thu, Mar 18, 8:27 AM   
to me ▾

Good Morning Jennifer,

After our talk last week, I had URE check into the curb stop replacements that were done last year, and we replaced 15 of them. Most of those were for leaks and not operating correctly. There is honestly no way I could give you the exact time each had been leaking but normally it takes us between 1-4 days to repair after we find, or they are reported to us depending on how busy the field crew is to replace them. Thought I would pass that along to you for the water loss.

Thank you
JJ

Town of Howey-in-the-Hills
Allowable Leakage Calculation for 2020

$$L = \frac{S \cdot D \cdot P^{1/2}}{133,200}$$

where:

L= Allowable Leakage

S= Length of Pipe in Feet

D= Diameter of Pipe

P= System Pressure

Assumptions:

Length of Pipe (from City) * = 98,525 miles

System Pressure Estimate= 45-50 psi

Pipe Diameter (varies) represents average throughout City

S (ft)	D (in)	P (psi)	L (gph)	L (GPD)	L (MGY)
1,675	2	50	0	4	0.002
1,310	4	50	0	7	0.002
72,525	6	50	23	554	0.202
22,275	8	50	9	227	0.083
	10	50	0	0	0.000
740	12	50	0	11	0.004
	16	50	0	0	0.000
	20	50	0	0	0.000
total					0.293

Water Master Plan June 2018:

Table 13
Estimated Lengths of Potable Water Piping (Linear Feet)

2"	4"	6"	8"	10"	12"	Total
1,675	1,310	72,525	22,275	---	740	98,525

Town of Howey Register Replacement

195 Registers x 1 month use estimated at 4,000 gallons 780,000 gallons

 Steven guba 3:03 PM (4 minutes ago)   
to me ▾

Sent from my iPhone

Begin forwarded message:

From: Steven guba <sguba6@gmail.com>
Date: March 21, 2021 at 3:22:46 PM EDT
To: James Southall <jsouthall@howey.org>
Subject: Re: Water loss

Hi JJ,

Only one of the curb stop replacements had a size and it was a 1.5" service line .
Also, in 2020 we replaced 195 meter registers .

Please let me know if you need any additional information.

Thanks,

Steve

Town of Howey 2020 Tank Flushing

Drain the tank	780,000 Gal
Tank Flushing (assume 4	208,000 Gal

James Southall

to me, Martha, John ▾

Thu, May 6, 6:45 AM (3 days ago)



Good morning Jennifer,

I wanted to double check with our lead operator on the tank flushing to make sure. We have drained the tank from 15 ft to empty twice that is roughly 780,000 gallons.

He also flushes about a foot of water from the tank every couple of months to help with the roughly 8 ft of water in the tank that does not get used due to the tank sitting below the grade of the HSPs at the plant. So that would be 52,000 gallons on 2 flushes.

Hope those numbers help.

Thank you

JJ

SJRWMD AUDIT FORM

2020 Audit based upon EN-50 data

SMW and Bolling Engineering were informed that the EN-50 and MOR data should be the same, but the data reported did not support this. This is a water audit based upon EN-50 data and MOR data.



St. Johns River Water Management District Water Audit Form



GENERAL AUDIT INFORMATION	
Utility Name:	Town of Howey-in-theHills
CUP Number:	2596
Audit Study Period (beginning and ending mo/dy/yr):	January 1, 2020 to December 21, 2020

The water audit is designed to provide assurances of water accountability within the treatment and water distribution systems.

The information provided below must reflect volumes covering a period of at least 12 consecutive months.

TASK 1: TREATMENT SYSTEM		
Line	Treatment System	Million Gallons
1A	Raw water produced	149.15
1B	Raw water purchased	
1C	Finished water purchased	
1D	Total water produced and purchased (sum of lines 1A – 1C)	149.15
1E	Metered uses in treatment	
1F	Unmetered but known uses in treatment	
1G	Total water used in treatment (line 1E plus line 1F)	
1H	Total water produced and purchased for distribution (line 1D minus line 1G)	149.15
1I	Metered finished water entering the distribution system	151.51
1J	Change in reservoir and tank storage (If increase, subtract) (If decrease, add)	
1K	Total water unaccounted for in the treatment process (line 1H minus line 1I, plus or minus line 1J)	-2.36

TASK 2: DISTRIBUTION SYSTEM – METERED USES ¹		
Line	Metered Use	Million Gallons
2A	Small and medium meter use (5/8 inch – 3 inches)	120.783
2B	Large meter use (greater than 3 inches)	
2C	Adjustment due to meter lag time	
2D	Sum of lines 2A – 2C	120.78

¹The applicant must perform a meter survey (see instructions and the attached survey form) if the initial unaccounted for water loss is 10% or greater (as listed in line 4F). When a meter survey is performed, the information submitted in Task 2 must be corrected pursuant to the meter survey.

TASK 3: DISTRIBUTION SYSTEM – METERED USES NOT COVERED IN TASK 2 AND UNMETERED USES				
Line	Unmetered or Other Use	Million Gallons	Documented ¹	Undocumented/ Negligible ²
3A	Irrigation		<input type="checkbox"/>	
3B	Swimming pools		<input type="checkbox"/>	
3C	Sewer cleaning		<input type="checkbox"/>	
3D	Water quality flushing	0.10	<input checked="" type="checkbox"/>	
3E	Firefighting		<input type="checkbox"/>	
3F	Construction flushing		<input type="checkbox"/>	
3G	Main breaks	6.99	<input checked="" type="checkbox"/>	
3H	Schools		<input type="checkbox"/>	
3I	Decorative fountains		<input type="checkbox"/>	
3J	Allowable line loss	0.29	<input checked="" type="checkbox"/>	
3K	Other Uses			
	Tank wq flushing	0.21	<input checked="" type="checkbox"/>	
	Drained tanks twice	0.78	<input checked="" type="checkbox"/>	
	Register replacement	0.79	<input checked="" type="checkbox"/>	
3L	Total (sum of lines 3A-3K)	9.16		

¹Check if the water use estimate is documented. Only documented use estimates will be accepted for items 3A-3K. Documentation must take the form of metered reports, journal entries or other records. Attach all documentation for these uses.

²Check if the amount represents a very small part of the overall total water use or if the amount is not documented.

Documentation provided by the Town for unmetered uses listed above are attached.

TASK 4 – SUMMARY OF WATER USE		
Line	Water Use	Million Gallons
4A	Total water from distribution system (line 2D plus line 3L)	129.94
4B	Total finished water pumped into distribution system (line 11)	151.51
4C	Finished water purchased after WTP master meter (not previously accounted for in TASK 1)	
4D	Sum of finished water going into the distribution system (sum line 4B and 4C)	151.51
4E	Total unaccounted for water loss from distribution (line 4D minus line 4A)	21.57
4F	Total unaccounted for water from treatment and distribution systems (sum line 1K and line 4E)	19.21
4G	Percent total unaccounted for loss from treatment and distribution systems (divide line 4F by the sum of lines 4C plus 1H, then multiply by 100)	12.9%

APPENDIX E

Sanitary Survey Reports



FLORIDA DEPARTMENT OF Environmental Protection

Central District Office
3319 Maguire Blvd., Suite 232
Orlando, Florida 32803

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Shawn Hamilton
Secretary

June 15, 2022

Morgan Cates, Public Works Director
Town of Howey-in-the-Hills
P.O. Box 128
Howey-in -the -Hills, FL 34737
mcates@howey.org

Re: Howey-in-the-Hills
PW Facility ID #3350573
Lake County

Dear Mr. Cates:

Department personnel conducted an inspection of the above-referenced facility on April 19, 2022. Based on the information provided during the inspection, the facility was determined to be in compliance with the Department's rules and regulations. A copy of the inspection report is attached for your records.

The Department appreciates your efforts to maintain this facility in compliance with state and federal rules. Should you have any questions or comments, please contact Manuel F. Cardona at 407-897-4134 or via e-mail at Manuel.Cardona@FloridaDEP.gov.

Sincerely,

David Smicherko

David Smicherko, Environmental Manager
Central District
Florida Department of Environmental Protection

Enclosure: Inspection Report

cc: Mark McKinnon, mark.mckinnon@ymail.com
David Smicherko, Manuel Cardona, Central District

State of Florida
Department of Environmental Protection
Central District

SANITARY SURVEY REPORT

Plant Name **HOWEY IN THE HILLS WTP1** County Lake PWS ID # **3350573**
 Plant Location 316 West Grant Street, Howey-in-the-Hills, FL 34737 Phone 352-324-2526
 Owner Name Town of Howey-in-the-Hills Phone 352-516-1346
 Owner Address P.O. Box 128, Howey-in-the-Hills, FL 34737
 Contact Person Morgan Cates Title Public Works Director Phone 352-805-0205
 This Survey Date 4/19/22 Last Survey Date 4/16/19 Last Compliance Inspection Date 9/22/98

PWS TYPE: Community

PLANT CATEGORY & CLASS: 5C

MAX-DAY DESIGN CAPACITY: 1,800,000 gpd

PWS STATUS: Approved

TREATMENT PROCESSES IN USE

Gas chlorination, Aeration, Iron Sequestration
(Aqua-Mag, Stenner 40 GPD)

SERVICE AREA CHARACTERISTICS

Municipal/city

Food Service: Yes No N/A

Number of Service Connections 811

Population Served 2,027 Basis MOR

OPERATION & MAINTENANCE LOG: Yes

Location Office

Comments _____

CERTIFIED OPERATOR: Yes

Operator(s) & Certification Class-Number:

Mark McKinnon B-17855

Hrs/day: Required *Visit Actual *Visit

Days/wk: Required 5+1 Actual 5+1

Non-consecutive Days? Yes No N/A

Comments *Visits must total 0.6 hr/week.

MONTHLY OPERATION REPORTS (MORS)

MORs submitted regularly? Yes No N/A

Data missing from MORs? No Yes N/A

Average Day (from MORs) 121,353 gpd

Maximum Day (from MORs) 419,300 gpd 12/21

Comments _____

Flow Measuring Device Flow Meter

Meter Size & Type 8" Sparling

Date Last Calibrated 6/20/19

RAW WATER SOURCE

<input checked="" type="checkbox"/> GROUND; Number of Wells	<u>2</u>
<input type="checkbox"/> PURCHASED from PWS ID #	_____
<input checked="" type="checkbox"/> Emergency Water Source	<u>WTP2</u>
Emergency Water Capacity	<u>720,000</u>

STANDBY POWER SOURCE: Yes

Source Diesel Generator

Capacity of Standby (kW) 200

Switchover: Automatic Manual

Hrs Operated Under Load 1 hr/wk.

What equipment does it operate?

<input checked="" type="checkbox"/> Well Pumps	<u>All</u>
<input checked="" type="checkbox"/> High Service Pumps	<u>All</u>
<input checked="" type="checkbox"/> Treatment Equipment	<u>All</u>

Satisfy avg. daily demand? Yes No Unknown

Audio-visual alarm? Yes No

Comments _____

PLANS AND MAPS

Coliform Sampling Plan	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A
D/DBP Monitoring Plan	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A
Lead and Copper Plan	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A
Distribution System Map	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A
Emergency Response Plan	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A
Comments	<u>ERP was revised 4/18/2022</u>		

PREVENTIVE MAINTENANCE/O&M

Operation & Maintenance Manual	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Preventive Maintenance Program	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No

Flushing Program Yes No N/A

Records Yes No N/A

Isolation Valve Exercise Yes No N/A

Records Yes No N/A

Comments Flush hydrants monthly, no dead-ends, no blowoffs or auto flushers. Isolation valves are executed annually.

CROSS CONNECTION CONTROL

BFPAs 72 # Tested 15 (2022)

WWTP RPZ N/A Date Tested N/A

Written Plan Yes Date 7/18/16

Comments Dual checks are being installed at all SFRs.

GROUND WATER SOURCE

Well Number (Florida Unique Well ID #)	2 (AAH7492)	4		
Year Drilled	1964	2012		
Depth Drilled	334'	450'		
Drilling Method	Unknown	Rotary		
Type of Grout	Unknown	Unknown		
Static Water Level	Unknown	Unknown		
Pumping Water Level	Unknown	Unknown		
Design Well Yield	Unknown	Unknown		
Test Yield	Unknown	Unknown		
Actual Yield (if different than rated capacity)	Unknown	Unknown		
Strainer	Unknown	Unknown		
Length (outside casing)	191'	Unknown		
Diameter (outside casing)	12"	Unknown		
Material (outside casing)	Black steel	Black steel		
Well Contamination History	None noted	None noted		
Is inundation of well possible?	Unknown	No		
6' X 6' X 4" Concrete Pad	Yes	Yes		
SET BACKS	Septic Tank	N/A	N/A	
	Reuse Water	N/A	N/A	
	WW Plumbing	>200'	N/A	
	Other Sanitary Hazard	None observed	None observed	
PUMP	Type	Vertical turbine	Vertical turbine	
	Manufacturer Name	Jacuzzi	Deming	
	Model Number	12MSB4	3-12Y-1100	
	Rated Capacity (gpm)	1,200	1000	
	Motor Horsepower	75	60	
Well casing 12" above grade?	Yes	Yes		
Well Casing Sanitary Seal	Ok	Ok		
Raw Water Sampling Tap	Yes	Yes		
Above Ground Check Valve	Yes	Yes		
Security	Yes	Yes		
Well Vent Protection	Yes	Yes		

COMMENTS Well #4 check valve was recently repacked.

CHLORINATION (Disinfection)

Type: Gas Hypo

Make Hydro Capacity 250 ppd

Chlorine Feed Rate 150 ppd

Avg. Amount of Cl₂ gas used 30-35 ppd

Chlorine Residuals: Plant 2.72 Remote 2.13

Remote tap location Across from High School

DPD Test Kit: On-site With operator
 None Not Used Daily

Injection Points Prior to elevated storage tank

Booster Pump Info N/A

Comments _____

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Scale	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-Pak	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Call Fire Dept.
Sign of Leaks	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Fresh Ammonia	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Fitted Wrench	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type Cascade Capacity Unknown

Aerator Condition Good

Visible Algae Growth None observed

Protective Screen Condition Good

Frequency of Cleaning Quarterly

Date Last Inspected/Cleaned 3/2022

Comments Observations were made at ground level.

STORAGE FACILITIES

(G) Ground (C) Clearwell (E) Elevated
(B) Bladder (H) Hydropneumatic / flow-through

Tank Type/Number	G
Capacity (gal)	500,000
Material	Concrete
Gravity Drain	Yes
By-Pass Piping	Yes
Protected Openings	N/A
Sight Glass or Level Indicator	Yes
PRV/ARV	N/A
Pressure Gauge	N/A
On/Off Pressure	10.6'/14.3'
Access Secured	Yes
Access Manhole	Yes
Tank Sample Tap Location	On manhole
Date of Inspection	2022/03
Date of Cleaning	2022/03

Comments _____

HIGH SERVICE PUMPS

Pump Number	1	2	3	4
Type	Horizontal Split Case			
Make	Aurora			
Model	Unknown	411A	411A	Unknown
Capacity (gpm)	900	1950	1950	900
Motor HP	60	125	125	60
Date Installed	2021	2013	2013	2018

Comments Discharge pressure setpoint is 73 psi.
Normally, it is 65 psi.

State of Florida
Department of Environmental Protection
Central District

SANITARY SURVEY REPORT

Plant Name	HOWEY IN THE HILLS WTP2	County	Lake	PWS ID #	3350573
Plant Location	316 West Grant Street, Howey-in-the-Hills, FL 34737			Phone	352-324-2526
Owner Name	Town of Howey-in-the-Hills			Phone	352-516-1346
Owner Address	P.O. Box 128, Howey-in-the-Hills, FL 34737				
Contact Person	Morgan Cates	Title	Public Works Director	Phone	352-805-0205
This Survey Date	4/19/22	Last Survey Date	4/16/19	Last Compliance Inspection Date	9/22/98

PWS TYPE: Community

PLANT CATEGORY & CLASS: SC

MAX-DAY DESIGN CAPACITY: 720,000 gpd

PWS STATUS: Approved

TREATMENT PROCESSES IN USE

Gas chlorination

SERVICE AREA CHARACTERISTICS

Municipal/city

Food Service: Yes No N/A

Number of Service Connections 811

Population Served 2,027 Basis MOR

OPERATION & MAINTENANCE LOG: Yes

Location Water treatment plant

Comments System is offline

CERTIFIED OPERATOR: Yes

Operator(s) & Certification Class-Number:

Mark McKinnon B-17855

Hrs/day: Required *Visit Actual *Visit

Days/wk: Required 5+1 Actual 5+1

Non-consecutive Days? Yes No N/A

Comments *Visits must total 0.6 hr/week.

MONTHLY OPERATION REPORTS (MORS)

MORs submitted regularly? Yes No N/A

Data missing from MORs? No Yes N/A

Average Day (from MORs) 126,199 gpd

Maximum Day (from MORs) 419,000 gpd 05/21

Comments System offline.

Flow Measuring Device Flow Meter

Meter Size & Type 8" Water Specialties

Date Last Calibrated System offline

RAW WATER SOURCE

GROUND; Number of Wells 1

PURCHASED from PWS ID #

Emergency Water Source WTP1

Emergency Water Capacity 1,800,000

STANDBY POWER SOURCE: Yes

Source Onan Diesel Generator

Capacity of Standby (kW) 150

Switchover: Automatic Manual

Hrs Operated Under Load 2 hrs/mo.

What equipment does it operate?

Well Pumps All

High Service Pumps

Treatment Equipment All

Satisfy avg. daily demand? Yes No Unknown

Audio-visual alarm? Yes No

Comments System Offline

PLANS AND MAPS

Coliform Sampling Plan Yes No N/A

D/DBP Monitoring Plan Yes No N/A

Lead and Copper Plan Yes No N/A

Distribution System Map Yes No N/A

Emergency Response Plan Yes No N/A

Comments System Offline

PREVENTIVE MAINTENANCE/O&M

Operation & Maintenance Manual Yes No

Preventive Maintenance Program Yes No N/A

Flushing Program Yes No N/A

Records Yes No N/A

Isolation Valve Exercise Yes No N/A

Records Yes No N/A

Comments System Offline

CROSS CONNECTION CONTROL

BFPAs 72 # Tested 15 (2022)

WWTP RPZ N/A Date Tested N/A

Written Plan Yes Date 7/18/16

Comments System Offline

GROUND WATER SOURCE

Well Number (Florida Unique Well ID #)	3 (AAE0875)			
Year Drilled	1990			
Depth Drilled	350'			
Drilling Method	Cable tool			
Type of Grout	Unknown			
Static Water Level	62'			
Pumping Water Level	Unknown			
Design Well Yield	Unknown			
Test Yield	Unknown			
Actual Yield (if different than rated capacity)	Unknown			
Strainer	Unknown			
Length (outside casing)	162'			
Diameter (outside casing)	14"			
Material (outside casing)	Black steel			
Well Contamination History	None noted			
Is inundation of well possible?	No			
6' X 6' X 4" Concrete Pad	Yes			
SET BACKS	Septic Tank	N/A		
	Reuse Water	N/A		
	WW Plumbing	>200'		
	Other Sanitary Hazard	None observed		
PUMP	Type	Vertical turbine		
	Manufacturer Name	Peerless		
	Model Number	NB-4		
	Rated Capacity (gpm)	1,000		
	Motor Horsepower	75		
Well casing 12" above grade?	Yes			
Well Casing Sanitary Seal	Ok			
Raw Water Sampling Tap	Yes			
Above Ground Check Valve	Yes			
Security	Yes			
Well Vent Protection	Yes			

COMMENTS System offline, motor down.

CHLORINATION (Disinfection)

Type: Gas Hypo
 Make Hydro Capacity 50 ppd
 Chlorine Feed Rate N/A
 Avg. Amount of Cl₂ gas used N/A ppd
 Chlorine Residuals: Plant N/A Remote N/A
 Remote tap location Across from High School
 DPD Test Kit: On-site With operator
 None Not Used Daily
 Injection Points Prior to hydro tank
 Booster Pump Info N/A
 Comments System Offline

Chlorine Gas Use Requirements	YES	NO	Comments
Dual System	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Auto-switchover	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Alarms:			
Loss of Cl ₂ capability	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Loss of Cl ₂ residual	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Cl ₂ leak detection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Scale	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Chained Cylinders	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Reserve Supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Adequate Air-pak	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Call Fire Dept.
Sign of Leaks	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Fresh Ammonia	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Ventilation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Room Lighting	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Warning Signs	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Repair Kits	<input type="checkbox"/>	<input checked="" type="checkbox"/>	N/A
Fitted Wrench	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Housing/Protection	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

AERATION (Gases, Fe, & Mn Removal)

Type Capacity
 Aerator Condition
 Visible Algae Growth
 Protective Screen Condition
 Frequency of Cleaning
 Date Last Inspected/Cleaned
 Comments

STORAGE FACILITIES

(G) Ground (C) Clearwell (E) Elevated
 (B) Bladder (H) Hydropneumatic / flow-through

Tank Type/Number	H
Capacity (gal)	15,000
Material	Steel
Gravity Drain	Yes
By-Pass Piping	Yes
Protected Openings	Yes
Sight Glass or Level Indicator	Yes
PRV/ARV	PRV
Pressure Gauge	Yes
On/Off Pressure	42/52
Access Secured	Yes
Access Manhole	Yes
Tank Sample Tap Location	On tank
Date of Inspection	2019/05
Date of Cleaning	2019/05

Comments _____

HIGH SERVICE PUMPS

Pump Number		
Type		
Make		
Model		
Capacity (gpm)		
Motor HP		
Date Installed		

Comments _____

DEFICIENCIES:

No deficiencies were noted during the inspection.

MONITORING REMINDER:

- Nitrate and nitrite samples are required to be collected from the point of entry (POE) to the distribution system annually. The 2022 results have been received.
- The consumer confidence report (CCR) must be delivered to consumers and the Department no later than July 1, 2022, and certification of delivery of the CCR must be submitted to the Department no later than August 10, 2022.
- Monitoring schedules are available on the Central District's FTP site: <https://floridadep.gov/central/cd-compliance-assurance/content/resources-drinking-water-facilities-and-operators-central>

COMMENTS:

- Contact **FRWA (Florida Rural Water Association)** at **850-668-2746**, or frwa@frwa.net, for free technical assistance with your system. FRWA has extended benefits offered to members.
- Provide documentation that the finished-drinking-water meter has been calibrated at least every 5 years.
Checking the calibration of finished-drinking-water meters at treatment plants shall be performed in accordance with the equipment manufacturer's recommendations or in accordance with a written preventive maintenance program established by the supplier of water. [Rule 62-555.350(2), F.A.C.]
- Suppliers of water shall submit written notification to the Department before beginning work or alterations to the public water system. Each notification shall be submitted to the appropriate Department of Environmental Protection District Office or Approved County Health Department and shall include the following: a description of the scope, purpose, and location of the work or alterations; and assurance that the work or alterations will comply with applicable requirements listed in Rule 62-555.330, F.A.C. Suppliers of water may begin such work or alterations 14 days after providing notification to the Department unless they are advised by the Department that the notification is incomplete or that a construction permit is required.
- Suppliers of water shall telephone the SWO at 1-800-320-0519 immediately (i.e., within two hours) after discovery of any actual or suspected sabotage or security breach, or any suspicious incident, involving a public water system. [Rule 62-555.350(10)(a), F.A.C.]
- Suppliers of water shall telephone, and speak directly to a person at, the appropriate DEP District Office as soon as possible, but never later than noon of the next business day, in the event of any of the following emergency or abnormal operating conditions:
 - The occurrence of any abnormal color, odor, or taste in a public water system's raw or finished water;
 - The failure of a public water system to comply with applicable disinfection requirements; or
 - The breakdown of any water treatment or pumping facilities, or the break of any water main, in a public water system if the breakdown or break is expected to adversely affect finished-water quality, interrupt water service to 150 or more service connections or 350 or more people, interrupt water service to any one service connection for more than eight hours, or necessitate the issuance of a precautionary "boil water" notice in accordance with the Department of Health's "Guidelines for the Issuance of Precautionary Boil Water Notices" as adopted in Rule 62-555.335, F.A.C. [Rule 62-555.350(10)(b), F.A.C.]

COMMENTS(continued):

- Suppliers of water shall notify affected water customers in writing or via telephone, newspaper, radio, or television; and telephone, and speak directly to a person at, the appropriate DEP District Office by no later than the previous business day before taking PWS components out of operation for planned maintenance or repair work if the work is expected to adversely affect finished-water quality, interrupt water service to 150 or more service connections or 350 or more people, interrupt water service to any one service connection for more than eight hours, or necessitate the issuance of a precautionary "boil water" notice in accordance with the Department of Health's "Guidelines for the Issuance of Precautionary Boil Water Notices" as adopted in Rule 62-555.335, F.A.C. [Rule 62-555.350(10)(d), F.A.C.]
- Suppliers of water shall issue precautionary "boil water" notices as required or recommended in the Department of Health's "Guidelines for the Issuance of Precautionary Boil Water Notices" as adopted in Rule 62-555.335, F.A.C. [Rule 62-555.350(11), F.A.C.]



Inspector Signature

Manuel F. Cardona

Printed Name

Environmental Consultant

Title

6/10/22

Date



Reviewer Signature

David Smicherko

Printed Name

Environmental Manager

Title

6/14/2022

Date

APPENDIX F

Water Treatment System Calculations

FDEP Design Capacity Review

PWS ID NO.: 3350573 PLANT: Howey WTP No. 3

1. Total Well Capacity:

$$\boxed{3,000} \text{ GPM} \div 0.55 \text{ GPM/ERU} = \underline{\underline{5,455}} \text{ ERU's}$$

2. Total Aerator Capacity:

$$\boxed{3,000} \text{ GPM} \div 0.55 \text{ GPM/ERU} = \underline{\underline{5,455}} \text{ ERU's}$$

3. Total Ground Storage Capacity:

$$\boxed{600,000} \text{ Gallons} \div 240 \text{ minutes} = \underline{\underline{2,500}} \text{ GPM} \div 0.366 \text{ GPM/ERU} = \underline{\underline{6,831}} \text{ ERU's}$$

4. Total High Service Capacity:

$$\boxed{3,600} \text{ GPM} \div 1.10 \text{ GPM/ERU} = \underline{\underline{3,273}} \text{ ERU's}$$

5. Auxiliary Power Throughput:

$$\boxed{3,000} \text{ GPM} \div 0.275 \text{ GPM/ERU} = \underline{\underline{10,909}} \text{ ERU's}$$

6. Raw Throughput:

$$\underline{\underline{3,000}} \text{ GPM} \times 240 \text{ minutes} + \text{Storage} \quad \underline{\underline{600,000}} \text{ gallons} = \\ \underline{\underline{1,320,000}} \text{ gallons} \div (1.10 \text{ GPM/ERU} \times 240 \text{ minutes}) = \underline{\underline{5,000}} \text{ ERU's}$$

7. Design ERU Capacity =

$$\underline{\underline{3,273}} \text{ ERU} \times 350 \text{ Gallons/day} \times 2.25 = \underline{\underline{2,577,273}} \text{ GPD}$$

8. Maximum Day Design Capacity = 2.58 MGD

WELL HYDRAULIC CALCULATIONS

"Howey WTP No.3 - Well No. 5"

I. Well Construction		II. Static Water Level																																																																							
Well Use Type Description: Irrigation Outer Casing Diameter: 16 inches Outer Casing Depth: 0 feet Inner Casing Diameter: 12 inches Inner Casing Depth: 750 feet Total Well Depth: 1,061 feet Design Pumping Demand: 1,500 gpm		Natural Grade Elevation: 140.00 feet Top of Casing Elevation: 141.50 feet Drawdown Measuring Point Elevation: 141.50 feet Static Measuring Point: Measuring Point Static Water Level: 74.81 feet Static Water Level Elevation: 66.69 feet																																																																							
IV. Storage		III. Step-Drawdown Results																																																																							
Type: Cascade Tray Aerator Influent Discharge Elevation: 180.00 feet 0.0 DHWL Elevation: 180.00 feet		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: left;">Step</th> <th style="text-align: center;">Average Rate (gpm)</th> <th style="text-align: center;">Pump Level (ft)</th> <th style="text-align: center;">Drawdown (ft below Static)</th> <th style="text-align: center;">Capacity (gpm/ft)</th> </tr> </thead> <tbody> <tr><td>1</td><td style="text-align: center;">0</td><td style="text-align: center;">74.81</td><td style="text-align: center;">0.00</td><td style="text-align: center;">0.00</td></tr> <tr><td>2</td><td style="text-align: center;">516</td><td style="text-align: center;">75.30</td><td style="text-align: center;">0.49</td><td style="text-align: center;">6.85</td></tr> <tr><td>3</td><td style="text-align: center;">1,002</td><td style="text-align: center;">76.35</td><td style="text-align: center;">1.54</td><td style="text-align: center;">13.12</td></tr> <tr><td>4</td><td style="text-align: center;">1,489</td><td style="text-align: center;">78.10</td><td style="text-align: center;">3.29</td><td style="text-align: center;">19.07</td></tr> <tr><td>5</td><td style="text-align: center;">1,500</td><td style="text-align: center;">78.16</td><td style="text-align: center;">3.35</td><td style="text-align: center;">19.19</td></tr> <tr><td>6</td><td style="text-align: center;">2,068</td><td style="text-align: center;">81.03</td><td style="text-align: center;">6.22</td><td style="text-align: center;">25.52</td></tr> <tr><td>7</td><td></td><td></td><td style="text-align: center;">-74.81</td><td style="text-align: center;">0.00</td></tr> <tr><td>8</td><td></td><td></td><td style="text-align: center;">-74.81</td><td style="text-align: center;">0.00</td></tr> <tr><td>9</td><td></td><td></td><td style="text-align: center;">-74.81</td><td style="text-align: center;">0.00</td></tr> <tr><td>10</td><td></td><td></td><td style="text-align: center;">-74.81</td><td style="text-align: center;">0.00</td></tr> <tr><td>11</td><td></td><td></td><td style="text-align: center;">-74.81</td><td style="text-align: center;">0.00</td></tr> <tr><td>12</td><td></td><td></td><td style="text-align: center;">-74.81</td><td style="text-align: center;">0.00</td></tr> <tr><td>13</td><td></td><td></td><td style="text-align: center;">-74.81</td><td style="text-align: center;">0.00</td></tr> </tbody> </table>		Step	Average Rate (gpm)	Pump Level (ft)	Drawdown (ft below Static)	Capacity (gpm/ft)	1	0	74.81	0.00	0.00	2	516	75.30	0.49	6.85	3	1,002	76.35	1.54	13.12	4	1,489	78.10	3.29	19.07	5	1,500	78.16	3.35	19.19	6	2,068	81.03	6.22	25.52	7			-74.81	0.00	8			-74.81	0.00	9			-74.81	0.00	10			-74.81	0.00	11			-74.81	0.00	12			-74.81	0.00	13			-74.81	0.00
Step	Average Rate (gpm)	Pump Level (ft)	Drawdown (ft below Static)	Capacity (gpm/ft)																																																																					
1	0	74.81	0.00	0.00																																																																					
2	516	75.30	0.49	6.85																																																																					
3	1,002	76.35	1.54	13.12																																																																					
4	1,489	78.10	3.29	19.07																																																																					
5	1,500	78.16	3.35	19.19																																																																					
6	2,068	81.03	6.22	25.52																																																																					
7			-74.81	0.00																																																																					
8			-74.81	0.00																																																																					
9			-74.81	0.00																																																																					
10			-74.81	0.00																																																																					
11			-74.81	0.00																																																																					
12			-74.81	0.00																																																																					
13			-74.81	0.00																																																																					
V. Well Dynamics																																																																									
Design Pumping Demand: 1,500 gpm Drawdown below static: 3.35 feet Static Head Loss: 116.66 feet																																																																									
VI. Backflow Prevention																																																																									
Backflow Device Installed: Yes Backflow Device Type: Double Check Headloss: 3.0 psi																																																																									
VII. Distribution System Pressure																																																																									
Pressurized Distribution System: No Connection Pressure: 0.0 psi																																																																									
VII. Design Pressure Main Piping:																																																																									
Note: Information from Friction Losses Table <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Diameter (inches)</th> <th style="text-align: center;">Area (Section) (sf)</th> <th style="text-align: center;">Material</th> <th style="text-align: center;">Roughness Coefficient</th> <th style="text-align: center;">Length (ft)</th> <th style="text-align: center;">Design Flow (gpm)</th> <th style="text-align: center;">Velocity (fps)</th> <th style="text-align: center;">Capacity (gallons/ft)</th> </tr> </thead> <tbody> <tr><td style="text-align: center;">10</td><td style="text-align: center;">0.611</td><td style="text-align: center;">DIP</td><td style="text-align: center;">100</td><td style="text-align: center;">55</td><td style="text-align: center;">1,500</td><td style="text-align: center;">5.5</td><td style="text-align: center;">4.57</td></tr> <tr><td style="text-align: center;">12</td><td style="text-align: center;">0.871</td><td style="text-align: center;">DIP</td><td style="text-align: center;">100</td><td style="text-align: center;">170</td><td style="text-align: center;">1,500</td><td style="text-align: center;">3.8</td><td style="text-align: center;">6.52</td></tr> <tr><td style="text-align: center;">N/A</td><td></td><td></td><td></td><td style="text-align: center;">0</td><td style="text-align: center;">0</td><td style="text-align: center;">0.0</td><td style="text-align: center;">0.00</td></tr> <tr><td style="text-align: center;">N/A</td><td></td><td></td><td></td><td style="text-align: center;">0</td><td style="text-align: center;">0</td><td style="text-align: center;">0.0</td><td style="text-align: center;">0.00</td></tr> <tr><td style="text-align: center;">N/A</td><td></td><td></td><td></td><td style="text-align: center;">0</td><td style="text-align: center;">0</td><td style="text-align: center;">0.0</td><td style="text-align: center;">0.00</td></tr> </tbody> </table> Friction Head: $h_f = [(10.44 \times L \times Q^{1.85}) \div (C^{1.85} \times d^{4.8655})]$ 0.00 8.97 1.12 116.66 126.76 54.9 150									Diameter (inches)	Area (Section) (sf)	Material	Roughness Coefficient	Length (ft)	Design Flow (gpm)	Velocity (fps)	Capacity (gallons/ft)	10	0.611	DIP	100	55	1,500	5.5	4.57	12	0.871	DIP	100	170	1,500	3.8	6.52	N/A				0	0	0.0	0.00	N/A				0	0	0.0	0.00	N/A				0	0	0.0	0.00																	
Diameter (inches)	Area (Section) (sf)	Material	Roughness Coefficient	Length (ft)	Design Flow (gpm)	Velocity (fps)	Capacity (gallons/ft)																																																																		
10	0.611	DIP	100	55	1,500	5.5	4.57																																																																		
12	0.871	DIP	100	170	1,500	3.8	6.52																																																																		
N/A				0	0	0.0	0.00																																																																		
N/A				0	0	0.0	0.00																																																																		
N/A				0	0	0.0	0.00																																																																		
1 psi = 2.307 feet <b style="color: red;">Pressure Rating Exceeds Hydraulic Head Pressure - Pipe Diameter IS Suitable																																																																									
<u>Pump Manufacturers' Websites</u> Fairbanks Nijhuis: Vertical Turbine Pump Selection Software: https://www.pentair.com/en-us/brands/fairbanks-nijhuis.html Flowserve: Vertical Turbine Pump Selection Software: http://flowserve.bigmachines.com																																																																									

WELL HYDRAULIC CALCULATIONS

"Howey WTP No.3 - Well No. 6"

I. Well Construction		II. Static Water Level									
Well Use Type Description: <input type="button" value="Irrigation"/> Outer Casing Diameter: <input type="button" value="16"/> inches		Natural Grade Elevation: <input type="button" value="140.00"/> feet									
Outer Casing Depth: <input type="button" value="0"/> feet		Top of Casing Elevation: <input type="button" value="141.50"/> feet									
Inner Casing Diameter: <input type="button" value="12"/> inches		Drawdown Measuring Point Elevation: <input type="button" value="141.50"/> feet									
Inner Casing Depth: <input type="button" value="755"/> feet		Static Measuring Point: <input type="button" value="Measuring Point"/>									
Total Well Depth: <input type="button" value="1,087"/> feet		Static Water Level: <input type="button" value="76.80"/> feet									
Design Pumping Demand: <input type="button" value="1,500"/> gpm		Static Water Level Elevation: 64.70 feet									
IV. Storage		III. Step-Drawdown Results									
Type: <input type="button" value="Cascade Tray Aerator"/> Influent Discharge Elevation: <input type="button" value="180.00"/> feet		Step (gpm)	Average Rate (ft)	Pump Level (ft below Static)	Drawdown (ft below Static)	Capacity (gpm/ft)					
DHWL Elevation: 180.00 feet		1	0	76.80	0.00	0.00					
		2	501	77.55	0.75	6.46					
		3	1,002	78.93	2.13	12.69					
		4	1,500	81.53	4.73	18.40					
		5	1,504	81.55	4.75	18.44					
		6	2,230	86.59	9.79	25.75					
		7			-76.80	0.00					
		8			-76.80	0.00					
		9			-76.80	0.00					
		10			-76.80	0.00					
		11			-76.80	0.00					
		12			-76.80	0.00					
		13			-76.80	0.00					
V. Well Dynamics											
Design Pumping Demand: 1,500 gpm											
Drawdown below static: 4.73 feet											
Static Head Loss: 120.03 feet											
VI. Backflow Prevention											
Backflow Device Installed: <input type="button" value="Yes"/> Backflow Device Type: <input type="button" value="Double Check"/> Headloss: <input type="button" value="3.0"/> psi											
VII. Distribution System Pressure											
Pressurized Distribution System: <input type="button" value="No"/> Connection Pressure: <input type="button" value="0.0"/> psi											
VII. Design Pressure Main Piping:											
Note: Information from Friction Losses Table		Diameter (inches)	Area (Section) (sf)	Material	Roughness Coefficient	Length (ft)	Design Flow (gpm)	Velocity (fps)	Capacity (gallons/ft)		
		10	0.611	DIP	100	55	1,500	5.5	4.57		
		12	0.871	DIP	100	170	1,500	3.8	6.52		
		N/A				0	0	0.0	0.00		
		N/A				0	0	0.0	0.00		
		N/A				0	0	0.0	0.00		
		Friction Head: $h_f = [(10.44 \times L \times Q^{1.85}) \div (C^{1.85} \times d^{4.8655})]$	Pressure Head (ft)	Pipe Friction Head (ft)	Fittings Friction Head (ft)	Static Head (ft)	Total Head Loss* (ft) (psi)	Pressure Rating (psi)			
		1 psi = 2.307 feet	0.00	8.97	1.12	120.03	130.13	56.4	150		
Pressure Rating Exceeds Hydraulic Head Pressure - Pipe Diameter IS Suitable											
Pump Manufacturers' Websites											
Fairbanks Nijhuis: Vertical Turbine Pump Selection Software: https://www.pentair.com/en-us/brands/fairbanks-nijhuis.html											
Flowserve: Vertical Turbine Pump Selection Software: http://flowserve.bigmachines.com											

WATER TREATMENT PLANT CALCULATIONS

Howey WTP No. 3

I. Design Demand Rates (Total System):

A. Residential

Parcel ID	Type Description	Unit Description	Units	Unit Flow (GPD/Unit)	Average Daily Flow (GPD)	Average Daily Flow (GPM)	Minimum Daily Flow (GPM)	Maximum Daily Flow (GPM)	Peak Daily Flow (GPM)
1	Residential - Existing ERU - 408	ERU	1,226	408	500,208	347	174	695	1,389
2	Residential - Proposed ERU - 150	ERU	4,353	150	652,950	453	227	907	1,814
3	N/A	---		---	0	0	0	0	0
4	N/A	---		---	0	0	0	0	0
5	N/A	---		---	0	0	0	0	0
Total Residential				1,153,158	801	400	1,602	3,203	
Residential Design Peaking Factors:									
					F _{min}		F _{max}		F _{peak}
					0.50		2.00		4.00

B. Non-Residential

Parcel ID	Non-Residential Land Use Description	Unit Description	Units	Unit Flow (GPD/Unit)	Average Daily Flow (GPD)	Average Daily Flow (GPM)	Minimum Daily Flow (GPM)	Maximum Daily Flow (GPM)	Peak Daily Flow (GPM)
1	Commercial - Existing	ERU	97	408	39,576	27	14	55	110
2	Irrigation - Existing	ERU	453	408	184,824	128	64	257	513
3	Municipal - Existing Builder Construction	ERU	0	250	0	0	0	0	0
4	Municipal - Unaccounted	varies	1	input flow	176,000	122	61	244	489
5	Commercial - Proposed	square feet	535,000	0.15	80,250	56	28	111	223
6	Institutional - Proposed	square feet	381,000	0.25	95,250	66	33	132	265
Total Non-Residential				575,900	400	200	800	1,600	
Non-Residential Design Peaking Factors:									
					F _{min}		F _{max}		F _{peak}
					0.50		2.00		4.00

Equivalent Residential Unit, ERU: **250** gpd/du

Total Project ERU's = **6,916**

Total Design	Daily Flow (GPD)	Daily Flow (GPM)	Daily Flow (GPM)	Daily Flow (GPM)	Daily Flow (GPM)
1,729,058	1,201	600	2,401	4,803	

WATER TREATMENT PLANT CALCULATIONS

Howey WTP No. 3

II. Water Supply:

Criteria: Water Supply source capacity shall provide ADD with the largest source out of service.

System Average Daily Demand: 1,201 gpm

Water Supply Capacity:

Water Treatment Plant No. 1

Water Source:	Groundwater	
Well Pump No.	2	~ 1,000 gpm
Well Pump No.	4	~ 1,200 gpm
Well Pump No.		~ 0 gpm

Water Treatment Plant No. 2

Water Source:	Groundwater	
Well Pump No.		~ 0 gpm
Well Pump No.		~ 0 gpm
Well Pump No.		~ 0 gpm

Water Treatment Plant No. 3

Water Source:	Groundwater	
Well Pump No.	5	~ 1,500 gpm
Well Pump No.	6	~ 1,500 gpm
Well Pump No.		~ 0 gpm

Total Water Supply Capacity: 5,200 gpm

Minimum Capacity Provided: 3,700 gpm

ADD Capacity Required: 1,201 gpm

NOTE:

WATER TREATMENT PLANT CALCULATIONS

Howey WTP No. 3

III. Disinfection:

Treatment Facility: **Water Treatment Plant No. 3**

Water Supply Capacity: **3,000** gpm

Method: **Gas: Cl₂ Chlorine**

Minimum Dosage: **5.0** mg/L

Demand per lb Required: **180** lb/day

Cylinder Size: **150** lbs

Storage Capacity: **14** days

No. of Cylinders: **17**

$$\text{Dosage (mg/L)} = \frac{\text{lbs of active chemical per day}}{Q_{(MGD)} \times 8.345 \frac{\text{lbs L}}{\text{MG mg}}}$$

Method: **Liquid: Sodium Hypochlorite**

Storage Type: **Storage Tank**

Minimum Dosage: **5.0** mg/L

Demand per lb Required: **180** lb/day

NaOCl Specific Gravity: **1.25**

NaOCl Weight: **10.43** lbs/gal

Percent Concentration: **12.5%**

NaOCl Active Weight: **1.30** lbs/gal

Required Pump Feed Rate: **364** mL/minute

Required Pump Feed Rate: **5.76** gal/hour

Storage Capacity: **14** days

Required Storage: **1,937** gallon storage tank

3,785 mL = 1 gallon

1 gallon = 8.34 lbs

WATER TREATMENT PLANT CALCULATIONS

Howey WTP No. 3

VI. Water Storage Requirements:

Design Flow Rates:

System Average Daily Demand: gpm

System Maximum Daily Demand: gpm

System Peak Hour Demand: gpm

Water Storage Criteria:

Condition 1. The water system's total useful finished water storage capacity (excluding fire protection demand) shall be sufficient to provide 25% of the water system's MMD. **If total finished storage capacity is less than 25%, refer to Condition 2 and/or Condition 3**

Storage Required: MDD gpm x 0.25 x 60 min/hour x 24 hours

Storage Required: gallons

Condition 2. In conjunction with the capacity of the water system's source, treatment and finished water pumping facilities, the water system's total useful finished water storage capacity shall be sufficient to meet the water system's PHD for at least four (4) consecutive hours.

Storage Required: PHD gpm x 60 min/hour x 4 hours

Storage Required: gallons

Condition 3. In conjunction with the capacity of the water system's source, treatment and finished water pumping facilities, the water system's total useful finished water storage capacity shall be sufficient to meet the water system's MMD plus fire flow for at least four (4) consecutive hours.

Storage Required: (MDD + Fire) gpm x 60 min/hour x 4 hours

Fire Flow Required: gpm

Storage Required: gallons

IV. Water Storage Facility:

Water Treatment Plant No. 1

<input type="checkbox"/> Ground Storage Tank:	~	<input type="text" value="250,000"/> gallons
<input type="checkbox"/> None:	~	<input type="text" value="0"/> gallons

Water Treatment Plant No. 2

<input type="checkbox"/> None:	~	<input type="text" value="0"/> gallons
<input type="checkbox"/> None:	~	<input type="text" value="0"/> gallons

Water Treatment Plant No. 3

<input type="checkbox"/> Ground Storage Tank:	~	<input type="text" value="600,000"/> gallons
<input type="checkbox"/> Ground Storage Tank:	~	<input type="text" value="0"/> gallons

Finished Storage Provided: gallons

Condition 1. **Storage Required:** gallons **Note: Use larger of Storage Criteria Conditions 2 and 3**

Water Supply Source: gallons (Q gpm x 240 min.)

Total Storage Provided: gallons

Condition 2. **Storage Required:** gallons

Condition 3. **Storage Required:** gallons

WATER TREATMENT PLANT CALCULATIONS

Howey WTP No. 3

V. Water Distribution: High Service Pumps

Design Flow Rates:

System Average Daily Demand: 1,201 gpm

System Maximum Daily Demand: 2,401 gpm

System Peak Hour Demand: 4,803 gpm

High Service Pump Criteria:

Condition 1. The total capacity of all high-service pumping stations connected to a water system shall meet at least the water system's peak-hour water demand (PHD).

Capacity Required: 4,803 gpm

Condition 2. The total capacity of all high-service pumping stations connected to a water system shall meet at least the water system's design fire-flow rate plus the maximum-day demand (MDD) if fire protection is provided.

Fire Flow Required: 1,500 gpm

Max.-Day Demand: 2,401 gpm

Capacity Required: 3,901 gpm

Condition 3. At each high-service pumping station connected to the water system the supplier shall provide a standby pump (installed or uninstalled) of sufficient capacity to replace the largest capacity pump.

High Service Pump Capacity:

Water Treatment Plant No. 1

HSP Pump No.	1	~	360	gpm
HSP Pump No.	2	~	2,800	gpm
HSP Pump No.	3	~	2,800	gpm
HSP Pump No.	4	~	1,000	gpm

Water Treatment Plant No. 2

HSP Pump No.		~	0	gpm
HSP Pump No.		~	0	gpm
HSP Pump No.		~	0	gpm

Water Treatment Plant No. 3

HSP Pump No.	4	~	600	gpm
HSP Pump No.	5	~	1,000	gpm
HSP Pump No.	6	~	1,000	gpm
HSP Pump No.	7	~	1,000	gpm

Total HSP Capacity: 10,560 gpm


Minimum Capacity Provided: 6,760 gpm

Minimum Capacity Required: 4,803 gpm

NOTE:

APPENDIX G

WaterCAD Analyses



Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Ave Day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1248	J-WTP3-1	140.00	0	0	141.99	1
668	J-WTP1-3	81.00	0	0	83.00	1
666	J-WTP1-2	81.00	0	0	83.00	1
664	J-WTP1-1	81.00	0	0	83.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	1	23,550	245.55	37
68	J-Mission Inn 6	154.00	1	6,528	245.56	40
568	J-Mission Inn 5	154.00	0	0	245.56	40
355	J-140	152.00	0	0	245.54	40
44	J-8	152.00	1	408	245.54	40
66	J-Mission Inn 10	152.00	0	0	245.56	40
41	J-6	152.00	0	0	245.57	40
46	J-9	151.00	0	0	245.57	41
74	J-Mission Inn 9	150.00	1	1,632	245.56	41
78	J-Mission Inn 4	150.00	0	0	245.57	41
82	J-Mission Inn 3	149.00	0	0	245.57	42
86	J-Mission Inn 2	149.00	1	6,120	245.57	42
70	J-Mission Inn 7	148.00	1	3,264	245.56	42
48	J-Mission Inn 1	148.00	0	0	245.57	42
764	J-Whispering Hills 2	146.07	0	0	245.54	43
374	J-141	146.00	0	0	245.53	43
72	J-Mission Inn 8	146.00	1	1,632	245.56	43
866	J-Watermark 4	145.57	1	3,600	245.55	43
351	J-94	144.00	0	0	245.54	44
539	J-142	141.00	0	0	245.53	45
1217	J-386	141.00	0	0	245.56	45
1122	J-354	140.00	0	0	245.60	46
1178	J-Lake Hills 1	140.00	0	0	245.62	46
1245	J-WTP3-2	140.00	0	0	245.63	46
863	J-Watermark 3	135.17	1	3,300	245.55	48
1162	J-365	135.00	0	0	245.55	48
50	J-Mission Inn 11	134.00	0	0	245.56	48
640	J-198	131.95	0	0	245.55	49
90	J-Mission Inn 14	131.00	0	0	245.57	50
94	J-Mission Inn 15	130.00	0	0	245.57	50
92	J-23	130.00	0	0	245.57	50
96	J-25	130.00	0	0	245.57	50
114	J-27	129.00	1	6,120	245.57	50
338	J-93	128.00	0	0	245.56	51
100	J-26	128.00	1	1,224	245.57	51
442	J-7	128.00	0	0	245.59	51
37	J-5	128.00	0	0	245.59	51
33	J-4	128.00	0	0	245.59	51
31	J-2	128.00	0	0	245.59	51
35	J-3	128.00	0	0	245.59	51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Ave Day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1108	J-Drake Point 3	126.24	1	26,400	245.51	52
52	J-Mission Inn 12	125.00	0	0	245.56	52
54	J-Mission Inn 13	124.00	1	14,688	245.56	53
544	J-170	123.00	0	0	245.53	53
502	J-98	122.00	0	0	245.55	53
490	J-102	122.00	0	0	245.57	53
512	J-96	121.00	0	0	245.54	54
104	J-92	121.00	0	0	245.56	54
102	J-38	121.00	0	0	245.57	54
1106	J-Drake Point 2	120.00	1	26,550	245.51	54
495	J-90	120.00	0	0	245.57	54
325	J-89	120.00	0	0	245.57	54
322	J-88	120.00	0	0	245.57	54
643	J-199	119.72	0	0	245.55	54
340	J-97	119.00	1	5,712	245.55	55
348	J-95	118.00	1	6,936	245.54	55
576	J-183	118.00	0	0	245.57	55
377	J-157	117.00	1	4,896	245.53	56
372	J-143	117.00	1	1,632	245.53	56
315	J-104	117.00	0	0	245.57	56
860	J-Watermark 2	116.57	1	3,300	245.55	56
108	J-39	116.00	0	0	245.58	56
110	J-40	116.00	1	4,488	245.58	56
319	J-87	115.00	0	0	245.57	56
332	J-99	113.00	1	4,080	245.55	57
334	J-91	113.00	1	1,632	245.56	57
106	J-37	112.00	1	2,040	245.57	58
357	J-139	107.00	1	6,120	245.54	60
306	J-106	106.00	0	0	245.58	60
983	J-Venezia 23	105.00	1	4,896	245.55	61
978	J-Venezia 18	105.00	1	4,080	245.56	61
447	J-36	105.00	0	0	245.57	61
612	J-190	104.74	0	0	245.59	61
897	J-Talichet 1	104.83	0	0	245.70	61
616	J-191	104.64	1	4,080	245.59	61
529	J-156	104.00	0	0	245.53	61
534	J-144	104.00	0	0	245.53	61
123	J-35	104.00	1	4,896	245.57	61
121	J-32	104.00	1	8,160	245.57	61
169	J-63	104.00	1	4,896	245.63	61
369	J-145	103.00	1	1,224	245.53	62
304	J-86	103.00	1	1,224	245.58	62
973	J-Venezia 19	102.41	1	4,488	245.56	62
786	J-248	102.22	0	0	245.62	62
382	J-158	102.00	1	4,896	245.53	62

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Ave Day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
507	J-136	102.00	0	0	245.55	62
215	J-77	102.00	0	0	245.59	62
165	J-60	102.00	1	4,488	245.62	62
167	J-61	102.00	0	0	245.62	62
1110	J-Lake Hills 12	101.23	0	0	245.57	62
772	J-240	100.95	0	0	245.55	63
1148	J-Watermark 1	100.95	0	0	245.55	63
566	J-62	101.00	0	0	245.62	63
211	J-56	100.22	0	0	245.62	63
809	J-Mission Rise 5	100.08	1	4,350	245.54	63
773	J-Venezia 1	100.12	0	0	245.61	63
1053	J-Venezia 2	100.09	0	0	245.60	63
379	J-155	100.00	1	3,264	245.53	63
156	J-54	100.06	1	816	245.62	63
635	J-197	100.00	0	0	245.59	63
201	J-52	100.00	0	0	245.64	63
203	J-51	100.00	1	816	245.64	63
895	J-Talichet 2	99.21	0	0	245.70	63
213	J-Venezia 3	99.00	0	0	245.59	63
812	J-Mission Rise 6	98.40	1	4,350	245.53	64
968	J-Venezia 20	97.78	1	4,488	245.56	64
815	J-Mission Rise 7	97.32	1	4,350	245.52	64
848	J-Mission Rise 18	97.08	1	4,200	245.53	64
702	J-Venezia 4	97.00	1	12,750	245.58	64
688	J-209	97.00	1	2,040	245.62	64
158	J-53	97.00	1	5,304	245.62	64
839	J-Mission Rise 15	96.89	1	4,200	245.52	64
192	J-50	96.50	1	408	245.66	65
842	J-Mission Rise 16	96.14	1	4,200	245.52	65
154	J-58	96.00	1	408	245.62	65
629	J-196	96.00	1	5,304	245.62	65
934	J-Talichet 6	95.60	1	1,224	245.70	65
1133	J-Venezia 24	95.33	1	6,528	245.55	65
524	J-154	95.00	0	0	245.53	65
235	J-131	95.00	0	0	245.55	65
930	J-Talichet 3	95.16	1	2,448	245.70	65
239	J-132	95.00	0	0	245.55	65
957	J-Venezia 25	95.00	1	4,080	245.55	65
465	J-78	95.00	0	0	245.59	65
1168	J-Venezia TH 1	95.00	0	0	245.59	65
607	J-189	95.00	0	0	245.62	65
932	J-Talichet 4	95.07	1	1,224	245.70	65
186	J-49	95.08	1	408	245.71	65
881	J-Talichet II 1	94.95	1	2,250	245.61	65
1043	J-324	95.01	0	0	245.78	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Ave Day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1041	J-323	94.88	0	0	245.78	65
806	J-Mission Rise 4	94.43	1	4,350	245.55	65
818	J-Mission Rise 8	94.12	1	4,350	245.51	65
824	J-Mission Rise 10	94.09	1	2,550	245.51	66
827	J-Mission Rise 11	94.06	1	2,550	245.51	66
1166	J-Venezia TH 2	94.00	1	2,700	245.58	66
255	J-79	94.00	1	1,632	245.59	66
386	J-153	93.00	1	2,448	245.53	66
388	J-159	93.00	0	0	245.53	66
367	J-146	93.00	1	1,224	245.53	66
704	J-Venezia 5	93.00	0	0	245.56	66
581	J-184	93.00	0	0	245.58	66
251	J-123	93.00	0	0	245.59	66
194	J-66	93.00	1	1,224	245.64	66
963	J-Venezia 21	92.72	1	5,304	245.56	66
1100	J-Golden Hills 1	92.58	1	91,050	245.50	66
1112	J-Thompson Grove 1	92.46	1	40,800	245.57	66
1102	J-Lake Hills 11	92.23	0	0	245.56	66
1195	J-Lake Hills 10	92.00	1	10,650	245.56	66
116	J-28	92.00	0	0	245.57	66
119	J-29	92.00	1	4,896	245.57	66
879	J-Talichet II 2	92.00	1	900	245.61	66
776	J-Cedar Creek 1	91.69	1	25,650	245.57	67
404	J-162	91.00	0	0	245.53	67
1203	J-Venezia TH 3	91.00	1	3,450	245.58	67
475	J-120	91.00	0	0	245.59	67
133	J-33	91.00	0	0	245.61	67
152	J-76	91.00	1	3,264	245.63	67
730	J-Venezia 30	90.81	0	0	245.56	67
883	J-Talichet 14	90.88	1	1,224	245.64	67
1138	J-Venezia 32	90.74	1	1,632	245.56	67
556	J-174	91.00	0	0	245.86	67
936	J-Talichet 5	90.78	1	2,040	245.70	67
1142	J-Mission Rise 1	90.47	0	0	245.57	67
845	J-Mission Rise 17	90.35	1	4,200	245.52	67
1035	J-Venezia 34	90.25	1	816	245.56	67
724	J-220	90.23	0	0	245.55	67
836	J-Mission Rise 14	90.07	1	2,550	245.52	67
400	J-160	90.00	1	6,528	245.53	67
245	J-134	90.00	1	4,080	245.54	67
241	J-133	90.00	0	0	245.54	67
720	J-Venezia 26	90.00	1	2,040	245.55	67
1059	J-Talichet 13	90.07	1	408	245.64	67
480	J-118	90.00	0	0	245.59	67
268	J-81	90.00	1	1,632	245.59	67

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Ave Day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1152	J-Mission Rise 22	89.96	0	0	245.55	67
800	J-Mission Rise 2	89.97	1	4,200	245.57	67
597	J-187	90.00	0	0	245.64	67
179	J-67	90.00	0	0	245.65	67
803	J-Mission Rise 3	89.89	1	4,200	245.55	67
876	J-The Reserve 14	89.84	0	0	245.58	67
432	J-44	90.00	0	0	245.78	67
436	J-45	90.00	0	0	245.78	67
585	J-185	90.00	0	0	245.87	67
1084	J-The Reserve 13	89.69	2	49,500	245.58	67
1081	J-The Reserve 12	89.60	1	900	245.58	67
893	J-Talichet 7	89.60	1	4,896	245.71	68
1078	J-The Reserve 11	89.47	1	900	245.58	68
830	J-Mission Rise 12	89.37	1	2,550	245.51	68
1075	J-The Reserve 10	89.34	2	52,150	245.58	68
732	J-Venezia 31	89.16	1	2,448	245.56	68
452	J-41	89.00	1	2,040	245.61	68
173	J-64	89.00	0	0	245.64	68
198	J-65	89.00	1	2,040	245.64	68
762	J-234	88.95	0	0	245.60	68
1004	J-Venezia 12	88.68	1	1,632	245.55	68
885	J-Talichet 12	88.74	1	816	245.64	68
833	J-Mission Rise 13	88.53	1	2,550	245.52	68
1129	J-Venezia 10	88.52	1	4,488	245.55	68
1064	J-329	88.47	0	0	245.57	68
851	J-Mission Rise 19	88.36	1	4,200	245.53	68
407	J-163	88.00	1	1,224	245.53	68
624	J-194	88.00	1	1,224	245.54	68
126	J-30	88.00	0	0	245.58	68
130	J-31	88.00	0	0	245.58	68
257	J-80	88.00	1	1,632	245.59	68
602	J-188	88.00	0	0	245.64	68
1157	J-330	87.56	0	0	245.57	68
914	J-Talichet 17	87.41	1	2,040	245.64	68
821	J-Mission Rise 9	87.13	1	2,550	245.51	69
402	J-161	87.00	0	0	245.53	69
426	J-168	87.00	0	0	245.53	69
1119	J-Westminster 1	87.02	1	52,500	245.56	69
738	J-Venezia 33	87.00	1	2,448	245.56	69
873	J-The Reserve 8	86.99	0	0	245.57	69
301	J-85	87.00	0	0	245.59	69
176	J-75	87.00	0	0	245.64	69
1017	J-Venezia 6	86.57	0	0	245.55	69
759	J-The Reserve 9	86.74	1	3,450	245.74	69
994	J-Venezia 22	86.52	1	1,632	245.55	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Ave Day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
712	J-215	86.31	0	0	245.54	69
706	J-Venezia 7	86.00	0	0	245.55	69
677	J-WTP1-6	86.25	0	0	245.89	69
678	J-WTP1-5	86.25	0	0	245.89	69
679	J-WTP1-4	86.25	0	0	245.89	69
887	J-Talichet 11	86.01	1	4,896	245.65	69
181	J-68	86.00	0	0	245.65	69
797	J-251	85.79	0	0	245.57	69
793	J-Venezia 35	85.52	0	0	245.57	69
857	J-Mission Rise 21	85.31	1	4,200	245.54	69
790	J-249	85.17	0	0	245.57	69
775	J-The Reserve 1	85.21	0	0	245.62	69
952	J-Venezia 29	85.03	1	2,040	245.55	69
1095	J-The Reserve 6	85.05	1	36,300	245.57	69
854	J-Mission Rise 20	85.00	1	4,200	245.54	69
621	J-193	85.00	1	408	245.55	69
1087	J-The Reserve 2	85.05	1	12,900	245.62	69
1093	J-The Reserve 5	85.01	1	1,500	245.58	69
1097	J-The Reserve 7	85.00	1	36,300	245.57	69
1091	J-The Reserve 4	85.00	1	1,500	245.58	69
470	J-122	85.00	0	0	245.59	69
1089	J-The Reserve 3	85.01	1	10,050	245.60	69
143	J-71	85.00	0	0	245.63	69
141	J-70	85.00	0	0	245.64	69
910	J-Talichet 15	85.00	1	4,488	245.64	70
912	J-Talichet 16	85.00	1	2,856	245.64	70
889	J-Talichet 10	85.00	1	1,224	245.69	70
891	J-Talichet 8	85.00	1	7,344	245.71	70
923	J-Talichet 9	85.00	1	1,224	245.72	70
926	J-295	85.00	1	1,224	245.74	70
549	J-Mitchell 1	85.00	1	5,304	245.74	70
592	J-186	85.00	1	2,856	245.75	70
769	J-238	85.00	0	0	245.86	70
728	J-Venezia 28	84.00	0	0	245.55	70
1183	J-Lake Hills 3	84.00	1	10,800	245.57	70
1205	J-Venezia TH 4	84.00	1	10,800	245.58	70
135	J-34	84.00	1	4,080	245.58	70
139	J-42	84.00	0	0	245.62	70
429	J-43	84.00	1	3,672	245.63	70
554	J-173	84.00	0	0	245.75	70
391	J-152	83.00	0	0	245.53	70
393	J-151	83.00	1	2,448	245.53	70
422	J-150	83.00	1	1,224	245.53	70
718	J-Venezia 11	83.00	1	3,264	245.55	70
722	J-Venezia 27	83.00	1	4,488	245.55	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Ave Day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
249	J-121	83.00	1	2,040	245.59	70
457	J-125	82.31	1	4,080	245.57	71
1012	J-Venezia 9	82.26	1	2,448	245.55	71
754	J-229	82.11	0	0	245.54	71
708	J-Venezia 8	82.00	1	816	245.55	71
1184	J-Lake Hills 4	82.00	1	10,800	245.56	71
485	J-108	82.00	0	0	245.59	71
264	J-117	82.00	0	0	245.59	71
1170	J-369	82.00	0	0	245.74	71
552	J-172	82.00	0	0	245.74	71
1032	J-Venezia 17	81.62	1	816	245.54	71
1023	J-Venezia 13	81.45	1	1,224	245.55	71
756	J-Whispering Hills 1	81.37	0	0	245.54	71
365	J-147	81.00	1	1,224	245.53	71
716	J-Venezia 16	81.00	1	1,632	245.54	71
1177	J-Lake Hills 2	81.00	2	66,500	245.57	71
273	J-113	81.00	0	0	245.59	71
275	J-82	81.00	0	0	245.59	71
150	J-74	81.00	1	816	245.63	71
757	J-231	80.71	0	0	245.54	71
999	J-Venezia 14	80.56	1	1,632	245.55	71
710	J-Venezia 15	80.00	1	1,224	245.54	72
1188	J-Lake Hills 6	80.00	1	10,650	245.56	72
1192	J-Lake Hills 7	79.00	1	10,650	245.56	72
1214	J-Venezia S	79.00	0	0	245.57	72
259	J-119	78.00	1	4,488	245.59	73
419	J-149	77.00	0	0	245.53	73
231	J-130	77.00	0	0	245.54	73
219	J-Island 1	77.00	1	816	245.56	73
289	J-84	77.00	0	0	245.60	73
112	J-72	77.00	0	0	245.61	73
280	J-112	77.00	0	0	245.61	73
148	J-73	77.00	0	0	245.62	73
363	J-148	76.00	0	0	245.53	73
360	J-138	76.00	1	4,488	245.53	73
1196	J-Lake Hills 9	76.00	1	10,800	245.56	73
1104	J-Drake Point 1	75.00	1	26,550	245.51	74
409	J-164	75.00	1	4,896	245.53	74
227	J-129	75.00	1	8,160	245.54	74
1187	J-Lake Hills 5	75.00	1	10,650	245.56	74
1114	J-Cypress Point 1	73.64	1	8,250	245.56	74
413	J-166	72.00	0	0	245.53	75
1189	J-Lake Hills 8	71.00	1	10,650	245.56	76
327	J-101	71.00	1	5,304	245.56	76
1068	J-Whispering Hills 3	70.72	1	18,750	245.53	76

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Ave Day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1116	J-Cypress Point 2	70.02	1	8,250	245.56	76
346	J-137	70.00	1	5,304	245.54	76
646	J-200	70.00	0	0	245.55	76
343	J-135	70.00	1	5,304	245.55	76
330	J-100	70.00	1	2,856	245.56	76
313	J-103	70.00	1	7,752	245.57	76
519	J-169	69.00	0	0	245.53	76
417	J-167	68.00	1	3,264	245.53	77
262	J-116	68.00	1	6,120	245.59	77
292	J-110	68.00	0	0	245.59	77
217	J-124	67.00	0	0	245.58	77
299	J-107	67.00	1	5,304	245.59	77
310	J-105	66.00	1	5,712	245.58	78
1070	J-Whispering Hills 4	65.00	1	4,650	245.53	78
225	J-Island 3	65.00	1	3,672	245.56	78
411	J-165	64.00	1	2,040	245.51	79
271	J-115	64.00	1	3,672	245.59	79
296	J-109	64.00	0	0	245.59	79
286	J-111	64.00	1	408	245.59	79
221	J-Island 2	62.00	1	1,632	245.56	79

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1248	J-WTP3-1	140.00	0	0	141.97	1
668	J-WTP1-3	81.00	0	0	82.98	1
666	J-WTP1-2	81.00	0	0	82.98	1
664	J-WTP1-1	81.00	0	0	82.98	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	1	60,053	245.44	37
68	J-Mission Inn 6	154.00	1	16,646	245.55	40
568	J-Mission Inn 5	154.00	0	0	245.56	40
355	J-140	152.00	0	0	245.41	40
44	J-8	152.00	1	1,040	245.42	40
66	J-Mission Inn 10	152.00	0	0	245.55	40
41	J-6	152.00	0	0	245.57	40
46	J-9	151.00	0	0	245.57	41
74	J-Mission Inn 9	150.00	1	4,162	245.55	41
78	J-Mission Inn 4	150.00	0	0	245.56	41
82	J-Mission Inn 3	149.00	0	0	245.56	42
86	J-Mission Inn 2	149.00	1	15,606	245.56	42
70	J-Mission Inn 7	148.00	1	8,323	245.55	42
48	J-Mission Inn 1	148.00	0	0	245.57	42
764	J-Whispering Hills 2	146.07	0	0	245.42	43
374	J-141	146.00	0	0	245.39	43
72	J-Mission Inn 8	146.00	1	4,162	245.55	43
866	J-Watermark 4	145.57	1	9,180	245.45	43
351	J-94	144.00	0	0	245.44	44
539	J-142	141.00	0	0	245.39	45
1217	J-386	141.00	0	0	245.56	45
1122	J-354	140.00	0	0	245.78	46
1178	J-Lake Hills 1	140.00	0	0	245.88	46
1245	J-WTP3-2	140.00	0	0	245.90	46
863	J-Watermark 3	135.17	1	8,415	245.45	48
1162	J-365	135.00	0	0	245.44	48
50	J-Mission Inn 11	134.00	0	0	245.55	48
640	J-198	131.95	0	0	245.50	49
90	J-Mission Inn 14	131.00	0	0	245.57	50
94	J-Mission Inn 15	130.00	0	0	245.57	50
92	J-23	130.00	0	0	245.57	50
96	J-25	130.00	0	0	245.57	50
114	J-27	129.00	1	15,606	245.57	50
338	J-93	128.00	0	0	245.52	51
100	J-26	128.00	1	3,121	245.57	51
442	J-7	128.00	0	0	245.67	51
37	J-5	128.00	0	0	245.68	51
33	J-4	128.00	0	0	245.68	51
31	J-2	128.00	0	0	245.68	51
35	J-3	128.00	0	0	245.69	51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1108	J-Drake Point 3	126.24	1	67,320	245.23	51
52	J-Mission Inn 12	125.00	0	0	245.54	52
54	J-Mission Inn 13	124.00	1	37,454	245.54	53
544	J-170	123.00	0	0	245.38	53
502	J-98	122.00	0	0	245.49	53
490	J-102	122.00	0	0	245.57	53
512	J-96	121.00	0	0	245.44	54
104	J-92	121.00	0	0	245.56	54
102	J-38	121.00	0	0	245.57	54
1106	J-Drake Point 2	120.00	1	67,703	245.24	54
495	J-90	120.00	0	0	245.60	54
325	J-89	120.00	0	0	245.60	54
322	J-88	120.00	0	0	245.61	54
643	J-199	119.72	0	0	245.46	54
340	J-97	119.00	1	14,566	245.47	55
348	J-95	118.00	1	17,687	245.43	55
576	J-183	118.00	0	0	245.61	55
377	J-157	117.00	1	12,485	245.38	56
372	J-143	117.00	1	4,162	245.38	56
315	J-104	117.00	0	0	245.60	56
860	J-Watermark 2	116.57	1	8,415	245.45	56
108	J-39	116.00	0	0	245.62	56
110	J-40	116.00	1	11,444	245.62	56
319	J-87	115.00	0	0	245.61	57
332	J-99	113.00	1	10,404	245.50	57
334	J-91	113.00	1	4,162	245.56	57
106	J-37	112.00	1	5,202	245.59	58
357	J-139	107.00	1	15,606	245.40	60
306	J-106	106.00	0	0	245.63	60
983	J-Venezia 23	105.00	1	12,485	245.46	61
978	J-Venezia 18	105.00	1	10,404	245.52	61
447	J-36	105.00	0	0	245.61	61
612	J-190	104.74	0	0	245.72	61
616	J-191	104.64	1	10,404	245.73	61
529	J-156	104.00	0	0	245.37	61
534	J-144	104.00	0	0	245.38	61
897	J-Talichet 1	104.83	0	0	246.33	61
123	J-35	104.00	1	12,485	245.61	61
121	J-32	104.00	1	20,808	245.61	61
169	J-63	104.00	1	12,485	245.92	61
369	J-145	103.00	1	3,121	245.38	62
304	J-86	103.00	1	3,121	245.64	62
973	J-Venezia 19	102.41	1	11,444	245.52	62
382	J-158	102.00	1	12,485	245.37	62
507	J-136	102.00	0	0	245.47	62

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
786	J-248	102.22	0	0	245.89	62
215	J-77	102.00	0	0	245.68	62
165	J-60	102.00	1	11,444	245.90	62
167	J-61	102.00	0	0	245.90	62
1110	J-Lake Hills 12	101.23	0	0	245.59	62
772	J-240	100.95	0	0	245.46	63
1148	J-Watermark 1	100.95	0	0	245.46	63
566	J-62	101.00	0	0	245.90	63
809	J-Mission Rise 5	100.08	1	11,093	245.40	63
379	J-155	100.00	1	8,323	245.37	63
211	J-56	100.22	0	0	245.85	63
635	J-197	100.00	0	0	245.68	63
1053	J-Venezia 2	100.09	0	0	245.77	63
773	J-Venezia 1	100.12	0	0	245.81	63
156	J-54	100.06	1	2,081	245.86	63
201	J-52	100.00	0	0	246.01	63
203	J-51	100.00	1	2,081	246.01	63
213	J-Venezia 3	99.00	0	0	245.71	63
812	J-Mission Rise 6	98.40	1	11,093	245.35	64
895	J-Talichet 2	99.21	0	0	246.33	64
968	J-Venezia 20	97.78	1	11,444	245.51	64
815	J-Mission Rise 7	97.32	1	11,093	245.31	64
848	J-Mission Rise 18	97.08	1	10,710	245.36	64
839	J-Mission Rise 15	96.89	1	10,710	245.30	64
702	J-Venezia 4	97.00	1	32,513	245.65	64
688	J-209	97.00	1	5,202	245.87	64
158	J-53	97.00	1	13,525	245.89	64
842	J-Mission Rise 16	96.14	1	10,710	245.31	65
192	J-50	96.50	1	1,040	246.10	65
154	J-58	96.00	1	1,040	245.89	65
629	J-196	96.00	1	13,525	245.89	65
1133	J-Venezia 24	95.33	1	16,646	245.47	65
524	J-154	95.00	0	0	245.37	65
235	J-131	95.00	0	0	245.44	65
239	J-132	95.00	0	0	245.44	65
957	J-Venezia 25	95.00	1	10,404	245.47	65
1168	J-Venezia TH 1	95.00	0	0	245.68	65
465	J-78	95.00	0	0	245.68	65
934	J-Talichet 6	95.60	1	3,121	246.33	65
881	J-Talichet II 1	94.95	1	5,738	245.79	65
607	J-189	95.00	0	0	245.89	65
806	J-Mission Rise 4	94.43	1	11,093	245.44	65
818	J-Mission Rise 8	94.12	1	11,093	245.23	65
824	J-Mission Rise 10	94.09	1	6,503	245.25	65
930	J-Talichet 3	95.16	1	6,242	246.33	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
827	J-Mission Rise 11	94.06	1	6,503	245.25	65
932	J-Talichet 4	95.07	1	3,121	246.33	65
186	J-49	95.08	1	1,040	246.40	65
1166	J-Venezia TH 2	94.00	1	6,885	245.65	66
255	J-79	94.00	1	4,162	245.68	66
1043	J-324	95.01	0	0	246.78	66
1041	J-323	94.88	0	0	246.79	66
386	J-153	93.00	1	6,242	245.37	66
388	J-159	93.00	0	0	245.38	66
367	J-146	93.00	1	3,121	245.38	66
704	J-Venezia 5	93.00	0	0	245.54	66
1100	J-Golden Hills 1	92.58	1	232,178	245.21	66
581	J-184	93.00	0	0	245.66	66
251	J-123	93.00	0	0	245.68	66
963	J-Venezia 21	92.72	1	13,525	245.51	66
194	J-66	93.00	1	3,121	246.01	66
1112	J-Thompson Grove 1	92.46	1	104,040	245.57	66
1102	J-Lake Hills 11	92.23	0	0	245.55	66
1195	J-Lake Hills 10	92.00	1	27,158	245.54	66
116	J-28	92.00	0	0	245.61	66
119	J-29	92.00	1	12,485	245.61	66
879	J-Talichet II 2	92.00	1	2,295	245.78	67
776	J-Cedar Creek 1	91.69	1	65,408	245.56	67
404	J-162	91.00	0	0	245.37	67
1203	J-Venezia TH 3	91.00	1	8,798	245.63	67
475	J-120	91.00	0	0	245.68	67
730	J-Venezia 30	90.81	0	0	245.51	67
1138	J-Venezia 32	90.74	1	4,162	245.54	67
133	J-33	91.00	0	0	245.82	67
152	J-76	91.00	1	8,323	245.94	67
845	J-Mission Rise 17	90.35	1	10,710	245.32	67
883	J-Talichet 14	90.88	1	3,121	245.91	67
1142	J-Mission Rise 1	90.47	0	0	245.58	67
724	J-220	90.23	0	0	245.45	67
836	J-Mission Rise 14	90.07	1	6,503	245.29	67
1035	J-Venezia 34	90.25	1	2,081	245.54	67
400	J-160	90.00	1	16,646	245.37	67
245	J-134	90.00	1	10,404	245.43	67
241	J-133	90.00	0	0	245.43	67
720	J-Venezia 26	90.00	1	5,202	245.47	67
1152	J-Mission Rise 22	89.96	0	0	245.46	67
936	J-Talichet 5	90.78	1	5,202	246.33	67
800	J-Mission Rise 2	89.97	1	10,710	245.56	67
803	J-Mission Rise 3	89.89	1	10,710	245.49	67
480	J-118	90.00	0	0	245.69	67

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
268	J-81	90.00	1	4,162	245.69	67
876	J-The Reserve 14	89.84	0	0	245.65	67
1059	J-Talichet 13	90.07	1	1,040	245.94	67
830	J-Mission Rise 12	89.37	1	6,503	245.26	67
1084	J-The Reserve 13	89.69	2	126,225	245.62	67
597	J-187	90.00	0	0	246.01	67
179	J-67	90.00	0	0	246.01	68
1081	J-The Reserve 12	89.60	1	2,295	245.62	68
1078	J-The Reserve 11	89.47	1	2,295	245.62	68
556	J-174	91.00	0	0	247.23	68
1075	J-The Reserve 10	89.34	2	132,983	245.62	68
732	J-Venezia 31	89.16	1	6,242	245.54	68
833	J-Mission Rise 13	88.53	1	6,503	245.27	68
893	J-Talichet 7	89.60	1	12,485	246.35	68
432	J-44	90.00	0	0	246.75	68
1004	J-Venezia 12	88.68	1	4,162	245.44	68
762	J-234	88.95	0	0	245.74	68
436	J-45	90.00	0	0	246.79	68
452	J-41	89.00	1	5,202	245.83	68
1129	J-Venezia 10	88.52	1	11,444	245.44	68
173	J-64	89.00	0	0	245.97	68
198	J-65	89.00	1	5,202	245.99	68
851	J-Mission Rise 19	88.36	1	10,710	245.37	68
1064	J-329	88.47	0	0	245.58	68
885	J-Talichet 12	88.74	1	2,081	245.95	68
585	J-185	90.00	0	0	247.27	68
407	J-163	88.00	1	3,121	245.37	68
624	J-194	88.00	1	3,121	245.43	68
126	J-30	88.00	0	0	245.64	68
130	J-31	88.00	0	0	245.67	68
257	J-80	88.00	1	4,162	245.69	68
602	J-188	88.00	0	0	245.97	68
1157	J-330	87.56	0	0	245.56	68
821	J-Mission Rise 9	87.13	1	6,503	245.24	68
402	J-161	87.00	0	0	245.37	69
426	J-168	87.00	0	0	245.37	69
1119	J-Westminster 1	87.02	1	133,875	245.54	69
914	J-Talichet 17	87.41	1	5,202	245.93	69
738	J-Venezia 33	87.00	1	6,242	245.54	69
873	J-The Reserve 8	86.99	0	0	245.55	69
301	J-85	87.00	0	0	245.68	69
1017	J-Venezia 6	86.57	0	0	245.47	69
994	J-Venezia 22	86.52	1	4,162	245.46	69
176	J-75	87.00	0	0	245.99	69
712	J-215	86.31	0	0	245.43	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
706	J-Venezia 7	86.00	0	0	245.46	69
759	J-The Reserve 9	86.74	1	8,798	246.54	69
797	J-251	85.79	0	0	245.59	69
887	J-Talichet 11	86.01	1	31,860	246.01	69
181	J-68	86.00	0	0	246.04	69
793	J-Venezia 35	85.52	0	0	245.56	69
857	J-Mission Rise 21	85.31	1	10,710	245.42	69
854	J-Mission Rise 20	85.00	1	10,710	245.39	69
790	J-249	85.17	0	0	245.59	69
952	J-Venezia 29	85.03	1	5,202	245.45	69
621	J-193	85.00	1	1,040	245.45	69
1095	J-The Reserve 6	85.05	1	92,565	245.61	69
1097	J-The Reserve 7	85.00	1	92,565	245.58	69
1093	J-The Reserve 5	85.01	1	3,825	245.63	69
1091	J-The Reserve 4	85.00	1	3,825	245.66	70
775	J-The Reserve 1	85.21	0	0	245.87	70
470	J-122	85.00	0	0	245.67	70
1089	J-The Reserve 3	85.01	1	25,628	245.73	70
1087	J-The Reserve 2	85.05	1	32,895	245.85	70
910	J-Talichet 15	85.00	1	11,444	245.92	70
912	J-Talichet 16	85.00	1	7,283	245.92	70
143	J-71	85.00	0	0	245.94	70
141	J-70	85.00	0	0	245.96	70
677	J-WTP1-6	86.25	0	0	247.40	70
678	J-WTP1-5	86.25	0	0	247.40	70
679	J-WTP1-4	86.25	0	0	247.40	70
889	J-Talichet 10	85.00	1	3,121	246.23	70
891	J-Talichet 8	85.00	1	18,727	246.39	70
923	J-Talichet 9	85.00	1	3,121	246.40	70
728	J-Venezia 28	84.00	0	0	245.45	70
926	J-295	85.00	1	3,121	246.53	70
549	J-Mitchell 1	85.00	1	13,525	246.54	70
1183	J-Lake Hills 3	84.00	1	27,540	245.57	70
592	J-186	85.00	1	7,283	246.60	70
1205	J-Venezia TH 4	84.00	1	27,540	245.62	70
135	J-34	84.00	1	10,404	245.64	70
139	J-42	84.00	0	0	245.90	70
429	J-43	84.00	1	9,364	245.90	70
769	J-238	85.00	0	0	247.22	70
393	J-151	83.00	1	6,242	245.37	70
422	J-150	83.00	1	3,121	245.37	70
391	J-152	83.00	0	0	245.37	70
718	J-Venezia 11	83.00	1	8,323	245.44	70
722	J-Venezia 27	83.00	1	11,444	245.45	70
554	J-173	84.00	0	0	246.59	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
249	J-121	83.00	1	5,202	245.67	70
1012	J-Venezia 9	82.26	1	6,242	245.45	71
457	J-125	82.31	1	10,404	245.58	71
754	J-229	82.11	0	0	245.43	71
708	J-Venezia 8	82.00	1	2,081	245.45	71
1184	J-Lake Hills 4	82.00	1	27,540	245.53	71
485	J-108	82.00	0	0	245.68	71
264	J-117	82.00	0	0	245.69	71
1032	J-Venezia 17	81.62	1	2,081	245.43	71
1023	J-Venezia 13	81.45	1	3,121	245.44	71
756	J-Whispering Hills 1	81.37	0	0	245.40	71
365	J-147	81.00	1	3,121	245.38	71
716	J-Venezia 16	81.00	1	4,162	245.43	71
1170	J-369	82.00	0	0	246.54	71
552	J-172	82.00	0	0	246.56	71
1177	J-Lake Hills 2	81.00	2	169,575	245.59	71
757	J-231	80.71	0	0	245.41	71
273	J-113	81.00	0	0	245.72	71
275	J-82	81.00	0	0	245.72	71
999	J-Venezia 14	80.56	1	4,162	245.44	71
150	J-74	81.00	1	2,081	245.94	71
710	J-Venezia 15	80.00	1	3,121	245.43	72
1188	J-Lake Hills 6	80.00	1	27,158	245.52	72
1192	J-Lake Hills 7	79.00	1	27,158	245.52	72
1214	J-Venezia S	79.00	0	0	245.56	72
259	J-119	78.00	1	11,444	245.68	73
419	J-149	77.00	0	0	245.38	73
231	J-130	77.00	0	0	245.43	73
219	J-Island 1	77.00	1	2,081	245.51	73
289	J-84	77.00	0	0	245.74	73
112	J-72	77.00	0	0	245.80	73
280	J-112	77.00	0	0	245.83	73
148	J-73	77.00	0	0	245.85	73
363	J-148	76.00	0	0	245.39	73
360	J-138	76.00	1	11,444	245.39	73
1196	J-Lake Hills 9	76.00	1	27,540	245.52	73
1104	J-Drake Point 1	75.00	1	67,703	245.27	74
409	J-164	75.00	1	12,485	245.37	74
227	J-129	75.00	1	20,808	245.43	74
1187	J-Lake Hills 5	75.00	1	27,158	245.52	74
1114	J-Cypress Point 1	73.64	1	21,038	245.54	74
413	J-166	72.00	0	0	245.37	75
1189	J-Lake Hills 8	71.00	1	27,158	245.52	76
327	J-101	71.00	1	13,525	245.53	76
1068	J-Whispering Hills 3	70.72	1	47,813	245.33	76

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max day - Existing Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
346	J-137	70.00	1	13,525	245.42	76
646	J-200	70.00	0	0	245.45	76
343	J-135	70.00	1	13,525	245.46	76
330	J-100	70.00	1	7,283	245.51	76
1116	J-Cypress Point 2	70.02	1	21,038	245.54	76
313	J-103	70.00	1	19,768	245.58	76
519	J-169	69.00	0	0	245.38	76
417	J-167	68.00	1	8,323	245.37	77
262	J-116	68.00	1	15,606	245.69	77
292	J-110	68.00	0	0	245.73	77
217	J-124	67.00	0	0	245.65	77
299	J-107	67.00	1	13,525	245.67	77
310	J-105	66.00	1	14,566	245.63	78
1070	J-Whispering Hills 4	65.00	1	11,858	245.33	78
225	J-Island 3	65.00	1	9,364	245.50	78
411	J-165	64.00	1	5,202	245.24	78
271	J-115	64.00	1	9,364	245.71	79
296	J-109	64.00	0	0	245.72	79
286	J-111	64.00	1	1,040	245.72	79
221	J-Island 2	62.00	1	4,162	245.50	79

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1248	J-WTP3-1	140.00	0	0	141.77	1
668	J-WTP1-3	81.00	0	0	82.98	1
666	J-WTP1-2	81.00	0	0	82.98	1
664	J-WTP1-1	81.00	0	0	82.98	1
30	J-WTP2-1	130.00	0	0	208.00	34
68	J-Mission Inn 6	154.00	2	2,176,646	238.22	36
568	J-Mission Inn 5	154.00	0	0	240.30	37
869	J-Watermark 5	159.36	1	60,053	246.28	38
66	J-Mission Inn 10	152.00	0	0	239.03	38
74	J-Mission Inn 9	150.00	1	4,162	238.22	38
70	J-Mission Inn 7	148.00	1	8,323	238.22	39
72	J-Mission Inn 8	146.00	1	4,162	238.22	40
78	J-Mission Inn 4	150.00	0	0	242.81	40
355	J-140	152.00	0	0	245.50	40
44	J-8	152.00	1	1,040	245.51	40
82	J-Mission Inn 3	149.00	0	0	242.91	41
86	J-Mission Inn 2	149.00	1	15,606	243.17	41
46	J-9	151.00	0	0	246.34	41
41	J-6	152.00	0	0	249.02	42
48	J-Mission Inn 1	148.00	0	0	245.73	42
374	J-141	146.00	0	0	245.48	43
764	J-Whispering Hills 2	146.07	0	0	246.21	43
1217	J-386	141.00	0	0	241.48	43
866	J-Watermark 4	145.57	1	9,180	246.29	44
351	J-94	144.00	0	0	245.53	44
539	J-142	141.00	0	0	245.48	45
50	J-Mission Inn 11	134.00	0	0	240.49	46
863	J-Watermark 3	135.17	1	8,415	246.29	48
1162	J-365	135.00	0	0	246.28	48
640	J-198	131.95	0	0	245.58	49
90	J-Mission Inn 14	131.00	0	0	245.34	49
94	J-Mission Inn 15	130.00	0	0	245.44	50
52	J-Mission Inn 12	125.00	0	0	240.47	50
92	J-23	130.00	0	0	245.57	50
96	J-25	130.00	0	0	245.57	50
54	J-Mission Inn 13	124.00	1	37,454	240.47	50
114	J-27	129.00	1	15,606	245.60	50
338	J-93	128.00	0	0	245.59	51
100	J-26	128.00	1	3,121	245.59	51
544	J-170	123.00	0	0	245.47	53
502	J-98	122.00	0	0	245.58	53
490	J-102	122.00	0	0	245.73	54
512	J-96	121.00	0	0	245.54	54
104	J-92	121.00	0	0	245.62	54
102	J-38	121.00	0	0	245.62	54

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
495	J-90	120.00	0	0	245.76	54
325	J-89	120.00	0	0	245.77	54
322	J-88	120.00	0	0	245.77	54
643	J-199	119.72	0	0	245.56	54
340	J-97	119.00	1	14,566	245.57	55
348	J-95	118.00	1	17,687	245.52	55
576	J-183	118.00	0	0	245.78	55
377	J-157	117.00	1	12,485	245.47	56
372	J-143	117.00	1	4,162	245.48	56
315	J-104	117.00	0	0	245.80	56
860	J-Watermark 2	116.57	1	8,415	246.30	56
108	J-39	116.00	0	0	245.79	56
110	J-40	116.00	1	11,444	245.79	56
319	J-87	115.00	0	0	245.82	57
332	J-99	113.00	1	10,404	245.61	57
334	J-91	113.00	1	4,162	245.64	57
106	J-37	112.00	1	5,202	245.71	58
357	J-139	107.00	1	15,606	245.49	60
306	J-106	106.00	0	0	245.90	61
447	J-36	105.00	0	0	245.74	61
983	J-Venezia 23	105.00	1	12,485	246.29	61
978	J-Venezia 18	105.00	1	10,404	246.36	61
612	J-190	104.74	0	0	246.17	61
529	J-156	104.00	0	0	245.47	61
534	J-144	104.00	0	0	245.48	61
616	J-191	104.64	1	10,404	246.18	61
123	J-35	104.00	1	12,485	245.75	61
121	J-32	104.00	1	20,808	245.76	61
897	J-Talichet 1	104.83	0	0	247.20	62
169	J-63	104.00	1	12,485	246.43	62
369	J-145	103.00	1	3,121	245.48	62
304	J-86	103.00	1	3,121	245.90	62
382	J-158	102.00	1	12,485	245.47	62
507	J-136	102.00	0	0	245.57	62
973	J-Venezia 19	102.41	1	11,444	246.36	62
215	J-77	102.00	0	0	246.12	62
786	J-248	102.22	0	0	246.40	62
165	J-60	102.00	1	11,444	246.41	62
167	J-61	102.00	0	0	246.41	62
772	J-240	100.95	0	0	246.31	63
1148	J-Watermark 1	100.95	0	0	246.31	63
566	J-62	101.00	0	0	246.41	63
379	J-155	100.00	1	8,323	245.47	63
635	J-197	100.00	0	0	246.12	63
211	J-56	100.22	0	0	246.34	63

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
809	J-Mission Rise 5	100.08	1	11,093	246.27	63
156	J-54	100.06	1	2,081	246.36	63
1053	J-Venezia 2	100.09	0	0	246.63	63
201	J-52	100.00	0	0	246.54	63
773	J-Venezia 1	100.12	0	0	246.66	63
203	J-51	100.00	1	2,081	246.55	63
213	J-Venezia 3	99.00	0	0	246.56	64
812	J-Mission Rise 6	98.40	1	11,093	246.23	64
895	J-Talichet 2	99.21	0	0	247.21	64
968	J-Venezia 20	97.78	1	11,444	246.35	64
815	J-Mission Rise 7	97.32	1	11,093	246.19	64
848	J-Mission Rise 18	97.08	1	10,710	246.21	65
839	J-Mission Rise 15	96.89	1	10,710	246.16	65
688	J-209	97.00	1	5,202	246.37	65
158	J-53	97.00	1	13,525	246.40	65
702	J-Venezia 4	97.00	1	32,513	246.50	65
842	J-Mission Rise 16	96.14	1	10,710	246.17	65
192	J-50	96.50	1	1,040	246.67	65
154	J-58	96.00	1	1,040	246.40	65
629	J-196	96.00	1	13,525	246.40	65
524	J-154	95.00	0	0	245.47	65
1133	J-Venezia 24	95.33	1	16,646	246.29	65
465	J-78	95.00	0	0	246.12	65
235	J-131	95.00	0	0	246.25	65
239	J-132	95.00	0	0	246.25	65
957	J-Venezia 25	95.00	1	10,404	246.30	65
607	J-189	95.00	0	0	246.40	66
1168	J-Venezia TH 1	95.00	0	0	246.53	66
934	J-Talichet 6	95.60	1	3,121	247.20	66
881	J-Talichet II 1	94.95	1	5,738	246.66	66
806	J-Mission Rise 4	94.43	1	11,093	246.32	66
818	J-Mission Rise 8	94.12	1	11,093	246.11	66
186	J-49	95.08	1	1,040	247.10	66
824	J-Mission Rise 10	94.09	1	6,503	246.12	66
930	J-Talichet 3	95.16	1	6,242	247.21	66
827	J-Mission Rise 11	94.06	1	6,503	246.12	66
255	J-79	94.00	1	4,162	246.12	66
932	J-Talichet 4	95.07	1	3,121	247.20	66
386	J-153	93.00	1	6,242	245.47	66
388	J-159	93.00	0	0	245.47	66
367	J-146	93.00	1	3,121	245.47	66
1166	J-Venezia TH 2	94.00	1	6,885	246.50	66
1043	J-324	95.01	0	0	247.65	66
1041	J-323	94.88	0	0	247.66	66
581	J-184	93.00	0	0	245.96	66

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
251	J-123	93.00	0	0	246.11	66
704	J-Venezia 5	93.00	0	0	246.38	66
1100	J-Golden Hills 1	92.58	1	232,178	246.08	66
194	J-66	93.00	1	3,121	246.55	66
963	J-Venezia 21	92.72	1	13,525	246.35	66
116	J-28	92.00	0	0	245.75	67
119	J-29	92.00	1	12,485	245.75	67
404	J-162	91.00	0	0	245.47	67
879	J-Talichet II 2	92.00	1	2,295	246.65	67
776	J-Cedar Creek 1	91.69	1	65,408	246.44	67
475	J-120	91.00	0	0	246.11	67
133	J-33	91.00	0	0	246.15	67
152	J-76	91.00	1	8,323	246.45	67
400	J-160	90.00	1	16,646	245.47	67
1203	J-Venezia TH 3	91.00	1	8,798	246.48	67
730	J-Venezia 30	90.81	0	0	246.35	67
1138	J-Venezia 32	90.74	1	4,162	246.39	67
845	J-Mission Rise 17	90.35	1	10,710	246.18	67
883	J-Talichet 14	90.88	1	3,121	246.79	67
1142	J-Mission Rise 1	90.47	0	0	246.47	67
724	J-220	90.23	0	0	246.28	68
836	J-Mission Rise 14	90.07	1	6,503	246.15	68
480	J-118	90.00	0	0	246.11	68
268	J-81	90.00	1	4,162	246.11	68
1035	J-Venezia 34	90.25	1	2,081	246.39	68
245	J-134	90.00	1	10,404	246.25	68
241	J-133	90.00	0	0	246.25	68
720	J-Venezia 26	90.00	1	5,202	246.30	68
1152	J-Mission Rise 22	89.96	0	0	246.31	68
936	J-Talichet 5	90.78	1	5,202	247.20	68
800	J-Mission Rise 2	89.97	1	10,710	246.45	68
803	J-Mission Rise 3	89.89	1	10,710	246.38	68
1122	J-354	140.00	0	0	296.51	68
597	J-187	90.00	0	0	246.53	68
179	J-67	90.00	0	0	246.55	68
876	J-The Reserve 14	89.84	0	0	246.51	68
1059	J-Talichet 13	90.07	1	1,040	246.81	68
830	J-Mission Rise 12	89.37	1	6,503	246.12	68
1084	J-The Reserve 13	89.69	2	126,225	246.48	68
1081	J-The Reserve 12	89.60	1	2,295	246.48	68
1078	J-The Reserve 11	89.47	1	2,295	246.48	68
1075	J-The Reserve 10	89.34	2	132,983	246.48	68
452	J-41	89.00	1	5,202	246.16	68
556	J-174	91.00	0	0	248.21	68
732	J-Venezia 31	89.16	1	6,242	246.39	68

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1178	J-Lake Hills 1	140.00	0	0	297.44	68
407	J-163	88.00	1	3,121	245.47	68
173	J-64	89.00	0	0	246.49	68
198	J-65	89.00	1	5,202	246.51	68
1004	J-Venezia 12	88.68	1	4,162	246.26	68
432	J-44	90.00	0	0	247.60	68
833	J-Mission Rise 13	88.53	1	6,503	246.13	68
893	J-Talichet 7	89.60	1	12,485	247.23	68
762	J-234	88.95	0	0	246.61	68
1245	J-WTP3-2	140.00	0	0	297.66	68
436	J-45	90.00	0	0	247.66	68
1129	J-Venezia 10	88.52	1	11,444	246.26	68
126	J-30	88.00	0	0	245.81	68
130	J-31	88.00	0	0	245.86	68
851	J-Mission Rise 19	88.36	1	10,710	246.23	68
1064	J-329	88.47	0	0	246.43	68
885	J-Talichet 12	88.74	1	2,081	246.83	68
257	J-80	88.00	1	4,162	246.11	68
624	J-194	88.00	1	3,121	246.25	68
585	J-185	90.00	0	0	248.25	68
402	J-161	87.00	0	0	245.47	69
426	J-168	87.00	0	0	245.47	69
602	J-188	88.00	0	0	246.49	69
1157	J-330	87.56	0	0	246.42	69
821	J-Mission Rise 9	87.13	1	6,503	246.11	69
301	J-85	87.00	0	0	246.00	69
738	J-Venezia 33	87.00	1	6,242	246.39	69
914	J-Talichet 17	87.41	1	5,202	246.81	69
873	J-The Reserve 8	86.99	0	0	246.41	69
176	J-75	87.00	0	0	246.51	69
1017	J-Venezia 6	86.57	0	0	246.29	69
994	J-Venezia 22	86.52	1	4,162	246.29	69
712	J-215	86.31	0	0	246.22	69
706	J-Venezia 7	86.00	0	0	246.29	69
181	J-68	86.00	0	0	246.57	69
797	J-251	85.79	0	0	246.45	70
759	J-The Reserve 9	86.74	1	8,798	247.46	70
887	J-Talichet 11	86.01	1	31,860	246.89	70
793	J-Venezia 35	85.52	0	0	246.41	70
857	J-Mission Rise 21	85.31	1	10,710	246.27	70
470	J-122	85.00	0	0	246.11	70
854	J-Mission Rise 20	85.00	1	10,710	246.25	70
952	J-Venezia 29	85.03	1	5,202	246.28	70
790	J-249	85.17	0	0	246.44	70
621	J-193	85.00	1	1,040	246.28	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
143	J-71	85.00	0	0	246.37	70
141	J-70	85.00	0	0	246.40	70
1095	J-The Reserve 6	85.05	1	92,565	246.48	70
1097	J-The Reserve 7	85.00	1	92,565	246.44	70
1093	J-The Reserve 5	85.01	1	3,825	246.51	70
1091	J-The Reserve 4	85.00	1	3,825	246.54	70
775	J-The Reserve 1	85.21	0	0	246.77	70
1089	J-The Reserve 3	85.01	1	25,628	246.61	70
1087	J-The Reserve 2	85.05	1	32,895	246.74	70
910	J-Talichet 15	85.00	1	11,444	246.80	70
912	J-Talichet 16	85.00	1	7,283	246.80	70
135	J-34	84.00	1	10,404	245.82	70
889	J-Talichet 10	85.00	1	3,121	247.12	70
677	J-WTP1-6	86.25	0	0	248.41	70
678	J-WTP1-5	86.25	0	0	248.41	70
679	J-WTP1-4	86.25	0	0	248.41	70
139	J-42	84.00	0	0	246.28	70
891	J-Talichet 8	85.00	1	18,727	247.28	70
728	J-Venezia 28	84.00	0	0	246.28	70
923	J-Talichet 9	85.00	1	3,121	247.29	70
429	J-43	84.00	1	9,364	246.30	70
442	J-7	128.00	0	0	290.38	70
926	J-295	85.00	1	3,121	247.44	70
549	J-Mitchell 1	85.00	1	13,525	247.46	70
393	J-151	83.00	1	6,242	245.47	70
422	J-150	83.00	1	3,121	245.47	70
391	J-152	83.00	0	0	245.47	70
1205	J-Venezia TH 4	84.00	1	27,540	246.47	70
592	J-186	85.00	1	7,283	247.52	70
249	J-121	83.00	1	5,202	246.11	71
769	J-238	85.00	0	0	248.20	71
718	J-Venezia 11	83.00	1	8,323	246.26	71
722	J-Venezia 27	83.00	1	11,444	246.28	71
554	J-173	84.00	0	0	247.50	71
457	J-125	82.31	1	10,404	246.09	71
485	J-108	82.00	0	0	246.00	71
1012	J-Venezia 9	82.26	1	6,242	246.26	71
754	J-229	82.11	0	0	246.22	71
264	J-117	82.00	0	0	246.11	71
37	J-5	128.00	0	0	292.21	71
708	J-Venezia 8	82.00	1	2,081	246.26	71
365	J-147	81.00	1	3,121	245.47	71
1032	J-Venezia 17	81.62	1	2,081	246.23	71
756	J-Whispering Hills 1	81.37	0	0	246.10	71
1023	J-Venezia 13	81.45	1	3,121	246.25	71

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
273	J-113	81.00	0	0	246.12	71
275	J-82	81.00	0	0	246.12	71
716	J-Venezia 16	81.00	1	4,162	246.23	71
757	J-231	80.71	0	0	246.10	72
150	J-74	81.00	1	2,081	246.43	72
1170	J-369	82.00	0	0	247.46	72
552	J-172	82.00	0	0	247.48	72
999	J-Venezia 14	80.56	1	4,162	246.24	72
710	J-Venezia 15	80.00	1	3,121	246.23	72
31	J-2	128.00	0	0	294.74	72
33	J-4	128.00	0	0	294.75	72
35	J-3	128.00	0	0	294.84	72
1214	J-Venezia S	79.00	0	0	246.42	72
259	J-119	78.00	1	11,444	246.11	73
419	J-149	77.00	0	0	245.48	73
219	J-Island 1	77.00	1	2,081	246.08	73
289	J-84	77.00	0	0	246.13	73
112	J-72	77.00	0	0	246.18	73
231	J-130	77.00	0	0	246.21	73
280	J-112	77.00	0	0	246.25	73
148	J-73	77.00	0	0	246.28	73
363	J-148	76.00	0	0	245.48	73
360	J-138	76.00	1	11,444	245.48	73
1108	J-Drake Point 3	126.24	1	67,320	295.74	73
409	J-164	75.00	1	12,485	245.46	74
227	J-129	75.00	1	20,808	246.08	74
413	J-166	72.00	0	0	245.47	75
327	J-101	71.00	1	13,525	245.68	76
1068	J-Whispering Hills 3	70.72	1	47,813	246.05	76
346	J-137	70.00	1	13,525	245.52	76
646	J-200	70.00	0	0	245.56	76
343	J-135	70.00	1	13,525	245.57	76
330	J-100	70.00	1	7,283	245.64	76
1106	J-Drake Point 2	120.00	1	67,703	295.74	76
313	J-103	70.00	1	19,768	245.79	76
519	J-169	69.00	0	0	245.47	76
417	J-167	68.00	1	8,323	245.47	77
262	J-116	68.00	1	15,606	246.11	77
292	J-110	68.00	0	0	246.11	77
299	J-107	67.00	1	13,525	245.99	77
217	J-124	67.00	0	0	246.11	77
310	J-105	66.00	1	14,566	245.89	78
1070	J-Whispering Hills 4	65.00	1	11,858	246.05	78
225	J-Island 3	65.00	1	9,364	246.07	78
411	J-165	64.00	1	5,202	245.34	78

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
296	J-109	64.00	0	0	246.11	79
271	J-115	64.00	1	9,364	246.11	79
286	J-111	64.00	1	1,040	246.12	79
221	J-Island 2	62.00	1	4,162	246.08	80
1110	J-Lake Hills 12	101.23	0	0	294.96	84
1112	J-Thompson Grove 1	92.46	1	104,040	294.94	88
1102	J-Lake Hills 11	92.23	0	0	296.05	88
1195	J-Lake Hills 10	92.00	1	27,158	295.99	88
1119	J-Westminster 1	87.02	1	133,875	294.91	90
1183	J-Lake Hills 3	84.00	1	27,540	295.75	92
1184	J-Lake Hills 4	82.00	1	27,540	295.75	92
1177	J-Lake Hills 2	81.00	2	169,575	295.75	93
1188	J-Lake Hills 6	80.00	1	27,158	295.76	93
1192	J-Lake Hills 7	79.00	1	27,158	295.78	94
1196	J-Lake Hills 9	76.00	1	27,540	295.90	95
1187	J-Lake Hills 5	75.00	1	27,158	295.76	96
1104	J-Drake Point 1	75.00	1	67,703	295.77	96
1114	J-Cypress Point 1	73.64	1	21,038	294.91	96
1189	J-Lake Hills 8	71.00	1	27,158	295.83	97
1116	J-Cypress Point 2	70.02	1	21,038	294.91	97

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
668	J-WTP1-3	81.00	0	0	82.95	1
666	J-WTP1-2	81.00	0	0	82.95	1
664	J-WTP1-1	81.00	0	0	82.95	1
1248	J-WTP3-1	140.00	0	0	141.97	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	2	1,500,053	238.21	34
68	J-Mission Inn 6	154.00	1	16,646	245.55	40
568	J-Mission Inn 5	154.00	0	0	245.56	40
355	J-140	152.00	0	0	245.40	40
44	J-8	152.00	1	1,040	245.42	40
866	J-Watermark 4	145.57	1	9,180	239.00	40
66	J-Mission Inn 10	152.00	0	0	245.55	40
41	J-6	152.00	0	0	245.57	40
46	J-9	151.00	0	0	245.57	41
74	J-Mission Inn 9	150.00	1	4,162	245.55	41
78	J-Mission Inn 4	150.00	0	0	245.56	41
764	J-Whispering Hills 2	146.07	0	0	241.68	41
82	J-Mission Inn 3	149.00	0	0	245.56	42
86	J-Mission Inn 2	149.00	1	15,606	245.56	42
70	J-Mission Inn 7	148.00	1	8,323	245.55	42
48	J-Mission Inn 1	148.00	0	0	245.57	42
374	J-141	146.00	0	0	245.38	43
72	J-Mission Inn 8	146.00	1	4,162	245.55	43
351	J-94	144.00	0	0	245.44	44
1162	J-365	135.00	0	0	238.56	45
863	J-Watermark 3	135.17	1	8,415	239.46	45
539	J-142	141.00	0	0	245.38	45
1217	J-386	141.00	0	0	245.56	45
1122	J-354	140.00	0	0	245.78	46
1178	J-Lake Hills 1	140.00	0	0	245.88	46
1245	J-WTP3-2	140.00	0	0	245.90	46
50	J-Mission Inn 11	134.00	0	0	245.55	48
640	J-198	131.95	0	0	245.50	49
90	J-Mission Inn 14	131.00	0	0	245.57	50
94	J-Mission Inn 15	130.00	0	0	245.57	50
92	J-23	130.00	0	0	245.57	50
96	J-25	130.00	0	0	245.57	50
114	J-27	129.00	1	15,606	245.57	50
338	J-93	128.00	0	0	245.51	51
100	J-26	128.00	1	3,121	245.57	51
442	J-7	128.00	0	0	245.67	51
37	J-5	128.00	0	0	245.68	51
33	J-4	128.00	0	0	245.68	51
31	J-2	128.00	0	0	245.68	51
35	J-3	128.00	0	0	245.69	51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1108	J-Drake Point 3	126.24	1	67,320	245.23	51
52	J-Mission Inn 12	125.00	0	0	245.54	52
54	J-Mission Inn 13	124.00	1	37,454	245.54	53
544	J-170	123.00	0	0	245.37	53
502	J-98	122.00	0	0	245.48	53
490	J-102	122.00	0	0	245.56	53
860	J-Watermark 2	116.57	1	8,415	240.49	54
512	J-96	121.00	0	0	245.44	54
104	J-92	121.00	0	0	245.56	54
102	J-38	121.00	0	0	245.57	54
1106	J-Drake Point 2	120.00	1	67,703	245.24	54
495	J-90	120.00	0	0	245.59	54
325	J-89	120.00	0	0	245.60	54
322	J-88	120.00	0	0	245.60	54
643	J-199	119.72	0	0	245.45	54
340	J-97	119.00	1	14,566	245.46	55
348	J-95	118.00	1	17,687	245.42	55
576	J-183	118.00	0	0	245.60	55
377	J-157	117.00	1	12,485	245.37	56
372	J-143	117.00	1	4,162	245.38	56
315	J-104	117.00	0	0	245.58	56
108	J-39	116.00	0	0	245.62	56
110	J-40	116.00	1	11,444	245.62	56
319	J-87	115.00	0	0	245.60	57
332	J-99	113.00	1	10,404	245.50	57
334	J-91	113.00	1	4,162	245.56	57
106	J-37	112.00	1	5,202	245.59	58
983	J-Venezia 23	105.00	1	12,485	241.62	59
978	J-Venezia 18	105.00	1	10,404	242.21	59
357	J-139	107.00	1	15,606	245.39	60
306	J-106	106.00	0	0	245.61	60
973	J-Venezia 19	102.41	1	11,444	242.14	60
772	J-240	100.95	0	0	240.97	61
1148	J-Watermark 1	100.95	0	0	240.97	61
447	J-36	105.00	0	0	245.61	61
612	J-190	104.74	0	0	245.48	61
897	J-Talichet 1	104.83	0	0	245.63	61
616	J-191	104.64	1	10,404	245.51	61
529	J-156	104.00	0	0	245.37	61
534	J-144	104.00	0	0	245.38	61
123	J-35	104.00	1	12,485	245.62	61
121	J-32	104.00	1	20,808	245.62	61
169	J-63	104.00	1	12,485	245.95	61
369	J-145	103.00	1	3,121	245.38	62
809	J-Mission Rise 5	100.08	1	11,093	242.54	62

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
304	J-86	103.00	1	3,121	245.61	62
382	J-158	102.00	1	12,485	245.37	62
215	J-77	102.00	0	0	245.38	62
507	J-136	102.00	0	0	245.46	62
1053	J-Venezia 2	100.09	0	0	243.56	62
773	J-Venezia 1	100.12	0	0	243.70	62
786	J-248	102.22	0	0	245.90	62
165	J-60	102.00	1	11,444	245.92	62
167	J-61	102.00	0	0	245.92	62
812	J-Mission Rise 6	98.40	1	11,093	242.37	62
213	J-Venezia 3	99.00	0	0	243.29	62
968	J-Venezia 20	97.78	1	11,444	242.08	62
1110	J-Lake Hills 12	101.23	0	0	245.59	62
848	J-Mission Rise 18	97.08	1	10,710	241.47	62
839	J-Mission Rise 15	96.89	1	10,710	241.53	63
815	J-Mission Rise 7	97.32	1	11,093	242.21	63
566	J-62	101.00	0	0	245.92	63
379	J-155	100.00	1	8,323	245.37	63
635	J-197	100.00	0	0	245.37	63
842	J-Mission Rise 16	96.14	1	10,710	241.52	63
211	J-56	100.22	0	0	245.80	63
239	J-132	95.00	0	0	240.59	63
235	J-131	95.00	0	0	240.71	63
156	J-54	100.06	1	2,081	245.83	63
702	J-Venezia 4	97.00	1	32,513	243.05	63
201	J-52	100.00	0	0	246.08	63
203	J-51	100.00	1	2,081	246.09	63
1133	J-Venezia 24	95.33	1	16,646	241.52	63
895	J-Talichet 2	99.21	0	0	245.64	63
957	J-Venezia 25	95.00	1	10,404	241.48	63
827	J-Mission Rise 11	94.06	1	6,503	241.70	64
824	J-Mission Rise 10	94.09	1	6,503	241.73	64
818	J-Mission Rise 8	94.12	1	11,093	241.87	64
1168	J-Venezia TH 1	95.00	0	0	243.19	64
806	J-Mission Rise 4	94.43	1	11,093	242.70	64
688	J-209	97.00	1	5,202	245.85	64
158	J-53	97.00	1	13,525	245.90	64
881	J-Talichet II 1	94.95	1	5,738	244.01	64
1166	J-Venezia TH 2	94.00	1	6,885	243.08	65
1100	J-Golden Hills 1	92.58	1	232,178	241.84	65
704	J-Venezia 5	93.00	0	0	242.29	65
963	J-Venezia 21	92.72	1	13,525	242.03	65
192	J-50	96.50	1	1,040	246.22	65
154	J-58	96.00	1	1,040	245.90	65
629	J-196	96.00	1	13,525	245.91	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
724	J-220	90.23	0	0	240.22	65
934	J-Talichet 6	95.60	1	3,121	245.64	65
524	J-154	95.00	0	0	245.37	65
465	J-78	95.00	0	0	245.39	65
930	J-Talichet 3	95.16	1	6,242	245.64	65
932	J-Talichet 4	95.07	1	3,121	245.64	65
245	J-134	90.00	1	10,404	240.59	65
241	J-133	90.00	0	0	240.59	65
607	J-189	95.00	0	0	245.90	65
845	J-Mission Rise 17	90.35	1	10,710	241.50	65
730	J-Venezia 30	90.81	0	0	242.02	65
255	J-79	94.00	1	4,162	245.39	65
776	J-Cedar Creek 1	91.69	1	65,408	243.16	66
1152	J-Mission Rise 22	89.96	0	0	241.43	66
720	J-Venezia 26	90.00	1	5,202	241.48	66
836	J-Mission Rise 14	90.07	1	6,503	241.57	66
186	J-49	95.08	1	1,040	246.65	66
1138	J-Venezia 32	90.74	1	4,162	242.33	66
879	J-Talichet II 2	92.00	1	2,295	243.97	66
1203	J-Venezia TH 3	91.00	1	8,798	243.06	66
1035	J-Venezia 34	90.25	1	2,081	242.33	66
1043	J-324	95.01	0	0	247.18	66
830	J-Mission Rise 12	89.37	1	6,503	241.67	66
1041	J-323	94.88	0	0	247.21	66
251	J-123	93.00	0	0	245.36	66
386	J-153	93.00	1	6,242	245.37	66
388	J-159	93.00	0	0	245.37	66
367	J-146	93.00	1	3,121	245.37	66
581	J-184	93.00	0	0	245.63	66
1142	J-Mission Rise 1	90.47	0	0	243.18	66
624	J-194	88.00	1	3,121	240.86	66
803	J-Mission Rise 3	89.89	1	10,710	242.89	66
1004	J-Venezia 12	88.68	1	4,162	241.73	66
194	J-66	93.00	1	3,121	246.09	66
833	J-Mission Rise 13	88.53	1	6,503	241.63	66
851	J-Mission Rise 19	88.36	1	10,710	241.46	66
1112	J-Thompson Grove 1	92.46	1	104,040	245.57	66
800	J-Mission Rise 2	89.97	1	10,710	243.13	66
732	J-Venezia 31	89.16	1	6,242	242.33	66
1129	J-Venezia 10	88.52	1	11,444	241.73	66
1102	J-Lake Hills 11	92.23	0	0	245.55	66
876	J-The Reserve 14	89.84	0	0	243.19	66
1084	J-The Reserve 13	89.69	2	126,225	243.20	66
1195	J-Lake Hills 10	92.00	1	27,158	245.54	66
883	J-Talichet 14	90.88	1	3,121	244.49	66

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
116	J-28	92.00	0	0	245.62	66
119	J-29	92.00	1	12,485	245.62	66
1081	J-The Reserve 12	89.60	1	2,295	243.24	66
1078	J-The Reserve 11	89.47	1	2,295	243.30	67
1075	J-The Reserve 10	89.34	2	132,983	243.36	67
1064	J-329	88.47	0	0	242.60	67
404	J-162	91.00	0	0	245.37	67
475	J-120	91.00	0	0	245.42	67
1059	J-Talichet 13	90.07	1	1,040	244.57	67
821	J-Mission Rise 9	87.13	1	6,503	241.76	67
936	J-Talichet 5	90.78	1	5,202	245.64	67
133	J-33	91.00	0	0	245.89	67
762	J-234	88.95	0	0	243.85	67
1157	J-330	87.56	0	0	242.49	67
152	J-76	91.00	1	8,323	245.99	67
994	J-Venezia 22	86.52	1	4,162	241.71	67
621	J-193	85.00	1	1,040	240.22	67
1017	J-Venezia 6	86.57	0	0	241.80	67
738	J-Venezia 33	87.00	1	6,242	242.33	67
400	J-160	90.00	1	16,646	245.37	67
712	J-215	86.31	0	0	241.68	67
952	J-Venezia 29	85.03	1	5,202	240.42	67
873	J-The Reserve 8	86.99	0	0	242.42	67
480	J-118	90.00	0	0	245.50	67
268	J-81	90.00	1	4,162	245.50	67
706	J-Venezia 7	86.00	0	0	241.76	67
885	J-Talichet 12	88.74	1	2,081	244.62	67
597	J-187	90.00	0	0	246.08	68
179	J-67	90.00	0	0	246.10	68
893	J-Talichet 7	89.60	1	12,485	245.72	68
857	J-Mission Rise 21	85.31	1	10,710	241.44	68
728	J-Venezia 28	84.00	0	0	240.42	68
854	J-Mission Rise 20	85.00	1	10,710	241.45	68
452	J-41	89.00	1	5,202	245.90	68
797	J-251	85.79	0	0	242.74	68
793	J-Venezia 35	85.52	0	0	242.47	68
173	J-64	89.00	0	0	246.04	68
198	J-65	89.00	1	5,202	246.06	68
432	J-44	90.00	0	0	247.16	68
914	J-Talichet 17	87.41	1	5,202	244.57	68
556	J-174	91.00	0	0	248.18	68
436	J-45	90.00	0	0	247.21	68
407	J-163	88.00	1	3,121	245.37	68
722	J-Venezia 27	83.00	1	11,444	240.42	68
257	J-80	88.00	1	4,162	245.43	68

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
790	J-249	85.17	0	0	242.67	68
126	J-30	88.00	0	0	245.66	68
130	J-31	88.00	0	0	245.69	68
1097	J-The Reserve 7	85.00	1	92,565	242.75	68
1095	J-The Reserve 6	85.05	1	92,565	242.95	68
602	J-188	88.00	0	0	246.03	68
1093	J-The Reserve 5	85.01	1	3,825	243.07	68
1091	J-The Reserve 4	85.00	1	3,825	243.18	68
585	J-185	90.00	0	0	248.30	68
402	J-161	87.00	0	0	245.37	69
426	J-168	87.00	0	0	245.37	69
1089	J-The Reserve 3	85.01	1	25,628	243.45	69
1119	J-Westminster 1	87.02	1	133,875	245.54	69
301	J-85	87.00	0	0	245.64	69
718	J-Venezia 11	83.00	1	8,323	241.73	69
775	J-The Reserve 1	85.21	0	0	243.99	69
887	J-Talichet 11	86.01	1	31,860	244.82	69
1087	J-The Reserve 2	85.05	1	32,895	243.89	69
1205	J-Venezia TH 4	84.00	1	27,540	243.05	69
176	J-75	87.00	0	0	246.06	69
1012	J-Venezia 9	82.26	1	6,242	241.73	69
910	J-Talichet 15	85.00	1	11,444	244.52	69
912	J-Talichet 16	85.00	1	7,283	244.54	69
754	J-229	82.11	0	0	241.68	69
759	J-The Reserve 9	86.74	1	8,798	246.45	69
708	J-Venezia 8	82.00	1	2,081	241.73	69
1032	J-Venezia 17	81.62	1	2,081	241.69	69
181	J-68	86.00	0	0	246.13	69
1023	J-Venezia 13	81.45	1	3,121	241.72	69
470	J-122	85.00	0	0	245.34	69
889	J-Talichet 10	85.00	1	3,121	245.43	69
756	J-Whispering Hills 1	81.37	0	0	241.94	69
716	J-Venezia 16	81.00	1	4,162	241.69	70
891	J-Talichet 8	85.00	1	18,727	245.88	70
923	J-Talichet 9	85.00	1	3,121	245.91	70
143	J-71	85.00	0	0	246.02	70
141	J-70	85.00	0	0	246.06	70
999	J-Venezia 14	80.56	1	4,162	241.70	70
757	J-231	80.71	0	0	241.96	70
926	J-295	85.00	1	3,121	246.30	70
549	J-Mitchell 1	85.00	1	13,525	246.45	70
592	J-186	85.00	1	7,283	246.51	70
1183	J-Lake Hills 3	84.00	1	27,540	245.57	70
135	J-34	84.00	1	10,404	245.65	70
710	J-Venezia 15	80.00	1	3,121	241.69	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
139	J-42	84.00	0	0	245.98	70
429	J-43	84.00	1	9,364	245.99	70
457	J-125	82.31	1	10,404	244.63	70
249	J-121	83.00	1	5,202	245.34	70
393	J-151	83.00	1	6,242	245.37	70
422	J-150	83.00	1	3,121	245.37	70
391	J-152	83.00	0	0	245.37	70
677	J-WTP1-6	86.25	0	0	248.63	70
678	J-WTP1-5	86.25	0	0	248.63	70
679	J-WTP1-4	86.25	0	0	248.63	70
554	J-173	84.00	0	0	246.49	70
769	J-238	85.00	0	0	248.14	71
1214	J-Venezia S	79.00	0	0	242.49	71
264	J-117	82.00	0	0	245.49	71
1184	J-Lake Hills 4	82.00	1	27,540	245.53	71
485	J-108	82.00	0	0	245.64	71
365	J-147	81.00	1	3,121	245.37	71
1170	J-369	82.00	0	0	246.45	71
552	J-172	82.00	0	0	246.47	71
1177	J-Lake Hills 2	81.00	2	169,575	245.59	71
273	J-113	81.00	0	0	245.59	71
275	J-82	81.00	0	0	245.59	71
231	J-130	77.00	0	0	241.71	71
150	J-74	81.00	1	2,081	245.99	71
1188	J-Lake Hills 6	80.00	1	27,158	245.52	72
1192	J-Lake Hills 7	79.00	1	27,158	245.52	72
219	J-Island 1	77.00	1	2,081	244.01	72
259	J-119	78.00	1	11,444	245.42	72
227	J-129	75.00	1	20,808	242.83	73
419	J-149	77.00	0	0	245.38	73
289	J-84	77.00	0	0	245.70	73
112	J-72	77.00	0	0	245.79	73
280	J-112	77.00	0	0	245.83	73
148	J-73	77.00	0	0	245.86	73
363	J-148	76.00	0	0	245.38	73
360	J-138	76.00	1	11,444	245.38	73
1196	J-Lake Hills 9	76.00	1	27,540	245.52	73
1104	J-Drake Point 1	75.00	1	67,703	245.27	74
409	J-164	75.00	1	12,485	245.36	74
1187	J-Lake Hills 5	75.00	1	27,158	245.52	74
1068	J-Whispering Hills 3	70.72	1	47,813	241.70	74
1114	J-Cypress Point 1	73.64	1	21,038	245.54	74
413	J-166	72.00	0	0	245.37	75
327	J-101	71.00	1	13,525	245.52	76
1189	J-Lake Hills 8	71.00	1	27,158	245.52	76

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
346	J-137	70.00	1	13,525	245.42	76
646	J-200	70.00	0	0	245.45	76
343	J-135	70.00	1	13,525	245.46	76
330	J-100	70.00	1	7,283	245.50	76
1116	J-Cypress Point 2	70.02	1	21,038	245.54	76
313	J-103	70.00	1	19,768	245.57	76
519	J-169	69.00	0	0	245.37	76
1070	J-Whispering Hills 4	65.00	1	11,858	241.70	76
417	J-167	68.00	1	8,323	245.37	77
262	J-116	68.00	1	15,606	245.49	77
292	J-110	68.00	0	0	245.67	77
217	J-124	67.00	0	0	245.18	77
299	J-107	67.00	1	13,525	245.63	77
225	J-Island 3	65.00	1	9,364	244.00	77
310	J-105	66.00	1	14,566	245.60	78
411	J-165	64.00	1	5,202	245.24	78
271	J-115	64.00	1	9,364	245.59	79
296	J-109	64.00	0	0	245.66	79
286	J-111	64.00	1	1,040	245.66	79
221	J-Island 2	62.00	1	4,162	244.00	79

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1248	J-WTP3-1	140.00	0	0	141.74	1
664	J-WTP1-1	81.00	0	0	83.00	1
666	J-WTP1-2	81.00	0	0	83.00	1
668	J-WTP1-3	81.00	0	0	83.00	1
869	J-Watermark 5	159.36	1	60,053	224.60	28
30	J-WTP2-1	130.00	0	0	208.00	34
764	J-Whispering Hills 2	146.07	0	0	224.77	34
866	J-Watermark 4	145.57	1	9,180	224.60	34
355	J-140	152.00	0	0	236.65	37
44	J-8	152.00	1	1,040	236.78	37
863	J-Watermark 3	135.17	1	8,415	224.60	39
1162	J-365	135.00	0	0	224.61	39
374	J-141	146.00	0	0	236.54	39
351	J-94	144.00	0	0	236.95	40
539	J-142	141.00	0	0	236.53	41
568	J-Mission Inn 5	154.00	0	0	250.03	42
68	J-Mission Inn 6	154.00	1	16,646	250.22	42
66	J-Mission Inn 10	152.00	0	0	250.37	43
78	J-Mission Inn 4	150.00	0	0	249.79	43
74	J-Mission Inn 9	150.00	1	4,162	250.22	43
86	J-Mission Inn 2	149.00	1	15,606	249.76	44
82	J-Mission Inn 3	149.00	0	0	249.78	44
46	J-9	151.00	0	0	251.79	44
48	J-Mission Inn 1	148.00	0	0	250.13	44
70	J-Mission Inn 7	148.00	1	8,323	250.22	44
41	J-6	152.00	0	0	254.93	45
72	J-Mission Inn 8	146.00	1	4,162	250.22	45
640	J-198	131.95	0	0	237.56	46
860	J-Watermark 2	116.57	1	8,415	224.60	47
338	J-93	128.00	0	0	237.76	47
1217	J-386	141.00	0	0	250.83	48
114	J-27	129.00	1	15,606	241.11	49
490	J-102	122.00	0	0	235.44	49
544	J-170	123.00	0	0	236.50	49
100	J-26	128.00	1	3,121	241.64	49
96	J-25	130.00	0	0	244.14	49
90	J-Mission Inn 14	131.00	0	0	245.62	50
94	J-Mission Inn 15	130.00	0	0	244.96	50
502	J-98	122.00	0	0	237.05	50
322	J-88	120.00	0	0	235.37	50
325	J-89	120.00	0	0	235.41	50
512	J-96	121.00	0	0	236.53	50
495	J-90	120.00	0	0	235.56	50
92	J-23	130.00	0	0	245.57	50
50	J-Mission Inn 11	134.00	0	0	250.63	50

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
643	J-199	119.72	0	0	236.53	51
576	J-183	118.00	0	0	235.14	51
315	J-104	117.00	0	0	234.20	51
104	J-92	121.00	0	0	238.45	51
340	J-97	119.00	1	14,566	236.53	51
102	J-38	121.00	0	0	238.83	51
348	J-95	118.00	1	17,687	236.52	51
319	J-87	115.00	0	0	234.21	52
110	J-40	116.00	1	11,444	235.30	52
108	J-39	116.00	0	0	235.36	52
377	J-157	117.00	1	12,485	236.49	52
372	J-143	117.00	1	4,162	236.50	52
983	J-Venezia 23	105.00	1	12,485	224.70	52
978	J-Venezia 18	105.00	1	10,404	224.73	52
897	J-Talichet 1	104.83	0	0	225.44	52
973	J-Venezia 19	102.41	1	11,444	224.72	53
332	J-99	113.00	1	10,404	236.47	53
772	J-240	100.95	0	0	224.60	53
1148	J-Watermark 1	100.95	0	0	224.60	53
334	J-91	113.00	1	4,162	236.89	54
809	J-Mission Rise 5	100.08	1	11,093	224.40	54
612	J-190	104.74	0	0	229.45	54
616	J-191	104.64	1	10,404	229.42	54
773	J-Venezia 1	100.12	0	0	224.94	54
1053	J-Venezia 2	100.09	0	0	224.92	54
106	J-37	112.00	1	5,202	237.04	54
169	J-63	104.00	1	12,485	229.10	54
52	J-Mission Inn 12	125.00	0	0	250.61	54
213	J-Venezia 3	99.00	0	0	224.87	54
812	J-Mission Rise 6	98.40	1	11,093	224.36	54
895	J-Talichet 2	99.21	0	0	225.43	55
54	J-Mission Inn 13	124.00	1	37,454	250.61	55
786	J-248	102.22	0	0	229.11	55
968	J-Venezia 20	97.78	1	11,444	224.71	55
815	J-Mission Rise 7	97.32	1	11,093	224.33	55
306	J-106	106.00	0	0	233.08	55
165	J-60	102.00	1	11,444	229.10	55
167	J-61	102.00	0	0	229.10	55
848	J-Mission Rise 18	97.08	1	10,710	224.46	55
839	J-Mission Rise 15	96.89	1	10,710	224.38	55
215	J-77	102.00	0	0	229.58	55
702	J-Venezia 4	97.00	1	32,513	224.83	55
566	J-62	101.00	0	0	229.10	55
842	J-Mission Rise 16	96.14	1	10,710	224.39	55
203	J-51	100.00	1	2,081	228.93	56

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
201	J-52	100.00	0	0	228.94	56
211	J-56	100.22	0	0	229.18	56
156	J-54	100.06	1	2,081	229.15	56
1133	J-Venezia 24	95.33	1	16,646	224.69	56
357	J-139	107.00	1	15,606	236.50	56
635	J-197	100.00	0	0	229.57	56
239	J-132	95.00	0	0	224.67	56
235	J-131	95.00	0	0	224.67	56
957	J-Venezia 25	95.00	1	10,404	224.68	56
934	J-Talichet 6	95.60	1	3,121	225.43	56
1168	J-Venezia TH 1	95.00	0	0	224.85	56
881	J-Talichet II 1	94.95	1	5,738	224.88	56
806	J-Mission Rise 4	94.43	1	11,093	224.43	56
304	J-86	103.00	1	3,121	233.08	56
818	J-Mission Rise 8	94.12	1	11,093	224.27	56
824	J-Mission Rise 10	94.09	1	6,503	224.29	56
827	J-Mission Rise 11	94.06	1	6,503	224.30	56
930	J-Talichet 3	95.16	1	6,242	225.43	56
932	J-Talichet 4	95.07	1	3,121	225.43	56
1166	J-Venezia TH 2	94.00	1	6,885	224.83	57
1043	J-324	95.01	0	0	226.03	57
1041	J-323	94.88	0	0	226.03	57
447	J-36	105.00	0	0	236.32	57
1100	J-Golden Hills 1	92.58	1	232,178	224.24	57
704	J-Venezia 5	93.00	0	0	224.75	57
963	J-Venezia 21	92.72	1	13,525	224.70	57
158	J-53	97.00	1	13,525	229.10	57
688	J-209	97.00	1	5,202	229.14	57
192	J-50	96.50	1	1,040	228.65	57
121	J-32	104.00	1	20,808	236.17	57
123	J-35	104.00	1	12,485	236.18	57
529	J-156	104.00	0	0	236.47	57
534	J-144	104.00	0	0	236.49	57
186	J-49	95.08	1	1,040	227.57	57
776	J-Cedar Creek 1	91.69	1	65,408	224.53	57
879	J-Talichet II 2	92.00	1	2,295	224.87	57
154	J-58	96.00	1	1,040	229.11	58
629	J-196	96.00	1	13,525	229.12	58
369	J-145	103.00	1	3,121	236.48	58
1203	J-Venezia TH 3	91.00	1	8,798	224.80	58
730	J-Venezia 30	90.81	0	0	224.70	58
1138	J-Venezia 32	90.74	1	4,162	224.71	58
845	J-Mission Rise 17	90.35	1	10,710	224.41	58
1142	J-Mission Rise 1	90.47	0	0	224.55	58
883	J-Talichet 14	90.88	1	3,121	224.98	58

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
607	J-189	95.00	0	0	229.12	58
836	J-Mission Rise 14	90.07	1	6,503	224.36	58
724	J-220	90.23	0	0	224.65	58
1035	J-Venezia 34	90.25	1	2,081	224.70	58
507	J-136	102.00	0	0	236.46	58
382	J-158	102.00	1	12,485	236.47	58
800	J-Mission Rise 2	89.97	1	10,710	224.54	58
803	J-Mission Rise 3	89.89	1	10,710	224.48	58
1152	J-Mission Rise 22	89.96	0	0	224.60	58
936	J-Talichet 5	90.78	1	5,202	225.43	58
465	J-78	95.00	0	0	229.66	58
245	J-134	90.00	1	10,404	224.66	58
241	J-133	90.00	0	0	224.66	58
720	J-Venezia 26	90.00	1	5,202	224.68	58
556	J-174	91.00	0	0	225.78	58
1059	J-Talichet 13	90.07	1	1,040	225.00	58
830	J-Mission Rise 12	89.37	1	6,503	224.31	58
876	J-The Reserve 14	89.84	0	0	224.78	58
1084	J-The Reserve 13	89.69	2	126,225	224.74	58
1081	J-The Reserve 12	89.60	1	2,295	224.74	58
1078	J-The Reserve 11	89.47	1	2,295	224.74	59
1075	J-The Reserve 10	89.34	2	132,983	224.74	59
732	J-Venezia 31	89.16	1	6,242	224.71	59
255	J-79	94.00	1	4,162	229.67	59
585	J-185	90.00	0	0	225.80	59
833	J-Mission Rise 13	88.53	1	6,503	224.33	59
893	J-Talichet 7	89.60	1	12,485	225.42	59
762	J-234	88.95	0	0	224.84	59
436	J-45	90.00	0	0	226.03	59
194	J-66	93.00	1	3,121	229.04	59
1004	J-Venezia 12	88.68	1	4,162	224.72	59
851	J-Mission Rise 19	88.36	1	10,710	224.48	59
1129	J-Venezia 10	88.52	1	11,444	224.73	59
1064	J-329	88.47	0	0	224.70	59
432	J-44	90.00	0	0	226.28	59
885	J-Talichet 12	88.74	1	2,081	225.01	59
379	J-155	100.00	1	8,323	236.47	59
251	J-123	93.00	0	0	229.67	59
624	J-194	88.00	1	3,121	224.69	59
1157	J-330	87.56	0	0	224.68	59
821	J-Mission Rise 9	87.13	1	6,503	224.29	59
914	J-Talichet 17	87.41	1	5,202	225.00	60
873	J-The Reserve 8	86.99	0	0	224.66	60
738	J-Venezia 33	87.00	1	6,242	224.70	60
1017	J-Venezia 6	86.57	0	0	224.73	60

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
152	J-76	91.00	1	8,323	229.20	60
994	J-Venezia 22	86.52	1	4,162	224.72	60
712	J-215	86.31	0	0	224.76	60
759	J-The Reserve 9	86.74	1	8,798	225.43	60
706	J-Venezia 7	86.00	0	0	224.73	60
797	J-251	85.79	0	0	224.73	60
475	J-120	91.00	0	0	230.00	60
887	J-Talichet 11	86.01	1	31,860	225.07	60
179	J-67	90.00	0	0	229.06	60
597	J-187	90.00	0	0	229.06	60
793	J-Venezia 35	85.52	0	0	224.71	60
857	J-Mission Rise 21	85.31	1	10,710	224.54	60
854	J-Mission Rise 20	85.00	1	10,710	224.51	60
581	J-184	93.00	0	0	232.52	60
790	J-249	85.17	0	0	224.72	60
677	J-WTP1-6	86.25	0	0	225.80	60
678	J-WTP1-5	86.25	0	0	225.80	60
679	J-WTP1-4	86.25	0	0	225.80	60
775	J-The Reserve 1	85.21	0	0	224.81	60
1095	J-The Reserve 6	85.05	1	92,565	224.67	60
952	J-Venezia 29	85.03	1	5,202	224.65	60
621	J-193	85.00	1	1,040	224.65	60
1097	J-The Reserve 7	85.00	1	92,565	224.66	60
1093	J-The Reserve 5	85.01	1	3,825	224.68	60
1091	J-The Reserve 4	85.00	1	3,825	224.70	60
1089	J-The Reserve 3	85.01	1	25,628	224.73	60
1087	J-The Reserve 2	85.05	1	32,895	224.79	60
910	J-Talichet 15	85.00	1	11,444	224.99	61
912	J-Talichet 16	85.00	1	7,283	224.99	61
198	J-65	89.00	1	5,202	229.05	61
173	J-64	89.00	0	0	229.10	61
889	J-Talichet 10	85.00	1	3,121	225.26	61
480	J-118	90.00	0	0	230.36	61
268	J-81	90.00	1	4,162	230.36	61
923	J-Talichet 9	85.00	1	3,121	225.41	61
891	J-Talichet 8	85.00	1	18,727	225.41	61
549	J-Mitchell 1	85.00	1	13,525	225.43	61
926	J-295	85.00	1	3,121	225.46	61
592	J-186	85.00	1	7,283	225.49	61
728	J-Venezia 28	84.00	0	0	224.65	61
769	J-238	85.00	0	0	225.76	61
1205	J-Venezia TH 4	84.00	1	27,540	224.79	61
602	J-188	88.00	0	0	229.10	61
524	J-154	95.00	0	0	236.46	61
554	J-173	84.00	0	0	225.47	61

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
722	J-Venezia 27	83.00	1	11,444	224.65	61
718	J-Venezia 11	83.00	1	8,323	224.72	61
133	J-33	91.00	0	0	232.80	61
257	J-80	88.00	1	4,162	230.00	61
176	J-75	87.00	0	0	229.13	61
1012	J-Venezia 9	82.26	1	6,242	224.73	62
754	J-229	82.11	0	0	224.76	62
708	J-Venezia 8	82.00	1	2,081	224.73	62
181	J-68	86.00	0	0	229.06	62
1032	J-Venezia 17	81.62	1	2,081	224.75	62
1023	J-Venezia 13	81.45	1	3,121	224.74	62
1170	J-369	82.00	0	0	225.43	62
552	J-172	82.00	0	0	225.45	62
386	J-153	93.00	1	6,242	236.45	62
388	J-159	93.00	0	0	236.46	62
367	J-146	93.00	1	3,121	236.46	62
452	J-41	89.00	1	5,202	232.69	62
716	J-Venezia 16	81.00	1	4,162	224.75	62
756	J-Whispering Hills 1	81.37	0	0	225.14	62
999	J-Venezia 14	80.56	1	4,162	224.75	62
757	J-231	80.71	0	0	225.16	62
119	J-29	92.00	1	12,485	236.52	63
116	J-28	92.00	0	0	236.65	63
470	J-122	85.00	0	0	229.67	63
710	J-Venezia 15	80.00	1	3,121	224.75	63
301	J-85	87.00	0	0	232.14	63
404	J-162	91.00	0	0	236.44	63
1214	J-Venezia S	79.00	0	0	224.68	63
141	J-70	85.00	0	0	231.03	63
143	J-71	85.00	0	0	231.05	63
457	J-125	82.31	1	10,404	228.71	63
400	J-160	90.00	1	16,646	236.44	63
249	J-121	83.00	1	5,202	229.67	63
130	J-31	88.00	0	0	235.37	64
429	J-43	84.00	1	9,364	231.42	64
231	J-130	77.00	0	0	224.80	64
139	J-42	84.00	0	0	231.84	64
126	J-30	88.00	0	0	235.95	64
264	J-117	82.00	0	0	230.36	64
407	J-163	88.00	1	3,121	236.44	64
150	J-74	81.00	1	2,081	229.45	64
402	J-161	87.00	0	0	236.44	65
426	J-168	87.00	0	0	236.44	65
273	J-113	81.00	0	0	230.78	65
275	J-82	81.00	0	0	230.78	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
485	J-108	82.00	0	0	232.14	65
219	J-Island 1	77.00	1	2,081	227.91	65
135	J-34	84.00	1	10,404	235.17	65
227	J-129	75.00	1	20,808	226.36	65
259	J-119	78.00	1	11,444	230.00	66
422	J-150	83.00	1	3,121	236.44	66
393	J-151	83.00	1	6,242	236.44	66
391	J-152	83.00	0	0	236.44	66
148	J-73	77.00	0	0	230.55	66
280	J-112	77.00	0	0	230.61	66
1068	J-Whispering Hills 3	70.72	1	47,813	224.83	67
112	J-72	77.00	0	0	231.22	67
289	J-84	77.00	0	0	231.23	67
365	J-147	81.00	1	3,121	236.44	67
419	J-149	77.00	0	0	236.44	69
1070	J-Whispering Hills 4	65.00	1	11,858	224.83	69
360	J-138	76.00	1	11,444	236.44	69
363	J-148	76.00	0	0	236.44	69
409	J-164	75.00	1	12,485	236.44	70
262	J-116	68.00	1	15,606	230.36	70
217	J-124	67.00	0	0	229.41	70
225	J-Island 3	65.00	1	9,364	227.90	70
292	J-110	68.00	0	0	231.22	71
313	J-103	70.00	1	19,768	234.20	71
413	J-166	72.00	0	0	236.44	71
327	J-101	71.00	1	13,525	235.48	71
299	J-107	67.00	1	13,525	232.14	71
330	J-100	70.00	1	7,283	235.83	72
221	J-Island 2	62.00	1	4,162	227.90	72
343	J-135	70.00	1	13,525	236.28	72
646	J-200	70.00	0	0	236.31	72
346	J-137	70.00	1	13,525	236.41	72
271	J-115	64.00	1	9,364	230.76	72
286	J-111	64.00	1	1,040	231.02	72
310	J-105	66.00	1	14,566	233.08	72
296	J-109	64.00	0	0	231.22	72
519	J-169	69.00	0	0	236.44	72
417	J-167	68.00	1	8,323	236.44	73
1122	J-354	140.00	0	0	310.50	74
1178	J-Lake Hills 1	140.00	0	0	311.55	74
1245	J-WTP3-2	140.00	0	0	311.80	74
411	J-165	64.00	1	5,202	236.31	75
442	J-7	128.00	0	0	303.38	76
37	J-5	128.00	0	0	305.52	77
31	J-2	128.00	0	0	308.49	78

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
33	J-4	128.00	0	0	308.50	78
35	J-3	128.00	0	0	308.60	78
1108	J-Drake Point 3	126.24	1	67,320	309.71	79
1106	J-Drake Point 2	120.00	1	67,703	309.72	82
1110	J-Lake Hills 12	101.23	0	0	308.76	90
1112	J-Thompson Grove 1	92.46	1	104,040	308.74	94
1102	J-Lake Hills 11	92.23	0	0	310.02	94
1195	J-Lake Hills 10	92.00	1	27,158	309.96	94
1119	J-Westminster 1	87.02	1	133,875	308.72	96
1183	J-Lake Hills 3	84.00	1	27,540	309.68	98
1184	J-Lake Hills 4	82.00	1	27,540	309.69	99
1177	J-Lake Hills 2	81.00	2	169,575	309.68	99
1188	J-Lake Hills 6	80.00	1	27,158	309.70	99
1192	J-Lake Hills 7	79.00	1	27,158	309.72	100
1196	J-Lake Hills 9	76.00	1	27,540	309.86	101
1187	J-Lake Hills 5	75.00	1	27,158	309.69	102
1104	J-Drake Point 1	75.00	1	67,703	309.75	102
1114	J-Cypress Point 1	73.64	1	21,038	308.71	102
1116	J-Cypress Point 2	70.02	1	21,038	308.71	103
1189	J-Lake Hills 8	71.00	1	27,158	309.77	103

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
869	J-Watermark 5	159.36	1	60,053	14.03	-63
764	J-Whispering Hills 2	146.07	0	0	14.20	-57
866	J-Watermark 4	145.57	1	9,180	14.03	-57
355	J-140	152.00	0	0	26.08	-54
44	J-8	152.00	1	1,040	26.22	-54
863	J-Watermark 3	135.17	1	8,415	14.03	-52
68	J-Mission Inn 6	154.00	2	2,176,646	32.91	-52
1162	J-365	135.00	0	0	14.04	-52
374	J-141	146.00	0	0	25.97	-52
568	J-Mission Inn 5	154.00	0	0	34.18	-52
66	J-Mission Inn 10	152.00	0	0	34.23	-51
351	J-94	144.00	0	0	26.38	-51
74	J-Mission Inn 9	150.00	1	4,162	32.91	-51
70	J-Mission Inn 7	148.00	1	8,323	32.91	-50
539	J-142	141.00	0	0	25.97	-50
78	J-Mission Inn 4	150.00	0	0	35.71	-49
82	J-Mission Inn 3	149.00	0	0	35.77	-49
72	J-Mission Inn 8	146.00	1	4,162	32.91	-49
86	J-Mission Inn 2	149.00	1	15,606	35.93	-49
48	J-Mission Inn 1	148.00	0	0	41.57	-46
640	J-198	131.95	0	0	26.99	-45
46	J-9	151.00	0	0	46.04	-45
1217	J-386	141.00	0	0	38.22	-44
860	J-Watermark 2	116.57	1	8,415	14.03	-44
338	J-93	128.00	0	0	27.19	-44
114	J-27	129.00	1	15,606	30.54	-43
50	J-Mission Inn 11	134.00	0	0	36.62	-42
490	J-102	122.00	0	0	24.87	-42
544	J-170	123.00	0	0	25.93	-42
100	J-26	128.00	1	3,121	31.08	-42
96	J-25	130.00	0	0	33.57	-42
90	J-Mission Inn 14	131.00	0	0	34.91	-42
94	J-Mission Inn 15	130.00	0	0	34.31	-41
502	J-98	122.00	0	0	26.48	-41
322	J-88	120.00	0	0	24.80	-41
325	J-89	120.00	0	0	24.84	-41
512	J-96	121.00	0	0	25.96	-41
41	J-6	152.00	0	0	56.98	-41
495	J-90	120.00	0	0	24.99	-41
92	J-23	130.00	0	0	35.04	-41
643	J-199	119.72	0	0	25.96	-41
576	J-183	118.00	0	0	24.57	-40
315	J-104	117.00	0	0	23.63	-40

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
104	J-92	121.00	0	0	27.88	-40
340	J-97	119.00	1	14,566	25.96	-40
102	J-38	121.00	0	0	28.26	-40
348	J-95	118.00	1	17,687	25.96	-40
319	J-87	115.00	0	0	23.64	-40
110	J-40	116.00	1	11,444	24.73	-39
108	J-39	116.00	0	0	24.80	-39
377	J-157	117.00	1	12,485	25.92	-39
372	J-143	117.00	1	4,162	25.93	-39
983	J-Venezia 23	105.00	1	12,485	14.14	-39
978	J-Venezia 18	105.00	1	10,404	14.16	-39
897	J-Talichet 1	104.83	0	0	14.87	-39
52	J-Mission Inn 12	125.00	0	0	36.60	-38
973	J-Venezia 19	102.41	1	11,444	14.15	-38
54	J-Mission Inn 13	124.00	1	37,454	36.60	-38
332	J-99	113.00	1	10,404	25.90	-38
772	J-240	100.95	0	0	14.03	-38
1148	J-Watermark 1	100.95	0	0	14.03	-38
334	J-91	113.00	1	4,162	26.33	-37
809	J-Mission Rise 5	100.08	1	11,093	13.83	-37
612	J-190	104.74	0	0	18.88	-37
616	J-191	104.64	1	10,404	18.85	-37
773	J-Venezia 1	100.12	0	0	14.38	-37
1053	J-Venezia 2	100.09	0	0	14.35	-37
106	J-37	112.00	1	5,202	26.48	-37
169	J-63	104.00	1	12,485	18.53	-37
213	J-Venezia 3	99.00	0	0	14.30	-37
812	J-Mission Rise 6	98.40	1	11,093	13.80	-37
895	J-Talichet 2	99.21	0	0	14.87	-36
786	J-248	102.22	0	0	18.54	-36
968	J-Venezia 20	97.78	1	11,444	14.14	-36
815	J-Mission Rise 7	97.32	1	11,093	13.76	-36
306	J-106	106.00	0	0	22.51	-36
165	J-60	102.00	1	11,444	18.53	-36
167	J-61	102.00	0	0	18.53	-36
848	J-Mission Rise 18	97.08	1	10,710	13.89	-36
839	J-Mission Rise 15	96.89	1	10,710	13.82	-36
215	J-77	102.00	0	0	19.01	-36
702	J-Venezia 4	97.00	1	32,513	14.26	-36
566	J-62	101.00	0	0	18.53	-36
842	J-Mission Rise 16	96.14	1	10,710	13.83	-36
203	J-51	100.00	1	2,081	18.36	-35
201	J-52	100.00	0	0	18.37	-35

Howey In The Hills Water System

FlexTable: Junction Table

**Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire
(North)**

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
211	J-56	100.22	0	0	18.61	-35
156	J-54	100.06	1	2,081	18.59	-35
1133	J-Venezia 24	95.33	1	16,646	14.12	-35
357	J-139	107.00	1	15,606	25.94	-35
635	J-197	100.00	0	0	19.01	-35
239	J-132	95.00	0	0	14.10	-35
235	J-131	95.00	0	0	14.11	-35
957	J-Venezia 25	95.00	1	10,404	14.12	-35
934	J-Talichet 6	95.60	1	3,121	14.87	-35
1168	J-Venezia TH 1	95.00	0	0	14.28	-35
881	J-Talichet II 1	94.95	1	5,738	14.31	-35
806	J-Mission Rise 4	94.43	1	11,093	13.87	-35
304	J-86	103.00	1	3,121	22.51	-35
818	J-Mission Rise 8	94.12	1	11,093	13.70	-35
824	J-Mission Rise 10	94.09	1	6,503	13.73	-35
827	J-Mission Rise 11	94.06	1	6,503	13.74	-35
930	J-Talichet 3	95.16	1	6,242	14.87	-35
932	J-Talichet 4	95.07	1	3,121	14.87	-35
1166	J-Venezia TH 2	94.00	1	6,885	14.26	-34
1043	J-324	95.01	0	0	15.46	-34
1041	J-323	94.88	0	0	15.46	-34
447	J-36	105.00	0	0	25.76	-34
1100	J-Golden Hills 1	92.58	1	232,178	13.67	-34
704	J-Venezia 5	93.00	0	0	14.19	-34
963	J-Venezia 21	92.72	1	13,525	14.13	-34
158	J-53	97.00	1	13,525	18.54	-34
688	J-209	97.00	1	5,202	18.57	-34
192	J-50	96.50	1	1,040	18.08	-34
121	J-32	104.00	1	20,808	25.61	-34
123	J-35	104.00	1	12,485	25.62	-34
529	J-156	104.00	0	0	25.91	-34
534	J-144	104.00	0	0	25.92	-34
186	J-49	95.08	1	1,040	17.00	-34
776	J-Cedar Creek 1	91.69	1	65,408	13.96	-34
879	J-Talichet II 2	92.00	1	2,295	14.30	-34
154	J-58	96.00	1	1,040	18.55	-34
629	J-196	96.00	1	13,525	18.55	-34
369	J-145	103.00	1	3,121	25.91	-33
1203	J-Venezia TH 3	91.00	1	8,798	14.24	-33
730	J-Venezia 30	90.81	0	0	14.13	-33
1138	J-Venezia 32	90.74	1	4,162	14.14	-33
845	J-Mission Rise 17	90.35	1	10,710	13.84	-33
1142	J-Mission Rise 1	90.47	0	0	13.98	-33

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
883	J-Talichet 14	90.88	1	3,121	14.42	-33
607	J-189	95.00	0	0	18.55	-33
836	J-Mission Rise 14	90.07	1	6,503	13.79	-33
724	J-220	90.23	0	0	14.08	-33
1035	J-Venezia 34	90.25	1	2,081	14.14	-33
507	J-136	102.00	0	0	25.89	-33
382	J-158	102.00	1	12,485	25.90	-33
800	J-Mission Rise 2	89.97	1	10,710	13.97	-33
803	J-Mission Rise 3	89.89	1	10,710	13.91	-33
1152	J-Mission Rise 22	89.96	0	0	14.03	-33
936	J-Talichet 5	90.78	1	5,202	14.87	-33
465	J-78	95.00	0	0	19.09	-33
245	J-134	90.00	1	10,404	14.09	-33
241	J-133	90.00	0	0	14.10	-33
720	J-Venezia 26	90.00	1	5,202	14.12	-33
556	J-174	91.00	0	0	15.21	-33
1059	J-Talichet 13	90.07	1	1,040	14.44	-33
830	J-Mission Rise 12	89.37	1	6,503	13.75	-33
876	J-The Reserve 14	89.84	0	0	14.22	-33
1084	J-The Reserve 13	89.69	2	126,225	14.18	-33
1081	J-The Reserve 12	89.60	1	2,295	14.18	-33
1078	J-The Reserve 11	89.47	1	2,295	14.18	-33
1075	J-The Reserve 10	89.34	2	132,983	14.18	-33
732	J-Venezia 31	89.16	1	6,242	14.14	-32
255	J-79	94.00	1	4,162	19.10	-32
585	J-185	90.00	0	0	15.23	-32
833	J-Mission Rise 13	88.53	1	6,503	13.76	-32
893	J-Talichet 7	89.60	1	12,485	14.85	-32
762	J-234	88.95	0	0	14.28	-32
436	J-45	90.00	0	0	15.47	-32
194	J-66	93.00	1	3,121	18.47	-32
1004	J-Venezia 12	88.68	1	4,162	14.16	-32
851	J-Mission Rise 19	88.36	1	10,710	13.92	-32
1129	J-Venezia 10	88.52	1	11,444	14.16	-32
1064	J-329	88.47	0	0	14.14	-32
432	J-44	90.00	0	0	15.71	-32
885	J-Talichet 12	88.74	1	2,081	14.45	-32
379	J-155	100.00	1	8,323	25.90	-32
251	J-123	93.00	0	0	19.11	-32
624	J-194	88.00	1	3,121	14.12	-32
1157	J-330	87.56	0	0	14.11	-32
821	J-Mission Rise 9	87.13	1	6,503	13.72	-32
914	J-Talichet 17	87.41	1	5,202	14.44	-32

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
873	J-The Reserve 8	86.99	0	0	14.09	-32
738	J-Venezia 33	87.00	1	6,242	14.14	-32
1017	J-Venezia 6	86.57	0	0	14.17	-31
152	J-76	91.00	1	8,323	18.63	-31
994	J-Venezia 22	86.52	1	4,162	14.15	-31
712	J-215	86.31	0	0	14.19	-31
759	J-The Reserve 9	86.74	1	8,798	14.86	-31
706	J-Venezia 7	86.00	0	0	14.16	-31
797	J-251	85.79	0	0	14.16	-31
475	J-120	91.00	0	0	19.44	-31
887	J-Talichet 11	86.01	1	31,860	14.50	-31
179	J-67	90.00	0	0	18.49	-31
597	J-187	90.00	0	0	18.50	-31
793	J-Venezia 35	85.52	0	0	14.14	-31
857	J-Mission Rise 21	85.31	1	10,710	13.97	-31
854	J-Mission Rise 20	85.00	1	10,710	13.94	-31
581	J-184	93.00	0	0	21.95	-31
790	J-249	85.17	0	0	14.15	-31
677	J-WTP1-6	86.25	0	0	15.23	-31
678	J-WTP1-5	86.25	0	0	15.23	-31
679	J-WTP1-4	86.25	0	0	15.23	-31
775	J-The Reserve 1	85.21	0	0	14.24	-31
1095	J-The Reserve 6	85.05	1	92,565	14.10	-31
952	J-Venezia 29	85.03	1	5,202	14.08	-31
621	J-193	85.00	1	1,040	14.08	-31
1097	J-The Reserve 7	85.00	1	92,565	14.09	-31
1093	J-The Reserve 5	85.01	1	3,825	14.12	-31
1091	J-The Reserve 4	85.00	1	3,825	14.13	-31
1089	J-The Reserve 3	85.01	1	25,628	14.16	-31
1087	J-The Reserve 2	85.05	1	32,895	14.22	-31
910	J-Talichet 15	85.00	1	11,444	14.42	-31
912	J-Talichet 16	85.00	1	7,283	14.43	-31
198	J-65	89.00	1	5,202	18.49	-31
173	J-64	89.00	0	0	18.53	-30
889	J-Talichet 10	85.00	1	3,121	14.69	-30
480	J-118	90.00	0	0	19.79	-30
268	J-81	90.00	1	4,162	19.79	-30
923	J-Talichet 9	85.00	1	3,121	14.84	-30
891	J-Talichet 8	85.00	1	18,727	14.84	-30
549	J-Mitchell 1	85.00	1	13,525	14.87	-30
926	J-295	85.00	1	3,121	14.89	-30
592	J-186	85.00	1	7,283	14.92	-30
728	J-Venezia 28	84.00	0	0	14.08	-30

Howey In The Hills Water System

FlexTable: Junction Table

**Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire
(North)**

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
769	J-238	85.00	0	0	15.19	-30
1205	J-Venezia TH 4	84.00	1	27,540	14.23	-30
602	J-188	88.00	0	0	18.53	-30
524	J-154	95.00	0	0	25.89	-30
554	J-173	84.00	0	0	14.91	-30
722	J-Venezia 27	83.00	1	11,444	14.08	-30
718	J-Venezia 11	83.00	1	8,323	14.16	-30
133	J-33	91.00	0	0	22.23	-30
257	J-80	88.00	1	4,162	19.44	-30
176	J-75	87.00	0	0	18.56	-30
1012	J-Venezia 9	82.26	1	6,242	14.16	-29
754	J-229	82.11	0	0	14.19	-29
708	J-Venezia 8	82.00	1	2,081	14.16	-29
181	J-68	86.00	0	0	18.49	-29
1032	J-Venezia 17	81.62	1	2,081	14.18	-29
1023	J-Venezia 13	81.45	1	3,121	14.17	-29
1170	J-369	82.00	0	0	14.86	-29
552	J-172	82.00	0	0	14.88	-29
386	J-153	93.00	1	6,242	25.89	-29
388	J-159	93.00	0	0	25.89	-29
367	J-146	93.00	1	3,121	25.89	-29
452	J-41	89.00	1	5,202	22.13	-29
716	J-Venezia 16	81.00	1	4,162	14.18	-29
756	J-Whispering Hills 1	81.37	0	0	14.57	-29
999	J-Venezia 14	80.56	1	4,162	14.18	-29
757	J-231	80.71	0	0	14.59	-29
119	J-29	92.00	1	12,485	25.96	-29
116	J-28	92.00	0	0	26.08	-29
470	J-122	85.00	0	0	19.11	-29
710	J-Venezia 15	80.00	1	3,121	14.18	-28
301	J-85	87.00	0	0	21.58	-28
404	J-162	91.00	0	0	25.87	-28
1214	J-Venezia S	79.00	0	0	14.11	-28
141	J-70	85.00	0	0	20.46	-28
143	J-71	85.00	0	0	20.49	-28
457	J-125	82.31	1	10,404	18.15	-28
400	J-160	90.00	1	16,646	25.87	-28
249	J-121	83.00	1	5,202	19.11	-28
130	J-31	88.00	0	0	24.80	-27
429	J-43	84.00	1	9,364	20.85	-27
231	J-130	77.00	0	0	14.23	-27
139	J-42	84.00	0	0	21.27	-27
126	J-30	88.00	0	0	25.38	-27

Howey In The Hills Water System

FlexTable: Junction Table

**Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire
(North)**

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
264	J-117	82.00	0	0	19.79	-27
407	J-163	88.00	1	3,121	25.87	-27
150	J-74	81.00	1	2,081	18.88	-27
402	J-161	87.00	0	0	25.87	-26
426	J-168	87.00	0	0	25.87	-26
273	J-113	81.00	0	0	20.21	-26
275	J-82	81.00	0	0	20.21	-26
485	J-108	82.00	0	0	21.57	-26
219	J-Island 1	77.00	1	2,081	17.34	-26
135	J-34	84.00	1	10,404	24.60	-26
227	J-129	75.00	1	20,808	15.79	-26
259	J-119	78.00	1	11,444	19.44	-25
422	J-150	83.00	1	3,121	25.87	-25
393	J-151	83.00	1	6,242	25.87	-25
391	J-152	83.00	0	0	25.88	-25
148	J-73	77.00	0	0	19.98	-25
280	J-112	77.00	0	0	20.05	-25
1068	J-Whispering Hills 3	70.72	1	47,813	14.27	-24
112	J-72	77.00	0	0	20.65	-24
289	J-84	77.00	0	0	20.66	-24
365	J-147	81.00	1	3,121	25.88	-24
419	J-149	77.00	0	0	25.87	-22
1070	J-Whispering Hills 4	65.00	1	11,858	14.26	-22
360	J-138	76.00	1	11,444	25.87	-22
363	J-148	76.00	0	0	25.87	-22
409	J-164	75.00	1	12,485	25.87	-21
262	J-116	68.00	1	15,606	19.79	-21
217	J-124	67.00	0	0	18.85	-21
225	J-Island 3	65.00	1	9,364	17.34	-21
292	J-110	68.00	0	0	20.65	-20
313	J-103	70.00	1	19,768	23.63	-20
413	J-166	72.00	0	0	25.87	-20
327	J-101	71.00	1	13,525	24.91	-20
299	J-107	67.00	1	13,525	21.57	-20
330	J-100	70.00	1	7,283	25.27	-19
221	J-Island 2	62.00	1	4,162	17.34	-19
343	J-135	70.00	1	13,525	25.71	-19
646	J-200	70.00	0	0	25.74	-19
346	J-137	70.00	1	13,525	25.84	-19
271	J-115	64.00	1	9,364	20.19	-19
286	J-111	64.00	1	1,040	20.46	-19
310	J-105	66.00	1	14,566	22.51	-19
296	J-109	64.00	0	0	20.65	-19

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
519	J-169	69.00	0	0	25.87	-19
417	J-167	68.00	1	8,323	25.87	-18
411	J-165	64.00	1	5,202	25.74	-17
1248	J-WTP3-1	140.00	0	0	141.31	1
664	J-WTP1-1	81.00	0	0	83.00	1
666	J-WTP1-2	81.00	0	0	83.00	1
668	J-WTP1-3	81.00	0	0	83.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
442	J-7	128.00	0	0	225.67	42
37	J-5	128.00	0	0	233.11	45
1122	J-354	140.00	0	0	249.66	47
1178	J-Lake Hills 1	140.00	0	0	252.53	49
1245	J-WTP3-2	140.00	0	0	253.19	49
31	J-2	128.00	0	0	243.46	50
33	J-4	128.00	0	0	243.51	50
35	J-3	128.00	0	0	243.79	50
1108	J-Drake Point 3	126.24	1	67,320	248.61	53
1106	J-Drake Point 2	120.00	1	67,703	248.61	56
1110	J-Lake Hills 12	101.23	0	0	244.93	62
1112	J-Thompson Grove 1	92.46	1	104,040	244.91	66
1102	J-Lake Hills 11	92.23	0	0	248.92	68
1195	J-Lake Hills 10	92.00	1	27,158	248.79	68
1119	J-Westminster 1	87.02	1	133,875	244.88	68
1183	J-Lake Hills 3	84.00	1	27,540	247.97	71
1184	J-Lake Hills 4	82.00	1	27,540	248.05	72
1177	J-Lake Hills 2	81.00	2	169,575	247.95	72
1188	J-Lake Hills 6	80.00	1	27,158	248.13	73
1192	J-Lake Hills 7	79.00	1	27,158	248.19	73
1114	J-Cypress Point 1	73.64	1	21,038	244.88	74
1196	J-Lake Hills 9	76.00	1	27,540	248.55	75
1187	J-Lake Hills 5	75.00	1	27,158	248.09	75
1104	J-Drake Point 1	75.00	1	67,703	248.64	75
1116	J-Cypress Point 2	70.02	1	21,038	244.88	76
1189	J-Lake Hills 8	71.00	1	27,158	248.35	77

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
869	J-Watermark 5	159.36	2	2,220,053	-72.21	-100
866	J-Watermark 4	145.57	1	9,180	-70.67	-94
764	J-Whispering Hills 2	146.07	0	0	-63.66	-91
1162	J-365	135.00	0	0	-71.41	-89
863	J-Watermark 3	135.17	1	8,415	-69.79	-89
860	J-Watermark 2	116.57	1	8,415	-67.81	-80
983	J-Venezia 23	105.00	1	12,485	-64.45	-73
978	J-Venezia 18	105.00	1	10,404	-63.75	-73
772	J-240	100.95	0	0	-66.88	-73
1148	J-Watermark 1	100.95	0	0	-66.88	-73
973	J-Venezia 19	102.41	1	11,444	-63.92	-72
809	J-Mission Rise 5	100.08	1	11,093	-64.24	-71
897	J-Talichet 1	104.83	0	0	-59.04	-71
848	J-Mission Rise 18	97.08	1	10,710	-65.90	-71
812	J-Mission Rise 6	98.40	1	11,093	-64.45	-70
839	J-Mission Rise 15	96.89	1	10,710	-65.76	-70
1053	J-Venezia 2	100.09	0	0	-62.01	-70
815	J-Mission Rise 7	97.32	1	11,093	-64.66	-70
773	J-Venezia 1	100.12	0	0	-61.83	-70
842	J-Mission Rise 16	96.14	1	10,710	-65.79	-70
968	J-Venezia 20	97.78	1	11,444	-64.10	-70
239	J-132	95.00	0	0	-66.66	-70
235	J-131	95.00	0	0	-66.35	-70
213	J-Venezia 3	99.00	0	0	-62.33	-70
1133	J-Venezia 24	95.33	1	16,646	-64.86	-69
957	J-Venezia 25	95.00	1	10,404	-65.08	-69
702	J-Venezia 4	97.00	1	32,513	-62.62	-69
355	J-140	152.00	0	0	-7.49	-69
827	J-Mission Rise 11	94.06	1	6,503	-65.43	-69
824	J-Mission Rise 10	94.09	1	6,503	-65.37	-69
818	J-Mission Rise 8	94.12	1	11,093	-65.11	-69
44	J-8	152.00	1	1,040	-7.09	-69
806	J-Mission Rise 4	94.43	1	11,093	-64.02	-69
895	J-Talichet 2	99.21	0	0	-59.04	-68
724	J-220	90.23	0	0	-67.68	-68
1100	J-Golden Hills 1	92.58	1	232,178	-65.14	-68
1168	J-Venezia TH 1	95.00	0	0	-62.44	-68
963	J-Venezia 21	92.72	1	13,525	-64.26	-68
245	J-134	90.00	1	10,404	-66.67	-68
241	J-133	90.00	0	0	-66.67	-68
1166	J-Venezia TH 2	94.00	1	6,885	-62.57	-68
704	J-Venezia 5	93.00	0	0	-63.55	-68
881	J-Talichet II 1	94.95	1	5,738	-61.51	-68

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
845	J-Mission Rise 17	90.35	1	10,710	-65.82	-68
1152	J-Mission Rise 22	89.96	0	0	-66.01	-67
836	J-Mission Rise 14	90.07	1	6,503	-65.68	-67
776	J-Cedar Creek 1	91.69	1	65,408	-63.43	-67
730	J-Venezia 30	90.81	0	0	-64.29	-67
720	J-Venezia 26	90.00	1	5,202	-65.09	-67
830	J-Mission Rise 12	89.37	1	6,503	-65.48	-67
1138	J-Venezia 32	90.74	1	4,162	-63.96	-67
934	J-Talichet 6	95.60	1	3,121	-59.04	-67
851	J-Mission Rise 19	88.36	1	10,710	-65.93	-67
1035	J-Venezia 34	90.25	1	2,081	-63.96	-67
930	J-Talichet 3	95.16	1	6,242	-59.04	-67
932	J-Talichet 4	95.07	1	3,121	-59.04	-67
833	J-Mission Rise 13	88.53	1	6,503	-65.57	-67
624	J-194	88.00	1	3,121	-65.96	-67
1142	J-Mission Rise 1	90.47	0	0	-63.41	-67
374	J-141	146.00	0	0	-7.81	-67
803	J-Mission Rise 3	89.89	1	10,710	-63.79	-66
1203	J-Venezia TH 3	91.00	1	8,798	-62.59	-66
879	J-Talichet II 2	92.00	1	2,295	-61.57	-66
800	J-Mission Rise 2	89.97	1	10,710	-63.48	-66
732	J-Venezia 31	89.16	1	6,242	-63.96	-66
621	J-193	85.00	1	1,040	-67.68	-66
1004	J-Venezia 12	88.68	1	4,162	-63.92	-66
876	J-The Reserve 14	89.84	0	0	-62.67	-66
821	J-Mission Rise 9	87.13	1	6,503	-65.32	-66
1129	J-Venezia 10	88.52	1	11,444	-63.92	-66
1084	J-The Reserve 13	89.69	2	126,225	-62.65	-66
952	J-Venezia 29	85.03	1	5,202	-67.27	-66
1064	J-329	88.47	0	0	-63.78	-66
1081	J-The Reserve 12	89.60	1	2,295	-62.58	-66
1078	J-The Reserve 11	89.47	1	2,295	-62.49	-66
883	J-Talichet 14	90.88	1	3,121	-60.87	-66
1075	J-The Reserve 10	89.34	2	132,983	-62.39	-66
1157	J-330	87.56	0	0	-64.06	-66
857	J-Mission Rise 21	85.31	1	10,710	-65.97	-65
728	J-Venezia 28	84.00	0	0	-67.27	-65
873	J-The Reserve 8	86.99	0	0	-64.24	-65
1043	J-324	95.01	0	0	-56.20	-65
1041	J-323	94.88	0	0	-56.20	-65
738	J-Venezia 33	87.00	1	6,242	-63.96	-65
854	J-Mission Rise 20	85.00	1	10,710	-65.95	-65
1059	J-Talichet 13	90.07	1	1,040	-60.76	-65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
762	J-234	88.95	0	0	-61.73	-65
994	J-Venezia 22	86.52	1	4,162	-64.09	-65
351	J-94	144.00	0	0	-6.59	-65
1017	J-Venezia 6	86.57	0	0	-63.89	-65
722	J-Venezia 27	83.00	1	11,444	-67.27	-65
712	J-215	86.31	0	0	-63.81	-65
706	J-Venezia 7	86.00	0	0	-63.92	-65
936	J-Talichet 5	90.78	1	5,202	-59.04	-65
885	J-Talichet 12	88.74	1	2,081	-60.70	-65
793	J-Venezia 35	85.52	0	0	-63.81	-65
797	J-251	85.79	0	0	-63.48	-65
1097	J-The Reserve 7	85.00	1	92,565	-63.84	-64
539	J-142	141.00	0	0	-7.82	-64
790	J-249	85.17	0	0	-63.60	-64
1095	J-The Reserve 6	85.05	1	92,565	-63.60	-64
893	J-Talichet 7	89.60	1	12,485	-59.04	-64
1093	J-The Reserve 5	85.01	1	3,825	-63.47	-64
556	J-174	91.00	0	0	-57.42	-64
1091	J-The Reserve 4	85.00	1	3,825	-63.34	-64
914	J-Talichet 17	87.41	1	5,202	-60.75	-64
1089	J-The Reserve 3	85.01	1	25,628	-63.02	-64
775	J-The Reserve 1	85.21	0	0	-62.42	-64
1087	J-The Reserve 2	85.05	1	32,895	-62.53	-64
585	J-185	90.00	0	0	-57.33	-64
718	J-Venezia 11	83.00	1	8,323	-63.92	-64
1205	J-Venezia TH 4	84.00	1	27,540	-62.60	-63
887	J-Talichet 11	86.01	1	31,860	-60.44	-63
436	J-45	90.00	0	0	-56.19	-63
1012	J-Venezia 9	82.26	1	6,242	-63.92	-63
708	J-Venezia 8	82.00	1	2,081	-63.91	-63
754	J-229	82.11	0	0	-63.76	-63
910	J-Talichet 15	85.00	1	11,444	-60.83	-63
912	J-Talichet 16	85.00	1	7,283	-60.80	-63
1032	J-Venezia 17	81.62	1	2,081	-63.84	-63
759	J-The Reserve 9	86.74	1	8,798	-58.68	-63
1023	J-Venezia 13	81.45	1	3,121	-63.89	-63
432	J-44	90.00	0	0	-55.04	-63
716	J-Venezia 16	81.00	1	4,162	-63.84	-63
169	J-63	104.00	1	12,485	-40.70	-63
889	J-Talichet 10	85.00	1	3,121	-59.65	-63
999	J-Venezia 14	80.56	1	4,162	-63.86	-62
891	J-Talichet 8	85.00	1	18,727	-59.05	-62
923	J-Talichet 9	85.00	1	3,121	-59.05	-62

Howey In The Hills Water System

FlexTable: Junction Table

**Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire
(South)**

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
710	J-Venezia 15	80.00	1	3,121	-63.84	-62
926	J-295	85.00	1	3,121	-58.77	-62
549	J-Mitchell 1	85.00	1	13,525	-58.68	-62
592	J-186	85.00	1	7,283	-58.63	-62
186	J-49	95.08	1	1,040	-48.52	-62
677	J-WTP1-6	86.25	0	0	-57.33	-62
678	J-WTP1-5	86.25	0	0	-57.33	-62
679	J-WTP1-4	86.25	0	0	-57.33	-62
616	J-191	104.64	1	10,404	-38.91	-62
612	J-190	104.74	0	0	-38.76	-62
1214	J-Venezia S	79.00	0	0	-64.06	-62
786	J-248	102.22	0	0	-40.54	-62
554	J-173	84.00	0	0	-58.64	-62
165	J-60	102.00	1	11,444	-40.63	-62
167	J-61	102.00	0	0	-40.63	-62
769	J-238	85.00	0	0	-57.52	-62
756	J-Whispering Hills 1	81.37	0	0	-60.82	-62
566	J-62	101.00	0	0	-40.63	-61
203	J-51	100.00	1	2,081	-41.61	-61
201	J-52	100.00	0	0	-41.55	-61
757	J-231	80.71	0	0	-60.72	-61
1170	J-369	82.00	0	0	-58.68	-61
552	J-172	82.00	0	0	-58.66	-61
231	J-130	77.00	0	0	-63.49	-61
211	J-56	100.22	0	0	-40.16	-61
156	J-54	100.06	1	2,081	-40.28	-61
215	J-77	102.00	0	0	-38.17	-61
192	J-50	96.50	1	1,040	-43.06	-60
635	J-197	100.00	0	0	-38.21	-60
158	J-53	97.00	1	13,525	-40.55	-60
688	J-209	97.00	1	5,202	-40.38	-59
640	J-198	131.95	0	0	-4.70	-59
154	J-58	96.00	1	1,040	-40.52	-59
629	J-196	96.00	1	13,525	-40.48	-59
607	J-189	95.00	0	0	-40.50	-59
315	J-104	117.00	0	0	-18.45	-59
490	J-102	122.00	0	0	-13.36	-59
194	J-66	93.00	1	3,121	-41.14	-58
322	J-88	120.00	0	0	-13.90	-58
325	J-89	120.00	0	0	-13.69	-58
319	J-87	115.00	0	0	-18.45	-58
495	J-90	120.00	0	0	-13.07	-58
465	J-78	95.00	0	0	-37.83	-57

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
576	J-183	118.00	0	0	-14.79	-57
1068	J-Whispering Hills 3	70.72	1	47,813	-62.06	-57
338	J-93	128.00	0	0	-4.07	-57
255	J-79	94.00	1	4,162	-37.77	-57
152	J-76	91.00	1	8,323	-40.27	-57
179	J-67	90.00	0	0	-41.10	-57
597	J-187	90.00	0	0	-41.02	-57
544	J-170	123.00	0	0	-7.92	-57
251	J-123	93.00	0	0	-37.76	-57
110	J-40	116.00	1	11,444	-14.24	-56
198	J-65	89.00	1	5,202	-41.02	-56
108	J-39	116.00	0	0	-13.96	-56
173	J-64	89.00	0	0	-40.77	-56
306	J-106	106.00	0	0	-23.24	-56
512	J-96	121.00	0	0	-7.99	-56
602	J-188	88.00	0	0	-40.76	-56
227	J-129	75.00	1	20,808	-53.72	-56
502	J-98	122.00	0	0	-6.34	-56
643	J-199	119.72	0	0	-8.01	-55
176	J-75	87.00	0	0	-40.71	-55
475	J-120	91.00	0	0	-36.32	-55
181	J-68	86.00	0	0	-41.14	-55
1070	J-Whispering Hills 4	65.00	1	11,858	-62.07	-55
340	J-97	119.00	1	14,566	-8.02	-55
304	J-86	103.00	1	3,121	-23.24	-55
348	J-95	118.00	1	17,687	-7.97	-55
377	J-157	117.00	1	12,485	-7.95	-54
372	J-143	117.00	1	4,162	-7.93	-54
480	J-118	90.00	0	0	-34.86	-54
268	J-81	90.00	1	4,162	-34.86	-54
457	J-125	82.31	1	10,404	-42.02	-54
257	J-80	88.00	1	4,162	-36.32	-54
104	J-92	121.00	0	0	-1.88	-53
219	J-Island 1	77.00	1	2,081	-45.79	-53
470	J-122	85.00	0	0	-37.75	-53
102	J-38	121.00	0	0	-0.61	-53
332	J-99	113.00	1	10,404	-8.52	-53
114	J-27	129.00	1	15,606	7.64	-53
249	J-121	83.00	1	5,202	-37.75	-52
334	J-91	113.00	1	4,162	-7.50	-52
150	J-74	81.00	1	2,081	-39.26	-52
106	J-37	112.00	1	5,202	-7.47	-52
581	J-184	93.00	0	0	-25.70	-51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
100	J-26	128.00	1	3,121	9.58	-51
141	J-70	85.00	0	0	-32.81	-51
143	J-71	85.00	0	0	-32.66	-51
264	J-117	82.00	0	0	-34.86	-51
133	J-33	91.00	0	0	-25.14	-50
447	J-36	105.00	0	0	-10.26	-50
357	J-139	107.00	1	15,606	-7.97	-50
429	J-43	84.00	1	9,364	-30.88	-50
121	J-32	104.00	1	20,808	-10.85	-50
123	J-35	104.00	1	12,485	-10.80	-50
452	J-41	89.00	1	5,202	-25.58	-50
301	J-85	87.00	0	0	-27.35	-49
259	J-119	78.00	1	11,444	-36.32	-49
273	J-113	81.00	0	0	-33.23	-49
275	J-82	81.00	0	0	-33.23	-49
568	J-Mission Inn 5	154.00	0	0	40.02	-49
139	J-42	84.00	0	0	-29.29	-49
68	J-Mission Inn 6	154.00	1	16,646	40.78	-49
529	J-156	104.00	0	0	-7.99	-48
534	J-144	104.00	0	0	-7.97	-48
148	J-73	77.00	0	0	-34.49	-48
96	J-25	130.00	0	0	18.58	-48
280	J-112	77.00	0	0	-34.20	-48
369	J-145	103.00	1	3,121	-7.99	-48
78	J-Mission Inn 4	150.00	0	0	39.11	-48
225	J-Island 3	65.00	1	9,364	-45.80	-48
66	J-Mission Inn 10	152.00	0	0	41.29	-48
507	J-136	102.00	0	0	-8.31	-48
86	J-Mission Inn 2	149.00	1	15,606	38.98	-48
382	J-158	102.00	1	12,485	-8.00	-48
82	J-Mission Inn 3	149.00	0	0	39.08	-48
485	J-108	82.00	0	0	-27.36	-47
74	J-Mission Inn 9	150.00	1	4,162	40.78	-47
112	J-72	77.00	0	0	-31.61	-47
289	J-84	77.00	0	0	-31.49	-47
94	J-Mission Inn 15	130.00	0	0	21.55	-47
379	J-155	100.00	1	8,323	-8.00	-47
48	J-Mission Inn 1	148.00	0	0	40.17	-47
221	J-Island 2	62.00	1	4,162	-45.80	-47
70	J-Mission Inn 7	148.00	1	8,323	40.78	-46
90	J-Mission Inn 14	131.00	0	0	23.92	-46
92	J-23	130.00	0	0	23.74	-46
217	J-124	67.00	0	0	-38.91	-46

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
72	J-Mission Inn 8	146.00	1	4,162	40.78	-46
46	J-9	151.00	0	0	46.04	-45
524	J-154	95.00	0	0	-8.05	-45
262	J-116	68.00	1	15,606	-34.86	-45
130	J-31	88.00	0	0	-14.33	-44
119	J-29	92.00	1	12,485	-9.57	-44
116	J-28	92.00	0	0	-9.09	-44
386	J-153	93.00	1	6,242	-8.06	-44
388	J-159	93.00	0	0	-8.05	-44
367	J-146	93.00	1	3,121	-8.05	-44
126	J-30	88.00	0	0	-11.94	-43
292	J-110	68.00	0	0	-31.50	-43
404	J-162	91.00	0	0	-8.09	-43
135	J-34	84.00	1	10,404	-14.85	-43
1217	J-386	141.00	0	0	42.87	-42
400	J-160	90.00	1	16,646	-8.09	-42
271	J-115	64.00	1	9,364	-33.28	-42
286	J-111	64.00	1	1,040	-32.29	-42
407	J-163	88.00	1	3,121	-8.09	-42
296	J-109	64.00	0	0	-31.50	-41
426	J-168	87.00	0	0	-8.09	-41
402	J-161	87.00	0	0	-8.09	-41
41	J-6	152.00	0	0	56.98	-41
299	J-107	67.00	1	13,525	-27.36	-41
50	J-Mission Inn 11	134.00	0	0	42.23	-40
422	J-150	83.00	1	3,121	-8.09	-39
393	J-151	83.00	1	6,242	-8.09	-39
391	J-152	83.00	0	0	-8.09	-39
310	J-105	66.00	1	14,566	-23.23	-39
365	J-147	81.00	1	3,121	-8.09	-39
313	J-103	70.00	1	19,768	-18.45	-38
419	J-149	77.00	0	0	-8.11	-37
360	J-138	76.00	1	11,444	-8.12	-36
363	J-148	76.00	0	0	-8.11	-36
327	J-101	71.00	1	13,525	-12.91	-36
409	J-164	75.00	1	12,485	-8.10	-36
52	J-Mission Inn 12	125.00	0	0	42.21	-36
54	J-Mission Inn 13	124.00	1	37,454	42.21	-35
330	J-100	70.00	1	7,283	-11.23	-35
413	J-166	72.00	0	0	-8.10	-35
343	J-135	70.00	1	13,525	-9.02	-34
646	J-200	70.00	0	0	-8.86	-34
346	J-137	70.00	1	13,525	-8.33	-34

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
519	J-169	69.00	0	0	-8.10	-33
417	J-167	68.00	1	8,323	-8.10	-33
411	J-165	64.00	1	5,202	-8.23	-31
1248	J-WTP3-1	140.00	0	0	141.31	1
664	J-WTP1-1	81.00	0	0	83.00	1
666	J-WTP1-2	81.00	0	0	83.00	1
668	J-WTP1-3	81.00	0	0	83.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
442	J-7	128.00	0	0	225.67	42
37	J-5	128.00	0	0	233.11	45
1122	J-354	140.00	0	0	249.66	47
1178	J-Lake Hills 1	140.00	0	0	252.54	49
1245	J-WTP3-2	140.00	0	0	253.19	49
31	J-2	128.00	0	0	243.46	50
33	J-4	128.00	0	0	243.51	50
35	J-3	128.00	0	0	243.79	50
1108	J-Drake Point 3	126.24	1	67,320	248.61	53
1106	J-Drake Point 2	120.00	1	67,703	248.61	56
1110	J-Lake Hills 12	101.23	0	0	244.93	62
1112	J-Thompson Grove 1	92.46	1	104,040	244.91	66
1102	J-Lake Hills 11	92.23	0	0	248.92	68
1195	J-Lake Hills 10	92.00	1	27,158	248.79	68
1119	J-Westminster 1	87.02	1	133,875	244.88	68
1183	J-Lake Hills 3	84.00	1	27,540	247.97	71
1184	J-Lake Hills 4	82.00	1	27,540	248.05	72
1177	J-Lake Hills 2	81.00	2	169,575	247.95	72
1188	J-Lake Hills 6	80.00	1	27,158	248.13	73
1192	J-Lake Hills 7	79.00	1	27,158	248.19	73
1114	J-Cypress Point 1	73.64	1	21,038	244.88	74
1196	J-Lake Hills 9	76.00	1	27,540	248.55	75
1187	J-Lake Hills 5	75.00	1	27,158	248.09	75
1104	J-Drake Point 1	75.00	1	67,703	248.64	75
1116	J-Cypress Point 2	70.02	1	21,038	244.88	76
1189	J-Lake Hills 8	71.00	1	27,158	248.35	77

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
869	J-Watermark 5	159.36	2	1,500,053	61.04	-43
866	J-Watermark 4	145.57	1	9,180	61.77	-36
764	J-Whispering Hills 2	146.07	0	0	65.41	-35
1162	J-365	135.00	0	0	61.44	-32
863	J-Watermark 3	135.17	1	8,415	62.19	-32
860	J-Watermark 2	116.57	1	8,415	63.14	-23
355	J-140	152.00	0	0	103.44	-21
44	J-8	152.00	1	1,040	103.74	-21
374	J-141	146.00	0	0	103.21	-19
983	J-Venezia 23	105.00	1	12,485	64.95	-17
351	J-94	144.00	0	0	104.10	-17
978	J-Venezia 18	105.00	1	10,404	65.33	-17
539	J-142	141.00	0	0	103.20	-16
772	J-240	100.95	0	0	63.58	-16
1148	J-Watermark 1	100.95	0	0	63.58	-16
973	J-Venezia 19	102.41	1	11,444	65.23	-16
897	J-Talichet 1	104.83	0	0	68.31	-16
809	J-Mission Rise 5	100.08	1	11,093	64.81	-15
812	J-Mission Rise 6	98.40	1	11,093	64.67	-15
1053	J-Venezia 2	100.09	0	0	66.37	-15
773	J-Venezia 1	100.12	0	0	66.48	-15
848	J-Mission Rise 18	97.08	1	10,710	64.02	-14
839	J-Mission Rise 15	96.89	1	10,710	64.04	-14
213	J-Venezia 3	99.00	0	0	66.17	-14
815	J-Mission Rise 7	97.32	1	11,093	64.54	-14
968	J-Venezia 20	97.78	1	11,444	65.13	-14
842	J-Mission Rise 16	96.14	1	10,710	64.04	-14
239	J-132	95.00	0	0	63.82	-13
235	J-131	95.00	0	0	63.98	-13
702	J-Venezia 4	97.00	1	32,513	65.99	-13
895	J-Talichet 2	99.21	0	0	68.31	-13
1133	J-Venezia 24	95.33	1	16,646	64.73	-13
957	J-Venezia 25	95.00	1	10,404	64.62	-13
824	J-Mission Rise 10	94.09	1	6,503	64.16	-13
827	J-Mission Rise 11	94.06	1	6,503	64.14	-13
818	J-Mission Rise 8	94.12	1	11,093	64.25	-13
806	J-Mission Rise 4	94.43	1	11,093	64.95	-13
1168	J-Venezia TH 1	95.00	0	0	66.10	-13
1100	J-Golden Hills 1	92.58	1	232,178	64.22	-12
881	J-Talichet II 1	94.95	1	5,738	66.62	-12
1166	J-Venezia TH 2	94.00	1	6,885	66.01	-12
963	J-Venezia 21	92.72	1	13,525	65.04	-12
704	J-Venezia 5	93.00	0	0	65.45	-12

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
934	J-Talichet 6	95.60	1	3,121	68.31	-12
724	J-220	90.23	0	0	63.30	-12
930	J-Talichet 3	95.16	1	6,242	68.31	-12
932	J-Talichet 4	95.07	1	3,121	68.31	-12
640	J-198	131.95	0	0	105.50	-11
776	J-Cedar Creek 1	91.69	1	65,408	65.33	-11
845	J-Mission Rise 17	90.35	1	10,710	64.03	-11
245	J-134	90.00	1	10,404	63.82	-11
241	J-133	90.00	0	0	63.82	-11
836	J-Mission Rise 14	90.07	1	6,503	64.07	-11
1152	J-Mission Rise 22	89.96	0	0	64.00	-11
730	J-Venezia 30	90.81	0	0	65.02	-11
1138	J-Venezia 32	90.74	1	4,162	65.19	-11
879	J-Talichet II 2	92.00	1	2,295	66.58	-11
720	J-Venezia 26	90.00	1	5,202	64.61	-11
830	J-Mission Rise 12	89.37	1	6,503	64.12	-11
1142	J-Mission Rise 1	90.47	0	0	65.36	-11
1035	J-Venezia 34	90.25	1	2,081	65.19	-11
1203	J-Venezia TH 3	91.00	1	8,798	65.99	-11
803	J-Mission Rise 3	89.89	1	10,710	65.11	-11
1043	J-324	95.01	0	0	70.23	-11
800	J-Mission Rise 2	89.97	1	10,710	65.31	-11
1041	J-323	94.88	0	0	70.23	-11
833	J-Mission Rise 13	88.53	1	6,503	64.10	-11
851	J-Mission Rise 19	88.36	1	10,710	64.01	-11
732	J-Venezia 31	89.16	1	6,242	65.19	-10
876	J-The Reserve 14	89.84	0	0	65.92	-10
883	J-Talichet 14	90.88	1	3,121	67.04	-10
624	J-194	88.00	1	3,121	64.19	-10
1084	J-The Reserve 13	89.69	2	126,225	65.93	-10
1081	J-The Reserve 12	89.60	1	2,295	65.96	-10
1078	J-The Reserve 11	89.47	1	2,295	66.00	-10
1004	J-Venezia 12	88.68	1	4,162	65.25	-10
169	J-63	104.00	1	12,485	80.62	-10
1075	J-The Reserve 10	89.34	2	132,983	66.05	-10
1129	J-Venezia 10	88.52	1	11,444	65.25	-10
1064	J-329	88.47	0	0	65.27	-10
1059	J-Talichet 13	90.07	1	1,040	67.11	-10
821	J-Mission Rise 9	87.13	1	6,503	64.18	-10
616	J-191	104.64	1	10,404	81.80	-10
612	J-190	104.74	0	0	81.90	-10
490	J-102	122.00	0	0	99.48	-10
762	J-234	88.95	0	0	66.47	-10

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
936	J-Talichet 5	90.78	1	5,202	68.31	-10
1157	J-330	87.56	0	0	65.10	-10
338	J-93	128.00	0	0	105.96	-10
873	J-The Reserve 8	86.99	0	0	64.99	-10
738	J-Venezia 33	87.00	1	6,242	65.19	-9
621	J-193	85.00	1	1,040	63.30	-9
556	J-174	91.00	0	0	69.41	-9
885	J-Talichet 12	88.74	1	2,081	67.15	-9
952	J-Venezia 29	85.03	1	5,202	63.51	-9
786	J-248	102.22	0	0	80.71	-9
994	J-Venezia 22	86.52	1	4,162	65.15	-9
165	J-60	102.00	1	11,444	80.66	-9
167	J-61	102.00	0	0	80.66	-9
857	J-Mission Rise 21	85.31	1	10,710	64.01	-9
1017	J-Venezia 6	86.57	0	0	65.26	-9
893	J-Talichet 7	89.60	1	12,485	68.30	-9
315	J-104	117.00	0	0	95.93	-9
854	J-Mission Rise 20	85.00	1	10,710	64.01	-9
712	J-215	86.31	0	0	65.33	-9
322	J-88	120.00	0	0	99.13	-9
706	J-Venezia 7	86.00	0	0	65.25	-9
325	J-89	120.00	0	0	99.28	-9
585	J-185	90.00	0	0	69.47	-9
728	J-Venezia 28	84.00	0	0	63.51	-9
566	J-62	101.00	0	0	80.66	-9
797	J-251	85.79	0	0	65.45	-9
914	J-Talichet 17	87.41	1	5,202	67.11	-9
495	J-90	120.00	0	0	99.71	-9
793	J-Venezia 35	85.52	0	0	65.27	-9
203	J-51	100.00	1	2,081	80.02	-9
201	J-52	100.00	0	0	80.06	-9
544	J-170	123.00	0	0	103.12	-9
1097	J-The Reserve 7	85.00	1	92,565	65.19	-9
790	J-249	85.17	0	0	65.38	-9
436	J-45	90.00	0	0	70.24	-9
1095	J-The Reserve 6	85.05	1	92,565	65.31	-9
186	J-49	95.08	1	1,040	75.39	-9
215	J-77	102.00	0	0	82.31	-9
1093	J-The Reserve 5	85.01	1	3,825	65.40	-8
1091	J-The Reserve 4	85.00	1	3,825	65.48	-8
576	J-183	118.00	0	0	98.50	-8
722	J-Venezia 27	83.00	1	11,444	63.51	-8
1089	J-The Reserve 3	85.01	1	25,628	65.67	-8

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
211	J-56	100.22	0	0	80.97	-8
156	J-54	100.06	1	2,081	80.89	-8
775	J-The Reserve 1	85.21	0	0	66.06	-8
319	J-87	115.00	0	0	95.93	-8
1087	J-The Reserve 2	85.05	1	32,895	65.98	-8
432	J-44	90.00	0	0	71.02	-8
887	J-Talichet 11	86.01	1	31,860	67.33	-8
759	J-The Reserve 9	86.74	1	8,798	68.52	-8
1205	J-Venezia TH 4	84.00	1	27,540	65.98	-8
910	J-Talichet 15	85.00	1	11,444	67.06	-8
912	J-Talichet 16	85.00	1	7,283	67.08	-8
512	J-96	121.00	0	0	103.09	-8
718	J-Venezia 11	83.00	1	8,323	65.25	-8
635	J-197	100.00	0	0	82.29	-8
502	J-98	122.00	0	0	104.30	-8
192	J-50	96.50	1	1,040	79.05	-8
889	J-Talichet 10	85.00	1	3,121	67.87	-7
110	J-40	116.00	1	11,444	98.90	-7
1012	J-Venezia 9	82.26	1	6,242	65.25	-7
108	J-39	116.00	0	0	99.10	-7
677	J-WTP1-6	86.25	0	0	69.47	-7
678	J-WTP1-5	86.25	0	0	69.47	-7
679	J-WTP1-4	86.25	0	0	69.47	-7
754	J-229	82.11	0	0	65.36	-7
708	J-Venezia 8	82.00	1	2,081	65.25	-7
923	J-Talichet 9	85.00	1	3,121	68.30	-7
891	J-Talichet 8	85.00	1	18,727	68.30	-7
643	J-199	119.72	0	0	103.08	-7
568	J-Mission Inn 5	154.00	0	0	137.45	-7
926	J-295	85.00	1	3,121	68.48	-7
549	J-Mitchell 1	85.00	1	13,525	68.52	-7
592	J-186	85.00	1	7,283	68.58	-7
1032	J-Venezia 17	81.62	1	2,081	65.31	-7
158	J-53	97.00	1	13,525	80.71	-7
688	J-209	97.00	1	5,202	80.82	-7
1023	J-Venezia 13	81.45	1	3,121	65.27	-7
68	J-Mission Inn 6	154.00	1	16,646	137.98	-7
340	J-97	119.00	1	14,566	103.08	-7
716	J-Venezia 16	81.00	1	4,162	65.31	-7
769	J-238	85.00	0	0	69.34	-7
554	J-173	84.00	0	0	68.56	-7
154	J-58	96.00	1	1,040	80.73	-7
999	J-Venezia 14	80.56	1	4,162	65.29	-7

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
629	J-196	96.00	1	13,525	80.75	-7
348	J-95	118.00	1	17,687	103.09	-6
710	J-Venezia 15	80.00	1	3,121	65.31	-6
114	J-27	129.00	1	15,606	114.38	-6
607	J-189	95.00	0	0	80.74	-6
756	J-Whispering Hills 1	81.37	0	0	67.18	-6
377	J-157	117.00	1	12,485	103.09	-6
1214	J-Venezia S	79.00	0	0	65.10	-6
372	J-143	117.00	1	4,162	103.12	-6
66	J-Mission Inn 10	152.00	0	0	138.35	-6
1170	J-369	82.00	0	0	68.52	-6
552	J-172	82.00	0	0	68.54	-6
757	J-231	80.71	0	0	67.25	-6
104	J-92	121.00	0	0	107.57	-6
306	J-106	106.00	0	0	92.62	-6
78	J-Mission Inn 4	150.00	0	0	136.81	-6
194	J-66	93.00	1	3,121	80.34	-5
102	J-38	121.00	0	0	108.49	-5
465	J-78	95.00	0	0	82.54	-5
86	J-Mission Inn 2	149.00	1	15,606	136.72	-5
100	J-26	128.00	1	3,121	115.76	-5
82	J-Mission Inn 3	149.00	0	0	136.79	-5
74	J-Mission Inn 9	150.00	1	4,162	137.98	-5
231	J-130	77.00	0	0	65.53	-5
255	J-79	94.00	1	4,162	82.58	-5
48	J-Mission Inn 1	148.00	0	0	137.59	-5
251	J-123	93.00	0	0	82.59	-5
304	J-86	103.00	1	3,121	92.62	-4
332	J-99	113.00	1	10,404	102.76	-4
152	J-76	91.00	1	8,323	80.92	-4
70	J-Mission Inn 7	148.00	1	8,323	137.98	-4
179	J-67	90.00	0	0	80.38	-4
597	J-187	90.00	0	0	80.42	-4
334	J-91	113.00	1	4,162	103.56	-4
46	J-9	151.00	0	0	141.80	-4
198	J-65	89.00	1	5,202	80.42	-4
173	J-64	89.00	0	0	80.58	-4
106	J-37	112.00	1	5,202	103.66	-4
72	J-Mission Inn 8	146.00	1	4,162	137.98	-3
96	J-25	130.00	0	0	122.18	-3
475	J-120	91.00	0	0	83.59	-3
602	J-188	88.00	0	0	80.59	-3
176	J-75	87.00	0	0	80.63	-3

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
94	J-Mission Inn 15	130.00	0	0	124.30	-2
181	J-68	86.00	0	0	80.35	-2
480	J-118	90.00	0	0	84.60	-2
268	J-81	90.00	1	4,162	84.60	-2
90	J-Mission Inn 14	131.00	0	0	125.99	-2
257	J-80	88.00	1	4,162	83.59	-2
1068	J-Whispering Hills 3	70.72	1	47,813	66.31	-2
92	J-23	130.00	0	0	125.86	-2
357	J-139	107.00	1	15,606	103.09	-2
447	J-36	105.00	0	0	101.70	-1
227	J-129	75.00	1	20,808	71.82	-1
121	J-32	104.00	1	20,808	101.29	-1
123	J-35	104.00	1	12,485	101.32	-1
457	J-125	82.31	1	10,404	79.67	-1
470	J-122	85.00	0	0	82.60	-1
41	J-6	152.00	0	0	149.66	-1
581	J-184	93.00	0	0	90.94	-1
1217	J-386	141.00	0	0	139.49	-1
529	J-156	104.00	0	0	103.07	0
534	J-144	104.00	0	0	103.09	0
249	J-121	83.00	1	5,202	82.60	0
369	J-145	103.00	1	3,121	103.07	0
219	J-Island 1	77.00	1	2,081	77.12	0
133	J-33	91.00	0	0	91.40	0
150	J-74	81.00	1	2,081	81.63	0
507	J-136	102.00	0	0	102.88	0
382	J-158	102.00	1	12,485	103.06	0
141	J-70	85.00	0	0	86.12	0
143	J-71	85.00	0	0	86.22	1
1070	J-Whispering Hills 4	65.00	1	11,858	66.31	1
1248	J-WTP3-1	140.00	0	0	141.47	1
664	J-WTP1-1	81.00	0	0	83.00	1
666	J-WTP1-2	81.00	0	0	83.00	1
668	J-WTP1-3	81.00	0	0	83.00	1
452	J-41	89.00	1	5,202	91.10	1
264	J-117	82.00	0	0	84.60	1
301	J-85	87.00	0	0	89.80	1
379	J-155	100.00	1	8,323	103.06	1
429	J-43	84.00	1	9,364	87.42	1
139	J-42	84.00	0	0	88.54	2
273	J-113	81.00	0	0	85.74	2
275	J-82	81.00	0	0	85.74	2
50	J-Mission Inn 11	134.00	0	0	139.02	2

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
259	J-119	78.00	1	11,444	83.59	2
485	J-108	82.00	0	0	89.79	3
148	J-73	77.00	0	0	84.91	3
524	J-154	95.00	0	0	103.02	3
280	J-112	77.00	0	0	85.11	4
112	J-72	77.00	0	0	86.90	4
289	J-84	77.00	0	0	86.97	4
386	J-153	93.00	1	6,242	103.02	4
388	J-159	93.00	0	0	103.02	4
367	J-146	93.00	1	3,121	103.02	4
119	J-29	92.00	1	12,485	102.20	4
116	J-28	92.00	0	0	102.54	5
130	J-31	88.00	0	0	98.88	5
404	J-162	91.00	0	0	102.99	5
225	J-Island 3	65.00	1	9,364	77.11	5
126	J-30	88.00	0	0	100.55	5
400	J-160	90.00	1	16,646	102.99	6
52	J-Mission Inn 12	125.00	0	0	139.01	6
135	J-34	84.00	1	10,404	98.49	6
217	J-124	67.00	0	0	81.80	6
407	J-163	88.00	1	3,121	102.99	6
54	J-Mission Inn 13	124.00	1	37,454	139.00	6
221	J-Island 2	62.00	1	4,162	77.11	7
426	J-168	87.00	0	0	102.99	7
402	J-161	87.00	0	0	102.99	7
262	J-116	68.00	1	15,606	84.60	7
292	J-110	68.00	0	0	86.96	8
422	J-150	83.00	1	3,121	102.99	9
393	J-151	83.00	1	6,242	102.99	9
391	J-152	83.00	0	0	102.99	9
271	J-115	64.00	1	9,364	85.71	9
365	J-147	81.00	1	3,121	102.99	10
286	J-111	64.00	1	1,040	86.41	10
299	J-107	67.00	1	13,525	89.79	10
296	J-109	64.00	0	0	86.96	10
313	J-103	70.00	1	19,768	95.93	11
419	J-149	77.00	0	0	102.98	11
310	J-105	66.00	1	14,566	92.63	12
360	J-138	76.00	1	11,444	102.98	12
363	J-148	76.00	0	0	102.98	12
409	J-164	75.00	1	12,485	102.98	12
327	J-101	71.00	1	13,525	99.75	12
330	J-100	70.00	1	7,283	100.89	13

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 1 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
413	J-166	72.00	0	0	102.98	13
343	J-135	70.00	1	13,525	102.37	14
646	J-200	70.00	0	0	102.49	14
346	J-137	70.00	1	13,525	102.83	14
519	J-169	69.00	0	0	102.98	15
417	J-167	68.00	1	8,323	102.98	15
411	J-165	64.00	1	5,202	102.86	17
30	J-WTP2-1	130.00	0	0	208.00	34
442	J-7	128.00	0	0	270.89	62
1122	J-354	140.00	0	0	288.24	64
37	J-5	128.00	0	0	276.24	64
1178	J-Lake Hills 1	140.00	0	0	290.41	65
1245	J-WTP3-2	140.00	0	0	290.91	65
31	J-2	128.00	0	0	283.67	67
33	J-4	128.00	0	0	283.70	67
35	J-3	128.00	0	0	283.92	67
1108	J-Drake Point 3	126.24	1	67,320	287.27	70
1106	J-Drake Point 2	120.00	1	67,703	287.28	72
1110	J-Lake Hills 12	101.23	0	0	284.65	79
1112	J-Thompson Grove 1	92.46	1	104,040	284.63	83
1102	J-Lake Hills 11	92.23	0	0	287.59	85
1195	J-Lake Hills 10	92.00	1	27,158	287.48	85
1119	J-Westminster 1	87.02	1	133,875	284.60	85
1183	J-Lake Hills 3	84.00	1	27,540	286.86	88
1184	J-Lake Hills 4	82.00	1	27,540	286.91	89
1177	J-Lake Hills 2	81.00	2	169,575	286.86	89
1188	J-Lake Hills 6	80.00	1	27,158	286.96	90
1192	J-Lake Hills 7	79.00	1	27,158	287.01	90
1114	J-Cypress Point 1	73.64	1	21,038	284.60	91
1196	J-Lake Hills 9	76.00	1	27,540	287.29	91
1187	J-Lake Hills 5	75.00	1	27,158	286.94	92
1104	J-Drake Point 1	75.00	1	67,703	287.31	92
1116	J-Cypress Point 2	70.02	1	21,038	284.60	93
1189	J-Lake Hills 8	71.00	1	27,158	287.13	94

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
668	J-WTP1-3	81.00	0	0	82.96	1
666	J-WTP1-2	81.00	0	0	82.96	1
664	J-WTP1-1	81.00	0	0	82.96	1
1248	J-WTP3-1	140.00	0	0	142.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
68	J-Mission Inn 6	154.00	1	16,646	244.13	39
568	J-Mission Inn 5	154.00	0	0	244.20	39
41	J-6	152.00	0	0	243.39	40
66	J-Mission Inn 10	152.00	0	0	244.10	40
46	J-9	151.00	0	0	243.94	40
1178	J-Lake Hills 1	140.00	0	0	233.97	41
1245	J-WTP3-2	140.00	0	0	233.97	41
1122	J-354	140.00	0	0	233.98	41
74	J-Mission Inn 9	150.00	1	4,162	244.13	41
869	J-Watermark 5	159.36	1	60,053	253.54	41
78	J-Mission Inn 4	150.00	0	0	244.27	41
355	J-140	152.00	0	0	246.81	41
44	J-8	152.00	1	1,040	246.81	41
82	J-Mission Inn 3	149.00	0	0	244.28	41
86	J-Mission Inn 2	149.00	1	15,606	244.28	41
70	J-Mission Inn 7	148.00	1	8,323	244.13	42
48	J-Mission Inn 1	148.00	0	0	244.26	42
72	J-Mission Inn 8	146.00	1	4,162	244.13	42
374	J-141	146.00	0	0	246.80	44
351	J-94	144.00	0	0	246.82	44
1217	J-386	141.00	0	0	244.03	45
539	J-142	141.00	0	0	246.80	46
35	J-3	128.00	0	0	234.13	46
33	J-4	128.00	0	0	234.13	46
31	J-2	128.00	0	0	234.14	46
37	J-5	128.00	0	0	234.65	46
442	J-7	128.00	0	0	235.02	46
764	J-Whispering Hills 2	146.07	0	0	253.14	46
1108	J-Drake Point 3	126.24	1	67,320	233.46	46
866	J-Watermark 4	145.57	1	9,180	253.56	47
50	J-Mission Inn 11	134.00	0	0	244.05	48
1106	J-Drake Point 2	120.00	1	67,703	233.47	49
90	J-Mission Inn 14	131.00	0	0	245.24	49
640	J-198	131.95	0	0	246.81	50
92	J-23	130.00	0	0	245.25	50
94	J-Mission Inn 15	130.00	0	0	245.38	50
96	J-25	130.00	0	0	245.57	50
114	J-27	129.00	1	15,606	246.24	51
100	J-26	128.00	1	3,121	246.12	51
863	J-Watermark 3	135.17	1	8,415	253.57	51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1162	J-365	135.00	0	0	253.54	51
338	J-93	128.00	0	0	246.81	51
52	J-Mission Inn 12	125.00	0	0	244.04	52
54	J-Mission Inn 13	124.00	1	37,454	244.03	52
544	J-170	123.00	0	0	246.79	54
502	J-98	122.00	0	0	246.90	54
102	J-38	121.00	0	0	246.74	54
490	J-102	122.00	0	0	247.78	54
104	J-92	121.00	0	0	246.79	54
512	J-96	121.00	0	0	246.89	54
643	J-199	119.72	0	0	246.93	55
495	J-90	120.00	0	0	247.83	55
325	J-89	120.00	0	0	247.90	55
322	J-88	120.00	0	0	247.94	55
340	J-97	119.00	1	14,566	246.96	55
348	J-95	118.00	1	17,687	246.86	56
377	J-157	117.00	1	12,485	246.79	56
372	J-143	117.00	1	4,162	246.80	56
576	J-183	118.00	0	0	248.02	56
315	J-104	117.00	0	0	248.32	57
108	J-39	116.00	0	0	247.97	57
110	J-40	116.00	1	11,444	248.01	57
1110	J-Lake Hills 12	101.23	0	0	233.91	57
319	J-87	115.00	0	0	248.34	58
332	J-99	113.00	1	10,404	247.13	58
334	J-91	113.00	1	4,162	247.14	58
106	J-37	112.00	1	5,202	247.37	59
860	J-Watermark 2	116.57	1	8,415	253.60	59
357	J-139	107.00	1	15,606	246.81	60
1112	J-Thompson Grove 1	92.46	1	104,040	233.88	61
1102	J-Lake Hills 11	92.23	0	0	233.78	61
1195	J-Lake Hills 10	92.00	1	27,158	233.77	61
447	J-36	105.00	0	0	247.63	62
529	J-156	104.00	0	0	246.79	62
534	J-144	104.00	0	0	246.80	62
306	J-106	106.00	0	0	248.90	62
123	J-35	104.00	1	12,485	247.69	62
121	J-32	104.00	1	20,808	247.70	62
369	J-145	103.00	1	3,121	246.80	62
382	J-158	102.00	1	12,485	246.79	63
507	J-136	102.00	0	0	246.98	63
304	J-86	103.00	1	3,121	248.91	63
612	J-190	104.74	0	0	250.65	63
616	J-191	104.64	1	10,404	250.68	63
379	J-155	100.00	1	8,323	246.79	64

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1119	J-Westminster 1	87.02	1	133,875	233.86	64
169	J-63	104.00	1	12,485	251.34	64
983	J-Venezia 23	105.00	1	12,485	253.47	64
215	J-77	102.00	0	0	250.49	64
978	J-Venezia 18	105.00	1	10,404	253.61	64
786	J-248	102.22	0	0	251.25	64
165	J-60	102.00	1	11,444	251.29	65
167	J-61	102.00	0	0	251.29	65
897	J-Talichet 1	104.83	0	0	254.54	65
1183	J-Lake Hills 3	84.00	1	27,540	233.84	65
566	J-62	101.00	0	0	251.29	65
635	J-197	100.00	0	0	250.49	65
211	J-56	100.22	0	0	251.11	65
156	J-54	100.06	1	2,081	251.15	65
973	J-Venezia 19	102.41	1	11,444	253.60	65
201	J-52	100.00	0	0	251.60	66
203	J-51	100.00	1	2,081	251.62	66
1184	J-Lake Hills 4	82.00	1	27,540	233.79	66
524	J-154	95.00	0	0	246.79	66
772	J-240	100.95	0	0	253.61	66
1148	J-Watermark 1	100.95	0	0	253.61	66
1177	J-Lake Hills 2	81.00	2	169,575	233.87	66
809	J-Mission Rise 5	100.08	1	11,093	253.71	66
1188	J-Lake Hills 6	80.00	1	27,158	233.77	67
386	J-153	93.00	1	6,242	246.79	67
388	J-159	93.00	0	0	246.80	67
367	J-146	93.00	1	3,121	246.80	67
1053	J-Venezia 2	100.09	0	0	253.93	67
773	J-Venezia 1	100.12	0	0	253.98	67
688	J-209	97.00	1	5,202	251.19	67
158	J-53	97.00	1	13,525	251.25	67
1192	J-Lake Hills 7	79.00	1	27,158	233.77	67
213	J-Venezia 3	99.00	0	0	253.85	67
154	J-58	96.00	1	1,040	251.25	67
629	J-196	96.00	1	13,525	251.26	67
812	J-Mission Rise 6	98.40	1	11,093	253.66	67
895	J-Talichet 2	99.21	0	0	254.55	67
465	J-78	95.00	0	0	250.45	67
192	J-50	96.50	1	1,040	251.97	67
116	J-28	92.00	0	0	247.57	67
119	J-29	92.00	1	12,485	247.61	67
404	J-162	91.00	0	0	246.79	67
968	J-Venezia 20	97.78	1	11,444	253.60	67
581	J-184	93.00	0	0	249.23	68
607	J-189	95.00	0	0	251.25	68

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
815	J-Mission Rise 7	97.32	1	11,093	253.60	68
255	J-79	94.00	1	4,162	250.45	68
848	J-Mission Rise 18	97.08	1	10,710	253.56	68
839	J-Mission Rise 15	96.89	1	10,710	253.53	68
702	J-Venezia 4	97.00	1	32,513	253.78	68
400	J-160	90.00	1	16,646	246.79	68
842	J-Mission Rise 16	96.14	1	10,710	253.53	68
251	J-123	93.00	0	0	250.44	68
1196	J-Lake Hills 9	76.00	1	27,540	233.77	68
186	J-49	95.08	1	1,040	253.23	68
1133	J-Venezia 24	95.33	1	16,646	253.50	68
235	J-131	95.00	0	0	253.38	69
239	J-132	95.00	0	0	253.41	69
1104	J-Drake Point 1	75.00	1	67,703	233.50	69
957	J-Venezia 25	95.00	1	10,404	253.53	69
133	J-33	91.00	0	0	249.55	69
194	J-66	93.00	1	3,121	251.57	69
1187	J-Lake Hills 5	75.00	1	27,158	233.77	69
407	J-163	88.00	1	3,121	246.79	69
1168	J-Venezia TH 1	95.00	0	0	253.82	69
934	J-Talichet 6	95.60	1	3,121	254.55	69
881	J-Talichet II 1	94.95	1	5,738	254.04	69
475	J-120	91.00	0	0	250.32	69
806	J-Mission Rise 4	94.43	1	11,093	253.77	69
818	J-Mission Rise 8	94.12	1	11,093	253.50	69
930	J-Talichet 3	95.16	1	6,242	254.55	69
824	J-Mission Rise 10	94.09	1	6,503	253.50	69
827	J-Mission Rise 11	94.06	1	6,503	253.50	69
932	J-Talichet 4	95.07	1	3,121	254.55	69
1166	J-Venezia TH 2	94.00	1	6,885	253.78	69
402	J-161	87.00	0	0	246.79	69
426	J-168	87.00	0	0	246.79	69
126	J-30	88.00	0	0	247.89	69
1043	J-324	95.01	0	0	254.92	69
1041	J-323	94.88	0	0	254.94	69
130	J-31	88.00	0	0	248.17	69
1114	J-Cypress Point 1	73.64	1	21,038	233.85	69
480	J-118	90.00	0	0	250.23	69
268	J-81	90.00	1	4,162	250.23	69
152	J-76	91.00	1	8,323	251.30	69
452	J-41	89.00	1	5,202	249.61	69
704	J-Venezia 5	93.00	0	0	253.61	69
963	J-Venezia 21	92.72	1	13,525	253.60	70
1100	J-Golden Hills 1	92.58	1	232,178	253.47	70
597	J-187	90.00	0	0	251.54	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
179	J-67	90.00	0	0	251.57	70
879	J-Talichet II 2	92.00	1	2,295	254.02	70
776	J-Cedar Creek 1	91.69	1	65,408	253.92	70
257	J-80	88.00	1	4,162	250.32	70
173	J-64	89.00	0	0	251.44	70
301	J-85	87.00	0	0	249.45	70
198	J-65	89.00	1	5,202	251.50	70
1203	J-Venezia TH 3	91.00	1	8,798	253.76	70
1189	J-Lake Hills 8	71.00	1	27,158	233.76	70
730	J-Venezia 30	90.81	0	0	253.60	70
1138	J-Venezia 32	90.74	1	4,162	253.67	70
845	J-Mission Rise 17	90.35	1	10,710	253.54	71
724	J-220	90.23	0	0	253.52	71
883	J-Talichet 14	90.88	1	3,121	254.20	71
245	J-134	90.00	1	10,404	253.40	71
241	J-133	90.00	0	0	253.41	71
1035	J-Venezia 34	90.25	1	2,081	253.67	71
602	J-188	88.00	0	0	251.43	71
836	J-Mission Rise 14	90.07	1	6,503	253.52	71
1142	J-Mission Rise 1	90.47	0	0	253.94	71
720	J-Venezia 26	90.00	1	5,202	253.53	71
1152	J-Mission Rise 22	89.96	0	0	253.62	71
936	J-Talichet 5	90.78	1	5,202	254.55	71
391	J-152	83.00	0	0	246.79	71
393	J-151	83.00	1	6,242	246.79	71
422	J-150	83.00	1	3,121	246.79	71
1116	J-Cypress Point 2	70.02	1	21,038	233.85	71
803	J-Mission Rise 3	89.89	1	10,710	253.83	71
800	J-Mission Rise 2	89.97	1	10,710	253.92	71
876	J-The Reserve 14	89.84	0	0	253.84	71
135	J-34	84.00	1	10,404	248.11	71
1084	J-The Reserve 13	89.69	2	126,225	253.81	71
830	J-Mission Rise 12	89.37	1	6,503	253.51	71
1059	J-Talichet 13	90.07	1	1,040	254.23	71
1081	J-The Reserve 12	89.60	1	2,295	253.82	71
1078	J-The Reserve 11	89.47	1	2,295	253.82	71
176	J-75	87.00	0	0	251.46	71
1075	J-The Reserve 10	89.34	2	132,983	253.82	71
732	J-Venezia 31	89.16	1	6,242	253.67	71
1004	J-Venezia 12	88.68	1	4,162	253.37	71
432	J-44	90.00	0	0	254.73	71
1129	J-Venezia 10	88.52	1	11,444	253.37	71
436	J-45	90.00	0	0	254.94	71
833	J-Mission Rise 13	88.53	1	6,503	253.51	71
893	J-Talichet 7	89.60	1	12,485	254.61	71

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
762	J-234	88.95	0	0	253.98	71
556	J-174	91.00	0	0	256.08	71
851	J-Mission Rise 19	88.36	1	10,710	253.57	71
1064	J-329	88.47	0	0	253.76	72
624	J-194	88.00	1	3,121	253.35	72
470	J-122	85.00	0	0	250.43	72
885	J-Talichet 12	88.74	1	2,081	254.25	72
143	J-71	85.00	0	0	250.56	72
181	J-68	86.00	0	0	251.62	72
141	J-70	85.00	0	0	250.62	72
365	J-147	81.00	1	3,121	246.80	72
139	J-42	84.00	0	0	250.12	72
585	J-185	90.00	0	0	256.15	72
1157	J-330	87.56	0	0	253.75	72
429	J-43	84.00	1	9,364	250.26	72
821	J-Mission Rise 9	87.13	1	6,503	253.50	72
738	J-Venezia 33	87.00	1	6,242	253.67	72
873	J-The Reserve 8	86.99	0	0	253.75	72
914	J-Talichet 17	87.41	1	5,202	254.23	72
1017	J-Venezia 6	86.57	0	0	253.46	72
712	J-215	86.31	0	0	253.21	72
994	J-Venezia 22	86.52	1	4,162	253.45	72
249	J-121	83.00	1	5,202	250.43	72
706	J-Venezia 7	86.00	0	0	253.45	72
485	J-108	82.00	0	0	249.45	72
797	J-251	85.79	0	0	253.77	73
793	J-Venezia 35	85.52	0	0	253.71	73
264	J-117	82.00	0	0	250.22	73
857	J-Mission Rise 21	85.31	1	10,710	253.59	73
887	J-Talichet 11	86.01	1	31,860	254.32	73
759	J-The Reserve 9	86.74	1	8,798	255.06	73
457	J-125	82.31	1	10,404	250.65	73
952	J-Venezia 29	85.03	1	5,202	253.52	73
621	J-193	85.00	1	1,040	253.52	73
854	J-Mission Rise 20	85.00	1	10,710	253.58	73
790	J-249	85.17	0	0	253.76	73
1097	J-The Reserve 7	85.00	1	92,565	253.81	73
1095	J-The Reserve 6	85.05	1	92,565	253.87	73
1093	J-The Reserve 5	85.01	1	3,825	253.92	73
1091	J-The Reserve 4	85.00	1	3,825	253.96	73
1089	J-The Reserve 3	85.01	1	25,628	254.07	73
775	J-The Reserve 1	85.21	0	0	254.29	73
275	J-82	81.00	0	0	250.15	73
273	J-113	81.00	0	0	250.15	73
1087	J-The Reserve 2	85.05	1	32,895	254.25	73

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
910	J-Talichet 15	85.00	1	11,444	254.21	73
912	J-Talichet 16	85.00	1	7,283	254.22	73
728	J-Venezia 28	84.00	0	0	253.52	73
889	J-Talichet 10	85.00	1	3,121	254.58	73
1205	J-Venezia TH 4	84.00	1	27,540	253.75	73
891	J-Talichet 8	85.00	1	18,727	254.76	73
923	J-Talichet 9	85.00	1	3,121	254.79	73
419	J-149	77.00	0	0	246.80	73
926	J-295	85.00	1	3,121	255.00	74
549	J-Mitchell 1	85.00	1	13,525	255.06	74
592	J-186	85.00	1	7,283	255.11	74
677	J-WTP1-6	86.25	0	0	256.41	74
678	J-WTP1-5	86.25	0	0	256.41	74
679	J-WTP1-4	86.25	0	0	256.41	74
150	J-74	81.00	1	2,081	251.21	74
718	J-Venezia 11	83.00	1	8,323	253.37	74
722	J-Venezia 27	83.00	1	11,444	253.52	74
363	J-148	76.00	0	0	246.81	74
360	J-138	76.00	1	11,444	246.81	74
756	J-Whispering Hills 1	81.37	0	0	252.40	74
754	J-229	82.11	0	0	253.18	74
769	J-238	85.00	0	0	256.08	74
554	J-173	84.00	0	0	255.10	74
1012	J-Venezia 9	82.26	1	6,242	253.38	74
708	J-Venezia 8	82.00	1	2,081	253.38	74
1032	J-Venezia 17	81.62	1	2,081	253.24	74
757	J-231	80.71	0	0	252.40	74
409	J-164	75.00	1	12,485	246.79	74
1023	J-Venezia 13	81.45	1	3,121	253.34	74
716	J-Venezia 16	81.00	1	4,162	253.24	75
259	J-119	78.00	1	11,444	250.32	75
999	J-Venezia 14	80.56	1	4,162	253.28	75
1170	J-369	82.00	0	0	255.06	75
289	J-84	77.00	0	0	250.07	75
552	J-172	82.00	0	0	255.08	75
112	J-72	77.00	0	0	250.15	75
710	J-Venezia 15	80.00	1	3,121	253.24	75
280	J-112	77.00	0	0	250.49	75
148	J-73	77.00	0	0	250.55	75
219	J-Island 1	77.00	1	2,081	250.88	75
1214	J-Venezia S	79.00	0	0	253.75	76
413	J-166	72.00	0	0	246.79	76
231	J-130	77.00	0	0	253.13	76
227	J-129	75.00	1	20,808	251.54	76
327	J-101	71.00	1	13,525	247.61	76

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
346	J-137	70.00	1	13,525	246.88	77
646	J-200	70.00	0	0	246.99	77
343	J-135	70.00	1	13,525	247.02	77
330	J-100	70.00	1	7,283	247.38	77
519	J-169	69.00	0	0	246.80	77
313	J-103	70.00	1	19,768	248.30	77
417	J-167	68.00	1	8,323	246.79	77
1068	J-Whispering Hills 3	70.72	1	47,813	252.41	79
292	J-110	68.00	0	0	250.04	79
262	J-116	68.00	1	15,606	250.22	79
299	J-107	67.00	1	13,525	249.45	79
411	J-165	64.00	1	5,202	246.66	79
310	J-105	66.00	1	14,566	248.89	79
217	J-124	67.00	0	0	250.51	79
225	J-Island 3	65.00	1	9,364	250.87	80
296	J-109	64.00	0	0	250.03	80
286	J-111	64.00	1	1,040	250.11	81
271	J-115	64.00	1	9,364	250.15	81
1070	J-Whispering Hills 4	65.00	1	11,858	252.41	81
221	J-Island 2	62.00	1	4,162	250.87	82

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
668	J-WTP1-3	81.00	0	0	82.89	1
666	J-WTP1-2	81.00	0	0	82.90	1
664	J-WTP1-1	81.00	0	0	82.90	1
1248	J-WTP3-1	140.00	0	0	142.00	1
68	J-Mission Inn 6	154.00	2	2,176,646	190.75	16
66	J-Mission Inn 10	152.00	0	0	191.31	17
568	J-Mission Inn 5	154.00	0	0	193.38	17
74	J-Mission Inn 9	150.00	1	4,162	190.75	18
70	J-Mission Inn 7	148.00	1	8,323	190.75	18
41	J-6	152.00	0	0	195.94	19
72	J-Mission Inn 8	146.00	1	4,162	190.75	19
46	J-9	151.00	0	0	196.48	20
1178	J-Lake Hills 1	140.00	0	0	186.51	20
1245	J-WTP3-2	140.00	0	0	186.51	20
1122	J-354	140.00	0	0	186.52	20
78	J-Mission Inn 4	150.00	0	0	196.57	20
82	J-Mission Inn 3	149.00	0	0	196.69	21
86	J-Mission Inn 2	149.00	1	15,606	197.01	21
48	J-Mission Inn 1	148.00	0	0	197.92	22
1217	J-386	141.00	0	0	193.04	23
50	J-Mission Inn 11	134.00	0	0	192.33	25
35	J-3	128.00	0	0	186.67	25
33	J-4	128.00	0	0	186.68	25
31	J-2	128.00	0	0	186.68	25
37	J-5	128.00	0	0	187.20	26
442	J-7	128.00	0	0	187.57	26
1108	J-Drake Point 3	126.24	1	67,320	186.01	26
1106	J-Drake Point 2	120.00	1	67,703	186.02	29
52	J-Mission Inn 12	125.00	0	0	192.32	29
54	J-Mission Inn 13	124.00	1	37,454	192.32	30
44	J-8	152.00	1	1,040	221.94	30
355	J-140	152.00	0	0	222.03	30
90	J-Mission Inn 14	131.00	0	0	206.29	33
374	J-141	146.00	0	0	222.09	33
92	J-23	130.00	0	0	206.46	33
94	J-Mission Inn 15	130.00	0	0	207.60	34
351	J-94	144.00	0	0	221.82	34
30	J-WTP2-1	130.00	0	0	208.00	34
96	J-25	130.00	0	0	209.26	34
539	J-142	141.00	0	0	222.09	35
1110	J-Lake Hills 12	101.23	0	0	186.45	37
100	J-26	128.00	1	3,121	214.18	37
114	J-27	129.00	1	15,606	215.24	37

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
640	J-198	131.95	0	0	221.26	39
338	J-93	128.00	0	0	221.07	40
1112	J-Thompson Grove 1	92.46	1	104,040	186.43	41
1102	J-Lake Hills 11	92.23	0	0	186.32	41
1195	J-Lake Hills 10	92.00	1	27,158	186.32	41
102	J-38	121.00	0	0	219.75	43
544	J-170	123.00	0	0	222.11	43
104	J-92	121.00	0	0	220.32	43
1119	J-Westminster 1	87.02	1	133,875	186.40	43
502	J-98	122.00	0	0	222.01	43
512	J-96	121.00	0	0	222.48	44
1183	J-Lake Hills 3	84.00	1	27,540	186.39	44
643	J-199	119.72	0	0	222.62	45
340	J-97	119.00	1	14,566	222.70	45
1184	J-Lake Hills 4	82.00	1	27,540	186.33	45
348	J-95	118.00	1	17,687	222.35	45
377	J-157	117.00	1	12,485	222.11	45
372	J-143	117.00	1	4,162	222.12	45
1177	J-Lake Hills 2	81.00	2	169,575	186.41	46
490	J-102	122.00	0	0	227.52	46
869	J-Watermark 5	159.36	1	60,053	264.98	46
1188	J-Lake Hills 6	80.00	1	27,158	186.31	46
1192	J-Lake Hills 7	79.00	1	27,158	186.31	46
495	J-90	120.00	0	0	227.61	47
325	J-89	120.00	0	0	228.08	47
322	J-88	120.00	0	0	228.27	47
1196	J-Lake Hills 9	76.00	1	27,540	186.31	48
334	J-91	113.00	1	4,162	223.38	48
332	J-99	113.00	1	10,404	223.47	48
576	J-183	118.00	0	0	228.84	48
1104	J-Drake Point 1	75.00	1	67,703	186.05	48
1187	J-Lake Hills 5	75.00	1	27,158	186.32	48
106	J-37	112.00	1	5,202	224.18	49
108	J-39	116.00	0	0	228.40	49
110	J-40	116.00	1	11,444	228.61	49
1114	J-Cypress Point 1	73.64	1	21,038	186.40	49
315	J-104	117.00	0	0	231.16	49
357	J-139	107.00	1	15,606	222.19	50
1189	J-Lake Hills 8	71.00	1	27,158	186.31	50
319	J-87	115.00	0	0	231.21	50
1116	J-Cypress Point 2	70.02	1	21,038	186.40	50
764	J-Whispering Hills 2	146.07	0	0	263.32	51
529	J-156	104.00	0	0	222.13	51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
534	J-144	104.00	0	0	222.13	51
369	J-145	103.00	1	3,121	222.14	52
866	J-Watermark 4	145.57	1	9,180	265.03	52
382	J-158	102.00	1	12,485	222.12	52
507	J-136	102.00	0	0	222.87	52
447	J-36	105.00	0	0	226.02	52
379	J-155	100.00	1	8,323	222.13	53
123	J-35	104.00	1	12,485	226.37	53
121	J-32	104.00	1	20,808	226.43	53
524	J-154	95.00	0	0	222.14	55
306	J-106	106.00	0	0	234.80	56
386	J-153	93.00	1	6,242	222.14	56
388	J-159	93.00	0	0	222.15	56
367	J-146	93.00	1	3,121	222.15	56
863	J-Watermark 3	135.17	1	8,415	265.07	56
1162	J-365	135.00	0	0	264.95	56
404	J-162	91.00	0	0	222.15	57
304	J-86	103.00	1	3,121	234.82	57
400	J-160	90.00	1	16,646	222.14	57
116	J-28	92.00	0	0	225.41	58
119	J-29	92.00	1	12,485	225.70	58
407	J-163	88.00	1	3,121	222.14	58
402	J-161	87.00	0	0	222.15	58
426	J-168	87.00	0	0	222.15	58
391	J-152	83.00	0	0	222.15	60
393	J-151	83.00	1	6,242	222.15	60
422	J-150	83.00	1	3,121	222.15	60
126	J-30	88.00	0	0	227.45	60
365	J-147	81.00	1	3,121	222.16	61
130	J-31	88.00	0	0	229.22	61
612	J-190	104.74	0	0	246.17	61
616	J-191	104.64	1	10,404	246.35	61
215	J-77	102.00	0	0	245.45	62
581	J-184	93.00	0	0	236.78	62
169	J-63	104.00	1	12,485	249.06	63
135	J-34	84.00	1	10,404	229.18	63
419	J-149	77.00	0	0	222.19	63
635	J-197	100.00	0	0	245.47	63
363	J-148	76.00	0	0	222.20	63
360	J-138	76.00	1	11,444	222.21	63
786	J-248	102.22	0	0	248.74	63
133	J-33	91.00	0	0	237.54	63
165	J-60	102.00	1	11,444	248.89	64

Howey In The Hills Water System

FlexTable: Junction Table

**Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire
(North)**

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
167	J-61	102.00	0	0	248.89	64
409	J-164	75.00	1	12,485	222.14	64
566	J-62	101.00	0	0	248.89	64
211	J-56	100.22	0	0	248.16	64
156	J-54	100.06	1	2,081	248.33	64
860	J-Watermark 2	116.57	1	8,415	265.15	64
452	J-41	89.00	1	5,202	237.89	64
413	J-166	72.00	0	0	222.15	65
201	J-52	100.00	0	0	250.16	65
465	J-78	95.00	0	0	245.19	65
203	J-51	100.00	1	2,081	250.23	65
301	J-85	87.00	0	0	238.11	65
255	J-79	94.00	1	4,162	245.14	65
688	J-209	97.00	1	5,202	248.48	66
158	J-53	97.00	1	13,525	248.74	66
251	J-123	93.00	0	0	245.11	66
346	J-137	70.00	1	13,525	222.52	66
629	J-196	96.00	1	13,525	248.73	66
154	J-58	96.00	1	1,040	248.73	66
646	J-200	70.00	0	0	223.10	66
519	J-169	69.00	0	0	222.17	66
475	J-120	91.00	0	0	244.19	66
343	J-135	70.00	1	13,525	223.28	66
480	J-118	90.00	0	0	243.34	66
268	J-81	90.00	1	4,162	243.34	66
607	J-189	95.00	0	0	248.73	67
417	J-167	68.00	1	8,323	222.15	67
330	J-100	70.00	1	7,283	225.35	67
192	J-50	96.50	1	1,040	251.87	67
327	J-101	71.00	1	13,525	226.77	67
485	J-108	82.00	0	0	238.11	68
257	J-80	88.00	1	4,162	244.19	68
139	J-42	84.00	0	0	240.87	68
194	J-66	93.00	1	3,121	249.89	68
152	J-76	91.00	1	8,323	248.74	68
429	J-43	84.00	1	9,364	241.89	68
411	J-165	64.00	1	5,202	222.02	68
143	J-71	85.00	0	0	243.51	69
141	J-70	85.00	0	0	243.75	69
983	J-Venezia 23	105.00	1	12,485	264.62	69
597	J-187	90.00	0	0	249.75	69
179	J-67	90.00	0	0	249.89	69
978	J-Venezia 18	105.00	1	10,404	264.93	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
470	J-122	85.00	0	0	245.09	69
173	J-64	89.00	0	0	249.38	69
198	J-65	89.00	1	5,202	249.66	70
897	J-Talichet 1	104.83	0	0	265.83	70
313	J-103	70.00	1	19,768	231.12	70
264	J-117	82.00	0	0	243.34	70
602	J-188	88.00	0	0	249.34	70
275	J-82	81.00	0	0	242.50	70
273	J-113	81.00	0	0	242.50	70
249	J-121	83.00	1	5,202	245.08	70
176	J-75	87.00	0	0	249.39	70
973	J-Venezia 19	102.41	1	11,444	264.93	70
186	J-49	95.08	1	1,040	257.79	70
181	J-68	86.00	0	0	250.04	71
772	J-240	100.95	0	0	265.19	71
1148	J-Watermark 1	100.95	0	0	265.19	71
289	J-84	77.00	0	0	241.61	71
112	J-72	77.00	0	0	241.90	71
457	J-125	82.31	1	10,404	247.31	71
1053	J-Venezia 2	100.09	0	0	265.37	72
773	J-Venezia 1	100.12	0	0	265.43	72
809	J-Mission Rise 5	100.08	1	11,093	265.67	72
259	J-119	78.00	1	11,444	244.19	72
213	J-Venezia 3	99.00	0	0	265.26	72
895	J-Talichet 2	99.21	0	0	265.90	72
280	J-112	77.00	0	0	243.95	72
150	J-74	81.00	1	2,081	248.07	72
968	J-Venezia 20	97.78	1	11,444	264.94	72
812	J-Mission Rise 6	98.40	1	11,093	265.57	72
148	J-73	77.00	0	0	244.23	72
848	J-Mission Rise 18	97.08	1	10,710	265.23	73
815	J-Mission Rise 7	97.32	1	11,093	265.48	73
702	J-Venezia 4	97.00	1	32,513	265.17	73
839	J-Mission Rise 15	96.89	1	10,710	265.23	73
310	J-105	66.00	1	14,566	234.78	73
842	J-Mission Rise 16	96.14	1	10,710	265.23	73
235	J-131	95.00	0	0	264.34	73
1133	J-Venezia 24	95.33	1	16,646	264.74	73
239	J-132	95.00	0	0	264.44	73
957	J-Venezia 25	95.00	1	10,404	264.83	73
1168	J-Venezia TH 1	95.00	0	0	265.22	74
934	J-Talichet 6	95.60	1	3,121	265.90	74
930	J-Talichet 3	95.16	1	6,242	265.90	74

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
932	J-Talichet 4	95.07	1	3,121	265.90	74
881	J-Talichet II 1	94.95	1	5,738	265.79	74
1043	J-324	95.01	0	0	265.94	74
1041	J-323	94.88	0	0	265.98	74
299	J-107	67.00	1	13,525	238.11	74
818	J-Mission Rise 8	94.12	1	11,093	265.28	74
824	J-Mission Rise 10	94.09	1	6,503	265.25	74
1166	J-Venezia TH 2	94.00	1	6,885	265.18	74
827	J-Mission Rise 11	94.06	1	6,503	265.24	74
806	J-Mission Rise 4	94.43	1	11,093	265.77	74
704	J-Venezia 5	93.00	0	0	264.93	74
963	J-Venezia 21	92.72	1	13,525	264.95	75
219	J-Island 1	77.00	1	2,081	249.40	75
1100	J-Golden Hills 1	92.58	1	232,178	265.25	75
292	J-110	68.00	0	0	241.57	75
879	J-Talichet II 2	92.00	1	2,295	265.76	75
730	J-Venezia 30	90.81	0	0	264.95	75
1203	J-Venezia TH 3	91.00	1	8,798	265.15	75
776	J-Cedar Creek 1	91.69	1	65,408	266.04	75
1138	J-Venezia 32	90.74	1	4,162	265.13	75
245	J-134	90.00	1	10,404	264.44	75
241	J-133	90.00	0	0	264.44	75
724	J-220	90.23	0	0	264.84	76
720	J-Venezia 26	90.00	1	5,202	264.84	76
845	J-Mission Rise 17	90.35	1	10,710	265.23	76
1035	J-Venezia 34	90.25	1	2,081	265.13	76
432	J-44	90.00	0	0	264.89	76
936	J-Talichet 5	90.78	1	5,202	265.90	76
836	J-Mission Rise 14	90.07	1	6,503	265.23	76
883	J-Talichet 14	90.88	1	3,121	266.06	76
1152	J-Mission Rise 22	89.96	0	0	265.23	76
262	J-116	68.00	1	15,606	243.34	76
876	J-The Reserve 14	89.84	0	0	265.38	76
1142	J-Mission Rise 1	90.47	0	0	266.07	76
1004	J-Venezia 12	88.68	1	4,162	264.28	76
1084	J-The Reserve 13	89.69	2	126,225	265.37	76
1129	J-Venezia 10	88.52	1	11,444	264.28	76
1081	J-The Reserve 12	89.60	1	2,295	265.38	76
830	J-Mission Rise 12	89.37	1	6,503	265.24	76
1078	J-The Reserve 11	89.47	1	2,295	265.40	76
732	J-Venezia 31	89.16	1	6,242	265.13	76
436	J-45	90.00	0	0	265.98	76
803	J-Mission Rise 3	89.89	1	10,710	265.88	76

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1059	J-Talichet 13	90.07	1	1,040	266.11	76
800	J-Mission Rise 2	89.97	1	10,710	266.03	76
1075	J-The Reserve 10	89.34	2	132,983	265.42	76
624	J-194	88.00	1	3,121	264.22	76
893	J-Talichet 7	89.60	1	12,485	266.22	76
833	J-Mission Rise 13	88.53	1	6,503	265.24	76
762	J-234	88.95	0	0	265.69	76
851	J-Mission Rise 19	88.36	1	10,710	265.23	77
1064	J-329	88.47	0	0	265.35	77
712	J-215	86.31	0	0	263.60	77
885	J-Talichet 12	88.74	1	2,081	266.13	77
296	J-109	64.00	0	0	241.55	77
1157	J-330	87.56	0	0	265.35	77
1017	J-Venezia 6	86.57	0	0	264.53	77
994	J-Venezia 22	86.52	1	4,162	264.53	77
286	J-111	64.00	1	1,040	242.08	77
821	J-Mission Rise 9	87.13	1	6,503	265.25	77
738	J-Venezia 33	87.00	1	6,242	265.13	77
873	J-The Reserve 8	86.99	0	0	265.36	77
706	J-Venezia 7	86.00	0	0	264.49	77
271	J-115	64.00	1	9,364	242.53	77
756	J-Whispering Hills 1	81.37	0	0	260.00	77
914	J-Talichet 17	87.41	1	5,202	266.11	77
556	J-174	91.00	0	0	269.72	77
217	J-124	67.00	0	0	245.74	77
757	J-231	80.71	0	0	259.97	78
227	J-129	75.00	1	20,808	254.50	78
797	J-251	85.79	0	0	265.35	78
793	J-Venezia 35	85.52	0	0	265.22	78
952	J-Venezia 29	85.03	1	5,202	264.84	78
621	J-193	85.00	1	1,040	264.84	78
585	J-185	90.00	0	0	269.86	78
857	J-Mission Rise 21	85.31	1	10,710	265.23	78
790	J-249	85.17	0	0	265.34	78
854	J-Mission Rise 20	85.00	1	10,710	265.23	78
887	J-Talichet 11	86.01	1	31,860	266.25	78
1097	J-The Reserve 7	85.00	1	92,565	265.60	78
1095	J-The Reserve 6	85.05	1	92,565	265.75	78
728	J-Venezia 28	84.00	0	0	264.84	78
1093	J-The Reserve 5	85.01	1	3,825	265.85	78
759	J-The Reserve 9	86.74	1	8,798	267.63	78
1091	J-The Reserve 4	85.00	1	3,825	265.94	78
910	J-Talichet 15	85.00	1	11,444	266.07	78

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
912	J-Talichet 16	85.00	1	7,283	266.09	78
1205	J-Venezia TH 4	84.00	1	27,540	265.14	78
1089	J-The Reserve 3	85.01	1	25,628	266.17	78
718	J-Venezia 11	83.00	1	8,323	264.28	78
754	J-229	82.11	0	0	263.50	78
775	J-The Reserve 1	85.21	0	0	266.61	78
1087	J-The Reserve 2	85.05	1	32,895	266.52	79
889	J-Talichet 10	85.00	1	3,121	266.64	79
722	J-Venezia 27	83.00	1	11,444	264.84	79
891	J-Talichet 8	85.00	1	18,727	266.85	79
923	J-Talichet 9	85.00	1	3,121	266.94	79
1012	J-Venezia 9	82.26	1	6,242	264.28	79
1032	J-Venezia 17	81.62	1	2,081	263.73	79
708	J-Venezia 8	82.00	1	2,081	264.28	79
926	J-295	85.00	1	3,121	267.43	79
549	J-Mitchell 1	85.00	1	13,525	267.63	79
1023	J-Venezia 13	81.45	1	3,121	264.12	79
592	J-186	85.00	1	7,283	267.68	79
716	J-Venezia 16	81.00	1	4,162	263.73	79
999	J-Venezia 14	80.56	1	4,162	263.88	79
554	J-173	84.00	0	0	267.67	79
710	J-Venezia 15	80.00	1	3,121	263.73	79
677	J-WTP1-6	86.25	0	0	270.55	80
678	J-WTP1-5	86.25	0	0	270.55	80
679	J-WTP1-4	86.25	0	0	270.55	80
225	J-Island 3	65.00	1	9,364	249.39	80
769	J-238	85.00	0	0	269.74	80
1170	J-369	82.00	0	0	267.63	80
552	J-172	82.00	0	0	267.65	80
231	J-130	77.00	0	0	263.22	81
1214	J-Venezia S	79.00	0	0	265.35	81
221	J-Island 2	62.00	1	4,162	249.40	81
1068	J-Whispering Hills 3	70.72	1	47,813	260.41	82
1070	J-Whispering Hills 4	65.00	1	11,858	260.41	85

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
668	J-WTP1-3	81.00	0	0	82.92	1
666	J-WTP1-2	81.00	0	0	82.92	1
664	J-WTP1-1	81.00	0	0	82.93	1
1248	J-WTP3-1	140.00	0	0	142.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	2	1,500,053	246.87	38
68	J-Mission Inn 6	154.00	1	16,646	244.13	39
568	J-Mission Inn 5	154.00	0	0	244.20	39
41	J-6	152.00	0	0	243.39	40
66	J-Mission Inn 10	152.00	0	0	244.10	40
46	J-9	151.00	0	0	243.94	40
1178	J-Lake Hills 1	140.00	0	0	233.97	41
1245	J-WTP3-2	140.00	0	0	233.97	41
1122	J-354	140.00	0	0	233.98	41
74	J-Mission Inn 9	150.00	1	4,162	244.13	41
78	J-Mission Inn 4	150.00	0	0	244.27	41
355	J-140	152.00	0	0	246.80	41
44	J-8	152.00	1	1,040	246.81	41
82	J-Mission Inn 3	149.00	0	0	244.28	41
86	J-Mission Inn 2	149.00	1	15,606	244.28	41
70	J-Mission Inn 7	148.00	1	8,323	244.13	42
48	J-Mission Inn 1	148.00	0	0	244.26	42
72	J-Mission Inn 8	146.00	1	4,162	244.13	42
374	J-141	146.00	0	0	246.79	44
866	J-Watermark 4	145.57	1	9,180	247.71	44
351	J-94	144.00	0	0	246.81	44
1217	J-386	141.00	0	0	244.03	45
764	J-Whispering Hills 2	146.07	0	0	249.75	45
539	J-142	141.00	0	0	246.79	46
35	J-3	128.00	0	0	234.13	46
33	J-4	128.00	0	0	234.13	46
31	J-2	128.00	0	0	234.14	46
37	J-5	128.00	0	0	234.65	46
442	J-7	128.00	0	0	235.02	46
1108	J-Drake Point 3	126.24	1	67,320	233.46	46
50	J-Mission Inn 11	134.00	0	0	244.05	48
1162	J-365	135.00	0	0	247.20	49
863	J-Watermark 3	135.17	1	8,415	248.20	49
1106	J-Drake Point 2	120.00	1	67,703	233.47	49
90	J-Mission Inn 14	131.00	0	0	245.24	49
640	J-198	131.95	0	0	246.81	50
92	J-23	130.00	0	0	245.25	50
94	J-Mission Inn 15	130.00	0	0	245.38	50

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
96	J-25	130.00	0	0	245.57	50
114	J-27	129.00	1	15,606	246.24	51
100	J-26	128.00	1	3,121	246.12	51
338	J-93	128.00	0	0	246.81	51
52	J-Mission Inn 12	125.00	0	0	244.04	52
54	J-Mission Inn 13	124.00	1	37,454	244.03	52
544	J-170	123.00	0	0	246.79	54
502	J-98	122.00	0	0	246.89	54
102	J-38	121.00	0	0	246.74	54
490	J-102	122.00	0	0	247.77	54
104	J-92	121.00	0	0	246.78	54
512	J-96	121.00	0	0	246.89	54
643	J-199	119.72	0	0	246.93	55
495	J-90	120.00	0	0	247.82	55
325	J-89	120.00	0	0	247.89	55
322	J-88	120.00	0	0	247.92	55
340	J-97	119.00	1	14,566	246.95	55
348	J-95	118.00	1	17,687	246.85	56
377	J-157	117.00	1	12,485	246.79	56
372	J-143	117.00	1	4,162	246.79	56
576	J-183	118.00	0	0	248.00	56
315	J-104	117.00	0	0	248.28	57
108	J-39	116.00	0	0	247.97	57
110	J-40	116.00	1	11,444	248.00	57
1110	J-Lake Hills 12	101.23	0	0	233.91	57
860	J-Watermark 2	116.57	1	8,415	249.29	57
319	J-87	115.00	0	0	248.30	58
332	J-99	113.00	1	10,404	247.12	58
334	J-91	113.00	1	4,162	247.13	58
106	J-37	112.00	1	5,202	247.37	59
357	J-139	107.00	1	15,606	246.81	60
1112	J-Thompson Grove 1	92.46	1	104,040	233.88	61
1102	J-Lake Hills 11	92.23	0	0	233.78	61
1195	J-Lake Hills 10	92.00	1	27,158	233.77	61
447	J-36	105.00	0	0	247.65	62
529	J-156	104.00	0	0	246.78	62
534	J-144	104.00	0	0	246.79	62
306	J-106	106.00	0	0	248.82	62
123	J-35	104.00	1	12,485	247.71	62
121	J-32	104.00	1	20,808	247.72	62
369	J-145	103.00	1	3,121	246.79	62
382	J-158	102.00	1	12,485	246.78	63
507	J-136	102.00	0	0	246.97	63

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
983	J-Venezia 23	105.00	1	12,485	250.01	63
612	J-190	104.74	0	0	250.29	63
616	J-191	104.64	1	10,404	250.36	63
978	J-Venezia 18	105.00	1	10,404	250.75	63
304	J-86	103.00	1	3,121	248.83	63
379	J-155	100.00	1	8,323	246.78	64
1119	J-Westminster 1	87.02	1	133,875	233.86	64
169	J-63	104.00	1	12,485	251.47	64
215	J-77	102.00	0	0	250.02	64
973	J-Venezia 19	102.41	1	11,444	250.70	64
772	J-240	100.95	0	0	249.80	64
1148	J-Watermark 1	100.95	0	0	249.80	64
786	J-248	102.22	0	0	251.35	65
165	J-60	102.00	1	11,444	251.40	65
167	J-61	102.00	0	0	251.40	65
897	J-Talichet 1	104.83	0	0	254.46	65
1183	J-Lake Hills 3	84.00	1	27,540	233.84	65
635	J-197	100.00	0	0	250.01	65
566	J-62	101.00	0	0	251.40	65
211	J-56	100.22	0	0	251.11	65
156	J-54	100.06	1	2,081	251.18	65
809	J-Mission Rise 5	100.08	1	11,093	251.61	66
524	J-154	95.00	0	0	246.78	66
1184	J-Lake Hills 4	82.00	1	27,540	233.79	66
201	J-52	100.00	0	0	251.81	66
203	J-51	100.00	1	2,081	251.83	66
1053	J-Venezia 2	100.09	0	0	252.31	66
773	J-Venezia 1	100.12	0	0	252.48	66
1177	J-Lake Hills 2	81.00	2	169,575	233.87	66
968	J-Venezia 20	97.78	1	11,444	250.65	66
213	J-Venezia 3	99.00	0	0	252.00	66
812	J-Mission Rise 6	98.40	1	11,093	251.43	66
848	J-Mission Rise 18	97.08	1	10,710	250.35	66
839	J-Mission Rise 15	96.89	1	10,710	250.43	66
1188	J-Lake Hills 6	80.00	1	27,158	233.77	67
386	J-153	93.00	1	6,242	246.78	67
388	J-159	93.00	0	0	246.79	67
367	J-146	93.00	1	3,121	246.79	67
815	J-Mission Rise 7	97.32	1	11,093	251.25	67
239	J-132	95.00	0	0	248.97	67
235	J-131	95.00	0	0	249.06	67
688	J-209	97.00	1	5,202	251.24	67
842	J-Mission Rise 16	96.14	1	10,710	250.42	67

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
158	J-53	97.00	1	13,525	251.35	67
1133	J-Venezia 24	95.33	1	16,646	249.97	67
702	J-Venezia 4	97.00	1	32,513	251.72	67
1192	J-Lake Hills 7	79.00	1	27,158	233.77	67
957	J-Venezia 25	95.00	1	10,404	249.95	67
465	J-78	95.00	0	0	250.00	67
895	J-Talichet 2	99.21	0	0	254.49	67
154	J-58	96.00	1	1,040	251.35	67
629	J-196	96.00	1	13,525	251.35	67
116	J-28	92.00	0	0	247.60	67
119	J-29	92.00	1	12,485	247.64	67
192	J-50	96.50	1	1,040	252.28	67
404	J-162	91.00	0	0	246.78	67
255	J-79	94.00	1	4,162	249.99	67
581	J-184	93.00	0	0	249.14	68
607	J-189	95.00	0	0	251.35	68
827	J-Mission Rise 11	94.06	1	6,503	250.65	68
824	J-Mission Rise 10	94.09	1	6,503	250.69	68
818	J-Mission Rise 8	94.12	1	11,093	250.87	68
400	J-160	90.00	1	16,646	246.78	68
1168	J-Venezia TH 1	95.00	0	0	251.89	68
251	J-123	93.00	0	0	249.97	68
806	J-Mission Rise 4	94.43	1	11,093	251.79	68
1196	J-Lake Hills 9	76.00	1	27,540	233.77	68
1166	J-Venezia TH 2	94.00	1	6,885	251.77	68
704	J-Venezia 5	93.00	0	0	250.82	68
963	J-Venezia 21	92.72	1	13,525	250.61	68
881	J-Talichet II 1	94.95	1	5,738	252.93	68
1100	J-Golden Hills 1	92.58	1	232,178	250.85	68
724	J-220	90.23	0	0	248.72	69
1104	J-Drake Point 1	75.00	1	67,703	233.50	69
133	J-33	91.00	0	0	249.68	69
186	J-49	95.08	1	1,040	253.83	69
1187	J-Lake Hills 5	75.00	1	27,158	233.77	69
407	J-163	88.00	1	3,121	246.78	69
194	J-66	93.00	1	3,121	251.78	69
934	J-Talichet 6	95.60	1	3,121	254.49	69
475	J-120	91.00	0	0	249.95	69
245	J-134	90.00	1	10,404	248.97	69
241	J-133	90.00	0	0	248.97	69
930	J-Talichet 3	95.16	1	6,242	254.49	69
932	J-Talichet 4	95.07	1	3,121	254.49	69
402	J-161	87.00	0	0	246.78	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
426	J-168	87.00	0	0	246.78	69
730	J-Venezia 30	90.81	0	0	250.60	69
126	J-30	88.00	0	0	247.93	69
480	J-118	90.00	0	0	249.95	69
268	J-81	90.00	1	4,162	249.95	69
720	J-Venezia 26	90.00	1	5,202	249.95	69
845	J-Mission Rise 17	90.35	1	10,710	250.40	69
1114	J-Cypress Point 1	73.64	1	21,038	233.85	69
130	J-31	88.00	0	0	248.23	69
1138	J-Venezia 32	90.74	1	4,162	251.02	69
1152	J-Mission Rise 22	89.96	0	0	250.29	69
836	J-Mission Rise 14	90.07	1	6,503	250.49	69
152	J-76	91.00	1	8,323	251.44	69
776	J-Cedar Creek 1	91.69	1	65,408	252.30	69
1203	J-Venezia TH 3	91.00	1	8,798	251.74	70
452	J-41	89.00	1	5,202	249.74	70
1035	J-Venezia 34	90.25	1	2,081	251.02	70
879	J-Talichet II 2	92.00	1	2,295	252.88	70
1043	J-324	95.01	0	0	255.91	70
1041	J-323	94.88	0	0	255.95	70
624	J-194	88.00	1	3,121	249.16	70
830	J-Mission Rise 12	89.37	1	6,503	250.62	70
1004	J-Venezia 12	88.68	1	4,162	249.98	70
1129	J-Venezia 10	88.52	1	11,444	249.98	70
597	J-187	90.00	0	0	251.75	70
179	J-67	90.00	0	0	251.78	70
1142	J-Mission Rise 1	90.47	0	0	252.32	70
732	J-Venezia 31	89.16	1	6,242	251.02	70
257	J-80	88.00	1	4,162	249.96	70
851	J-Mission Rise 19	88.36	1	10,710	250.33	70
833	J-Mission Rise 13	88.53	1	6,503	250.56	70
803	J-Mission Rise 3	89.89	1	10,710	252.00	70
876	J-The Reserve 14	89.84	0	0	252.00	70
800	J-Mission Rise 2	89.97	1	10,710	252.26	70
1084	J-The Reserve 13	89.69	2	126,225	252.01	70
301	J-85	87.00	0	0	249.35	70
1081	J-The Reserve 12	89.60	1	2,295	252.06	70
883	J-Talichet 14	90.88	1	3,121	253.46	70
173	J-64	89.00	0	0	251.62	70
1078	J-The Reserve 11	89.47	1	2,295	252.13	70
198	J-65	89.00	1	5,202	251.70	70
1189	J-Lake Hills 8	71.00	1	27,158	233.76	70
1075	J-The Reserve 10	89.34	2	132,983	252.20	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1064	J-329	88.47	0	0	251.42	70
712	J-215	86.31	0	0	249.76	71
1059	J-Talichet 13	90.07	1	1,040	253.55	71
994	J-Venezia 22	86.52	1	4,162	250.05	71
1017	J-Venezia 6	86.57	0	0	250.13	71
821	J-Mission Rise 9	87.13	1	6,503	250.73	71
602	J-188	88.00	0	0	251.60	71
936	J-Talichet 5	90.78	1	5,202	254.49	71
621	J-193	85.00	1	1,040	248.72	71
1157	J-330	87.56	0	0	251.34	71
391	J-152	83.00	0	0	246.78	71
393	J-151	83.00	1	6,242	246.78	71
422	J-150	83.00	1	3,121	246.78	71
762	J-234	88.95	0	0	252.74	71
1116	J-Cypress Point 2	70.02	1	21,038	233.85	71
952	J-Venezia 29	85.03	1	5,202	248.91	71
738	J-Venezia 33	87.00	1	6,242	251.02	71
706	J-Venezia 7	86.00	0	0	250.07	71
135	J-34	84.00	1	10,404	248.13	71
873	J-The Reserve 8	86.99	0	0	251.29	71
176	J-75	87.00	0	0	251.65	71
885	J-Talichet 12	88.74	1	2,081	253.61	71
728	J-Venezia 28	84.00	0	0	248.91	71
470	J-122	85.00	0	0	249.96	71
857	J-Mission Rise 21	85.31	1	10,710	250.31	71
893	J-Talichet 7	89.60	1	12,485	254.65	71
854	J-Mission Rise 20	85.00	1	10,710	250.32	72
793	J-Venezia 35	85.52	0	0	251.20	72
432	J-44	90.00	0	0	255.70	72
143	J-71	85.00	0	0	250.73	72
797	J-251	85.79	0	0	251.54	72
365	J-147	81.00	1	3,121	246.79	72
141	J-70	85.00	0	0	250.82	72
181	J-68	86.00	0	0	251.85	72
722	J-Venezia 27	83.00	1	11,444	248.91	72
436	J-45	90.00	0	0	255.95	72
914	J-Talichet 17	87.41	1	5,202	253.56	72
139	J-42	84.00	0	0	250.29	72
790	J-249	85.17	0	0	251.47	72
429	J-43	84.00	1	9,364	250.44	72
1097	J-The Reserve 7	85.00	1	92,565	251.71	72
1095	J-The Reserve 6	85.05	1	92,565	251.95	72
556	J-174	91.00	0	0	257.92	72

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
249	J-121	83.00	1	5,202	249.95	72
718	J-Venezia 11	83.00	1	8,323	249.98	72
1093	J-The Reserve 5	85.01	1	3,825	252.10	72
1091	J-The Reserve 4	85.00	1	3,825	252.23	72
485	J-108	82.00	0	0	249.34	72
1089	J-The Reserve 3	85.01	1	25,628	252.56	72
457	J-125	82.31	1	10,404	249.88	72
754	J-229	82.11	0	0	249.75	73
1012	J-Venezia 9	82.26	1	6,242	249.99	73
1205	J-Venezia TH 4	84.00	1	27,540	251.73	73
887	J-Talichet 11	86.01	1	31,860	253.83	73
264	J-117	82.00	0	0	249.94	73
775	J-The Reserve 1	85.21	0	0	253.19	73
708	J-Venezia 8	82.00	1	2,081	249.99	73
1087	J-The Reserve 2	85.05	1	32,895	253.07	73
585	J-185	90.00	0	0	258.07	73
1032	J-Venezia 17	81.62	1	2,081	249.80	73
756	J-Whispering Hills 1	81.37	0	0	249.72	73
1023	J-Venezia 13	81.45	1	3,121	249.93	73
910	J-Talichet 15	85.00	1	11,444	253.49	73
912	J-Talichet 16	85.00	1	7,283	253.52	73
716	J-Venezia 16	81.00	1	4,162	249.80	73
273	J-113	81.00	0	0	249.94	73
275	J-82	81.00	0	0	249.94	73
759	J-The Reserve 9	86.74	1	8,798	255.74	73
757	J-231	80.71	0	0	249.73	73
999	J-Venezia 14	80.56	1	4,162	249.85	73
889	J-Talichet 10	85.00	1	3,121	254.50	73
419	J-149	77.00	0	0	246.80	73
710	J-Venezia 15	80.00	1	3,121	249.80	73
891	J-Talichet 8	85.00	1	18,727	254.97	74
923	J-Talichet 9	85.00	1	3,121	255.02	74
150	J-74	81.00	1	2,081	251.34	74
926	J-295	85.00	1	3,121	255.52	74
549	J-Mitchell 1	85.00	1	13,525	255.74	74
592	J-186	85.00	1	7,283	255.80	74
363	J-148	76.00	0	0	246.80	74
360	J-138	76.00	1	11,444	246.80	74
409	J-164	75.00	1	12,485	246.78	74
554	J-173	84.00	0	0	255.78	74
259	J-119	78.00	1	11,444	249.95	74
1214	J-Venezia S	79.00	0	0	251.34	75
677	J-WTP1-6	86.25	0	0	258.59	75

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Ex Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
678	J-WTP1-5	86.25	0	0	258.59	75
679	J-WTP1-4	86.25	0	0	258.59	75
231	J-130	77.00	0	0	249.75	75
219	J-Island 1	77.00	1	2,081	249.81	75
769	J-238	85.00	0	0	257.89	75
289	J-84	77.00	0	0	249.94	75
112	J-72	77.00	0	0	250.11	75
280	J-112	77.00	0	0	250.48	75
148	J-73	77.00	0	0	250.56	75
1170	J-369	82.00	0	0	255.74	75
552	J-172	82.00	0	0	255.76	75
227	J-129	75.00	1	20,808	249.74	76
413	J-166	72.00	0	0	246.78	76
327	J-101	71.00	1	13,525	247.59	76
346	J-137	70.00	1	13,525	246.87	77
646	J-200	70.00	0	0	246.98	77
343	J-135	70.00	1	13,525	247.01	77
330	J-100	70.00	1	7,283	247.37	77
519	J-169	69.00	0	0	246.79	77
313	J-103	70.00	1	19,768	248.26	77
417	J-167	68.00	1	8,323	246.78	77
1068	J-Whispering Hills 3	70.72	1	47,813	249.65	77
292	J-110	68.00	0	0	249.90	79
262	J-116	68.00	1	15,606	249.94	79
299	J-107	67.00	1	13,525	249.34	79
411	J-165	64.00	1	5,202	246.65	79
310	J-105	66.00	1	14,566	248.81	79
217	J-124	67.00	0	0	249.95	79
1070	J-Whispering Hills 4	65.00	1	11,858	249.65	80
225	J-Island 3	65.00	1	9,364	249.80	80
296	J-109	64.00	0	0	249.88	80
286	J-111	64.00	1	1,040	249.94	80
271	J-115	64.00	1	9,364	249.94	80
221	J-Island 2	62.00	1	4,162	249.81	81

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Proposed Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1248	J-WTP3-1	140.00	0	0	141.96	1
668	J-WTP1-3	81.00	0	0	82.98	1
666	J-WTP1-2	81.00	0	0	82.98	1
664	J-WTP1-1	81.00	0	0	82.98	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	1	60,053	244.48	37
68	J-Mission Inn 6	154.00	1	16,646	245.57	40
568	J-Mission Inn 5	154.00	0	0	245.57	40
355	J-140	152.00	0	0	245.51	40
44	J-8	152.00	1	1,040	245.55	40
41	J-6	152.00	0	0	245.56	40
66	J-Mission Inn 10	152.00	0	0	245.57	40
46	J-9	151.00	0	0	245.57	41
74	J-Mission Inn 9	150.00	1	4,162	245.56	41
78	J-Mission Inn 4	150.00	0	0	245.57	41
82	J-Mission Inn 3	149.00	0	0	245.57	42
86	J-Mission Inn 2	149.00	1	15,606	245.57	42
70	J-Mission Inn 7	148.00	1	8,323	245.56	42
48	J-Mission Inn 1	148.00	0	0	245.57	42
764	J-Whispering Hills 2	146.07	0	0	244.49	43
866	J-Watermark 4	145.57	1	9,180	244.48	43
374	J-141	146.00	0	0	245.47	43
72	J-Mission Inn 8	146.00	1	4,162	245.56	43
351	J-94	144.00	0	0	245.55	44
539	J-142	141.00	0	0	245.47	45
1217	J-386	141.00	0	0	245.58	45
1122	J-354	140.00	0	0	245.63	46
1178	J-Lake Hills 1	140.00	0	0	245.77	46
1245	J-WTP3-2	140.00	0	0	245.80	46
863	J-Watermark 3	135.17	1	8,415	244.48	47
1162	J-365	135.00	0	0	244.48	47
50	J-Mission Inn 11	134.00	0	0	245.57	48
640	J-198	131.95	0	0	245.55	49
90	J-Mission Inn 14	131.00	0	0	245.57	50
94	J-Mission Inn 15	130.00	0	0	245.57	50
92	J-23	130.00	0	0	245.57	50
96	J-25	130.00	0	0	245.57	50
114	J-27	129.00	1	15,606	245.57	50
338	J-93	128.00	0	0	245.55	51
33	J-4	128.00	0	0	245.56	51
100	J-26	128.00	1	3,121	245.57	51
442	J-7	128.00	0	0	245.57	51
37	J-5	128.00	0	0	245.57	51
31	J-2	128.00	0	0	245.57	51
35	J-3	128.00	0	0	245.57	51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Proposed Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1108	J-Drake Point 3	126.24	1	67,320	245.10	51
52	J-Mission Inn 12	125.00	0	0	245.56	52
54	J-Mission Inn 13	124.00	1	37,454	245.55	53
544	J-170	123.00	0	0	245.46	53
502	J-98	122.00	0	0	245.52	53
490	J-102	122.00	0	0	245.53	53
512	J-96	121.00	0	0	245.48	54
104	J-92	121.00	0	0	245.56	54
102	J-38	121.00	0	0	245.57	54
1106	J-Drake Point 2	120.00	1	67,703	245.11	54
495	J-90	120.00	0	0	245.55	54
325	J-89	120.00	0	0	245.55	54
322	J-88	120.00	0	0	245.55	54
643	J-199	119.72	0	0	245.49	54
340	J-97	119.00	1	14,566	245.49	55
348	J-95	118.00	1	17,687	245.48	55
576	J-183	118.00	0	0	245.54	55
860	J-Watermark 2	116.57	1	8,415	244.48	55
377	J-157	117.00	1	12,485	245.45	56
372	J-143	117.00	1	4,162	245.46	56
315	J-104	117.00	0	0	245.51	56
108	J-39	116.00	0	0	245.56	56
110	J-40	116.00	1	11,444	245.56	56
319	J-87	115.00	0	0	245.52	56
332	J-99	113.00	1	10,404	245.50	57
334	J-91	113.00	1	4,162	245.55	57
106	J-37	112.00	1	5,202	245.57	58
357	J-139	107.00	1	15,606	245.47	60
983	J-Venezia 23	105.00	1	12,485	244.50	60
306	J-106	106.00	0	0	245.51	60
978	J-Venezia 18	105.00	1	10,404	244.55	60
897	J-Talichet 1	104.83	0	0	245.31	61
447	J-36	105.00	0	0	245.58	61
612	J-190	104.74	0	0	245.37	61
616	J-191	104.64	1	10,404	245.38	61
529	J-156	104.00	0	0	245.45	61
534	J-144	104.00	0	0	245.46	61
169	J-63	104.00	1	12,485	245.51	61
121	J-32	104.00	1	20,808	245.58	61
123	J-35	104.00	1	12,485	245.58	61
973	J-Venezia 19	102.41	1	11,444	244.55	61
369	J-145	103.00	1	3,121	245.46	62
304	J-86	103.00	1	3,121	245.52	62
786	J-248	102.22	0	0	245.49	62
215	J-77	102.00	0	0	245.35	62

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Proposed Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
382	J-158	102.00	1	12,485	245.45	62
507	J-136	102.00	0	0	245.49	62
165	J-60	102.00	1	11,444	245.49	62
167	J-61	102.00	0	0	245.49	62
772	J-240	100.95	0	0	244.48	62
1148	J-Watermark 1	100.95	0	0	244.48	62
1110	J-Lake Hills 12	101.23	0	0	245.47	62
809	J-Mission Rise 5	100.08	1	11,093	244.39	62
566	J-62	101.00	0	0	245.49	63
773	J-Venezia 1	100.12	0	0	244.81	63
1053	J-Venezia 2	100.09	0	0	244.78	63
211	J-56	100.22	0	0	245.46	63
635	J-197	100.00	0	0	245.35	63
156	J-54	100.06	1	2,081	245.47	63
379	J-155	100.00	1	8,323	245.45	63
201	J-52	100.00	0	0	245.56	63
203	J-51	100.00	1	2,081	245.56	63
213	J-Venezia 3	99.00	0	0	244.72	63
812	J-Mission Rise 6	98.40	1	11,093	244.35	63
895	J-Talichet 2	99.21	0	0	245.31	63
968	J-Venezia 20	97.78	1	11,444	244.54	63
815	J-Mission Rise 7	97.32	1	11,093	244.31	64
848	J-Mission Rise 18	97.08	1	10,710	244.37	64
839	J-Mission Rise 15	96.89	1	10,710	244.32	64
702	J-Venezia 4	97.00	1	32,513	244.67	64
842	J-Mission Rise 16	96.14	1	10,710	244.32	64
688	J-209	97.00	1	5,202	245.47	64
158	J-53	97.00	1	13,525	245.49	64
192	J-50	96.50	1	1,040	245.59	65
1133	J-Venezia 24	95.33	1	16,646	244.51	65
239	J-132	95.00	0	0	244.49	65
235	J-131	95.00	0	0	244.49	65
154	J-58	96.00	1	1,040	245.49	65
629	J-196	96.00	1	13,525	245.49	65
957	J-Venezia 25	95.00	1	10,404	244.51	65
1168	J-Venezia TH 1	95.00	0	0	244.70	65
934	J-Talichet 6	95.60	1	3,121	245.31	65
881	J-Talichet II 1	94.95	1	5,738	244.78	65
806	J-Mission Rise 4	94.43	1	11,093	244.44	65
818	J-Mission Rise 8	94.12	1	11,093	244.24	65
930	J-Talichet 3	95.16	1	6,242	245.31	65
824	J-Mission Rise 10	94.09	1	6,503	244.25	65
827	J-Mission Rise 11	94.06	1	6,503	244.26	65
932	J-Talichet 4	95.07	1	3,121	245.31	65
465	J-78	95.00	0	0	245.35	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Proposed Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
524	J-154	95.00	0	0	245.45	65
607	J-189	95.00	0	0	245.49	65
186	J-49	95.08	1	1,040	245.67	65
1166	J-Venezia TH 2	94.00	1	6,885	244.67	65
1043	J-324	95.01	0	0	245.76	65
1041	J-323	94.88	0	0	245.77	65
255	J-79	94.00	1	4,162	245.35	65
704	J-Venezia 5	93.00	0	0	244.57	66
1100	J-Golden Hills 1	92.58	1	232,178	244.21	66
963	J-Venezia 21	92.72	1	13,525	244.54	66
251	J-123	93.00	0	0	245.35	66
386	J-153	93.00	1	6,242	245.45	66
388	J-159	93.00	0	0	245.45	66
367	J-146	93.00	1	3,121	245.45	66
581	J-184	93.00	0	0	245.52	66
194	J-66	93.00	1	3,121	245.57	66
879	J-Talichet II 2	92.00	1	2,295	244.77	66
776	J-Cedar Creek 1	91.69	1	65,408	244.55	66
1112	J-Thompson Grove 1	92.46	1	104,040	245.45	66
1102	J-Lake Hills 11	92.23	0	0	245.41	66
1195	J-Lake Hills 10	92.00	1	27,158	245.40	66
116	J-28	92.00	0	0	245.58	66
119	J-29	92.00	1	12,485	245.58	66
1203	J-Venezia TH 3	91.00	1	8,798	244.64	66
730	J-Venezia 30	90.81	0	0	244.54	67
1138	J-Venezia 32	90.74	1	4,162	244.56	67
845	J-Mission Rise 17	90.35	1	10,710	244.34	67
883	J-Talichet 14	90.88	1	3,121	244.90	67
1142	J-Mission Rise 1	90.47	0	0	244.57	67
836	J-Mission Rise 14	90.07	1	6,503	244.30	67
724	J-220	90.23	0	0	244.49	67
1035	J-Venezia 34	90.25	1	2,081	244.56	67
475	J-120	91.00	0	0	245.37	67
404	J-162	91.00	0	0	245.44	67
245	J-134	90.00	1	10,404	244.48	67
241	J-133	90.00	0	0	244.48	67
720	J-Venezia 26	90.00	1	5,202	244.51	67
1152	J-Mission Rise 22	89.96	0	0	244.48	67
936	J-Talichet 5	90.78	1	5,202	245.31	67
152	J-76	91.00	1	8,323	245.55	67
800	J-Mission Rise 2	89.97	1	10,710	244.55	67
803	J-Mission Rise 3	89.89	1	10,710	244.49	67
133	J-33	91.00	0	0	245.64	67
876	J-The Reserve 14	89.84	0	0	244.66	67
1059	J-Talichet 13	90.07	1	1,040	244.92	67

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Proposed Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
830	J-Mission Rise 12	89.37	1	6,503	244.27	67
1084	J-The Reserve 13	89.69	2	126,225	244.63	67
1081	J-The Reserve 12	89.60	1	2,295	244.63	67
556	J-174	91.00	0	0	246.15	67
1078	J-The Reserve 11	89.47	1	2,295	244.63	67
1075	J-The Reserve 10	89.34	2	132,983	244.63	67
732	J-Venezia 31	89.16	1	6,242	244.56	67
480	J-118	90.00	0	0	245.41	67
268	J-81	90.00	1	4,162	245.41	67
400	J-160	90.00	1	16,646	245.44	67
597	J-187	90.00	0	0	245.57	67
179	J-67	90.00	0	0	245.57	67
893	J-Talichet 7	89.60	1	12,485	245.33	67
833	J-Mission Rise 13	88.53	1	6,503	244.28	67
432	J-44	90.00	0	0	245.76	67
436	J-45	90.00	0	0	245.77	67
762	J-234	88.95	0	0	244.74	67
1004	J-Venezia 12	88.68	1	4,162	244.49	67
1129	J-Venezia 10	88.52	1	11,444	244.49	67
851	J-Mission Rise 19	88.36	1	10,710	244.39	68
1064	J-329	88.47	0	0	244.59	68
585	J-185	90.00	0	0	246.19	68
885	J-Talichet 12	88.74	1	2,081	244.94	68
624	J-194	88.00	1	3,121	244.49	68
173	J-64	89.00	0	0	245.55	68
198	J-65	89.00	1	5,202	245.56	68
452	J-41	89.00	1	5,202	245.65	68
1157	J-330	87.56	0	0	244.58	68
821	J-Mission Rise 9	87.13	1	6,503	244.25	68
257	J-80	88.00	1	4,162	245.38	68
407	J-163	88.00	1	3,121	245.44	68
914	J-Talichet 17	87.41	1	5,202	244.92	68
602	J-188	88.00	0	0	245.55	68
738	J-Venezia 33	87.00	1	6,242	244.56	68
873	J-The Reserve 8	86.99	0	0	244.57	68
126	J-30	88.00	0	0	245.59	68
130	J-31	88.00	0	0	245.60	68
1017	J-Venezia 6	86.57	0	0	244.51	68
994	J-Venezia 22	86.52	1	4,162	244.51	68
712	J-215	86.31	0	0	244.49	68
1119	J-Westminster 1	87.02	1	133,875	245.42	69
402	J-161	87.00	0	0	245.44	69
426	J-168	87.00	0	0	245.44	69
706	J-Venezia 7	86.00	0	0	244.51	69
301	J-85	87.00	0	0	245.52	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Proposed Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
176	J-75	87.00	0	0	245.57	69
759	J-The Reserve 9	86.74	1	8,798	245.50	69
797	J-251	85.79	0	0	244.61	69
887	J-Talichet 11	86.01	1	31,860	245.00	69
793	J-Venezia 35	85.52	0	0	244.58	69
857	J-Mission Rise 21	85.31	1	10,710	244.44	69
854	J-Mission Rise 20	85.00	1	10,710	244.41	69
790	J-249	85.17	0	0	244.60	69
952	J-Venezia 29	85.03	1	5,202	244.49	69
621	J-193	85.00	1	1,040	244.49	69
1095	J-The Reserve 6	85.05	1	92,565	244.61	69
1097	J-The Reserve 7	85.00	1	92,565	244.58	69
181	J-68	86.00	0	0	245.59	69
1093	J-The Reserve 5	85.01	1	3,825	244.64	69
775	J-The Reserve 1	85.21	0	0	244.86	69
1091	J-The Reserve 4	85.00	1	3,825	244.66	69
1089	J-The Reserve 3	85.01	1	25,628	244.72	69
1087	J-The Reserve 2	85.05	1	32,895	244.83	69
910	J-Talichet 15	85.00	1	11,444	244.91	69
912	J-Talichet 16	85.00	1	7,283	244.91	69
677	J-WTP1-6	86.25	0	0	246.31	69
678	J-WTP1-5	86.25	0	0	246.31	69
679	J-WTP1-4	86.25	0	0	246.31	69
889	J-Talichet 10	85.00	1	3,121	245.20	69
470	J-122	85.00	0	0	245.34	69
891	J-Talichet 8	85.00	1	18,727	245.36	69
923	J-Talichet 9	85.00	1	3,121	245.37	69
728	J-Venezia 28	84.00	0	0	244.49	69
926	J-295	85.00	1	3,121	245.49	69
549	J-Mitchell 1	85.00	1	13,525	245.50	69
592	J-186	85.00	1	7,283	245.55	69
1205	J-Venezia TH 4	84.00	1	27,540	244.64	70
143	J-71	85.00	0	0	245.68	70
141	J-70	85.00	0	0	245.70	70
769	J-238	85.00	0	0	246.14	70
1183	J-Lake Hills 3	84.00	1	27,540	245.45	70
722	J-Venezia 27	83.00	1	11,444	244.49	70
718	J-Venezia 11	83.00	1	8,323	244.49	70
554	J-173	84.00	0	0	245.54	70
135	J-34	84.00	1	10,404	245.60	70
429	J-43	84.00	1	9,364	245.66	70
139	J-42	84.00	0	0	245.67	70
1012	J-Venezia 9	82.26	1	6,242	244.50	70
249	J-121	83.00	1	5,202	245.34	70
754	J-229	82.11	0	0	244.49	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Proposed Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
422	J-150	83.00	1	3,121	245.44	70
393	J-151	83.00	1	6,242	245.44	70
391	J-152	83.00	0	0	245.44	70
708	J-Venezia 8	82.00	1	2,081	244.50	70
457	J-125	82.31	1	10,404	245.12	70
1032	J-Venezia 17	81.62	1	2,081	244.49	70
1023	J-Venezia 13	81.45	1	3,121	244.50	71
756	J-Whispering Hills 1	81.37	0	0	244.49	71
1184	J-Lake Hills 4	82.00	1	27,540	245.41	71
264	J-117	82.00	0	0	245.41	71
716	J-Venezia 16	81.00	1	4,162	244.49	71
1170	J-369	82.00	0	0	245.50	71
485	J-108	82.00	0	0	245.51	71
552	J-172	82.00	0	0	245.52	71
757	J-231	80.71	0	0	244.50	71
999	J-Venezia 14	80.56	1	4,162	244.49	71
365	J-147	81.00	1	3,121	245.45	71
273	J-113	81.00	0	0	245.46	71
275	J-82	81.00	0	0	245.47	71
1177	J-Lake Hills 2	81.00	2	169,575	245.47	71
710	J-Venezia 15	80.00	1	3,121	244.49	71
150	J-74	81.00	1	2,081	245.56	71
1188	J-Lake Hills 6	80.00	1	27,158	245.39	72
1214	J-Venezia S	79.00	0	0	244.58	72
1192	J-Lake Hills 7	79.00	1	27,158	245.39	72
259	J-119	78.00	1	11,444	245.37	72
231	J-130	77.00	0	0	244.49	72
219	J-Island 1	77.00	1	2,081	244.94	73
419	J-149	77.00	0	0	245.45	73
289	J-84	77.00	0	0	245.52	73
280	J-112	77.00	0	0	245.55	73
112	J-72	77.00	0	0	245.56	73
148	J-73	77.00	0	0	245.56	73
1196	J-Lake Hills 9	76.00	1	27,540	245.40	73
363	J-148	76.00	0	0	245.45	73
360	J-138	76.00	1	11,444	245.45	73
227	J-129	75.00	1	20,808	244.65	73
1104	J-Drake Point 1	75.00	1	67,703	245.14	74
1187	J-Lake Hills 5	75.00	1	27,158	245.40	74
409	J-164	75.00	1	12,485	245.44	74
1114	J-Cypress Point 1	73.64	1	21,038	245.42	74
413	J-166	72.00	0	0	245.44	75
1068	J-Whispering Hills 3	70.72	1	47,813	244.47	75
1189	J-Lake Hills 8	71.00	1	27,158	245.39	75
327	J-101	71.00	1	13,525	245.50	75

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Proposed Interconnect

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1116	J-Cypress Point 2	70.02	1	21,038	245.42	76
346	J-137	70.00	1	13,525	245.47	76
646	J-200	70.00	0	0	245.48	76
343	J-135	70.00	1	13,525	245.48	76
330	J-100	70.00	1	7,283	245.50	76
313	J-103	70.00	1	19,768	245.50	76
519	J-169	69.00	0	0	245.45	76
262	J-116	68.00	1	15,606	245.41	77
417	J-167	68.00	1	8,323	245.44	77
292	J-110	68.00	0	0	245.51	77
217	J-124	67.00	0	0	245.29	77
299	J-107	67.00	1	13,525	245.50	77
1070	J-Whispering Hills 4	65.00	1	11,858	244.47	78
310	J-105	66.00	1	14,566	245.50	78
225	J-Island 3	65.00	1	9,364	244.93	78
411	J-165	64.00	1	5,202	245.31	78
271	J-115	64.00	1	9,364	245.46	79
286	J-111	64.00	1	1,040	245.50	79
296	J-109	64.00	0	0	245.51	79
221	J-Island 2	62.00	1	4,162	244.93	79

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - Existing Conditions

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
668	J-WTP1-3	81.00	0	0	83.00	1
666	J-WTP1-2	81.00	0	0	83.00	1
664	J-WTP1-1	81.00	0	0	83.00	1
1248	J-WTP3-1	140.00	0	0	142.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	0	0	245.21	37
68	J-Mission Inn 6	154.00	1	16,646	245.56	40
568	J-Mission Inn 5	154.00	0	0	245.56	40
355	J-140	152.00	0	0	245.51	40
44	J-8	152.00	1	1,040	245.56	40
41	J-6	152.00	0	0	245.56	40
66	J-Mission Inn 10	152.00	0	0	245.56	40
46	J-9	151.00	0	0	245.57	41
74	J-Mission Inn 9	150.00	1	4,162	245.56	41
78	J-Mission Inn 4	150.00	0	0	245.56	41
82	J-Mission Inn 3	149.00	0	0	245.56	42
86	J-Mission Inn 2	149.00	1	15,606	245.56	42
70	J-Mission Inn 7	148.00	1	8,323	245.56	42
48	J-Mission Inn 1	148.00	0	0	245.57	42
764	J-Whispering Hills 2	146.07	0	0	245.18	43
374	J-141	146.00	0	0	245.48	43
72	J-Mission Inn 8	146.00	1	4,162	245.56	43
866	J-Watermark 4	145.57	0	0	245.24	43
351	J-94	144.00	0	0	245.55	44
539	J-142	141.00	0	0	245.47	45
1217	J-386	141.00	0	0	245.57	45
1122	J-354	140.00	0	0	245.61	46
1178	J-Lake Hills 1	140.00	0	0	245.62	46
1245	J-WTP3-2	140.00	0	0	245.62	46
863	J-Watermark 3	135.17	0	0	245.26	48
1162	J-365	135.00	0	0	245.19	48
50	J-Mission Inn 11	134.00	0	0	245.57	48
640	J-198	131.95	0	0	245.55	49
90	J-Mission Inn 14	131.00	0	0	245.57	50
94	J-Mission Inn 15	130.00	0	0	245.57	50
92	J-23	130.00	0	0	245.57	50
96	J-25	130.00	0	0	245.57	50
114	J-27	129.00	1	15,606	245.57	50
338	J-93	128.00	0	0	245.55	51
100	J-26	128.00	1	3,121	245.57	51
442	J-7	128.00	0	0	245.60	51
37	J-5	128.00	0	0	245.61	51
31	J-2	128.00	0	0	245.61	51
35	J-3	128.00	0	0	245.61	51
33	J-4	128.00	0	0	245.61	51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - Existing Conditions

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1108	J-Drake Point 3	126.24	0	0	245.61	52
52	J-Mission Inn 12	125.00	0	0	245.55	52
54	J-Mission Inn 13	124.00	1	37,454	245.55	53
544	J-170	123.00	0	0	245.46	53
502	J-98	122.00	0	0	245.52	53
490	J-102	122.00	0	0	245.53	53
512	J-96	121.00	0	0	245.49	54
104	J-92	121.00	0	0	245.56	54
102	J-38	121.00	0	0	245.57	54
495	J-90	120.00	0	0	245.55	54
325	J-89	120.00	0	0	245.55	54
322	J-88	120.00	0	0	245.55	54
1106	J-Drake Point 2	120.00	0	0	245.61	54
643	J-199	119.72	0	0	245.49	54
340	J-97	119.00	1	14,566	245.50	55
348	J-95	118.00	1	17,687	245.48	55
576	J-183	118.00	0	0	245.55	55
377	J-157	117.00	1	12,485	245.46	56
372	J-143	117.00	1	4,162	245.46	56
315	J-104	117.00	0	0	245.52	56
860	J-Watermark 2	116.57	0	0	245.28	56
108	J-39	116.00	0	0	245.56	56
110	J-40	116.00	1	11,444	245.56	56
319	J-87	115.00	0	0	245.53	56
332	J-99	113.00	1	10,404	245.50	57
334	J-91	113.00	1	4,162	245.55	57
106	J-37	112.00	1	5,202	245.57	58
357	J-139	107.00	1	15,606	245.47	60
306	J-106	106.00	0	0	245.52	60
983	J-Venezia 23	105.00	1	12,485	245.17	61
978	J-Venezia 18	105.00	1	10,404	245.23	61
447	J-36	105.00	0	0	245.58	61
612	J-190	104.74	0	0	245.44	61
616	J-191	104.64	1	10,404	245.45	61
897	J-Talichet 1	104.83	0	0	245.67	61
529	J-156	104.00	0	0	245.45	61
534	J-144	104.00	0	0	245.46	61
169	J-63	104.00	1	12,485	245.52	61
121	J-32	104.00	1	20,808	245.58	61
123	J-35	104.00	1	12,485	245.58	61
369	J-145	103.00	1	3,121	245.46	62
304	J-86	103.00	1	3,121	245.53	62
973	J-Venezia 19	102.41	1	11,444	245.21	62
786	J-248	102.22	0	0	245.51	62
215	J-77	102.00	0	0	245.43	62

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - Existing Conditions

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
382	J-158	102.00	1	12,485	245.45	62
507	J-136	102.00	0	0	245.49	62
165	J-60	102.00	1	11,444	245.51	62
167	J-61	102.00	0	0	245.51	62
772	J-240	100.95	0	0	245.31	62
1148	J-Watermark 1	100.95	0	0	245.31	62
1110	J-Lake Hills 12	101.23	0	0	245.62	62
566	J-62	101.00	0	0	245.51	63
211	J-56	100.22	0	0	245.49	63
635	J-197	100.00	0	0	245.43	63
156	J-54	100.06	1	2,081	245.49	63
379	J-155	100.00	1	8,323	245.45	63
773	J-Venezia 1	100.12	0	0	245.59	63
1053	J-Venezia 2	100.09	0	0	245.55	63
201	J-52	100.00	0	0	245.56	63
203	J-51	100.00	1	2,081	245.56	63
809	J-Mission Rise 5	100.08	0	0	245.66	63
895	J-Talichet 2	99.21	0	0	245.67	63
213	J-Venezia 3	99.00	0	0	245.49	63
812	J-Mission Rise 6	98.40	0	0	245.64	64
968	J-Venezia 20	97.78	1	11,444	245.18	64
815	J-Mission Rise 7	97.32	0	0	245.63	64
848	J-Mission Rise 18	97.08	0	0	245.41	64
702	J-Venezia 4	97.00	1	32,513	245.44	64
688	J-209	97.00	1	5,202	245.50	64
158	J-53	97.00	1	13,525	245.51	64
839	J-Mission Rise 15	96.89	0	0	245.47	64
192	J-50	96.50	1	1,040	245.59	65
842	J-Mission Rise 16	96.14	0	0	245.45	65
154	J-58	96.00	1	1,040	245.51	65
629	J-196	96.00	1	13,525	245.51	65
1133	J-Venezia 24	95.33	1	16,646	245.17	65
934	J-Talichet 6	95.60	1	3,121	245.67	65
239	J-132	95.00	0	0	245.16	65
235	J-131	95.00	0	0	245.16	65
957	J-Venezia 25	95.00	1	10,404	245.17	65
465	J-78	95.00	0	0	245.44	65
524	J-154	95.00	0	0	245.45	65
1168	J-Venezia TH 1	95.00	0	0	245.48	65
607	J-189	95.00	0	0	245.51	65
930	J-Talichet 3	95.16	1	6,242	245.67	65
186	J-49	95.08	1	1,040	245.66	65
932	J-Talichet 4	95.07	1	3,121	245.67	65
881	J-Talichet II 1	94.95	0	0	245.67	65
1043	J-324	95.01	0	0	245.73	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - Existing Conditions

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1041	J-323	94.88	0	0	245.74	65
806	J-Mission Rise 4	94.43	0	0	245.68	65
255	J-79	94.00	1	4,162	245.44	66
1166	J-Venezia TH 2	94.00	0	0	245.45	66
824	J-Mission Rise 10	94.09	0	0	245.57	66
827	J-Mission Rise 11	94.06	0	0	245.55	66
818	J-Mission Rise 8	94.12	0	0	245.61	66
704	J-Venezia 5	93.00	0	0	245.26	66
251	J-123	93.00	0	0	245.43	66
963	J-Venezia 21	92.72	1	13,525	245.17	66
386	J-153	93.00	1	6,242	245.45	66
388	J-159	93.00	0	0	245.45	66
367	J-146	93.00	1	3,121	245.45	66
581	J-184	93.00	0	0	245.53	66
194	J-66	93.00	1	3,121	245.57	66
1100	J-Golden Hills 1	92.58	0	0	245.61	66
1112	J-Thompson Grove 1	92.46	0	0	245.62	66
1102	J-Lake Hills 11	92.23	0	0	245.61	66
116	J-28	92.00	0	0	245.57	66
119	J-29	92.00	1	12,485	245.57	66
1195	J-Lake Hills 10	92.00	0	0	245.61	66
879	J-Talichet II 2	92.00	0	0	245.67	66
776	J-Cedar Creek 1	91.69	0	0	245.74	67
730	J-Venezia 30	90.81	0	0	245.17	67
1138	J-Venezia 32	90.74	1	4,162	245.17	67
475	J-120	91.00	0	0	245.44	67
404	J-162	91.00	0	0	245.45	67
1203	J-Venezia TH 3	91.00	0	0	245.45	67
152	J-76	91.00	1	8,323	245.56	67
133	J-33	91.00	0	0	245.63	67
883	J-Talichet 14	90.88	1	3,121	245.67	67
936	J-Talichet 5	90.78	1	5,202	245.67	67
1035	J-Venezia 34	90.25	1	2,081	245.17	67
556	J-174	91.00	0	0	245.91	67
724	J-220	90.23	0	0	245.16	67
845	J-Mission Rise 17	90.35	0	0	245.43	67
245	J-134	90.00	1	10,404	245.16	67
241	J-133	90.00	0	0	245.16	67
720	J-Venezia 26	90.00	1	5,202	245.17	67
1142	J-Mission Rise 1	90.47	0	0	245.74	67
1152	J-Mission Rise 22	89.96	0	0	245.33	67
836	J-Mission Rise 14	90.07	0	0	245.49	67
400	J-160	90.00	1	16,646	245.45	67
480	J-118	90.00	0	0	245.46	67
268	J-81	90.00	1	4,162	245.46	67

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - Existing Conditions

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
597	J-187	90.00	0	0	245.57	67
179	J-67	90.00	0	0	245.58	67
1059	J-Talichet 13	90.07	1	1,040	245.67	67
876	J-The Reserve 14	89.84	0	0	245.47	67
432	J-44	90.00	0	0	245.74	67
436	J-45	90.00	0	0	245.74	67
800	J-Mission Rise 2	89.97	0	0	245.72	67
803	J-Mission Rise 3	89.89	0	0	245.70	67
1084	J-The Reserve 13	89.69	0	0	245.51	67
585	J-185	90.00	0	0	245.92	67
1081	J-The Reserve 12	89.60	0	0	245.55	67
732	J-Venezia 31	89.16	1	6,242	245.17	67
893	J-Talichet 7	89.60	1	12,485	245.68	68
1078	J-The Reserve 11	89.47	0	0	245.59	68
830	J-Mission Rise 12	89.37	0	0	245.53	68
1075	J-The Reserve 10	89.34	0	0	245.63	68
1004	J-Venezia 12	88.68	1	4,162	245.17	68
173	J-64	89.00	0	0	245.56	68
198	J-65	89.00	1	5,202	245.56	68
452	J-41	89.00	1	5,202	245.64	68
1129	J-Venezia 10	88.52	1	11,444	245.17	68
762	J-234	88.95	0	0	245.67	68
1064	J-329	88.47	0	0	245.22	68
885	J-Talichet 12	88.74	1	2,081	245.67	68
833	J-Mission Rise 13	88.53	0	0	245.51	68
851	J-Mission Rise 19	88.36	0	0	245.39	68
624	J-194	88.00	1	3,121	245.17	68
257	J-80	88.00	1	4,162	245.45	68
407	J-163	88.00	1	3,121	245.45	68
602	J-188	88.00	0	0	245.55	68
126	J-30	88.00	0	0	245.58	68
130	J-31	88.00	0	0	245.59	68
1157	J-330	87.56	0	0	245.28	68
738	J-Venezia 33	87.00	1	6,242	245.17	68
914	J-Talichet 17	87.41	1	5,202	245.67	68
873	J-The Reserve 8	86.99	0	0	245.34	69
402	J-161	87.00	0	0	245.45	69
426	J-168	87.00	0	0	245.45	69
821	J-Mission Rise 9	87.13	0	0	245.59	69
301	J-85	87.00	0	0	245.53	69
176	J-75	87.00	0	0	245.57	69
1119	J-Westminster 1	87.02	0	0	245.62	69
1017	J-Venezia 6	86.57	0	0	245.19	69
994	J-Venezia 22	86.52	1	4,162	245.18	69
712	J-215	86.31	0	0	245.18	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - Existing Conditions

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
759	J-The Reserve 9	86.74	0	0	245.73	69
706	J-Venezia 7	86.00	0	0	245.19	69
797	J-251	85.79	0	0	245.32	69
181	J-68	86.00	0	0	245.59	69
793	J-Venezia 35	85.52	0	0	245.17	69
887	J-Talichet 11	86.01	1	31,860	245.67	69
677	J-WTP1-6	86.25	0	0	245.95	69
678	J-WTP1-5	86.25	0	0	245.95	69
679	J-WTP1-4	86.25	0	0	245.95	69
790	J-249	85.17	0	0	245.17	69
857	J-Mission Rise 21	85.31	0	0	245.35	69
952	J-Venezia 29	85.03	1	5,202	245.16	69
621	J-193	85.00	1	1,040	245.16	69
854	J-Mission Rise 20	85.00	0	0	245.37	69
1097	J-The Reserve 7	85.00	0	0	245.40	69
1095	J-The Reserve 6	85.05	0	0	245.46	69
470	J-122	85.00	0	0	245.43	69
1093	J-The Reserve 5	85.01	0	0	245.52	69
775	J-The Reserve 1	85.21	0	0	245.76	69
1091	J-The Reserve 4	85.00	0	0	245.58	69
1089	J-The Reserve 3	85.01	0	0	245.64	69
1087	J-The Reserve 2	85.05	0	0	245.70	70
910	J-Talichet 15	85.00	1	11,444	245.67	70
912	J-Talichet 16	85.00	1	7,283	245.67	70
143	J-71	85.00	0	0	245.67	70
141	J-70	85.00	0	0	245.68	70
889	J-Talichet 10	85.00	1	3,121	245.69	70
891	J-Talichet 8	85.00	1	18,727	245.70	70
923	J-Talichet 9	85.00	1	3,121	245.71	70
549	J-Mitchell 1	85.00	1	13,525	245.73	70
926	J-295	85.00	1	3,121	245.74	70
592	J-186	85.00	1	7,283	245.75	70
769	J-238	85.00	0	0	245.84	70
728	J-Venezia 28	84.00	0	0	245.16	70
1205	J-Venezia TH 4	84.00	0	0	245.45	70
135	J-34	84.00	1	10,404	245.60	70
1183	J-Lake Hills 3	84.00	0	0	245.62	70
429	J-43	84.00	1	9,364	245.64	70
139	J-42	84.00	0	0	245.66	70
554	J-173	84.00	0	0	245.75	70
722	J-Venezia 27	83.00	1	11,444	245.16	70
718	J-Venezia 11	83.00	1	8,323	245.17	70
249	J-121	83.00	1	5,202	245.43	70
422	J-150	83.00	1	3,121	245.45	70
393	J-151	83.00	1	6,242	245.45	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - Existing Conditions

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
391	J-152	83.00	0	0	245.45	70
1012	J-Venezia 9	82.26	1	6,242	245.18	70
457	J-125	82.31	1	10,404	245.34	71
754	J-229	82.11	0	0	245.18	71
708	J-Venezia 8	82.00	1	2,081	245.18	71
264	J-117	82.00	0	0	245.46	71
485	J-108	82.00	0	0	245.52	71
1032	J-Venezia 17	81.62	1	2,081	245.18	71
1184	J-Lake Hills 4	82.00	0	0	245.62	71
1170	J-369	82.00	0	0	245.73	71
1023	J-Venezia 13	81.45	1	3,121	245.18	71
552	J-172	82.00	0	0	245.74	71
756	J-Whispering Hills 1	81.37	0	0	245.18	71
716	J-Venezia 16	81.00	1	4,162	245.18	71
365	J-147	81.00	1	3,121	245.45	71
757	J-231	80.71	0	0	245.18	71
273	J-113	81.00	0	0	245.50	71
275	J-82	81.00	0	0	245.50	71
150	J-74	81.00	1	2,081	245.56	71
999	J-Venezia 14	80.56	1	4,162	245.18	71
1177	J-Lake Hills 2	81.00	0	0	245.62	71
710	J-Venezia 15	80.00	1	3,121	245.18	71
1188	J-Lake Hills 6	80.00	0	0	245.62	72
1214	J-Venezia S	79.00	0	0	245.28	72
1192	J-Lake Hills 7	79.00	0	0	245.62	72
259	J-119	78.00	1	11,444	245.44	72
231	J-130	77.00	0	0	245.18	73
219	J-Island 1	77.00	1	2,081	245.27	73
419	J-149	77.00	0	0	245.45	73
289	J-84	77.00	0	0	245.54	73
280	J-112	77.00	0	0	245.56	73
112	J-72	77.00	0	0	245.56	73
148	J-73	77.00	0	0	245.56	73
363	J-148	76.00	0	0	245.46	73
360	J-138	76.00	1	11,444	245.46	73
1196	J-Lake Hills 9	76.00	0	0	245.61	73
227	J-129	75.00	1	20,808	245.20	74
409	J-164	75.00	1	12,485	245.44	74
1104	J-Drake Point 1	75.00	0	0	245.61	74
1187	J-Lake Hills 5	75.00	0	0	245.62	74
1114	J-Cypress Point 1	73.64	0	0	245.62	74
413	J-166	72.00	0	0	245.45	75
1068	J-Whispering Hills 3	70.72	0	0	245.18	75
327	J-101	71.00	1	13,525	245.50	76
1189	J-Lake Hills 8	71.00	0	0	245.61	76

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - Existing Conditions

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
346	J-137	70.00	1	13,525	245.48	76
646	J-200	70.00	0	0	245.49	76
343	J-135	70.00	1	13,525	245.49	76
330	J-100	70.00	1	7,283	245.50	76
313	J-103	70.00	1	19,768	245.51	76
1116	J-Cypress Point 2	70.02	0	0	245.62	76
519	J-169	69.00	0	0	245.45	76
417	J-167	68.00	1	8,323	245.45	77
262	J-116	68.00	1	15,606	245.46	77
292	J-110	68.00	0	0	245.53	77
217	J-124	67.00	0	0	245.41	77
299	J-107	67.00	1	13,525	245.52	77
310	J-105	66.00	1	14,566	245.51	78
1070	J-Whispering Hills 4	65.00	0	0	245.18	78
225	J-Island 3	65.00	1	9,364	245.26	78
411	J-165	64.00	1	5,202	245.32	78
271	J-115	64.00	1	9,364	245.49	79
286	J-111	64.00	1	1,040	245.52	79
296	J-109	64.00	0	0	245.52	79
221	J-Island 2	62.00	1	4,162	245.27	79

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1248	J-WTP3-1	140.00	0	0	141.73	1
668	J-WTP1-3	81.00	0	0	82.98	1
666	J-WTP1-2	81.00	0	0	82.98	1
664	J-WTP1-1	81.00	0	0	82.98	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	1	60,053	244.53	37
68	J-Mission Inn 6	154.00	2	2,176,646	240.75	38
568	J-Mission Inn 5	154.00	0	0	242.09	38
66	J-Mission Inn 10	152.00	0	0	242.01	39
74	J-Mission Inn 9	150.00	1	4,162	240.75	39
70	J-Mission Inn 7	148.00	1	8,323	240.75	40
355	J-140	152.00	0	0	245.63	41
44	J-8	152.00	1	1,040	245.72	41
78	J-Mission Inn 4	150.00	0	0	243.72	41
41	J-6	152.00	0	0	245.74	41
46	J-9	151.00	0	0	245.64	41
72	J-Mission Inn 8	146.00	1	4,162	240.75	41
82	J-Mission Inn 3	149.00	0	0	243.78	41
86	J-Mission Inn 2	149.00	1	15,606	243.95	41
48	J-Mission Inn 1	148.00	0	0	245.58	42
764	J-Whispering Hills 2	146.07	0	0	244.54	43
866	J-Watermark 4	145.57	1	9,180	244.53	43
374	J-141	146.00	0	0	245.57	43
351	J-94	144.00	0	0	245.63	44
539	J-142	141.00	0	0	245.56	45
1217	J-386	141.00	0	0	245.82	45
863	J-Watermark 3	135.17	1	8,415	244.53	47
1162	J-365	135.00	0	0	244.53	47
1122	J-354	140.00	0	0	250.12	48
50	J-Mission Inn 11	134.00	0	0	244.29	48
1178	J-Lake Hills 1	140.00	0	0	251.40	48
1245	J-WTP3-2	140.00	0	0	251.65	48
640	J-198	131.95	0	0	245.59	49
90	J-Mission Inn 14	131.00	0	0	245.41	50
94	J-Mission Inn 15	130.00	0	0	245.48	50
92	J-23	130.00	0	0	245.57	50
96	J-25	130.00	0	0	245.57	50
114	J-27	129.00	1	15,606	245.57	50
100	J-26	128.00	1	3,121	245.57	51
338	J-93	128.00	0	0	245.58	51
52	J-Mission Inn 12	125.00	0	0	244.28	52
54	J-Mission Inn 13	124.00	1	37,454	244.27	52
442	J-7	128.00	0	0	249.53	53
37	J-5	128.00	0	0	249.70	53
31	J-2	128.00	0	0	249.93	53

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
33	J-4	128.00	0	0	249.93	53
35	J-3	128.00	0	0	249.94	53
544	J-170	123.00	0	0	245.54	53
1108	J-Drake Point 3	126.24	1	67,320	249.66	53
490	J-102	122.00	0	0	245.55	53
502	J-98	122.00	0	0	245.56	53
512	J-96	121.00	0	0	245.54	54
102	J-38	121.00	0	0	245.57	54
104	J-92	121.00	0	0	245.57	54
495	J-90	120.00	0	0	245.57	54
325	J-89	120.00	0	0	245.57	54
322	J-88	120.00	0	0	245.57	54
643	J-199	119.72	0	0	245.54	54
340	J-97	119.00	1	14,566	245.54	55
348	J-95	118.00	1	17,687	245.54	55
576	J-183	118.00	0	0	245.56	55
860	J-Watermark 2	116.57	1	8,415	244.54	55
377	J-157	117.00	1	12,485	245.53	56
372	J-143	117.00	1	4,162	245.54	56
315	J-104	117.00	0	0	245.54	56
108	J-39	116.00	0	0	245.58	56
110	J-40	116.00	1	11,444	245.58	56
1106	J-Drake Point 2	120.00	1	67,703	249.67	56
319	J-87	115.00	0	0	245.55	56
332	J-99	113.00	1	10,404	245.54	57
334	J-91	113.00	1	4,162	245.57	57
106	J-37	112.00	1	5,202	245.58	58
357	J-139	107.00	1	15,606	245.54	60
306	J-106	106.00	0	0	245.54	60
983	J-Venezia 23	105.00	1	12,485	244.56	60
978	J-Venezia 18	105.00	1	10,404	244.61	60
897	J-Talichet 1	104.83	0	0	245.36	61
447	J-36	105.00	0	0	245.59	61
612	J-190	104.74	0	0	245.40	61
616	J-191	104.64	1	10,404	245.41	61
529	J-156	104.00	0	0	245.53	61
169	J-63	104.00	1	12,485	245.54	61
534	J-144	104.00	0	0	245.54	61
121	J-32	104.00	1	20,808	245.59	61
123	J-35	104.00	1	12,485	245.59	61
973	J-Venezia 19	102.41	1	11,444	244.60	62
369	J-145	103.00	1	3,121	245.53	62
304	J-86	103.00	1	3,121	245.55	62
786	J-248	102.22	0	0	245.51	62
215	J-77	102.00	0	0	245.38	62

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
165	J-60	102.00	1	11,444	245.52	62
167	J-61	102.00	0	0	245.52	62
382	J-158	102.00	1	12,485	245.53	62
507	J-136	102.00	0	0	245.54	62
772	J-240	100.95	0	0	244.54	62
1148	J-Watermark 1	100.95	0	0	244.54	62
809	J-Mission Rise 5	100.08	1	11,093	244.45	62
566	J-62	101.00	0	0	245.52	63
773	J-Venezia 1	100.12	0	0	244.87	63
1053	J-Venezia 2	100.09	0	0	244.83	63
211	J-56	100.22	0	0	245.49	63
635	J-197	100.00	0	0	245.38	63
156	J-54	100.06	1	2,081	245.49	63
379	J-155	100.00	1	8,323	245.53	63
201	J-52	100.00	0	0	245.59	63
203	J-51	100.00	1	2,081	245.59	63
213	J-Venezia 3	99.00	0	0	244.77	63
812	J-Mission Rise 6	98.40	1	11,093	244.41	63
895	J-Talichet 2	99.21	0	0	245.37	63
968	J-Venezia 20	97.78	1	11,444	244.60	64
815	J-Mission Rise 7	97.32	1	11,093	244.37	64
848	J-Mission Rise 18	97.08	1	10,710	244.43	64
839	J-Mission Rise 15	96.89	1	10,710	244.37	64
702	J-Venezia 4	97.00	1	32,513	244.72	64
842	J-Mission Rise 16	96.14	1	10,710	244.38	64
688	J-209	97.00	1	5,202	245.50	64
158	J-53	97.00	1	13,525	245.51	64
1110	J-Lake Hills 12	101.23	0	0	249.94	64
192	J-50	96.50	1	1,040	245.62	65
1133	J-Venezia 24	95.33	1	16,646	244.56	65
154	J-58	96.00	1	1,040	245.51	65
629	J-196	96.00	1	13,525	245.52	65
239	J-132	95.00	0	0	244.54	65
235	J-131	95.00	0	0	244.54	65
957	J-Venezia 25	95.00	1	10,404	244.56	65
1168	J-Venezia TH 1	95.00	0	0	244.75	65
934	J-Talichet 6	95.60	1	3,121	245.36	65
881	J-Talichet II 1	94.95	1	5,738	244.84	65
806	J-Mission Rise 4	94.43	1	11,093	244.49	65
818	J-Mission Rise 8	94.12	1	11,093	244.30	65
930	J-Talichet 3	95.16	1	6,242	245.37	65
824	J-Mission Rise 10	94.09	1	6,503	244.31	65
827	J-Mission Rise 11	94.06	1	6,503	244.32	65
932	J-Talichet 4	95.07	1	3,121	245.36	65
465	J-78	95.00	0	0	245.39	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
607	J-189	95.00	0	0	245.52	65
524	J-154	95.00	0	0	245.52	65
186	J-49	95.08	1	1,040	245.71	65
1166	J-Venezia TH 2	94.00	1	6,885	244.72	65
1043	J-324	95.01	0	0	245.80	65
1041	J-323	94.88	0	0	245.82	65
255	J-79	94.00	1	4,162	245.39	65
704	J-Venezia 5	93.00	0	0	244.62	66
1100	J-Golden Hills 1	92.58	1	232,178	244.27	66
963	J-Venezia 21	92.72	1	13,525	244.59	66
251	J-123	93.00	0	0	245.38	66
386	J-153	93.00	1	6,242	245.52	66
388	J-159	93.00	0	0	245.52	66
367	J-146	93.00	1	3,121	245.52	66
581	J-184	93.00	0	0	245.55	66
194	J-66	93.00	1	3,121	245.60	66
879	J-Talichet II 2	92.00	1	2,295	244.83	66
776	J-Cedar Creek 1	91.69	1	65,408	244.61	66
116	J-28	92.00	0	0	245.59	66
119	J-29	92.00	1	12,485	245.59	66
1203	J-Venezia TH 3	91.00	1	8,798	244.70	66
730	J-Venezia 30	90.81	0	0	244.59	67
1138	J-Venezia 32	90.74	1	4,162	244.62	67
845	J-Mission Rise 17	90.35	1	10,710	244.39	67
883	J-Talichet 14	90.88	1	3,121	244.96	67
1142	J-Mission Rise 1	90.47	0	0	244.63	67
836	J-Mission Rise 14	90.07	1	6,503	244.35	67
724	J-220	90.23	0	0	244.54	67
1035	J-Venezia 34	90.25	1	2,081	244.62	67
475	J-120	91.00	0	0	245.41	67
404	J-162	91.00	0	0	245.52	67
245	J-134	90.00	1	10,404	244.54	67
241	J-133	90.00	0	0	244.54	67
720	J-Venezia 26	90.00	1	5,202	244.56	67
152	J-76	91.00	1	8,323	245.58	67
1152	J-Mission Rise 22	89.96	0	0	244.54	67
936	J-Talichet 5	90.78	1	5,202	245.36	67
800	J-Mission Rise 2	89.97	1	10,710	244.61	67
803	J-Mission Rise 3	89.89	1	10,710	244.55	67
133	J-33	91.00	0	0	245.67	67
876	J-The Reserve 14	89.84	0	0	244.72	67
1059	J-Talichet 13	90.07	1	1,040	244.98	67
830	J-Mission Rise 12	89.37	1	6,503	244.32	67
1084	J-The Reserve 13	89.69	2	126,225	244.68	67
1081	J-The Reserve 12	89.60	1	2,295	244.68	67

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1078	J-The Reserve 11	89.47	1	2,295	244.68	67
556	J-174	91.00	0	0	246.22	67
1075	J-The Reserve 10	89.34	2	132,983	244.68	67
480	J-118	90.00	0	0	245.44	67
268	J-81	90.00	1	4,162	245.44	67
732	J-Venezia 31	89.16	1	6,242	244.62	67
400	J-160	90.00	1	16,646	245.52	67
597	J-187	90.00	0	0	245.60	67
179	J-67	90.00	0	0	245.60	67
893	J-Talichet 7	89.60	1	12,485	245.38	67
833	J-Mission Rise 13	88.53	1	6,503	244.34	67
432	J-44	90.00	0	0	245.81	67
436	J-45	90.00	0	0	245.82	67
762	J-234	88.95	0	0	244.80	67
1004	J-Venezia 12	88.68	1	4,162	244.55	67
1129	J-Venezia 10	88.52	1	11,444	244.55	68
851	J-Mission Rise 19	88.36	1	10,710	244.45	68
1064	J-329	88.47	0	0	244.65	68
885	J-Talichet 12	88.74	1	2,081	244.99	68
585	J-185	90.00	0	0	246.26	68
624	J-194	88.00	1	3,121	244.54	68
173	J-64	89.00	0	0	245.58	68
198	J-65	89.00	1	5,202	245.58	68
452	J-41	89.00	1	5,202	245.67	68
1157	J-330	87.56	0	0	244.63	68
821	J-Mission Rise 9	87.13	1	6,503	244.31	68
257	J-80	88.00	1	4,162	245.41	68
1112	J-Thompson Grove 1	92.46	1	104,040	249.92	68
407	J-163	88.00	1	3,121	245.52	68
914	J-Talichet 17	87.41	1	5,202	244.98	68
602	J-188	88.00	0	0	245.58	68
126	J-30	88.00	0	0	245.60	68
130	J-31	88.00	0	0	245.61	68
738	J-Venezia 33	87.00	1	6,242	244.62	68
873	J-The Reserve 8	86.99	0	0	244.62	68
1102	J-Lake Hills 11	92.23	0	0	249.97	68
1195	J-Lake Hills 10	92.00	1	27,158	249.97	68
1017	J-Venezia 6	86.57	0	0	244.57	68
994	J-Venezia 22	86.52	1	4,162	244.56	68
712	J-215	86.31	0	0	244.54	68
402	J-161	87.00	0	0	245.52	69
426	J-168	87.00	0	0	245.52	69
301	J-85	87.00	0	0	245.55	69
706	J-Venezia 7	86.00	0	0	244.56	69
176	J-75	87.00	0	0	245.59	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
759	J-The Reserve 9	86.74	1	8,798	245.56	69
797	J-251	85.79	0	0	244.66	69
887	J-Talichet 11	86.01	1	31,860	245.05	69
793	J-Venezia 35	85.52	0	0	244.63	69
857	J-Mission Rise 21	85.31	1	10,710	244.49	69
854	J-Mission Rise 20	85.00	1	10,710	244.47	69
790	J-249	85.17	0	0	244.66	69
952	J-Venezia 29	85.03	1	5,202	244.54	69
621	J-193	85.00	1	1,040	244.54	69
181	J-68	86.00	0	0	245.62	69
1095	J-The Reserve 6	85.05	1	92,565	244.67	69
1097	J-The Reserve 7	85.00	1	92,565	244.64	69
1093	J-The Reserve 5	85.01	1	3,825	244.69	69
775	J-The Reserve 1	85.21	0	0	244.92	69
1091	J-The Reserve 4	85.00	1	3,825	244.72	69
1089	J-The Reserve 3	85.01	1	25,628	244.78	69
1087	J-The Reserve 2	85.05	1	32,895	244.89	69
910	J-Talichet 15	85.00	1	11,444	244.96	69
912	J-Talichet 16	85.00	1	7,283	244.97	69
677	J-WTP1-6	86.25	0	0	246.38	69
678	J-WTP1-5	86.25	0	0	246.38	69
679	J-WTP1-4	86.25	0	0	246.38	69
889	J-Talichet 10	85.00	1	3,121	245.26	69
470	J-122	85.00	0	0	245.37	69
891	J-Talichet 8	85.00	1	18,727	245.41	69
923	J-Talichet 9	85.00	1	3,121	245.42	69
728	J-Venezia 28	84.00	0	0	244.54	69
926	J-295	85.00	1	3,121	245.55	69
549	J-Mitchell 1	85.00	1	13,525	245.56	69
592	J-186	85.00	1	7,283	245.61	69
1205	J-Venezia TH 4	84.00	1	27,540	244.69	70
143	J-71	85.00	0	0	245.72	70
141	J-70	85.00	0	0	245.74	70
769	J-238	85.00	0	0	246.21	70
722	J-Venezia 27	83.00	1	11,444	244.54	70
718	J-Venezia 11	83.00	1	8,323	244.55	70
554	J-173	84.00	0	0	245.60	70
135	J-34	84.00	1	10,404	245.62	70
429	J-43	84.00	1	9,364	245.69	70
139	J-42	84.00	0	0	245.70	70
1012	J-Venezia 9	82.26	1	6,242	244.55	70
249	J-121	83.00	1	5,202	245.37	70
754	J-229	82.11	0	0	244.54	70
422	J-150	83.00	1	3,121	245.52	70
393	J-151	83.00	1	6,242	245.52	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
391	J-152	83.00	0	0	245.52	70
708	J-Venezia 8	82.00	1	2,081	244.55	70
457	J-125	82.31	1	10,404	245.15	70
1119	J-Westminster 1	87.02	1	133,875	249.89	70
1032	J-Venezia 17	81.62	1	2,081	244.55	70
1023	J-Venezia 13	81.45	1	3,121	244.55	71
756	J-Whispering Hills 1	81.37	0	0	244.55	71
264	J-117	82.00	0	0	245.44	71
485	J-108	82.00	0	0	245.54	71
716	J-Venezia 16	81.00	1	4,162	244.55	71
1170	J-369	82.00	0	0	245.56	71
552	J-172	82.00	0	0	245.58	71
757	J-231	80.71	0	0	244.55	71
999	J-Venezia 14	80.56	1	4,162	244.55	71
273	J-113	81.00	0	0	245.49	71
275	J-82	81.00	0	0	245.49	71
365	J-147	81.00	1	3,121	245.52	71
710	J-Venezia 15	80.00	1	3,121	244.55	71
150	J-74	81.00	1	2,081	245.58	71
1214	J-Venezia S	79.00	0	0	244.63	72
1183	J-Lake Hills 3	84.00	1	27,540	250.13	72
259	J-119	78.00	1	11,444	245.40	72
231	J-130	77.00	0	0	244.55	72
219	J-Island 1	77.00	1	2,081	244.98	73
1184	J-Lake Hills 4	82.00	1	27,540	250.04	73
419	J-149	77.00	0	0	245.52	73
289	J-84	77.00	0	0	245.55	73
280	J-112	77.00	0	0	245.58	73
112	J-72	77.00	0	0	245.58	73
148	J-73	77.00	0	0	245.58	73
1177	J-Lake Hills 2	81.00	2	169,575	250.17	73
363	J-148	76.00	0	0	245.52	73
360	J-138	76.00	1	11,444	245.53	73
227	J-129	75.00	1	20,808	244.70	73
1188	J-Lake Hills 6	80.00	1	27,158	250.00	74
409	J-164	75.00	1	12,485	245.51	74
1192	J-Lake Hills 7	79.00	1	27,158	249.99	74
413	J-166	72.00	0	0	245.52	75
1068	J-Whispering Hills 3	70.72	1	47,813	244.53	75
1196	J-Lake Hills 9	76.00	1	27,540	249.97	75
327	J-101	71.00	1	13,525	245.54	76
1104	J-Drake Point 1	75.00	1	67,703	249.70	76
1187	J-Lake Hills 5	75.00	1	27,158	250.01	76
346	J-137	70.00	1	13,525	245.53	76
646	J-200	70.00	0	0	245.53	76

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
343	J-135	70.00	1	13,525	245.53	76
313	J-103	70.00	1	19,768	245.54	76
330	J-100	70.00	1	7,283	245.54	76
1114	J-Cypress Point 1	73.64	1	21,038	249.89	76
519	J-169	69.00	0	0	245.52	76
262	J-116	68.00	1	15,606	245.44	77
417	J-167	68.00	1	8,323	245.52	77
292	J-110	68.00	0	0	245.54	77
217	J-124	67.00	0	0	245.32	77
299	J-107	67.00	1	13,525	245.54	77
1189	J-Lake Hills 8	71.00	1	27,158	249.98	77
1070	J-Whispering Hills 4	65.00	1	11,858	244.52	78
310	J-105	66.00	1	14,566	245.54	78
1116	J-Cypress Point 2	70.02	1	21,038	249.89	78
225	J-Island 3	65.00	1	9,364	244.97	78
411	J-165	64.00	1	5,202	245.39	78
271	J-115	64.00	1	9,364	245.49	79
286	J-111	64.00	1	1,040	245.53	79
296	J-109	64.00	0	0	245.54	79
221	J-Island 2	62.00	1	4,162	244.97	79

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
668	J-WTP1-3	81.00	0	0	82.95	1
666	J-WTP1-2	81.00	0	0	82.95	1
664	J-WTP1-1	81.00	0	0	82.96	1
1248	J-WTP3-1	140.00	0	0	141.96	1
869	J-Watermark 5	159.36	2	1,500,053	236.89	34
30	J-WTP2-1	130.00	0	0	208.00	34
68	J-Mission Inn 6	154.00	1	16,646	245.57	40
568	J-Mission Inn 5	154.00	0	0	245.57	40
866	J-Watermark 4	145.57	1	9,180	237.68	40
355	J-140	152.00	0	0	245.50	40
44	J-8	152.00	1	1,040	245.55	40
41	J-6	152.00	0	0	245.56	40
66	J-Mission Inn 10	152.00	0	0	245.57	40
764	J-Whispering Hills 2	146.07	0	0	240.48	41
46	J-9	151.00	0	0	245.57	41
74	J-Mission Inn 9	150.00	1	4,162	245.56	41
78	J-Mission Inn 4	150.00	0	0	245.57	41
82	J-Mission Inn 3	149.00	0	0	245.57	42
86	J-Mission Inn 2	149.00	1	15,606	245.57	42
70	J-Mission Inn 7	148.00	1	8,323	245.56	42
48	J-Mission Inn 1	148.00	0	0	245.57	42
374	J-141	146.00	0	0	245.46	43
72	J-Mission Inn 8	146.00	1	4,162	245.56	43
351	J-94	144.00	0	0	245.54	44
1162	J-365	135.00	0	0	237.25	44
863	J-Watermark 3	135.17	1	8,415	238.13	45
539	J-142	141.00	0	0	245.46	45
1217	J-386	141.00	0	0	245.58	45
1122	J-354	140.00	0	0	245.64	46
1178	J-Lake Hills 1	140.00	0	0	245.77	46
1245	J-WTP3-2	140.00	0	0	245.81	46
50	J-Mission Inn 11	134.00	0	0	245.57	48
640	J-198	131.95	0	0	245.54	49
90	J-Mission Inn 14	131.00	0	0	245.57	50
94	J-Mission Inn 15	130.00	0	0	245.57	50
92	J-23	130.00	0	0	245.57	50
96	J-25	130.00	0	0	245.57	50
114	J-27	129.00	1	15,606	245.57	50
338	J-93	128.00	0	0	245.55	51
100	J-26	128.00	1	3,121	245.57	51
33	J-4	128.00	0	0	245.57	51
442	J-7	128.00	0	0	245.57	51
37	J-5	128.00	0	0	245.57	51
31	J-2	128.00	0	0	245.57	51
35	J-3	128.00	0	0	245.57	51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1108	J-Drake Point 3	126.24	1	67,320	245.10	51
52	J-Mission Inn 12	125.00	0	0	245.56	52
54	J-Mission Inn 13	124.00	1	37,454	245.55	53
544	J-170	123.00	0	0	245.45	53
860	J-Watermark 2	116.57	1	8,415	239.15	53
502	J-98	122.00	0	0	245.51	53
490	J-102	122.00	0	0	245.51	53
512	J-96	121.00	0	0	245.47	54
104	J-92	121.00	0	0	245.56	54
102	J-38	121.00	0	0	245.57	54
1106	J-Drake Point 2	120.00	1	67,703	245.11	54
325	J-89	120.00	0	0	245.53	54
495	J-90	120.00	0	0	245.53	54
322	J-88	120.00	0	0	245.54	54
643	J-199	119.72	0	0	245.47	54
340	J-97	119.00	1	14,566	245.48	55
348	J-95	118.00	1	17,687	245.47	55
576	J-183	118.00	0	0	245.53	55
377	J-157	117.00	1	12,485	245.44	56
372	J-143	117.00	1	4,162	245.45	56
315	J-104	117.00	0	0	245.48	56
108	J-39	116.00	0	0	245.55	56
110	J-40	116.00	1	11,444	245.55	56
319	J-87	115.00	0	0	245.50	56
332	J-99	113.00	1	10,404	245.48	57
334	J-91	113.00	1	4,162	245.53	57
106	J-37	112.00	1	5,202	245.57	58
983	J-Venezia 23	105.00	1	12,485	240.35	59
978	J-Venezia 18	105.00	1	10,404	240.91	59
973	J-Venezia 19	102.41	1	11,444	240.84	60
357	J-139	107.00	1	15,606	245.45	60
772	J-240	100.95	0	0	239.63	60
1148	J-Watermark 1	100.95	0	0	239.63	60
897	J-Talichet 1	104.83	0	0	244.26	60
306	J-106	106.00	0	0	245.48	60
612	J-190	104.74	0	0	245.10	61
616	J-191	104.64	1	10,404	245.12	61
447	J-36	105.00	0	0	245.58	61
809	J-Mission Rise 5	100.08	1	11,093	241.16	61
529	J-156	104.00	0	0	245.44	61
534	J-144	104.00	0	0	245.45	61
169	J-63	104.00	1	12,485	245.46	61
121	J-32	104.00	1	20,808	245.58	61
123	J-35	104.00	1	12,485	245.58	61
1053	J-Venezia 2	100.09	0	0	242.22	61

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
773	J-Venezia 1	100.12	0	0	242.36	62
369	J-145	103.00	1	3,121	245.44	62
304	J-86	103.00	1	3,121	245.48	62
812	J-Mission Rise 6	98.40	1	11,093	241.00	62
213	J-Venezia 3	99.00	0	0	241.96	62
968	J-Venezia 20	97.78	1	11,444	240.78	62
215	J-77	102.00	0	0	245.02	62
848	J-Mission Rise 18	97.08	1	10,710	240.12	62
786	J-248	102.22	0	0	245.41	62
839	J-Mission Rise 15	96.89	1	10,710	240.18	62
165	J-60	102.00	1	11,444	245.43	62
167	J-61	102.00	0	0	245.43	62
382	J-158	102.00	1	12,485	245.44	62
507	J-136	102.00	0	0	245.47	62
815	J-Mission Rise 7	97.32	1	11,093	240.84	62
842	J-Mission Rise 16	96.14	1	10,710	240.17	62
1110	J-Lake Hills 12	101.23	0	0	245.48	62
239	J-132	95.00	0	0	239.32	62
566	J-62	101.00	0	0	245.43	62
235	J-131	95.00	0	0	239.44	62
702	J-Venezia 4	97.00	1	32,513	241.72	63
1133	J-Venezia 24	95.33	1	16,646	240.24	63
635	J-197	100.00	0	0	245.01	63
895	J-Talichet 2	99.21	0	0	244.28	63
211	J-56	100.22	0	0	245.34	63
957	J-Venezia 25	95.00	1	10,404	240.19	63
156	J-54	100.06	1	2,081	245.36	63
379	J-155	100.00	1	8,323	245.44	63
201	J-52	100.00	0	0	245.54	63
203	J-51	100.00	1	2,081	245.54	63
827	J-Mission Rise 11	94.06	1	6,503	240.34	63
824	J-Mission Rise 10	94.09	1	6,503	240.37	63
818	J-Mission Rise 8	94.12	1	11,093	240.51	63
1168	J-Venezia TH 1	95.00	0	0	241.86	64
806	J-Mission Rise 4	94.43	1	11,093	241.33	64
881	J-Talichet II 1	94.95	1	5,738	242.65	64
1166	J-Venezia TH 2	94.00	1	6,885	241.76	64
1100	J-Golden Hills 1	92.58	1	232,178	240.48	64
704	J-Venezia 5	93.00	0	0	241.00	64
963	J-Venezia 21	92.72	1	13,525	240.72	64
688	J-209	97.00	1	5,202	245.38	64
158	J-53	97.00	1	13,525	245.41	64
934	J-Talichet 6	95.60	1	3,121	244.27	64
724	J-220	90.23	0	0	238.93	64
192	J-50	96.50	1	1,040	245.59	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
930	J-Talichet 3	95.16	1	6,242	244.28	65
932	J-Talichet 4	95.07	1	3,121	244.27	65
245	J-134	90.00	1	10,404	239.31	65
241	J-133	90.00	0	0	239.31	65
154	J-58	96.00	1	1,040	245.42	65
629	J-196	96.00	1	13,525	245.43	65
845	J-Mission Rise 17	90.35	1	10,710	240.15	65
730	J-Venezia 30	90.81	0	0	240.72	65
465	J-78	95.00	0	0	245.03	65
776	J-Cedar Creek 1	91.69	1	65,408	241.78	65
1152	J-Mission Rise 22	89.96	0	0	240.09	65
836	J-Mission Rise 14	90.07	1	6,503	240.22	65
720	J-Venezia 26	90.00	1	5,202	240.19	65
1138	J-Venezia 32	90.74	1	4,162	241.01	65
607	J-189	95.00	0	0	245.42	65
524	J-154	95.00	0	0	245.43	65
879	J-Talichet II 2	92.00	1	2,295	242.61	65
186	J-49	95.08	1	1,040	245.70	65
1203	J-Venezia TH 3	91.00	1	8,798	241.74	65
1035	J-Venezia 34	90.25	1	2,081	241.01	65
1043	J-324	95.01	0	0	245.82	65
830	J-Mission Rise 12	89.37	1	6,503	240.31	65
1041	J-323	94.88	0	0	245.85	65
255	J-79	94.00	1	4,162	245.03	65
1142	J-Mission Rise 1	90.47	0	0	241.80	65
624	J-194	88.00	1	3,121	239.59	66
803	J-Mission Rise 3	89.89	1	10,710	241.51	66
833	J-Mission Rise 13	88.53	1	6,503	240.27	66
851	J-Mission Rise 19	88.36	1	10,710	240.11	66
800	J-Mission Rise 2	89.97	1	10,710	241.75	66
1004	J-Venezia 12	88.68	1	4,162	240.48	66
732	J-Venezia 31	89.16	1	6,242	241.01	66
1129	J-Venezia 10	88.52	1	11,444	240.48	66
251	J-123	93.00	0	0	245.00	66
876	J-The Reserve 14	89.84	0	0	241.85	66
1084	J-The Reserve 13	89.69	2	126,225	241.86	66
883	J-Talichet 14	90.88	1	3,121	243.12	66
1081	J-The Reserve 12	89.60	1	2,295	241.89	66
386	J-153	93.00	1	6,242	245.43	66
388	J-159	93.00	0	0	245.44	66
367	J-146	93.00	1	3,121	245.44	66
1078	J-The Reserve 11	89.47	1	2,295	241.95	66
581	J-184	93.00	0	0	245.48	66
194	J-66	93.00	1	3,121	245.56	66
1075	J-The Reserve 10	89.34	2	132,983	242.01	66

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1064	J-329	88.47	0	0	241.26	66
1112	J-Thompson Grove 1	92.46	1	104,040	245.45	66
1059	J-Talichet 13	90.07	1	1,040	243.20	66
1102	J-Lake Hills 11	92.23	0	0	245.42	66
821	J-Mission Rise 9	87.13	1	6,503	240.40	66
1195	J-Lake Hills 10	92.00	1	27,158	245.41	66
936	J-Talichet 5	90.78	1	5,202	244.27	66
762	J-234	88.95	0	0	242.49	66
116	J-28	92.00	0	0	245.58	66
119	J-29	92.00	1	12,485	245.58	66
1157	J-330	87.56	0	0	241.14	66
621	J-193	85.00	1	1,040	238.93	67
994	J-Venezia 22	86.52	1	4,162	240.45	67
1017	J-Venezia 6	86.57	0	0	240.54	67
738	J-Venezia 33	87.00	1	6,242	241.01	67
873	J-The Reserve 8	86.99	0	0	241.07	67
475	J-120	91.00	0	0	245.10	67
952	J-Venezia 29	85.03	1	5,202	239.13	67
712	J-215	86.31	0	0	240.46	67
404	J-162	91.00	0	0	245.43	67
706	J-Venezia 7	86.00	0	0	240.51	67
885	J-Talichet 12	88.74	1	2,081	243.25	67
152	J-76	91.00	1	8,323	245.53	67
133	J-33	91.00	0	0	245.67	67
893	J-Talichet 7	89.60	1	12,485	244.34	67
857	J-Mission Rise 21	85.31	1	10,710	240.10	67
854	J-Mission Rise 20	85.00	1	10,710	240.10	67
728	J-Venezia 28	84.00	0	0	239.13	67
480	J-118	90.00	0	0	245.21	67
268	J-81	90.00	1	4,162	245.21	67
400	J-160	90.00	1	16,646	245.43	67
597	J-187	90.00	0	0	245.56	67
179	J-67	90.00	0	0	245.56	67
797	J-251	85.79	0	0	241.40	67
793	J-Venezia 35	85.52	0	0	241.14	67
556	J-174	91.00	0	0	246.72	67
914	J-Talichet 17	87.41	1	5,202	243.21	67
432	J-44	90.00	0	0	245.84	67
436	J-45	90.00	0	0	245.85	67
722	J-Venezia 27	83.00	1	11,444	239.13	68
790	J-249	85.17	0	0	241.33	68
1097	J-The Reserve 7	85.00	1	92,565	241.39	68
173	J-64	89.00	0	0	245.53	68
1095	J-The Reserve 6	85.05	1	92,565	241.58	68
198	J-65	89.00	1	5,202	245.54	68

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
452	J-41	89.00	1	5,202	245.67	68
1093	J-The Reserve 5	85.01	1	3,825	241.70	68
1091	J-The Reserve 4	85.00	1	3,825	241.81	68
585	J-185	90.00	0	0	246.83	68
1089	J-The Reserve 3	85.01	1	25,628	242.08	68
257	J-80	88.00	1	4,162	245.10	68
775	J-The Reserve 1	85.21	0	0	242.60	68
407	J-163	88.00	1	3,121	245.43	68
887	J-Talichet 11	86.01	1	31,860	243.44	68
1087	J-The Reserve 2	85.05	1	32,895	242.50	68
718	J-Venezia 11	83.00	1	8,323	240.48	68
602	J-188	88.00	0	0	245.52	68
126	J-30	88.00	0	0	245.59	68
130	J-31	88.00	0	0	245.61	68
1205	J-Venezia TH 4	84.00	1	27,540	241.73	68
910	J-Talichet 15	85.00	1	11,444	243.15	68
912	J-Talichet 16	85.00	1	7,283	243.17	68
1012	J-Venezia 9	82.26	1	6,242	240.48	68
759	J-The Reserve 9	86.74	1	8,798	245.04	68
754	J-229	82.11	0	0	240.46	69
1119	J-Westminster 1	87.02	1	133,875	245.43	69
402	J-161	87.00	0	0	245.43	69
426	J-168	87.00	0	0	245.43	69
301	J-85	87.00	0	0	245.48	69
708	J-Venezia 8	82.00	1	2,081	240.49	69
176	J-75	87.00	0	0	245.55	69
1032	J-Venezia 17	81.62	1	2,081	240.46	69
1023	J-Venezia 13	81.45	1	3,121	240.48	69
889	J-Talichet 10	85.00	1	3,121	244.05	69
756	J-Whispering Hills 1	81.37	0	0	240.65	69
716	J-Venezia 16	81.00	1	4,162	240.46	69
891	J-Talichet 8	85.00	1	18,727	244.49	69
923	J-Talichet 9	85.00	1	3,121	244.52	69
181	J-68	86.00	0	0	245.58	69
926	J-295	85.00	1	3,121	244.90	69
999	J-Venezia 14	80.56	1	4,162	240.47	69
757	J-231	80.71	0	0	240.68	69
470	J-122	85.00	0	0	244.99	69
549	J-Mitchell 1	85.00	1	13,525	245.04	69
592	J-186	85.00	1	7,283	245.10	69
710	J-Venezia 15	80.00	1	3,121	240.46	69
143	J-71	85.00	0	0	245.72	70
141	J-70	85.00	0	0	245.74	70
677	J-WTP1-6	86.25	0	0	247.15	70
678	J-WTP1-5	86.25	0	0	247.15	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
679	J-WTP1-4	86.25	0	0	247.15	70
554	J-173	84.00	0	0	245.08	70
1183	J-Lake Hills 3	84.00	1	27,540	245.45	70
135	J-34	84.00	1	10,404	245.61	70
769	J-238	85.00	0	0	246.67	70
429	J-43	84.00	1	9,364	245.69	70
139	J-42	84.00	0	0	245.70	70
457	J-125	82.31	1	10,404	244.11	70
249	J-121	83.00	1	5,202	244.98	70
1214	J-Venezia S	79.00	0	0	241.14	70
422	J-150	83.00	1	3,121	245.43	70
393	J-151	83.00	1	6,242	245.43	70
391	J-152	83.00	0	0	245.43	70
1170	J-369	82.00	0	0	245.04	71
552	J-172	82.00	0	0	245.06	71
264	J-117	82.00	0	0	245.21	71
1184	J-Lake Hills 4	82.00	1	27,540	245.41	71
485	J-108	82.00	0	0	245.47	71
231	J-130	77.00	0	0	240.48	71
273	J-113	81.00	0	0	245.35	71
275	J-82	81.00	0	0	245.35	71
365	J-147	81.00	1	3,121	245.44	71
1177	J-Lake Hills 2	81.00	2	169,575	245.48	71
150	J-74	81.00	1	2,081	245.54	71
1188	J-Lake Hills 6	80.00	1	27,158	245.40	72
219	J-Island 1	77.00	1	2,081	243.33	72
1192	J-Lake Hills 7	79.00	1	27,158	245.40	72
227	J-129	75.00	1	20,808	241.84	72
259	J-119	78.00	1	11,444	245.10	72
419	J-149	77.00	0	0	245.44	73
289	J-84	77.00	0	0	245.48	73
280	J-112	77.00	0	0	245.53	73
148	J-73	77.00	0	0	245.54	73
112	J-72	77.00	0	0	245.54	73
1196	J-Lake Hills 9	76.00	1	27,540	245.40	73
363	J-148	76.00	0	0	245.44	73
360	J-138	76.00	1	11,444	245.44	73
1068	J-Whispering Hills 3	70.72	1	47,813	240.54	73
1104	J-Drake Point 1	75.00	1	67,703	245.14	74
1187	J-Lake Hills 5	75.00	1	27,158	245.40	74
409	J-164	75.00	1	12,485	245.43	74
1114	J-Cypress Point 1	73.64	1	21,038	245.42	74
413	J-166	72.00	0	0	245.43	75
1189	J-Lake Hills 8	71.00	1	27,158	245.40	75
327	J-101	71.00	1	13,525	245.47	75

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect + Fire (South)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1116	J-Cypress Point 2	70.02	1	21,038	245.42	76
346	J-137	70.00	1	13,525	245.46	76
646	J-200	70.00	0	0	245.46	76
343	J-135	70.00	1	13,525	245.47	76
313	J-103	70.00	1	19,768	245.47	76
330	J-100	70.00	1	7,283	245.47	76
1070	J-Whispering Hills 4	65.00	1	11,858	240.54	76
519	J-169	69.00	0	0	245.43	76
262	J-116	68.00	1	15,606	245.21	77
417	J-167	68.00	1	8,323	245.43	77
292	J-110	68.00	0	0	245.47	77
217	J-124	67.00	0	0	244.79	77
225	J-Island 3	65.00	1	9,364	243.32	77
299	J-107	67.00	1	13,525	245.46	77
310	J-105	66.00	1	14,566	245.47	78
411	J-165	64.00	1	5,202	245.30	78
221	J-Island 2	62.00	1	4,162	243.33	78
271	J-115	64.00	1	9,364	245.34	78
286	J-111	64.00	1	1,040	245.45	79
296	J-109	64.00	0	0	245.46	79

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1248	J-WTP3-1	140.00	0	0	141.74	1
664	J-WTP1-1	81.00	0	0	83.00	1
666	J-WTP1-2	81.00	0	0	83.00	1
668	J-WTP1-3	81.00	0	0	83.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	1	60,053	240.08	35
568	J-Mission Inn 5	154.00	0	0	246.41	40
68	J-Mission Inn 6	154.00	1	16,646	246.61	40
355	J-140	152.00	0	0	245.59	40
44	J-8	152.00	1	1,040	246.06	41
764	J-Whispering Hills 2	146.07	0	0	240.15	41
41	J-6	152.00	0	0	246.20	41
866	J-Watermark 4	145.57	1	9,180	240.08	41
66	J-Mission Inn 10	152.00	0	0	246.75	41
46	J-9	151.00	0	0	246.20	41
78	J-Mission Inn 4	150.00	0	0	246.18	42
74	J-Mission Inn 9	150.00	1	4,162	246.61	42
86	J-Mission Inn 2	149.00	1	15,606	246.15	42
82	J-Mission Inn 3	149.00	0	0	246.17	42
48	J-Mission Inn 1	148.00	0	0	246.08	42
70	J-Mission Inn 7	148.00	1	8,323	246.61	43
374	J-141	146.00	0	0	245.24	43
72	J-Mission Inn 8	146.00	1	4,162	246.61	44
351	J-94	144.00	0	0	245.45	44
539	J-142	141.00	0	0	245.22	45
863	J-Watermark 3	135.17	1	8,415	240.08	45
1162	J-365	135.00	0	0	240.09	45
1217	J-386	141.00	0	0	247.21	46
1122	J-354	140.00	0	0	251.07	48
1178	J-Lake Hills 1	140.00	0	0	252.30	49
1245	J-WTP3-2	140.00	0	0	252.55	49
50	J-Mission Inn 11	134.00	0	0	247.01	49
640	J-198	131.95	0	0	245.11	49
90	J-Mission Inn 14	131.00	0	0	245.58	50
96	J-25	130.00	0	0	245.41	50
94	J-Mission Inn 15	130.00	0	0	245.51	50
92	J-23	130.00	0	0	245.57	50
114	J-27	129.00	1	15,606	245.09	50
338	J-93	128.00	0	0	245.00	51
100	J-26	128.00	1	3,121	245.22	51
52	J-Mission Inn 12	125.00	0	0	247.00	53
490	J-102	122.00	0	0	244.03	53
544	J-170	123.00	0	0	245.11	53
442	J-7	128.00	0	0	250.42	53
37	J-5	128.00	0	0	250.60	53

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
31	J-2	128.00	0	0	250.86	53
33	J-4	128.00	0	0	250.86	53
502	J-98	122.00	0	0	244.87	53
35	J-3	128.00	0	0	250.87	53
54	J-Mission Inn 13	124.00	1	37,454	246.99	53
860	J-Watermark 2	116.57	1	8,415	240.08	53
512	J-96	121.00	0	0	244.89	54
322	J-88	120.00	0	0	243.94	54
104	J-92	121.00	0	0	244.96	54
325	J-89	120.00	0	0	243.96	54
102	J-38	121.00	0	0	244.96	54
495	J-90	120.00	0	0	244.02	54
1108	J-Drake Point 3	126.24	1	67,320	250.61	54
643	J-199	119.72	0	0	244.82	54
340	J-97	119.00	1	14,566	244.78	54
576	J-183	118.00	0	0	243.86	54
315	J-104	117.00	0	0	243.55	55
348	J-95	118.00	1	17,687	244.95	55
110	J-40	116.00	1	11,444	243.89	55
108	J-39	116.00	0	0	243.92	55
377	J-157	117.00	1	12,485	245.07	55
372	J-143	117.00	1	4,162	245.10	55
319	J-87	115.00	0	0	243.55	56
1106	J-Drake Point 2	120.00	1	67,703	250.61	57
332	J-99	113.00	1	10,404	244.59	57
334	J-91	113.00	1	4,162	244.59	57
106	J-37	112.00	1	5,202	244.50	57
983	J-Venezia 23	105.00	1	12,485	240.15	58
978	J-Venezia 18	105.00	1	10,404	240.19	58
897	J-Talichet 1	104.83	0	0	241.02	59
306	J-106	106.00	0	0	243.14	59
612	J-190	104.74	0	0	241.99	59
616	J-191	104.64	1	10,404	241.99	59
973	J-Venezia 19	102.41	1	11,444	240.18	60
169	J-63	104.00	1	12,485	242.00	60
357	J-139	107.00	1	15,606	245.02	60
772	J-240	100.95	0	0	240.09	60
1148	J-Watermark 1	100.95	0	0	240.09	60
447	J-36	105.00	0	0	244.22	60
786	J-248	102.22	0	0	241.99	60
809	J-Mission Rise 5	100.08	1	11,093	239.92	60
215	J-77	102.00	0	0	242.00	61
165	J-60	102.00	1	11,444	242.00	61
167	J-61	102.00	0	0	242.00	61
121	J-32	104.00	1	20,808	244.10	61

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
304	J-86	103.00	1	3,121	243.14	61
123	J-35	104.00	1	12,485	244.16	61
773	J-Venezia 1	100.12	0	0	240.46	61
1053	J-Venezia 2	100.09	0	0	240.43	61
566	J-62	101.00	0	0	242.00	61
529	J-156	104.00	0	0	245.03	61
534	J-144	104.00	0	0	245.05	61
213	J-Venezia 3	99.00	0	0	240.37	61
812	J-Mission Rise 6	98.40	1	11,093	239.88	61
211	J-56	100.22	0	0	241.99	61
895	J-Talichet 2	99.21	0	0	241.02	61
156	J-54	100.06	1	2,081	241.99	61
635	J-197	100.00	0	0	241.99	61
203	J-51	100.00	1	2,081	242.00	61
201	J-52	100.00	0	0	242.00	61
369	J-145	103.00	1	3,121	245.02	61
968	J-Venezia 20	97.78	1	11,444	240.17	62
815	J-Mission Rise 7	97.32	1	11,093	239.85	62
507	J-136	102.00	0	0	244.75	62
848	J-Mission Rise 18	97.08	1	10,710	239.96	62
839	J-Mission Rise 15	96.89	1	10,710	239.88	62
382	J-158	102.00	1	12,485	245.02	62
702	J-Venezia 4	97.00	1	32,513	240.32	62
842	J-Mission Rise 16	96.14	1	10,710	239.89	62
1133	J-Venezia 24	95.33	1	16,646	240.14	63
688	J-209	97.00	1	5,202	241.99	63
158	J-53	97.00	1	13,525	241.99	63
379	J-155	100.00	1	8,323	245.02	63
239	J-132	95.00	0	0	240.12	63
235	J-131	95.00	0	0	240.12	63
957	J-Venezia 25	95.00	1	10,404	240.14	63
1168	J-Venezia TH 1	95.00	0	0	240.34	63
934	J-Talichet 6	95.60	1	3,121	241.01	63
881	J-Talichet II 1	94.95	1	5,738	240.41	63
192	J-50	96.50	1	1,040	241.98	63
806	J-Mission Rise 4	94.43	1	11,093	239.95	63
818	J-Mission Rise 8	94.12	1	11,093	239.78	63
824	J-Mission Rise 10	94.09	1	6,503	239.80	63
827	J-Mission Rise 11	94.06	1	6,503	239.81	63
930	J-Talichet 3	95.16	1	6,242	241.02	63
932	J-Talichet 4	95.07	1	3,121	241.02	63
154	J-58	96.00	1	1,040	242.00	63
629	J-196	96.00	1	13,525	242.00	63
1166	J-Venezia TH 2	94.00	1	6,885	240.32	63
1043	J-324	95.01	0	0	241.68	63

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
186	J-49	95.08	1	1,040	241.86	64
1041	J-323	94.88	0	0	241.67	64
607	J-189	95.00	0	0	242.00	64
465	J-78	95.00	0	0	242.01	64
1100	J-Golden Hills 1	92.58	1	232,178	239.75	64
704	J-Venezia 5	93.00	0	0	240.21	64
963	J-Venezia 21	92.72	1	13,525	240.17	64
255	J-79	94.00	1	4,162	242.01	64
776	J-Cedar Creek 1	91.69	1	65,408	240.05	64
879	J-Talichet II 2	92.00	1	2,295	240.40	64
251	J-123	93.00	0	0	242.01	64
194	J-66	93.00	1	3,121	242.03	64
1203	J-Venezia TH 3	91.00	1	8,798	240.29	65
730	J-Venezia 30	90.81	0	0	240.17	65
1138	J-Venezia 32	90.74	1	4,162	240.19	65
845	J-Mission Rise 17	90.35	1	10,710	239.91	65
1142	J-Mission Rise 1	90.47	0	0	240.07	65
1110	J-Lake Hills 12	101.23	0	0	250.87	65
883	J-Talichet 14	90.88	1	3,121	240.53	65
836	J-Mission Rise 14	90.07	1	6,503	239.86	65
724	J-220	90.23	0	0	240.11	65
1035	J-Venezia 34	90.25	1	2,081	240.19	65
581	J-184	93.00	0	0	242.95	65
524	J-154	95.00	0	0	244.99	65
800	J-Mission Rise 2	89.97	1	10,710	240.06	65
803	J-Mission Rise 3	89.89	1	10,710	240.00	65
245	J-134	90.00	1	10,404	240.11	65
241	J-133	90.00	0	0	240.11	65
1152	J-Mission Rise 22	89.96	0	0	240.09	65
720	J-Venezia 26	90.00	1	5,202	240.14	65
936	J-Talichet 5	90.78	1	5,202	241.01	65
556	J-174	91.00	0	0	241.40	65
830	J-Mission Rise 12	89.37	1	6,503	239.82	65
876	J-The Reserve 14	89.84	0	0	240.29	65
1059	J-Talichet 13	90.07	1	1,040	240.55	65
1084	J-The Reserve 13	89.69	2	126,225	240.26	65
1081	J-The Reserve 12	89.60	1	2,295	240.26	65
1078	J-The Reserve 11	89.47	1	2,295	240.26	65
1075	J-The Reserve 10	89.34	2	132,983	240.26	65
732	J-Venezia 31	89.16	1	6,242	240.19	65
152	J-76	91.00	1	8,323	242.04	65
475	J-120	91.00	0	0	242.10	65
833	J-Mission Rise 13	88.53	1	6,503	239.84	65
893	J-Talichet 7	89.60	1	12,485	241.00	66
585	J-185	90.00	0	0	241.42	66

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
762	J-234	88.95	0	0	240.37	66
1004	J-Venezia 12	88.68	1	4,162	240.15	66
851	J-Mission Rise 19	88.36	1	10,710	239.98	66
1129	J-Venezia 10	88.52	1	11,444	240.15	66
436	J-45	90.00	0	0	241.67	66
432	J-44	90.00	0	0	241.71	66
1064	J-329	88.47	0	0	240.20	66
885	J-Talichet 12	88.74	1	2,081	240.56	66
386	J-153	93.00	1	6,242	244.98	66
388	J-159	93.00	0	0	244.99	66
367	J-146	93.00	1	3,121	244.99	66
133	J-33	91.00	0	0	243.02	66
597	J-187	90.00	0	0	242.04	66
179	J-67	90.00	0	0	242.04	66
624	J-194	88.00	1	3,121	240.12	66
119	J-29	92.00	1	12,485	244.14	66
116	J-28	92.00	0	0	244.16	66
480	J-118	90.00	0	0	242.22	66
268	J-81	90.00	1	4,162	242.22	66
1157	J-330	87.56	0	0	240.17	66
821	J-Mission Rise 9	87.13	1	6,503	239.80	66
198	J-65	89.00	1	5,202	242.03	66
173	J-64	89.00	0	0	242.03	66
914	J-Talichet 17	87.41	1	5,202	240.55	66
873	J-The Reserve 8	86.99	0	0	240.16	66
738	J-Venezia 33	87.00	1	6,242	240.19	66
1017	J-Venezia 6	86.57	0	0	240.16	66
994	J-Venezia 22	86.52	1	4,162	240.15	66
712	J-215	86.31	0	0	240.15	67
404	J-162	91.00	0	0	244.96	67
452	J-41	89.00	1	5,202	242.97	67
602	J-188	88.00	0	0	242.03	67
257	J-80	88.00	1	4,162	242.10	67
706	J-Venezia 7	86.00	0	0	240.16	67
759	J-The Reserve 9	86.74	1	8,798	241.02	67
797	J-251	85.79	0	0	240.23	67
887	J-Talichet 11	86.01	1	31,860	240.62	67
793	J-Venezia 35	85.52	0	0	240.20	67
857	J-Mission Rise 21	85.31	1	10,710	240.03	67
400	J-160	90.00	1	16,646	244.96	67
854	J-Mission Rise 20	85.00	1	10,710	240.00	67
790	J-249	85.17	0	0	240.22	67
176	J-75	87.00	0	0	242.05	67
952	J-Venezia 29	85.03	1	5,202	240.12	67
621	J-193	85.00	1	1,040	240.11	67

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1095	J-The Reserve 6	85.05	1	92,565	240.17	67
775	J-The Reserve 1	85.21	0	0	240.34	67
1097	J-The Reserve 7	85.00	1	92,565	240.16	67
677	J-WTP1-6	86.25	0	0	241.42	67
678	J-WTP1-5	86.25	0	0	241.42	67
679	J-WTP1-4	86.25	0	0	241.42	67
1093	J-The Reserve 5	85.01	1	3,825	240.19	67
1091	J-The Reserve 4	85.00	1	3,825	240.21	67
1089	J-The Reserve 3	85.01	1	25,628	240.25	67
1087	J-The Reserve 2	85.05	1	32,895	240.32	67
910	J-Talichet 15	85.00	1	11,444	240.53	67
912	J-Talichet 16	85.00	1	7,283	240.54	67
130	J-31	88.00	0	0	243.82	67
301	J-85	87.00	0	0	242.82	67
889	J-Talichet 10	85.00	1	3,121	240.83	67
126	J-30	88.00	0	0	243.98	67
923	J-Talichet 9	85.00	1	3,121	240.99	67
891	J-Talichet 8	85.00	1	18,727	240.99	67
549	J-Mitchell 1	85.00	1	13,525	241.03	68
181	J-68	86.00	0	0	242.05	68
926	J-295	85.00	1	3,121	241.05	68
592	J-186	85.00	1	7,283	241.08	68
728	J-Venezia 28	84.00	0	0	240.12	68
1205	J-Venezia TH 4	84.00	1	27,540	240.29	68
769	J-238	85.00	0	0	241.38	68
407	J-163	88.00	1	3,121	244.96	68
470	J-122	85.00	0	0	242.01	68
554	J-173	84.00	0	0	241.07	68
722	J-Venezia 27	83.00	1	11,444	240.12	68
718	J-Venezia 11	83.00	1	8,323	240.15	68
141	J-70	85.00	0	0	242.21	68
143	J-71	85.00	0	0	242.25	68
1012	J-Venezia 9	82.26	1	6,242	240.15	68
426	J-168	87.00	0	0	244.96	68
402	J-161	87.00	0	0	244.96	68
754	J-229	82.11	0	0	240.15	68
708	J-Venezia 8	82.00	1	2,081	240.15	68
1112	J-Thompson Grove 1	92.46	1	104,040	250.85	69
429	J-43	84.00	1	9,364	242.50	69
1032	J-Venezia 17	81.62	1	2,081	240.15	69
139	J-42	84.00	0	0	242.61	69
1102	J-Lake Hills 11	92.23	0	0	250.92	69
1023	J-Venezia 13	81.45	1	3,121	240.15	69
756	J-Whispering Hills 1	81.37	0	0	240.20	69
1195	J-Lake Hills 10	92.00	1	27,158	250.92	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
249	J-121	83.00	1	5,202	242.01	69
1170	J-369	82.00	0	0	241.02	69
552	J-172	82.00	0	0	241.04	69
716	J-Venezia 16	81.00	1	4,162	240.15	69
457	J-125	82.31	1	10,404	241.58	69
757	J-231	80.71	0	0	240.21	69
999	J-Venezia 14	80.56	1	4,162	240.15	69
135	J-34	84.00	1	10,404	243.72	69
710	J-Venezia 15	80.00	1	3,121	240.15	69
264	J-117	82.00	0	0	242.21	69
485	J-108	82.00	0	0	242.82	70
150	J-74	81.00	1	2,081	242.11	70
1214	J-Venezia S	79.00	0	0	240.17	70
273	J-113	81.00	0	0	242.36	70
275	J-82	81.00	0	0	242.36	70
422	J-150	83.00	1	3,121	244.96	70
393	J-151	83.00	1	6,242	244.96	70
391	J-152	83.00	0	0	244.96	70
231	J-130	77.00	0	0	240.16	71
1119	J-Westminster 1	87.02	1	133,875	250.82	71
365	J-147	81.00	1	3,121	244.96	71
259	J-119	78.00	1	11,444	242.10	71
219	J-Island 1	77.00	1	2,081	241.23	71
148	J-73	77.00	0	0	242.36	72
280	J-112	77.00	0	0	242.37	72
112	J-72	77.00	0	0	242.50	72
289	J-84	77.00	0	0	242.51	72
227	J-129	75.00	1	20,808	240.62	72
1183	J-Lake Hills 3	84.00	1	27,540	251.06	72
419	J-149	77.00	0	0	244.95	73
360	J-138	76.00	1	11,444	244.95	73
363	J-148	76.00	0	0	244.95	73
1184	J-Lake Hills 4	82.00	1	27,540	250.97	73
1068	J-Whispering Hills 3	70.72	1	47,813	240.15	73
409	J-164	75.00	1	12,485	244.95	74
1177	J-Lake Hills 2	81.00	2	169,575	251.10	74
1188	J-Lake Hills 6	80.00	1	27,158	250.94	74
1192	J-Lake Hills 7	79.00	1	27,158	250.93	74
413	J-166	72.00	0	0	244.95	75
327	J-101	71.00	1	13,525	244.12	75
313	J-103	70.00	1	19,768	243.55	75
262	J-116	68.00	1	15,606	242.21	75
330	J-100	70.00	1	7,283	244.33	75
292	J-110	68.00	0	0	242.51	76
343	J-135	70.00	1	13,525	244.68	76

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
646	J-200	70.00	0	0	244.73	76
346	J-137	70.00	1	13,525	244.87	76
217	J-124	67.00	0	0	241.90	76
1196	J-Lake Hills 9	76.00	1	27,540	250.92	76
1070	J-Whispering Hills 4	65.00	1	11,858	240.15	76
1104	J-Drake Point 1	75.00	1	67,703	250.64	76
299	J-107	67.00	1	13,525	242.82	76
1187	J-Lake Hills 5	75.00	1	27,158	250.95	76
519	J-169	69.00	0	0	244.95	76
225	J-Island 3	65.00	1	9,364	241.23	76
417	J-167	68.00	1	8,323	244.95	77
310	J-105	66.00	1	14,566	243.14	77
1114	J-Cypress Point 1	73.64	1	21,038	250.82	77
271	J-115	64.00	1	9,364	242.35	77
286	J-111	64.00	1	1,040	242.45	77
296	J-109	64.00	0	0	242.51	77
221	J-Island 2	62.00	1	4,162	241.23	78
1189	J-Lake Hills 8	71.00	1	27,158	250.92	78
1116	J-Cypress Point 2	70.02	1	21,038	250.82	78
411	J-165	64.00	1	5,202	244.83	78

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1248	J-WTP3-1	140.00	0	0	141.31	1
664	J-WTP1-1	81.00	0	0	83.00	1
666	J-WTP1-2	81.00	0	0	83.00	1
668	J-WTP1-3	81.00	0	0	83.00	1
869	J-Watermark 5	159.36	1	60,053	226.72	29
68	J-Mission Inn 6	154.00	2	2,176,646	229.07	32
568	J-Mission Inn 5	154.00	0	0	230.04	33
30	J-WTP2-1	130.00	0	0	208.00	34
66	J-Mission Inn 10	152.00	0	0	230.65	34
74	J-Mission Inn 9	150.00	1	4,162	229.07	34
355	J-140	152.00	0	0	232.66	35
764	J-Whispering Hills 2	146.07	0	0	226.79	35
70	J-Mission Inn 7	148.00	1	8,323	229.07	35
866	J-Watermark 4	145.57	1	9,180	226.72	35
78	J-Mission Inn 4	150.00	0	0	231.21	35
44	J-8	152.00	1	1,040	233.25	35
41	J-6	152.00	0	0	233.44	35
82	J-Mission Inn 3	149.00	0	0	231.26	36
46	J-9	151.00	0	0	233.27	36
86	J-Mission Inn 2	149.00	1	15,606	231.38	36
72	J-Mission Inn 8	146.00	1	4,162	229.07	36
48	J-Mission Inn 1	148.00	0	0	232.91	37
374	J-141	146.00	0	0	232.21	37
351	J-94	144.00	0	0	232.39	38
539	J-142	141.00	0	0	232.19	39
863	J-Watermark 3	135.17	1	8,415	226.72	40
1162	J-365	135.00	0	0	226.73	40
1217	J-386	141.00	0	0	235.41	41
50	J-Mission Inn 11	134.00	0	0	233.51	43
640	J-198	131.95	0	0	231.86	43
90	J-Mission Inn 14	131.00	0	0	231.98	44
94	J-Mission Inn 15	130.00	0	0	231.98	44
96	J-25	130.00	0	0	231.98	44
92	J-23	130.00	0	0	232.14	44
114	J-27	129.00	1	15,606	231.68	44
338	J-93	128.00	0	0	231.69	45
100	J-26	128.00	1	3,121	231.80	45
52	J-Mission Inn 12	125.00	0	0	233.50	47
490	J-102	122.00	0	0	230.70	47
544	J-170	123.00	0	0	232.05	47
1122	J-354	140.00	0	0	249.17	47
54	J-Mission Inn 13	124.00	1	37,454	233.49	47
502	J-98	122.00	0	0	231.60	47

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
860	J-Watermark 2	116.57	1	8,415	226.72	48
104	J-92	121.00	0	0	231.58	48
102	J-38	121.00	0	0	231.58	48
322	J-88	120.00	0	0	230.59	48
325	J-89	120.00	0	0	230.61	48
495	J-90	120.00	0	0	230.68	48
512	J-96	121.00	0	0	231.71	48
643	J-199	119.72	0	0	231.60	48
576	J-183	118.00	0	0	230.52	49
1178	J-Lake Hills 1	140.00	0	0	252.53	49
340	J-97	119.00	1	14,566	231.54	49
1245	J-WTP3-2	140.00	0	0	253.19	49
315	J-104	117.00	0	0	230.22	49
348	J-95	118.00	1	17,687	231.80	49
110	J-40	116.00	1	11,444	230.53	50
108	J-39	116.00	0	0	230.56	50
377	J-157	117.00	1	12,485	232.00	50
372	J-143	117.00	1	4,162	232.03	50
319	J-87	115.00	0	0	230.22	50
334	J-91	113.00	1	4,162	231.27	51
332	J-99	113.00	1	10,404	231.29	51
106	J-37	112.00	1	5,202	231.12	52
442	J-7	128.00	0	0	247.30	52
37	J-5	128.00	0	0	247.91	52
31	J-2	128.00	0	0	248.76	52
33	J-4	128.00	0	0	248.76	52
35	J-3	128.00	0	0	248.78	52
983	J-Venezia 23	105.00	1	12,485	226.79	53
978	J-Venezia 18	105.00	1	10,404	226.83	53
1108	J-Drake Point 3	126.24	1	67,320	248.80	53
897	J-Talichet 1	104.83	0	0	227.66	53
306	J-106	106.00	0	0	229.80	54
612	J-190	104.74	0	0	228.64	54
616	J-191	104.64	1	10,404	228.64	54
973	J-Venezia 19	102.41	1	11,444	226.82	54
169	J-63	104.00	1	12,485	228.65	54
357	J-139	107.00	1	15,606	231.93	54
772	J-240	100.95	0	0	226.73	54
1148	J-Watermark 1	100.95	0	0	226.73	54
447	J-36	105.00	0	0	230.84	54
786	J-248	102.22	0	0	228.64	55
809	J-Mission Rise 5	100.08	1	11,093	226.56	55
215	J-77	102.00	0	0	228.64	55

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
165	J-60	102.00	1	11,444	228.64	55
167	J-61	102.00	0	0	228.64	55
121	J-32	104.00	1	20,808	230.72	55
123	J-35	104.00	1	12,485	230.79	55
304	J-86	103.00	1	3,121	229.80	55
773	J-Venezia 1	100.12	0	0	227.10	55
1053	J-Venezia 2	100.09	0	0	227.07	55
566	J-62	101.00	0	0	228.64	55
529	J-156	104.00	0	0	231.94	55
534	J-144	104.00	0	0	231.97	55
213	J-Venezia 3	99.00	0	0	227.01	55
812	J-Mission Rise 6	98.40	1	11,093	226.52	55
211	J-56	100.22	0	0	228.64	56
895	J-Talichet 2	99.21	0	0	227.66	56
156	J-54	100.06	1	2,081	228.64	56
635	J-197	100.00	0	0	228.63	56
203	J-51	100.00	1	2,081	228.64	56
201	J-52	100.00	0	0	228.64	56
1106	J-Drake Point 2	120.00	1	67,703	248.81	56
369	J-145	103.00	1	3,121	231.93	56
968	J-Venezia 20	97.78	1	11,444	226.82	56
815	J-Mission Rise 7	97.32	1	11,093	226.49	56
507	J-136	102.00	0	0	231.52	56
848	J-Mission Rise 18	97.08	1	10,710	226.60	56
839	J-Mission Rise 15	96.89	1	10,710	226.53	56
382	J-158	102.00	1	12,485	231.93	56
702	J-Venezia 4	97.00	1	32,513	226.96	56
842	J-Mission Rise 16	96.14	1	10,710	226.53	56
1133	J-Venezia 24	95.33	1	16,646	226.78	57
688	J-209	97.00	1	5,202	228.64	57
158	J-53	97.00	1	13,525	228.64	57
239	J-132	95.00	0	0	226.76	57
235	J-131	95.00	0	0	226.76	57
957	J-Venezia 25	95.00	1	10,404	226.78	57
379	J-155	100.00	1	8,323	231.93	57
1168	J-Venezia TH 1	95.00	0	0	226.99	57
934	J-Talichet 6	95.60	1	3,121	227.66	57
881	J-Talichet II 1	94.95	1	5,738	227.05	57
192	J-50	96.50	1	1,040	228.62	57
806	J-Mission Rise 4	94.43	1	11,093	226.59	57
818	J-Mission Rise 8	94.12	1	11,093	226.42	57
824	J-Mission Rise 10	94.09	1	6,503	226.44	57
827	J-Mission Rise 11	94.06	1	6,503	226.45	57

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
930	J-Talichet 3	95.16	1	6,242	227.66	57
932	J-Talichet 4	95.07	1	3,121	227.66	57
154	J-58	96.00	1	1,040	228.64	57
629	J-196	96.00	1	13,525	228.64	57
1166	J-Venezia TH 2	94.00	1	6,885	226.96	58
1043	J-324	95.01	0	0	228.32	58
186	J-49	95.08	1	1,040	228.50	58
1041	J-323	94.88	0	0	228.31	58
607	J-189	95.00	0	0	228.64	58
465	J-78	95.00	0	0	228.65	58
1100	J-Golden Hills 1	92.58	1	232,178	226.39	58
704	J-Venezia 5	93.00	0	0	226.85	58
963	J-Venezia 21	92.72	1	13,525	226.81	58
255	J-79	94.00	1	4,162	228.66	58
776	J-Cedar Creek 1	91.69	1	65,408	226.69	58
879	J-Talichet II 2	92.00	1	2,295	227.04	58
251	J-123	93.00	0	0	228.65	59
194	J-66	93.00	1	3,121	228.68	59
1203	J-Venezia TH 3	91.00	1	8,798	226.93	59
730	J-Venezia 30	90.81	0	0	226.81	59
1138	J-Venezia 32	90.74	1	4,162	226.83	59
845	J-Mission Rise 17	90.35	1	10,710	226.55	59
1142	J-Mission Rise 1	90.47	0	0	226.71	59
883	J-Talichet 14	90.88	1	3,121	227.17	59
836	J-Mission Rise 14	90.07	1	6,503	226.50	59
724	J-220	90.23	0	0	226.75	59
1035	J-Venezia 34	90.25	1	2,081	226.83	59
581	J-184	93.00	0	0	229.60	59
800	J-Mission Rise 2	89.97	1	10,710	226.70	59
803	J-Mission Rise 3	89.89	1	10,710	226.64	59
245	J-134	90.00	1	10,404	226.75	59
241	J-133	90.00	0	0	226.75	59
1152	J-Mission Rise 22	89.96	0	0	226.73	59
720	J-Venezia 26	90.00	1	5,202	226.78	59
936	J-Talichet 5	90.78	1	5,202	227.66	59
524	J-154	95.00	0	0	231.89	59
556	J-174	91.00	0	0	228.04	59
830	J-Mission Rise 12	89.37	1	6,503	226.46	59
876	J-The Reserve 14	89.84	0	0	226.93	59
1059	J-Talichet 13	90.07	1	1,040	227.19	59
1084	J-The Reserve 13	89.69	2	126,225	226.90	59
1081	J-The Reserve 12	89.60	1	2,295	226.90	59
1078	J-The Reserve 11	89.47	1	2,295	226.90	59

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1075	J-The Reserve 10	89.34	2	132,983	226.90	60
732	J-Venezia 31	89.16	1	6,242	226.83	60
152	J-76	91.00	1	8,323	228.69	60
475	J-120	91.00	0	0	228.75	60
833	J-Mission Rise 13	88.53	1	6,503	226.48	60
893	J-Talichet 7	89.60	1	12,485	227.64	60
585	J-185	90.00	0	0	228.06	60
762	J-234	88.95	0	0	227.01	60
1004	J-Venezia 12	88.68	1	4,162	226.79	60
851	J-Mission Rise 19	88.36	1	10,710	226.62	60
1129	J-Venezia 10	88.52	1	11,444	226.79	60
436	J-45	90.00	0	0	228.31	60
432	J-44	90.00	0	0	228.35	60
1064	J-329	88.47	0	0	226.84	60
885	J-Talichet 12	88.74	1	2,081	227.20	60
133	J-33	91.00	0	0	229.65	60
597	J-187	90.00	0	0	228.68	60
179	J-67	90.00	0	0	228.69	60
119	J-29	92.00	1	12,485	230.76	60
624	J-194	88.00	1	3,121	226.76	60
116	J-28	92.00	0	0	230.78	60
480	J-118	90.00	0	0	228.86	60
268	J-81	90.00	1	4,162	228.86	60
386	J-153	93.00	1	6,242	231.88	60
388	J-159	93.00	0	0	231.89	60
367	J-146	93.00	1	3,121	231.89	60
1157	J-330	87.56	0	0	226.82	60
821	J-Mission Rise 9	87.13	1	6,503	226.44	60
198	J-65	89.00	1	5,202	228.67	60
173	J-64	89.00	0	0	228.67	60
914	J-Talichet 17	87.41	1	5,202	227.19	60
873	J-The Reserve 8	86.99	0	0	226.80	60
738	J-Venezia 33	87.00	1	6,242	226.83	60
1017	J-Venezia 6	86.57	0	0	226.80	61
994	J-Venezia 22	86.52	1	4,162	226.79	61
712	J-215	86.31	0	0	226.79	61
452	J-41	89.00	1	5,202	229.61	61
602	J-188	88.00	0	0	228.67	61
257	J-80	88.00	1	4,162	228.75	61
706	J-Venezia 7	86.00	0	0	226.80	61
404	J-162	91.00	0	0	231.85	61
759	J-The Reserve 9	86.74	1	8,798	227.66	61
797	J-251	85.79	0	0	226.87	61

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
887	J-Talichet 11	86.01	1	31,860	227.26	61
793	J-Venezia 35	85.52	0	0	226.84	61
857	J-Mission Rise 21	85.31	1	10,710	226.67	61
854	J-Mission Rise 20	85.00	1	10,710	226.64	61
790	J-249	85.17	0	0	226.86	61
176	J-75	87.00	0	0	228.69	61
952	J-Venezia 29	85.03	1	5,202	226.76	61
621	J-193	85.00	1	1,040	226.75	61
1095	J-The Reserve 6	85.05	1	92,565	226.81	61
775	J-The Reserve 1	85.21	0	0	226.98	61
1097	J-The Reserve 7	85.00	1	92,565	226.80	61
677	J-WTP1-6	86.25	0	0	228.06	61
678	J-WTP1-5	86.25	0	0	228.06	61
679	J-WTP1-4	86.25	0	0	228.06	61
1093	J-The Reserve 5	85.01	1	3,825	226.83	61
1091	J-The Reserve 4	85.00	1	3,825	226.85	61
400	J-160	90.00	1	16,646	231.85	61
1089	J-The Reserve 3	85.01	1	25,628	226.89	61
1087	J-The Reserve 2	85.05	1	32,895	226.96	61
910	J-Talichet 15	85.00	1	11,444	227.17	62
912	J-Talichet 16	85.00	1	7,283	227.18	62
130	J-31	88.00	0	0	230.44	62
889	J-Talichet 10	85.00	1	3,121	227.47	62
301	J-85	87.00	0	0	229.47	62
126	J-30	88.00	0	0	230.60	62
923	J-Talichet 9	85.00	1	3,121	227.63	62
891	J-Talichet 8	85.00	1	18,727	227.63	62
549	J-Mitchell 1	85.00	1	13,525	227.67	62
926	J-295	85.00	1	3,121	227.69	62
181	J-68	86.00	0	0	228.69	62
592	J-186	85.00	1	7,283	227.72	62
728	J-Venezia 28	84.00	0	0	226.76	62
1205	J-Venezia TH 4	84.00	1	27,540	226.93	62
769	J-238	85.00	0	0	228.02	62
470	J-122	85.00	0	0	228.65	62
554	J-173	84.00	0	0	227.71	62
722	J-Venezia 27	83.00	1	11,444	226.76	62
718	J-Venezia 11	83.00	1	8,323	226.79	62
141	J-70	85.00	0	0	228.85	62
407	J-163	88.00	1	3,121	231.85	62
143	J-71	85.00	0	0	228.89	62
1012	J-Venezia 9	82.26	1	6,242	226.79	63
754	J-229	82.11	0	0	226.79	63

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
708	J-Venezia 8	82.00	1	2,081	226.79	63
426	J-168	87.00	0	0	231.85	63
402	J-161	87.00	0	0	231.85	63
429	J-43	84.00	1	9,364	229.14	63
1032	J-Venezia 17	81.62	1	2,081	226.79	63
139	J-42	84.00	0	0	229.24	63
1023	J-Venezia 13	81.45	1	3,121	226.79	63
756	J-Whispering Hills 1	81.37	0	0	226.84	63
249	J-121	83.00	1	5,202	228.65	63
1170	J-369	82.00	0	0	227.66	63
552	J-172	82.00	0	0	227.68	63
716	J-Venezia 16	81.00	1	4,162	226.79	63
457	J-125	82.31	1	10,404	228.23	63
757	J-231	80.71	0	0	226.85	63
999	J-Venezia 14	80.56	1	4,162	226.79	63
135	J-34	84.00	1	10,404	230.35	63
710	J-Venezia 15	80.00	1	3,121	226.79	64
264	J-117	82.00	0	0	228.86	64
485	J-108	82.00	0	0	229.47	64
1110	J-Lake Hills 12	101.23	0	0	248.96	64
150	J-74	81.00	1	2,081	228.75	64
1214	J-Venezia S	79.00	0	0	226.82	64
273	J-113	81.00	0	0	229.00	64
275	J-82	81.00	0	0	229.00	64
422	J-150	83.00	1	3,121	231.85	64
393	J-151	83.00	1	6,242	231.85	64
391	J-152	83.00	0	0	231.86	64
231	J-130	77.00	0	0	226.80	65
259	J-119	78.00	1	11,444	228.75	65
365	J-147	81.00	1	3,121	231.86	65
219	J-Island 1	77.00	1	2,081	227.88	65
148	J-73	77.00	0	0	229.00	66
280	J-112	77.00	0	0	229.01	66
112	J-72	77.00	0	0	229.15	66
289	J-84	77.00	0	0	229.15	66
227	J-129	75.00	1	20,808	227.26	66
419	J-149	77.00	0	0	231.84	67
360	J-138	76.00	1	11,444	231.84	67
363	J-148	76.00	0	0	231.84	67
1068	J-Whispering Hills 3	70.72	1	47,813	226.79	68
1112	J-Thompson Grove 1	92.46	1	104,040	248.93	68
409	J-164	75.00	1	12,485	231.85	68
1102	J-Lake Hills 11	92.23	0	0	249.12	68

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1195	J-Lake Hills 10	92.00	1	27,158	249.12	68
327	J-101	71.00	1	13,525	230.81	69
413	J-166	72.00	0	0	231.85	69
313	J-103	70.00	1	19,768	230.22	69
262	J-116	68.00	1	15,606	228.86	70
330	J-100	70.00	1	7,283	231.04	70
292	J-110	68.00	0	0	229.15	70
343	J-135	70.00	1	13,525	231.46	70
646	J-200	70.00	0	0	231.52	70
217	J-124	67.00	0	0	228.55	70
346	J-137	70.00	1	13,525	231.72	70
1070	J-Whispering Hills 4	65.00	1	11,858	226.79	70
1119	J-Westminster 1	87.02	1	133,875	248.91	70
299	J-107	67.00	1	13,525	229.47	70
519	J-169	69.00	0	0	231.85	70
225	J-Island 3	65.00	1	9,364	227.87	70
310	J-105	66.00	1	14,566	229.80	71
417	J-167	68.00	1	8,323	231.85	71
271	J-115	64.00	1	9,364	229.00	71
286	J-111	64.00	1	1,040	229.10	71
296	J-109	64.00	0	0	229.15	71
1183	J-Lake Hills 3	84.00	1	27,540	249.62	72
221	J-Island 2	62.00	1	4,162	227.87	72
1184	J-Lake Hills 4	82.00	1	27,540	249.41	72
411	J-165	64.00	1	5,202	231.72	73
1177	J-Lake Hills 2	81.00	2	169,575	249.70	73
1188	J-Lake Hills 6	80.00	1	27,158	249.30	73
1192	J-Lake Hills 7	79.00	1	27,158	249.26	74
1196	J-Lake Hills 9	76.00	1	27,540	249.15	75
1104	J-Drake Point 1	75.00	1	67,703	248.84	75
1187	J-Lake Hills 5	75.00	1	27,158	249.33	75
1114	J-Cypress Point 1	73.64	1	21,038	248.90	76
1189	J-Lake Hills 8	71.00	1	27,158	249.20	77
1116	J-Cypress Point 2	70.02	1	21,038	248.90	77

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1248	J-WTP3-1	140.00	0	0	141.47	1
664	J-WTP1-1	81.00	0	0	83.00	1
666	J-WTP1-2	81.00	0	0	83.00	1
668	J-WTP1-3	81.00	0	0	83.00	1
869	J-Watermark 5	159.36	2	1,500,053	224.48	28
30	J-WTP2-1	130.00	0	0	208.00	34
866	J-Watermark 4	145.57	1	9,180	225.24	34
764	J-Whispering Hills 2	146.07	0	0	228.39	36
1162	J-365	135.00	0	0	224.86	39
863	J-Watermark 3	135.17	1	8,415	225.67	39
568	J-Mission Inn 5	154.00	0	0	247.83	41
355	J-140	152.00	0	0	245.88	41
68	J-Mission Inn 6	154.00	1	16,646	248.35	41
44	J-8	152.00	1	1,040	246.91	41
41	J-6	152.00	0	0	247.25	41
46	J-9	151.00	0	0	247.24	42
66	J-Mission Inn 10	152.00	0	0	248.70	42
78	J-Mission Inn 4	150.00	0	0	247.22	42
86	J-Mission Inn 2	149.00	1	15,606	247.13	42
82	J-Mission Inn 3	149.00	0	0	247.19	42
74	J-Mission Inn 9	150.00	1	4,162	248.35	43
48	J-Mission Inn 1	148.00	0	0	246.93	43
374	J-141	146.00	0	0	245.10	43
70	J-Mission Inn 7	148.00	1	8,323	248.35	43
351	J-94	144.00	0	0	245.37	44
72	J-Mission Inn 8	146.00	1	4,162	248.35	44
539	J-142	141.00	0	0	245.06	45
1217	J-386	141.00	0	0	249.80	47
860	J-Watermark 2	116.57	1	8,415	226.66	48
640	J-198	131.95	0	0	244.43	49
90	J-Mission Inn 14	131.00	0	0	245.60	50
96	J-25	130.00	0	0	245.16	50
114	J-27	129.00	1	15,606	244.32	50
50	J-Mission Inn 11	134.00	0	0	249.35	50
94	J-Mission Inn 15	130.00	0	0	245.41	50
92	J-23	130.00	0	0	245.57	50
338	J-93	128.00	0	0	244.12	50
100	J-26	128.00	1	3,121	244.64	50
1122	J-354	140.00	0	0	259.43	52
490	J-102	122.00	0	0	241.49	52
322	J-88	120.00	0	0	241.17	52
325	J-89	120.00	0	0	241.25	52
495	J-90	120.00	0	0	241.43	53

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
544	J-170	123.00	0	0	244.83	53
502	J-98	122.00	0	0	243.89	53
1178	J-Lake Hills 1	140.00	0	0	261.98	53
1245	J-WTP3-2	140.00	0	0	262.47	53
104	J-92	121.00	0	0	243.96	53
102	J-38	121.00	0	0	243.96	53
576	J-183	118.00	0	0	240.98	53
512	J-96	121.00	0	0	244.11	53
983	J-Venezia 23	105.00	1	12,485	228.14	53
315	J-104	117.00	0	0	240.20	53
978	J-Venezia 18	105.00	1	10,404	228.65	53
643	J-199	119.72	0	0	243.86	54
52	J-Mission Inn 12	125.00	0	0	249.33	54
340	J-97	119.00	1	14,566	243.72	54
110	J-40	116.00	1	11,444	241.01	54
108	J-39	116.00	0	0	241.10	54
319	J-87	115.00	0	0	240.19	54
54	J-Mission Inn 13	124.00	1	37,454	249.33	54
973	J-Venezia 19	102.41	1	11,444	228.57	55
772	J-240	100.95	0	0	227.12	55
1148	J-Watermark 1	100.95	0	0	227.12	55
348	J-95	118.00	1	17,687	244.31	55
897	J-Talichet 1	104.83	0	0	232.13	55
377	J-157	117.00	1	12,485	244.75	55
372	J-143	117.00	1	4,162	244.79	55
809	J-Mission Rise 5	100.08	1	11,093	228.45	56
1053	J-Venezia 2	100.09	0	0	229.95	56
812	J-Mission Rise 6	98.40	1	11,093	228.30	56
442	J-7	128.00	0	0	257.94	56
773	J-Venezia 1	100.12	0	0	230.09	56
334	J-91	113.00	1	4,162	243.07	56
332	J-99	113.00	1	10,404	243.11	56
37	J-5	128.00	0	0	258.42	56
848	J-Mission Rise 18	97.08	1	10,710	227.58	56
106	J-37	112.00	1	5,202	242.66	57
213	J-Venezia 3	99.00	0	0	229.69	57
968	J-Venezia 20	97.78	1	11,444	228.49	57
839	J-Mission Rise 15	96.89	1	10,710	227.61	57
815	J-Mission Rise 7	97.32	1	11,093	228.16	57
612	J-190	104.74	0	0	235.64	57
616	J-191	104.64	1	10,404	235.64	57
31	J-2	128.00	0	0	259.07	57
33	J-4	128.00	0	0	259.08	57

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
35	J-3	128.00	0	0	259.09	57
842	J-Mission Rise 16	96.14	1	10,710	227.61	57
169	J-63	104.00	1	12,485	235.65	57
239	J-132	95.00	0	0	227.06	57
235	J-131	95.00	0	0	227.19	57
702	J-Venezia 4	97.00	1	32,513	229.46	57
1133	J-Venezia 24	95.33	1	16,646	227.99	57
1108	J-Drake Point 3	126.24	1	67,320	259.04	57
895	J-Talichet 2	99.21	0	0	232.13	58
957	J-Venezia 25	95.00	1	10,404	227.92	58
306	J-106	106.00	0	0	239.02	58
786	J-248	102.22	0	0	235.63	58
165	J-60	102.00	1	11,444	235.64	58
167	J-61	102.00	0	0	235.64	58
215	J-77	102.00	0	0	235.64	58
824	J-Mission Rise 10	94.09	1	6,503	227.75	58
827	J-Mission Rise 11	94.06	1	6,503	227.73	58
818	J-Mission Rise 8	94.12	1	11,093	227.86	58
806	J-Mission Rise 4	94.43	1	11,093	228.60	58
1168	J-Venezia TH 1	95.00	0	0	229.60	58
566	J-62	101.00	0	0	235.64	58
1100	J-Golden Hills 1	92.58	1	232,178	227.83	59
881	J-Talichet II 1	94.95	1	5,738	230.29	59
211	J-56	100.22	0	0	235.63	59
1166	J-Venezia TH 2	94.00	1	6,885	229.50	59
156	J-54	100.06	1	2,081	235.63	59
203	J-51	100.00	1	2,081	235.59	59
201	J-52	100.00	0	0	235.60	59
635	J-197	100.00	0	0	235.63	59
963	J-Venezia 21	92.72	1	13,525	228.42	59
704	J-Venezia 5	93.00	0	0	228.75	59
304	J-86	103.00	1	3,121	239.02	59
724	J-220	90.23	0	0	226.62	59
934	J-Talichet 6	95.60	1	3,121	232.12	59
447	J-36	105.00	0	0	241.87	59
930	J-Talichet 3	95.16	1	6,242	232.13	59
245	J-134	90.00	1	10,404	227.05	59
241	J-133	90.00	0	0	227.05	59
932	J-Talichet 4	95.07	1	3,121	232.12	59
845	J-Mission Rise 17	90.35	1	10,710	227.60	59
776	J-Cedar Creek 1	91.69	1	65,408	229.00	59
121	J-32	104.00	1	20,808	241.57	60
836	J-Mission Rise 14	90.07	1	6,503	227.64	60

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
357	J-139	107.00	1	15,606	244.59	60
730	J-Venezia 30	90.81	0	0	228.41	60
1152	J-Mission Rise 22	89.96	0	0	227.56	60
123	J-35	104.00	1	12,485	241.72	60
1138	J-Venezia 32	90.74	1	4,162	228.65	60
720	J-Venezia 26	90.00	1	5,202	227.92	60
879	J-Talichet II 2	92.00	1	2,295	230.24	60
830	J-Mission Rise 12	89.37	1	6,503	227.71	60
1035	J-Venezia 34	90.25	1	2,081	228.65	60
1203	J-Venezia TH 3	91.00	1	8,798	229.47	60
1142	J-Mission Rise 1	90.47	0	0	229.02	60
158	J-53	97.00	1	13,525	235.63	60
688	J-209	97.00	1	5,202	235.63	60
803	J-Mission Rise 3	89.89	1	10,710	228.76	60
192	J-50	96.50	1	1,040	235.47	60
800	J-Mission Rise 2	89.97	1	10,710	228.97	60
1106	J-Drake Point 2	120.00	1	67,703	259.04	60
833	J-Mission Rise 13	88.53	1	6,503	227.68	60
851	J-Mission Rise 19	88.36	1	10,710	227.57	60
1043	J-324	95.01	0	0	234.25	60
1041	J-323	94.88	0	0	234.23	60
624	J-194	88.00	1	3,121	227.37	60
732	J-Venezia 31	89.16	1	6,242	228.65	60
154	J-58	96.00	1	1,040	235.64	60
629	J-196	96.00	1	13,525	235.64	60
1004	J-Venezia 12	88.68	1	4,162	228.33	60
876	J-The Reserve 14	89.84	0	0	229.51	60
1129	J-Venezia 10	88.52	1	11,444	228.33	60
1084	J-The Reserve 13	89.69	2	126,225	229.51	60
883	J-Talichet 14	90.88	1	3,121	230.75	61
186	J-49	95.08	1	1,040	234.96	61
1081	J-The Reserve 12	89.60	1	2,295	229.55	61
1078	J-The Reserve 11	89.47	1	2,295	229.60	61
1075	J-The Reserve 10	89.34	2	132,983	229.66	61
1064	J-329	88.47	0	0	228.82	61
607	J-189	95.00	0	0	235.64	61
529	J-156	104.00	0	0	244.64	61
821	J-Mission Rise 9	87.13	1	6,503	227.77	61
534	J-144	104.00	0	0	244.68	61
465	J-78	95.00	0	0	235.69	61
1059	J-Talichet 13	90.07	1	1,040	230.82	61
1157	J-330	87.56	0	0	228.66	61
762	J-234	88.95	0	0	230.13	61

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
936	J-Talichet 5	90.78	1	5,202	232.12	61
873	J-The Reserve 8	86.99	0	0	228.56	61
369	J-145	103.00	1	3,121	244.62	61
621	J-193	85.00	1	1,040	226.62	61
738	J-Venezia 33	87.00	1	6,242	228.65	61
507	J-136	102.00	0	0	243.67	61
255	J-79	94.00	1	4,162	235.70	61
994	J-Venezia 22	86.52	1	4,162	228.27	61
952	J-Venezia 29	85.03	1	5,202	226.83	61
1017	J-Venezia 6	86.57	0	0	228.37	61
712	J-215	86.31	0	0	228.33	61
885	J-Talichet 12	88.74	1	2,081	230.87	61
857	J-Mission Rise 21	85.31	1	10,710	227.56	62
706	J-Venezia 7	86.00	0	0	228.34	62
556	J-174	91.00	0	0	233.34	62
893	J-Talichet 7	89.60	1	12,485	232.12	62
854	J-Mission Rise 20	85.00	1	10,710	227.57	62
382	J-158	102.00	1	12,485	244.63	62
194	J-66	93.00	1	3,121	235.67	62
251	J-123	93.00	0	0	235.69	62
728	J-Venezia 28	84.00	0	0	226.83	62
797	J-251	85.79	0	0	229.00	62
793	J-Venezia 35	85.52	0	0	228.76	62
585	J-185	90.00	0	0	233.40	62
914	J-Talichet 17	87.41	1	5,202	230.83	62
790	J-249	85.17	0	0	228.92	62
1097	J-The Reserve 7	85.00	1	92,565	228.79	62
722	J-Venezia 27	83.00	1	11,444	226.83	62
1095	J-The Reserve 6	85.05	1	92,565	228.94	62
1093	J-The Reserve 5	85.01	1	3,825	229.03	62
1091	J-The Reserve 4	85.00	1	3,825	229.12	62
436	J-45	90.00	0	0	234.23	62
1089	J-The Reserve 3	85.01	1	25,628	229.33	62
432	J-44	90.00	0	0	234.35	62
775	J-The Reserve 1	85.21	0	0	229.75	63
1087	J-The Reserve 2	85.05	1	32,895	229.67	63
379	J-155	100.00	1	8,323	244.62	63
152	J-76	91.00	1	8,323	235.74	63
475	J-120	91.00	0	0	235.98	63
887	J-Talichet 11	86.01	1	31,860	231.06	63
718	J-Venezia 11	83.00	1	8,323	228.33	63
581	J-184	93.00	0	0	238.43	63
1205	J-Venezia TH 4	84.00	1	27,540	229.47	63

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
759	J-The Reserve 9	86.74	1	8,798	232.37	63
597	J-187	90.00	0	0	235.68	63
179	J-67	90.00	0	0	235.69	63
910	J-Talichet 15	85.00	1	11,444	230.77	63
912	J-Talichet 16	85.00	1	7,283	230.80	63
1012	J-Venezia 9	82.26	1	6,242	228.33	63
754	J-229	82.11	0	0	228.35	63
480	J-118	90.00	0	0	236.30	63
268	J-81	90.00	1	4,162	236.30	63
708	J-Venezia 8	82.00	1	2,081	228.33	63
889	J-Talichet 10	85.00	1	3,121	231.66	63
198	J-65	89.00	1	5,202	235.67	63
173	J-64	89.00	0	0	235.68	63
1032	J-Venezia 17	81.62	1	2,081	228.33	63
1023	J-Venezia 13	81.45	1	3,121	228.33	64
891	J-Talichet 8	85.00	1	18,727	232.12	64
923	J-Talichet 9	85.00	1	3,121	232.12	64
677	J-WTP1-6	86.25	0	0	233.40	64
678	J-WTP1-5	86.25	0	0	233.40	64
679	J-WTP1-4	86.25	0	0	233.40	64
926	J-295	85.00	1	3,121	232.32	64
716	J-Venezia 16	81.00	1	4,162	228.33	64
133	J-33	91.00	0	0	238.33	64
756	J-Whispering Hills 1	81.37	0	0	228.71	64
549	J-Mitchell 1	85.00	1	13,525	232.37	64
592	J-186	85.00	1	7,283	232.42	64
602	J-188	88.00	0	0	235.68	64
999	J-Venezia 14	80.56	1	4,162	228.33	64
257	J-80	88.00	1	4,162	235.99	64
757	J-231	80.71	0	0	228.76	64
769	J-238	85.00	0	0	233.27	64
710	J-Venezia 15	80.00	1	3,121	228.33	64
554	J-173	84.00	0	0	232.41	64
176	J-75	87.00	0	0	235.72	64
452	J-41	89.00	1	5,202	238.20	65
524	J-154	95.00	0	0	244.55	65
1214	J-Venezia S	79.00	0	0	228.66	65
119	J-29	92.00	1	12,485	241.69	65
181	J-68	86.00	0	0	235.70	65
116	J-28	92.00	0	0	241.76	65
1170	J-369	82.00	0	0	232.37	65
552	J-172	82.00	0	0	232.39	65
470	J-122	85.00	0	0	235.68	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
141	J-70	85.00	0	0	235.91	65
301	J-85	87.00	0	0	238.03	65
143	J-71	85.00	0	0	236.05	65
231	J-130	77.00	0	0	228.37	65
386	J-153	93.00	1	6,242	244.54	66
388	J-159	93.00	0	0	244.54	66
367	J-146	93.00	1	3,121	244.54	66
457	J-125	82.31	1	10,404	234.31	66
249	J-121	83.00	1	5,202	235.68	66
130	J-31	88.00	0	0	240.73	66
429	J-43	84.00	1	9,364	236.87	66
139	J-42	84.00	0	0	237.10	66
126	J-30	88.00	0	0	241.21	66
404	J-162	91.00	0	0	244.49	66
264	J-117	82.00	0	0	236.30	67
400	J-160	90.00	1	16,646	244.49	67
150	J-74	81.00	1	2,081	235.91	67
273	J-113	81.00	0	0	236.67	67
275	J-82	81.00	0	0	236.67	67
227	J-129	75.00	1	20,808	230.71	67
485	J-108	82.00	0	0	238.03	68
219	J-Island 1	77.00	1	2,081	233.11	68
135	J-34	84.00	1	10,404	240.42	68
407	J-163	88.00	1	3,121	244.49	68
426	J-168	87.00	0	0	244.48	68
402	J-161	87.00	0	0	244.49	68
1068	J-Whispering Hills 3	70.72	1	47,813	228.54	68
1110	J-Lake Hills 12	101.23	0	0	259.19	68
259	J-119	78.00	1	11,444	235.98	68
148	J-73	77.00	0	0	236.61	69
280	J-112	77.00	0	0	236.65	69
112	J-72	77.00	0	0	237.02	69
289	J-84	77.00	0	0	237.06	69
422	J-150	83.00	1	3,121	244.48	70
393	J-151	83.00	1	6,242	244.49	70
391	J-152	83.00	0	0	244.49	70
365	J-147	81.00	1	3,121	244.49	71
1070	J-Whispering Hills 4	65.00	1	11,858	228.53	71
1112	J-Thompson Grove 1	92.46	1	104,040	259.17	72
1102	J-Lake Hills 11	92.23	0	0	259.35	72
1195	J-Lake Hills 10	92.00	1	27,158	259.35	72
419	J-149	77.00	0	0	244.46	72
225	J-Island 3	65.00	1	9,364	233.10	73

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 1 Off-line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
262	J-116	68.00	1	15,606	236.30	73
217	J-124	67.00	0	0	235.34	73
360	J-138	76.00	1	11,444	244.45	73
363	J-148	76.00	0	0	244.45	73
292	J-110	68.00	0	0	237.07	73
409	J-164	75.00	1	12,485	244.48	73
313	J-103	70.00	1	19,768	240.20	74
327	J-101	71.00	1	13,525	241.83	74
299	J-107	67.00	1	13,525	238.03	74
221	J-Island 2	62.00	1	4,162	233.10	74
1119	J-Westminster 1	87.02	1	133,875	259.14	74
330	J-100	70.00	1	7,283	242.44	75
413	J-166	72.00	0	0	244.48	75
271	J-115	64.00	1	9,364	236.66	75
286	J-111	64.00	1	1,040	236.92	75
310	J-105	66.00	1	14,566	239.02	75
296	J-109	64.00	0	0	237.07	75
343	J-135	70.00	1	13,525	243.52	75
646	J-200	70.00	0	0	243.67	75
346	J-137	70.00	1	13,525	244.14	75
519	J-169	69.00	0	0	244.47	76
1183	J-Lake Hills 3	84.00	1	27,540	259.68	76
417	J-167	68.00	1	8,323	244.47	76
1184	J-Lake Hills 4	82.00	1	27,540	259.52	77
1177	J-Lake Hills 2	81.00	2	169,575	259.75	77
1188	J-Lake Hills 6	80.00	1	27,158	259.44	78
411	J-165	64.00	1	5,202	244.35	78
1192	J-Lake Hills 7	79.00	1	27,158	259.42	78
1196	J-Lake Hills 9	76.00	1	27,540	259.36	79
1104	J-Drake Point 1	75.00	1	67,703	259.07	80
1187	J-Lake Hills 5	75.00	1	27,158	259.47	80
1114	J-Cypress Point 1	73.64	1	21,038	259.14	80
1189	J-Lake Hills 8	71.00	1	27,158	259.39	82
1116	J-Cypress Point 2	70.02	1	21,038	259.14	82

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
668	J-WTP1-3	81.00	0	0	82.96	1
666	J-WTP1-2	81.00	0	0	82.96	1
664	J-WTP1-1	81.00	0	0	82.96	1
1248	J-WTP3-1	140.00	0	0	142.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	1	60,053	246.77	38
68	J-Mission Inn 6	154.00	1	16,646	245.14	39
568	J-Mission Inn 5	154.00	0	0	245.20	39
66	J-Mission Inn 10	152.00	0	0	245.12	40
41	J-6	152.00	0	0	245.21	40
355	J-140	152.00	0	0	245.66	41
44	J-8	152.00	1	1,040	245.68	41
46	J-9	151.00	0	0	245.26	41
74	J-Mission Inn 9	150.00	1	4,162	245.14	41
78	J-Mission Inn 4	150.00	0	0	245.27	41
82	J-Mission Inn 3	149.00	0	0	245.27	42
86	J-Mission Inn 2	149.00	1	15,606	245.28	42
70	J-Mission Inn 7	148.00	1	8,323	245.14	42
48	J-Mission Inn 1	148.00	0	0	245.31	42
72	J-Mission Inn 8	146.00	1	4,162	245.14	43
374	J-141	146.00	0	0	245.65	43
764	J-Whispering Hills 2	146.07	0	0	246.67	44
866	J-Watermark 4	145.57	1	9,180	246.77	44
351	J-94	144.00	0	0	245.69	44
1217	J-386	141.00	0	0	245.05	45
1178	J-Lake Hills 1	140.00	0	0	244.37	45
1245	J-WTP3-2	140.00	0	0	244.37	45
1122	J-354	140.00	0	0	244.39	45
539	J-142	141.00	0	0	245.65	45
50	J-Mission Inn 11	134.00	0	0	245.07	48
863	J-Watermark 3	135.17	1	8,415	246.78	48
1162	J-365	135.00	0	0	246.77	48
640	J-198	131.95	0	0	245.73	49
90	J-Mission Inn 14	131.00	0	0	245.50	50
92	J-23	130.00	0	0	245.51	50
94	J-Mission Inn 15	130.00	0	0	245.53	50
96	J-25	130.00	0	0	245.57	50
33	J-4	128.00	0	0	244.38	50
31	J-2	128.00	0	0	244.38	50
35	J-3	128.00	0	0	244.38	50
37	J-5	128.00	0	0	244.43	50
442	J-7	128.00	0	0	244.46	50
114	J-27	129.00	1	15,606	245.67	50
1108	J-Drake Point 3	126.24	1	67,320	243.85	51
100	J-26	128.00	1	3,121	245.64	51

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
338	J-93	128.00	0	0	245.74	51
52	J-Mission Inn 12	125.00	0	0	245.06	52
54	J-Mission Inn 13	124.00	1	37,454	245.05	52
544	J-170	123.00	0	0	245.64	53
502	J-98	122.00	0	0	245.74	54
1106	J-Drake Point 2	120.00	1	67,703	243.86	54
490	J-102	122.00	0	0	246.02	54
512	J-96	121.00	0	0	245.71	54
102	J-38	121.00	0	0	245.75	54
104	J-92	121.00	0	0	245.75	54
643	J-199	119.72	0	0	245.73	55
495	J-90	120.00	0	0	246.06	55
325	J-89	120.00	0	0	246.09	55
322	J-88	120.00	0	0	246.10	55
340	J-97	119.00	1	14,566	245.74	55
348	J-95	118.00	1	17,687	245.69	55
576	J-183	118.00	0	0	246.11	55
377	J-157	117.00	1	12,485	245.64	56
372	J-143	117.00	1	4,162	245.64	56
315	J-104	117.00	0	0	246.14	56
108	J-39	116.00	0	0	246.13	56
110	J-40	116.00	1	11,444	246.15	56
860	J-Watermark 2	116.57	1	8,415	246.79	56
319	J-87	115.00	0	0	246.16	57
332	J-99	113.00	1	10,404	245.81	57
334	J-91	113.00	1	4,162	245.83	57
106	J-37	112.00	1	5,202	245.95	58
357	J-139	107.00	1	15,606	245.66	60
306	J-106	106.00	0	0	246.28	61
447	J-36	105.00	0	0	246.08	61
529	J-156	104.00	0	0	245.64	61
534	J-144	104.00	0	0	245.64	61
983	J-Venezia 23	105.00	1	12,485	246.76	61
978	J-Venezia 18	105.00	1	10,404	246.83	61
612	J-190	104.74	0	0	246.64	61
616	J-191	104.64	1	10,404	246.65	61
123	J-35	104.00	1	12,485	246.11	61
121	J-32	104.00	1	20,808	246.11	61
369	J-145	103.00	1	3,121	245.64	62
897	J-Talichet 1	104.83	0	0	247.53	62
169	J-63	104.00	1	12,485	246.87	62
1110	J-Lake Hills 12	101.23	0	0	244.22	62
304	J-86	103.00	1	3,121	246.29	62
382	J-158	102.00	1	12,485	245.63	62
507	J-136	102.00	0	0	245.74	62

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
973	J-Venezia 19	102.41	1	11,444	246.82	62
215	J-77	102.00	0	0	246.60	63
786	J-248	102.22	0	0	246.83	63
165	J-60	102.00	1	11,444	246.84	63
167	J-61	102.00	0	0	246.84	63
379	J-155	100.00	1	8,323	245.64	63
566	J-62	101.00	0	0	246.84	63
772	J-240	100.95	0	0	246.80	63
1148	J-Watermark 1	100.95	0	0	246.80	63
211	J-56	100.22	0	0	246.79	63
635	J-197	100.00	0	0	246.60	63
156	J-54	100.06	1	2,081	246.80	63
809	J-Mission Rise 5	100.08	1	11,093	246.84	63
201	J-52	100.00	0	0	246.96	64
203	J-51	100.00	1	2,081	246.97	64
773	J-Venezia 1	100.12	0	0	247.09	64
1053	J-Venezia 2	100.09	0	0	247.06	64
213	J-Venezia 3	99.00	0	0	247.00	64
895	J-Talichet 2	99.21	0	0	247.55	64
812	J-Mission Rise 6	98.40	1	11,093	246.79	64
968	J-Venezia 20	97.78	1	11,444	246.82	64
815	J-Mission Rise 7	97.32	1	11,093	246.75	65
848	J-Mission Rise 18	97.08	1	10,710	246.73	65
839	J-Mission Rise 15	96.89	1	10,710	246.69	65
688	J-209	97.00	1	5,202	246.81	65
158	J-53	97.00	1	13,525	246.83	65
702	J-Venezia 4	97.00	1	32,513	246.94	65
842	J-Mission Rise 16	96.14	1	10,710	246.69	65
192	J-50	96.50	1	1,040	247.07	65
524	J-154	95.00	0	0	245.64	65
154	J-58	96.00	1	1,040	246.83	65
629	J-196	96.00	1	13,525	246.84	65
1133	J-Venezia 24	95.33	1	16,646	246.77	66
465	J-78	95.00	0	0	246.60	66
235	J-131	95.00	0	0	246.73	66
239	J-132	95.00	0	0	246.73	66
1112	J-Thompson Grove 1	92.46	1	104,040	244.20	66
957	J-Venezia 25	95.00	1	10,404	246.78	66
607	J-189	95.00	0	0	246.83	66
1102	J-Lake Hills 11	92.23	0	0	244.16	66
934	J-Talichet 6	95.60	1	3,121	247.54	66
1168	J-Venezia TH 1	95.00	0	0	246.97	66
1195	J-Lake Hills 10	92.00	1	27,158	244.15	66
881	J-Talichet II 1	94.95	1	5,738	247.13	66
186	J-49	95.08	1	1,040	247.41	66

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
930	J-Talichet 3	95.16	1	6,242	247.55	66
806	J-Mission Rise 4	94.43	1	11,093	246.90	66
932	J-Talichet 4	95.07	1	3,121	247.54	66
818	J-Mission Rise 8	94.12	1	11,093	246.65	66
824	J-Mission Rise 10	94.09	1	6,503	246.66	66
255	J-79	94.00	1	4,162	246.60	66
827	J-Mission Rise 11	94.06	1	6,503	246.66	66
386	J-153	93.00	1	6,242	245.64	66
388	J-159	93.00	0	0	245.64	66
367	J-146	93.00	1	3,121	245.64	66
1043	J-324	95.01	0	0	247.82	66
1166	J-Venezia TH 2	94.00	1	6,885	246.94	66
1041	J-323	94.88	0	0	247.86	66
581	J-184	93.00	0	0	246.37	66
251	J-123	93.00	0	0	246.59	66
704	J-Venezia 5	93.00	0	0	246.84	67
194	J-66	93.00	1	3,121	246.97	67
1100	J-Golden Hills 1	92.58	1	232,178	246.62	67
116	J-28	92.00	0	0	246.07	67
119	J-29	92.00	1	12,485	246.08	67
963	J-Venezia 21	92.72	1	13,525	246.82	67
404	J-162	91.00	0	0	245.63	67
879	J-Talichet II 2	92.00	1	2,295	247.12	67
776	J-Cedar Creek 1	91.69	1	65,408	247.03	67
475	J-120	91.00	0	0	246.59	67
400	J-160	90.00	1	16,646	245.63	67
133	J-33	91.00	0	0	246.82	67
152	J-76	91.00	1	8,323	246.88	67
1203	J-Venezia TH 3	91.00	1	8,798	246.92	67
730	J-Venezia 30	90.81	0	0	246.82	67
1138	J-Venezia 32	90.74	1	4,162	246.86	68
845	J-Mission Rise 17	90.35	1	10,710	246.70	68
883	J-Talichet 14	90.88	1	3,121	247.27	68
724	J-220	90.23	0	0	246.77	68
1142	J-Mission Rise 1	90.47	0	0	247.06	68
480	J-118	90.00	0	0	246.59	68
268	J-81	90.00	1	4,162	246.59	68
1035	J-Venezia 34	90.25	1	2,081	246.86	68
836	J-Mission Rise 14	90.07	1	6,503	246.68	68
245	J-134	90.00	1	10,404	246.73	68
241	J-133	90.00	0	0	246.73	68
936	J-Talichet 5	90.78	1	5,202	247.54	68
720	J-Venezia 26	90.00	1	5,202	246.78	68
1152	J-Mission Rise 22	89.96	0	0	246.81	68
597	J-187	90.00	0	0	246.96	68

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
179	J-67	90.00	0	0	246.97	68
803	J-Mission Rise 3	89.89	1	10,710	246.96	68
800	J-Mission Rise 2	89.97	1	10,710	247.04	68
876	J-The Reserve 14	89.84	0	0	246.97	68
1119	J-Westminster 1	87.02	1	133,875	244.17	68
1059	J-Talichet 13	90.07	1	1,040	247.30	68
1084	J-The Reserve 13	89.69	2	126,225	246.94	68
830	J-Mission Rise 12	89.37	1	6,503	246.66	68
1081	J-The Reserve 12	89.60	1	2,295	246.94	68
1078	J-The Reserve 11	89.47	1	2,295	246.95	68
1075	J-The Reserve 10	89.34	2	132,983	246.95	68
407	J-163	88.00	1	3,121	245.63	68
732	J-Venezia 31	89.16	1	6,242	246.86	68
432	J-44	90.00	0	0	247.82	68
452	J-41	89.00	1	5,202	246.84	68
436	J-45	90.00	0	0	247.86	68
173	J-64	89.00	0	0	246.92	68
198	J-65	89.00	1	5,202	246.94	68
893	J-Talichet 7	89.60	1	12,485	247.62	68
556	J-174	91.00	0	0	249.05	68
1004	J-Venezia 12	88.68	1	4,162	246.73	68
762	J-234	88.95	0	0	247.09	68
833	J-Mission Rise 13	88.53	1	6,503	246.67	68
126	J-30	88.00	0	0	246.19	68
1129	J-Venezia 10	88.52	1	11,444	246.73	68
130	J-31	88.00	0	0	246.29	68
851	J-Mission Rise 19	88.36	1	10,710	246.74	69
1064	J-329	88.47	0	0	246.92	69
885	J-Talichet 12	88.74	1	2,081	247.31	69
257	J-80	88.00	1	4,162	246.59	69
402	J-161	87.00	0	0	245.63	69
426	J-168	87.00	0	0	245.63	69
624	J-194	88.00	1	3,121	246.72	69
602	J-188	88.00	0	0	246.92	69
585	J-185	90.00	0	0	249.11	69
1157	J-330	87.56	0	0	246.91	69
301	J-85	87.00	0	0	246.43	69
821	J-Mission Rise 9	87.13	1	6,503	246.66	69
738	J-Venezia 33	87.00	1	6,242	246.86	69
914	J-Talichet 17	87.41	1	5,202	247.30	69
873	J-The Reserve 8	86.99	0	0	246.91	69
176	J-75	87.00	0	0	246.94	69
1183	J-Lake Hills 3	84.00	1	27,540	244.19	69
1017	J-Venezia 6	86.57	0	0	246.76	69
994	J-Venezia 22	86.52	1	4,162	246.76	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
712	J-215	86.31	0	0	246.69	69
706	J-Venezia 7	86.00	0	0	246.76	70
181	J-68	86.00	0	0	247.00	70
797	J-251	85.79	0	0	246.93	70
759	J-The Reserve 9	86.74	1	8,798	248.06	70
793	J-Venezia 35	85.52	0	0	246.89	70
887	J-Talichet 11	86.01	1	31,860	247.38	70
857	J-Mission Rise 21	85.31	1	10,710	246.77	70
470	J-122	85.00	0	0	246.59	70
952	J-Venezia 29	85.03	1	5,202	246.77	70
790	J-249	85.17	0	0	246.92	70
854	J-Mission Rise 20	85.00	1	10,710	246.75	70
621	J-193	85.00	1	1,040	246.77	70
1097	J-The Reserve 7	85.00	1	92,565	246.96	70
1095	J-The Reserve 6	85.05	1	92,565	247.01	70
1093	J-The Reserve 5	85.01	1	3,825	247.05	70
1091	J-The Reserve 4	85.00	1	3,825	247.09	70
1184	J-Lake Hills 4	82.00	1	27,540	244.15	70
775	J-The Reserve 1	85.21	0	0	247.39	70
1089	J-The Reserve 3	85.01	1	25,628	247.19	70
143	J-71	85.00	0	0	247.28	70
910	J-Talichet 15	85.00	1	11,444	247.28	70
912	J-Talichet 16	85.00	1	7,283	247.29	70
1087	J-The Reserve 2	85.05	1	32,895	247.35	70
135	J-34	84.00	1	10,404	246.36	70
141	J-70	85.00	0	0	247.36	70
889	J-Talichet 10	85.00	1	3,121	247.62	70
393	J-151	83.00	1	6,242	245.64	70
422	J-150	83.00	1	3,121	245.64	70
391	J-152	83.00	0	0	245.64	70
728	J-Venezia 28	84.00	0	0	246.77	70
891	J-Talichet 8	85.00	1	18,727	247.77	70
923	J-Talichet 9	85.00	1	3,121	247.80	70
1205	J-Venezia TH 4	84.00	1	27,540	246.91	70
926	J-295	85.00	1	3,121	248.01	71
549	J-Mitchell 1	85.00	1	13,525	248.06	71
429	J-43	84.00	1	9,364	247.08	71
139	J-42	84.00	0	0	247.09	71
592	J-186	85.00	1	7,283	248.11	71
677	J-WTP1-6	86.25	0	0	249.37	71
678	J-WTP1-5	86.25	0	0	249.37	71
679	J-WTP1-4	86.25	0	0	249.37	71
1177	J-Lake Hills 2	81.00	2	169,575	244.21	71
249	J-121	83.00	1	5,202	246.59	71
718	J-Venezia 11	83.00	1	8,323	246.73	71

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
722	J-Venezia 27	83.00	1	11,444	246.77	71
769	J-238	85.00	0	0	249.05	71
554	J-173	84.00	0	0	248.10	71
1188	J-Lake Hills 6	80.00	1	27,158	244.14	71
457	J-125	82.31	1	10,404	246.58	71
485	J-108	82.00	0	0	246.43	71
1012	J-Venezia 9	82.26	1	6,242	246.73	71
754	J-229	82.11	0	0	246.68	71
264	J-117	82.00	0	0	246.59	71
365	J-147	81.00	1	3,121	245.64	71
708	J-Venezia 8	82.00	1	2,081	246.73	71
1032	J-Venezia 17	81.62	1	2,081	246.70	71
1192	J-Lake Hills 7	79.00	1	27,158	244.14	71
756	J-Whispering Hills 1	81.37	0	0	246.60	71
1023	J-Venezia 13	81.45	1	3,121	246.72	72
273	J-113	81.00	0	0	246.60	72
275	J-82	81.00	0	0	246.60	72
716	J-Venezia 16	81.00	1	4,162	246.70	72
150	J-74	81.00	1	2,081	246.88	72
757	J-231	80.71	0	0	246.60	72
1170	J-369	82.00	0	0	248.06	72
552	J-172	82.00	0	0	248.08	72
999	J-Venezia 14	80.56	1	4,162	246.71	72
710	J-Venezia 15	80.00	1	3,121	246.70	72
1214	J-Venezia S	79.00	0	0	246.91	73
1196	J-Lake Hills 9	76.00	1	27,540	244.14	73
259	J-119	78.00	1	11,444	246.59	73
419	J-149	77.00	0	0	245.64	73
1104	J-Drake Point 1	75.00	1	67,703	243.89	73
1187	J-Lake Hills 5	75.00	1	27,158	244.14	73
219	J-Island 1	77.00	1	2,081	246.57	73
289	J-84	77.00	0	0	246.61	73
363	J-148	76.00	0	0	245.65	73
360	J-138	76.00	1	11,444	245.65	73
231	J-130	77.00	0	0	246.68	73
112	J-72	77.00	0	0	246.70	73
280	J-112	77.00	0	0	246.74	73
148	J-73	77.00	0	0	246.76	73
1114	J-Cypress Point 1	73.64	1	21,038	244.17	74
409	J-164	75.00	1	12,485	245.63	74
227	J-129	75.00	1	20,808	246.57	74
1189	J-Lake Hills 8	71.00	1	27,158	244.14	75
413	J-166	72.00	0	0	245.63	75
1116	J-Cypress Point 2	70.02	1	21,038	244.17	75
327	J-101	71.00	1	13,525	245.94	76

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
346	J-137	70.00	1	13,525	245.69	76
646	J-200	70.00	0	0	245.73	76
343	J-135	70.00	1	13,525	245.75	76
330	J-100	70.00	1	7,283	245.87	76
1068	J-Whispering Hills 3	70.72	1	47,813	246.60	76
313	J-103	70.00	1	19,768	246.13	76
519	J-169	69.00	0	0	245.64	76
417	J-167	68.00	1	8,323	245.63	77
292	J-110	68.00	0	0	246.59	77
262	J-116	68.00	1	15,606	246.59	77
299	J-107	67.00	1	13,525	246.42	78
217	J-124	67.00	0	0	246.59	78
310	J-105	66.00	1	14,566	246.28	78
411	J-165	64.00	1	5,202	245.50	79
225	J-Island 3	65.00	1	9,364	246.56	79
1070	J-Whispering Hills 4	65.00	1	11,858	246.60	79
296	J-109	64.00	0	0	246.58	79
271	J-115	64.00	1	9,364	246.59	79
286	J-111	64.00	1	1,040	246.59	79
221	J-Island 2	62.00	1	4,162	246.56	80

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
668	J-WTP1-3	81.00	0	0	82.89	1
666	J-WTP1-2	81.00	0	0	82.90	1
664	J-WTP1-1	81.00	0	0	82.90	1
1248	J-WTP3-1	140.00	0	0	142.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
68	J-Mission Inn 6	154.00	2	2,176,646	237.60	36
568	J-Mission Inn 5	154.00	0	0	239.37	37
66	J-Mission Inn 10	152.00	0	0	238.57	37
74	J-Mission Inn 9	150.00	1	4,162	237.60	38
70	J-Mission Inn 7	148.00	1	8,323	237.60	39
41	J-6	152.00	0	0	243.01	39
78	J-Mission Inn 4	150.00	0	0	241.52	40
72	J-Mission Inn 8	146.00	1	4,162	237.60	40
46	J-9	151.00	0	0	243.13	40
82	J-Mission Inn 3	149.00	0	0	241.60	40
86	J-Mission Inn 2	149.00	1	15,606	241.82	40
48	J-Mission Inn 1	148.00	0	0	243.39	41
44	J-8	152.00	1	1,040	247.59	41
355	J-140	152.00	0	0	247.60	41
869	J-Watermark 5	159.36	1	60,053	258.45	43
1217	J-386	141.00	0	0	241.51	43
1178	J-Lake Hills 1	140.00	0	0	241.07	44
1245	J-WTP3-2	140.00	0	0	241.07	44
1122	J-354	140.00	0	0	241.09	44
374	J-141	146.00	0	0	247.60	44
351	J-94	144.00	0	0	247.58	45
50	J-Mission Inn 11	134.00	0	0	240.32	46
539	J-142	141.00	0	0	247.60	46
764	J-Whispering Hills 2	146.07	0	0	257.81	48
866	J-Watermark 4	145.57	1	9,180	258.49	49
33	J-4	128.00	0	0	241.08	49
35	J-3	128.00	0	0	241.09	49
31	J-2	128.00	0	0	241.09	49
37	J-5	128.00	0	0	241.20	49
442	J-7	128.00	0	0	241.27	49
90	J-Mission Inn 14	131.00	0	0	244.90	49
1108	J-Drake Point 3	126.24	1	67,320	240.55	49
92	J-23	130.00	0	0	245.04	50
94	J-Mission Inn 15	130.00	0	0	245.20	50
52	J-Mission Inn 12	125.00	0	0	240.31	50
640	J-198	131.95	0	0	247.50	50
96	J-25	130.00	0	0	245.57	50
54	J-Mission Inn 13	124.00	1	37,454	240.31	50

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
114	J-27	129.00	1	15,606	246.53	51
100	J-26	128.00	1	3,121	246.25	51
338	J-93	128.00	0	0	247.47	52
1106	J-Drake Point 2	120.00	1	67,703	240.56	52
863	J-Watermark 3	135.17	1	8,415	258.51	53
1162	J-365	135.00	0	0	258.44	53
544	J-170	123.00	0	0	247.60	54
502	J-98	122.00	0	0	247.71	54
102	J-38	121.00	0	0	247.17	55
104	J-92	121.00	0	0	247.31	55
512	J-96	121.00	0	0	247.78	55
490	J-102	122.00	0	0	249.63	55
643	J-199	119.72	0	0	247.85	55
340	J-97	119.00	1	14,566	247.89	56
348	J-95	118.00	1	17,687	247.72	56
495	J-90	120.00	0	0	249.73	56
325	J-89	120.00	0	0	249.89	56
322	J-88	120.00	0	0	249.97	56
377	J-157	117.00	1	12,485	247.60	57
372	J-143	117.00	1	4,162	247.60	57
576	J-183	118.00	0	0	250.11	57
315	J-104	117.00	0	0	250.67	58
108	J-39	116.00	0	0	250.07	58
110	J-40	116.00	1	11,444	250.16	58
332	J-99	113.00	1	10,404	248.22	59
334	J-91	113.00	1	4,162	248.22	59
319	J-87	115.00	0	0	250.71	59
106	J-37	112.00	1	5,202	248.52	59
1110	J-Lake Hills 12	101.23	0	0	240.92	60
357	J-139	107.00	1	15,606	247.63	61
860	J-Watermark 2	116.57	1	8,415	258.55	61
529	J-156	104.00	0	0	247.60	62
534	J-144	104.00	0	0	247.60	62
447	J-36	105.00	0	0	249.36	62
369	J-145	103.00	1	3,121	247.61	63
123	J-35	104.00	1	12,485	249.53	63
121	J-32	104.00	1	20,808	249.58	63
382	J-158	102.00	1	12,485	247.60	63
306	J-106	106.00	0	0	251.74	63
507	J-136	102.00	0	0	247.93	63
379	J-155	100.00	1	8,323	247.60	64
1112	J-Thompson Grove 1	92.46	1	104,040	240.90	64
1102	J-Lake Hills 11	92.23	0	0	240.86	64

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
304	J-86	103.00	1	3,121	251.75	64
1195	J-Lake Hills 10	92.00	1	27,158	240.85	64
612	J-190	104.74	0	0	254.59	65
616	J-191	104.64	1	10,404	254.63	65
169	J-63	104.00	1	12,485	255.31	65
215	J-77	102.00	0	0	254.43	66
524	J-154	95.00	0	0	247.60	66
786	J-248	102.22	0	0	255.22	66
165	J-60	102.00	1	11,444	255.26	66
167	J-61	102.00	0	0	255.26	66
983	J-Venezia 23	105.00	1	12,485	258.31	66
978	J-Venezia 18	105.00	1	10,404	258.44	66
1119	J-Westminster 1	87.02	1	133,875	240.88	67
897	J-Talichet 1	104.83	0	0	258.89	67
566	J-62	101.00	0	0	255.26	67
635	J-197	100.00	0	0	254.44	67
386	J-153	93.00	1	6,242	247.60	67
388	J-159	93.00	0	0	247.61	67
367	J-146	93.00	1	3,121	247.61	67
211	J-56	100.22	0	0	255.07	67
156	J-54	100.06	1	2,081	255.12	67
201	J-52	100.00	0	0	255.58	67
203	J-51	100.00	1	2,081	255.59	67
973	J-Venezia 19	102.41	1	11,444	258.44	68
404	J-162	91.00	0	0	247.60	68
1183	J-Lake Hills 3	84.00	1	27,540	240.89	68
116	J-28	92.00	0	0	249.34	68
119	J-29	92.00	1	12,485	249.42	68
400	J-160	90.00	1	16,646	247.60	68
772	J-240	100.95	0	0	258.58	68
1148	J-Watermark 1	100.95	0	0	258.58	68
688	J-209	97.00	1	5,202	255.15	68
158	J-53	97.00	1	13,525	255.22	68
773	J-Venezia 1	100.12	0	0	258.69	69
1053	J-Venezia 2	100.09	0	0	258.66	69
1184	J-Lake Hills 4	82.00	1	27,540	240.85	69
809	J-Mission Rise 5	100.08	1	11,093	258.99	69
154	J-58	96.00	1	1,040	255.22	69
629	J-196	96.00	1	13,525	255.22	69
581	J-184	93.00	0	0	252.35	69
465	J-78	95.00	0	0	254.38	69
192	J-50	96.50	1	1,040	255.96	69
213	J-Venezia 3	99.00	0	0	258.60	69

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
407	J-163	88.00	1	3,121	247.60	69
895	J-Talichet 2	99.21	0	0	258.96	69
1177	J-Lake Hills 2	81.00	2	169,575	240.91	69
607	J-189	95.00	0	0	255.22	69
255	J-79	94.00	1	4,162	254.38	69
812	J-Mission Rise 6	98.40	1	11,093	258.89	69
402	J-161	87.00	0	0	247.60	69
426	J-168	87.00	0	0	247.60	69
968	J-Venezia 20	97.78	1	11,444	258.45	70
1188	J-Lake Hills 6	80.00	1	27,158	240.84	70
251	J-123	93.00	0	0	254.37	70
815	J-Mission Rise 7	97.32	1	11,093	258.81	70
848	J-Mission Rise 18	97.08	1	10,710	258.59	70
702	J-Venezia 4	97.00	1	32,513	258.55	70
839	J-Mission Rise 15	96.89	1	10,710	258.59	70
1192	J-Lake Hills 7	79.00	1	27,158	240.84	70
126	J-30	88.00	0	0	250.02	70
186	J-49	95.08	1	1,040	257.25	70
842	J-Mission Rise 16	96.14	1	10,710	258.59	70
194	J-66	93.00	1	3,121	255.55	70
133	J-33	91.00	0	0	253.59	70
130	J-31	88.00	0	0	250.62	70
1133	J-Venezia 24	95.33	1	16,646	258.36	71
475	J-120	91.00	0	0	254.21	71
235	J-131	95.00	0	0	258.22	71
239	J-132	95.00	0	0	258.25	71
934	J-Talichet 6	95.60	1	3,121	258.96	71
957	J-Venezia 25	95.00	1	10,404	258.39	71
1168	J-Venezia TH 1	95.00	0	0	258.57	71
930	J-Talichet 3	95.16	1	6,242	258.96	71
932	J-Talichet 4	95.07	1	3,121	258.96	71
1043	J-324	95.01	0	0	258.90	71
480	J-118	90.00	0	0	254.08	71
268	J-81	90.00	1	4,162	254.08	71
881	J-Talichet II 1	94.95	1	5,738	259.03	71
1041	J-323	94.88	0	0	259.02	71
152	J-76	91.00	1	8,323	255.26	71
818	J-Mission Rise 8	94.12	1	11,093	258.62	71
824	J-Mission Rise 10	94.09	1	6,503	258.60	71
827	J-Mission Rise 11	94.06	1	6,503	258.60	71
1166	J-Venezia TH 2	94.00	1	6,885	258.55	71
391	J-152	83.00	0	0	247.60	71
393	J-151	83.00	1	6,242	247.60	71

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
422	J-150	83.00	1	3,121	247.60	71
806	J-Mission Rise 4	94.43	1	11,093	259.08	71
452	J-41	89.00	1	5,202	253.75	71
1196	J-Lake Hills 9	76.00	1	27,540	240.84	71
704	J-Venezia 5	93.00	0	0	258.44	72
597	J-187	90.00	0	0	255.52	72
179	J-67	90.00	0	0	255.55	72
1104	J-Drake Point 1	75.00	1	67,703	240.59	72
963	J-Venezia 21	92.72	1	13,525	258.45	72
301	J-85	87.00	0	0	252.75	72
1187	J-Lake Hills 5	75.00	1	27,158	240.84	72
1100	J-Golden Hills 1	92.58	1	232,178	258.59	72
257	J-80	88.00	1	4,162	254.21	72
173	J-64	89.00	0	0	255.42	72
198	J-65	89.00	1	5,202	255.48	72
365	J-147	81.00	1	3,121	247.61	72
879	J-Talichet II 2	92.00	1	2,295	259.00	72
135	J-34	84.00	1	10,404	251.03	72
1114	J-Cypress Point 1	73.64	1	21,038	240.87	72
602	J-188	88.00	0	0	255.40	72
1203	J-Venezia TH 3	91.00	1	8,798	258.52	72
730	J-Venezia 30	90.81	0	0	258.45	73
776	J-Cedar Creek 1	91.69	1	65,408	259.34	73
1138	J-Venezia 32	90.74	1	4,162	258.55	73
724	J-220	90.23	0	0	258.40	73
936	J-Talichet 5	90.78	1	5,202	258.96	73
845	J-Mission Rise 17	90.35	1	10,710	258.59	73
245	J-134	90.00	1	10,404	258.25	73
241	J-133	90.00	0	0	258.25	73
1035	J-Venezia 34	90.25	1	2,081	258.55	73
883	J-Talichet 14	90.88	1	3,121	259.27	73
720	J-Venezia 26	90.00	1	5,202	258.40	73
176	J-75	87.00	0	0	255.43	73
836	J-Mission Rise 14	90.07	1	6,503	258.59	73
1152	J-Mission Rise 22	89.96	0	0	258.60	73
876	J-The Reserve 14	89.84	0	0	258.67	73
432	J-44	90.00	0	0	258.84	73
1142	J-Mission Rise 1	90.47	0	0	259.36	73
1084	J-The Reserve 13	89.69	2	126,225	258.67	73
436	J-45	90.00	0	0	259.02	73
1081	J-The Reserve 12	89.60	1	2,295	258.67	73
1078	J-The Reserve 11	89.47	1	2,295	258.69	73
830	J-Mission Rise 12	89.37	1	6,503	258.60	73

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1059	J-Talichet 13	90.07	1	1,040	259.31	73
803	J-Mission Rise 3	89.89	1	10,710	259.19	73
800	J-Mission Rise 2	89.97	1	10,710	259.33	73
470	J-122	85.00	0	0	254.36	73
1075	J-The Reserve 10	89.34	2	132,983	258.70	73
732	J-Venezia 31	89.16	1	6,242	258.55	73
1004	J-Venezia 12	88.68	1	4,162	258.18	73
181	J-68	86.00	0	0	255.60	73
1129	J-Venezia 10	88.52	1	11,444	258.18	73
893	J-Talichet 7	89.60	1	12,485	259.30	73
1189	J-Lake Hills 8	71.00	1	27,158	240.84	73
762	J-234	88.95	0	0	258.94	74
833	J-Mission Rise 13	88.53	1	6,503	258.60	74
624	J-194	88.00	1	3,121	258.18	74
1064	J-329	88.47	0	0	258.67	74
851	J-Mission Rise 19	88.36	1	10,710	258.59	74
885	J-Talichet 12	88.74	1	2,081	259.34	74
419	J-149	77.00	0	0	247.62	74
485	J-108	82.00	0	0	252.75	74
1116	J-Cypress Point 2	70.02	1	21,038	240.87	74
139	J-42	84.00	0	0	255.10	74
1157	J-330	87.56	0	0	258.68	74
429	J-43	84.00	1	9,364	255.17	74
143	J-71	85.00	0	0	256.28	74
249	J-121	83.00	1	5,202	254.36	74
821	J-Mission Rise 9	87.13	1	6,503	258.61	74
738	J-Venezia 33	87.00	1	6,242	258.55	74
141	J-70	85.00	0	0	256.60	74
363	J-148	76.00	0	0	247.63	74
360	J-138	76.00	1	11,444	247.63	74
712	J-215	86.31	0	0	257.98	74
873	J-The Reserve 8	86.99	0	0	258.69	74
1017	J-Venezia 6	86.57	0	0	258.28	74
994	J-Venezia 22	86.52	1	4,162	258.28	74
556	J-174	91.00	0	0	262.82	74
914	J-Talichet 17	87.41	1	5,202	259.31	74
264	J-117	82.00	0	0	254.07	74
706	J-Venezia 7	86.00	0	0	258.27	75
457	J-125	82.31	1	10,404	254.72	75
409	J-164	75.00	1	12,485	247.60	75
797	J-251	85.79	0	0	258.67	75
273	J-113	81.00	0	0	253.96	75
275	J-82	81.00	0	0	253.96	75

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
585	J-185	90.00	0	0	262.96	75
793	J-Venezia 35	85.52	0	0	258.60	75
857	J-Mission Rise 21	85.31	1	10,710	258.60	75
952	J-Venezia 29	85.03	1	5,202	258.40	75
621	J-193	85.00	1	1,040	258.40	75
887	J-Talichet 11	86.01	1	31,860	259.44	75
790	J-249	85.17	0	0	258.67	75
854	J-Mission Rise 20	85.00	1	10,710	258.59	75
1097	J-The Reserve 7	85.00	1	92,565	258.92	75
759	J-The Reserve 9	86.74	1	8,798	260.75	75
1095	J-The Reserve 6	85.05	1	92,565	259.06	75
1093	J-The Reserve 5	85.01	1	3,825	259.15	75
150	J-74	81.00	1	2,081	255.17	75
1091	J-The Reserve 4	85.00	1	3,825	259.24	75
910	J-Talichet 15	85.00	1	11,444	259.28	75
912	J-Talichet 16	85.00	1	7,283	259.29	75
728	J-Venezia 28	84.00	0	0	258.40	75
1089	J-The Reserve 3	85.01	1	25,628	259.45	75
1205	J-Venezia TH 4	84.00	1	27,540	258.52	76
775	J-The Reserve 1	85.21	0	0	259.87	76
1087	J-The Reserve 2	85.05	1	32,895	259.79	76
889	J-Talichet 10	85.00	1	3,121	259.80	76
891	J-Talichet 8	85.00	1	18,727	259.97	76
923	J-Talichet 9	85.00	1	3,121	260.07	76
718	J-Venezia 11	83.00	1	8,323	258.18	76
722	J-Venezia 27	83.00	1	11,444	258.40	76
926	J-295	85.00	1	3,121	260.55	76
413	J-166	72.00	0	0	247.60	76
549	J-Mitchell 1	85.00	1	13,525	260.75	76
592	J-186	85.00	1	7,283	260.81	76
754	J-229	82.11	0	0	257.92	76
1012	J-Venezia 9	82.26	1	6,242	258.19	76
756	J-Whispering Hills 1	81.37	0	0	257.34	76
708	J-Venezia 8	82.00	1	2,081	258.19	76
259	J-119	78.00	1	11,444	254.21	76
1032	J-Venezia 17	81.62	1	2,081	258.01	76
757	J-231	80.71	0	0	257.33	76
1023	J-Venezia 13	81.45	1	3,121	258.14	76
554	J-173	84.00	0	0	260.79	76
289	J-84	77.00	0	0	253.87	77
716	J-Venezia 16	81.00	1	4,162	258.01	77
112	J-72	77.00	0	0	254.08	77
280	J-112	77.00	0	0	254.39	77

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire (North)

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
677	J-WTP1-6	86.25	0	0	263.64	77
678	J-WTP1-5	86.25	0	0	263.64	77
679	J-WTP1-4	86.25	0	0	263.64	77
148	J-73	77.00	0	0	254.47	77
999	J-Venezia 14	80.56	1	4,162	258.06	77
346	J-137	70.00	1	13,525	247.76	77
769	J-238	85.00	0	0	262.85	77
646	J-200	70.00	0	0	247.98	77
710	J-Venezia 15	80.00	1	3,121	258.02	77
343	J-135	70.00	1	13,525	248.05	77
219	J-Island 1	77.00	1	2,081	255.09	77
327	J-101	71.00	1	13,525	249.27	77
519	J-169	69.00	0	0	247.61	77
1170	J-369	82.00	0	0	260.75	77
552	J-172	82.00	0	0	260.77	77
330	J-100	70.00	1	7,283	248.79	77
417	J-167	68.00	1	8,323	247.60	78
1214	J-Venezia S	79.00	0	0	258.68	78
313	J-103	70.00	1	19,768	250.63	78
231	J-130	77.00	0	0	257.91	78
227	J-129	75.00	1	20,808	256.09	78
411	J-165	64.00	1	5,202	247.47	79
310	J-105	66.00	1	14,566	251.73	80
299	J-107	67.00	1	13,525	252.74	80
292	J-110	68.00	0	0	253.80	80
262	J-116	68.00	1	15,606	254.07	81
1068	J-Whispering Hills 3	70.72	1	47,813	257.38	81
217	J-124	67.00	0	0	254.47	81
296	J-109	64.00	0	0	253.76	82
286	J-111	64.00	1	1,040	253.88	82
271	J-115	64.00	1	9,364	253.96	82
225	J-Island 3	65.00	1	9,364	255.08	82
1070	J-Whispering Hills 4	65.00	1	11,858	257.38	83
221	J-Island 2	62.00	1	4,162	255.08	84

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
668	J-WTP1-3	81.00	0	0	82.92	1
666	J-WTP1-2	81.00	0	0	82.92	1
664	J-WTP1-1	81.00	0	0	82.93	1
1248	J-WTP3-1	140.00	0	0	142.00	1
30	J-WTP2-1	130.00	0	0	208.00	34
869	J-Watermark 5	159.36	2	1,500,053	239.61	35
68	J-Mission Inn 6	154.00	1	16,646	245.14	39
568	J-Mission Inn 5	154.00	0	0	245.20	39
66	J-Mission Inn 10	152.00	0	0	245.12	40
41	J-6	152.00	0	0	245.21	40
355	J-140	152.00	0	0	245.66	41
44	J-8	152.00	1	1,040	245.67	41
46	J-9	151.00	0	0	245.26	41
866	J-Watermark 4	145.57	1	9,180	240.42	41
74	J-Mission Inn 9	150.00	1	4,162	245.14	41
78	J-Mission Inn 4	150.00	0	0	245.27	41
82	J-Mission Inn 3	149.00	0	0	245.27	42
86	J-Mission Inn 2	149.00	1	15,606	245.28	42
764	J-Whispering Hills 2	146.07	0	0	243.00	42
70	J-Mission Inn 7	148.00	1	8,323	245.14	42
48	J-Mission Inn 1	148.00	0	0	245.31	42
72	J-Mission Inn 8	146.00	1	4,162	245.14	43
374	J-141	146.00	0	0	245.64	43
351	J-94	144.00	0	0	245.69	44
1217	J-386	141.00	0	0	245.05	45
1178	J-Lake Hills 1	140.00	0	0	244.37	45
1245	J-WTP3-2	140.00	0	0	244.37	45
1122	J-354	140.00	0	0	244.39	45
539	J-142	141.00	0	0	245.64	45
1162	J-365	135.00	0	0	239.96	45
863	J-Watermark 3	135.17	1	8,415	240.88	46
50	J-Mission Inn 11	134.00	0	0	245.07	48
640	J-198	131.95	0	0	245.72	49
90	J-Mission Inn 14	131.00	0	0	245.50	50
92	J-23	130.00	0	0	245.51	50
94	J-Mission Inn 15	130.00	0	0	245.53	50
96	J-25	130.00	0	0	245.57	50
33	J-4	128.00	0	0	244.38	50
31	J-2	128.00	0	0	244.38	50
35	J-3	128.00	0	0	244.38	50
37	J-5	128.00	0	0	244.43	50
442	J-7	128.00	0	0	244.46	50
114	J-27	129.00	1	15,606	245.68	50

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1108	J-Drake Point 3	126.24	1	67,320	243.85	51
100	J-26	128.00	1	3,121	245.64	51
338	J-93	128.00	0	0	245.73	51
52	J-Mission Inn 12	125.00	0	0	245.06	52
54	J-Mission Inn 13	124.00	1	37,454	245.05	52
544	J-170	123.00	0	0	245.63	53
502	J-98	122.00	0	0	245.73	54
1106	J-Drake Point 2	120.00	1	67,703	243.86	54
490	J-102	122.00	0	0	245.99	54
512	J-96	121.00	0	0	245.70	54
102	J-38	121.00	0	0	245.75	54
104	J-92	121.00	0	0	245.75	54
860	J-Watermark 2	116.57	1	8,415	241.93	54
643	J-199	119.72	0	0	245.72	55
495	J-90	120.00	0	0	246.03	55
325	J-89	120.00	0	0	246.06	55
322	J-88	120.00	0	0	246.07	55
340	J-97	119.00	1	14,566	245.73	55
348	J-95	118.00	1	17,687	245.68	55
576	J-183	118.00	0	0	246.08	55
377	J-157	117.00	1	12,485	245.63	56
372	J-143	117.00	1	4,162	245.63	56
315	J-104	117.00	0	0	246.08	56
108	J-39	116.00	0	0	246.11	56
110	J-40	116.00	1	11,444	246.13	56
319	J-87	115.00	0	0	246.10	57
332	J-99	113.00	1	10,404	245.79	57
334	J-91	113.00	1	4,162	245.82	57
106	J-37	112.00	1	5,202	245.95	58
983	J-Venezia 23	105.00	1	12,485	242.95	60
978	J-Venezia 18	105.00	1	10,404	243.53	60
357	J-139	107.00	1	15,606	245.65	60
306	J-106	106.00	0	0	246.18	61
973	J-Venezia 19	102.41	1	11,444	243.48	61
447	J-36	105.00	0	0	246.10	61
772	J-240	100.95	0	0	242.42	61
1148	J-Watermark 1	100.95	0	0	242.42	61
612	J-190	104.74	0	0	246.27	61
529	J-156	104.00	0	0	245.63	61
534	J-144	104.00	0	0	245.63	61
616	J-191	104.64	1	10,404	246.30	61
897	J-Talichet 1	104.83	0	0	246.76	61
123	J-35	104.00	1	12,485	246.13	61

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
121	J-32	104.00	1	20,808	246.13	61
369	J-145	103.00	1	3,121	245.63	62
169	J-63	104.00	1	12,485	246.78	62
1110	J-Lake Hills 12	101.23	0	0	244.22	62
304	J-86	103.00	1	3,121	246.18	62
382	J-158	102.00	1	12,485	245.63	62
507	J-136	102.00	0	0	245.73	62
809	J-Mission Rise 5	100.08	1	11,093	244.11	62
215	J-77	102.00	0	0	246.17	62
786	J-248	102.22	0	0	246.72	63
165	J-60	102.00	1	11,444	246.74	63
167	J-61	102.00	0	0	246.74	63
1053	J-Venezia 2	100.09	0	0	244.84	63
773	J-Venezia 1	100.12	0	0	244.99	63
812	J-Mission Rise 6	98.40	1	11,093	243.93	63
213	J-Venezia 3	99.00	0	0	244.58	63
379	J-155	100.00	1	8,323	245.63	63
968	J-Venezia 20	97.78	1	11,444	243.42	63
566	J-62	101.00	0	0	246.74	63
848	J-Mission Rise 18	97.08	1	10,710	242.93	63
839	J-Mission Rise 15	96.89	1	10,710	243.00	63
635	J-197	100.00	0	0	246.16	63
211	J-56	100.22	0	0	246.61	63
815	J-Mission Rise 7	97.32	1	11,093	243.77	63
156	J-54	100.06	1	2,081	246.64	63
842	J-Mission Rise 16	96.14	1	10,710	242.99	64
201	J-52	100.00	0	0	246.91	64
203	J-51	100.00	1	2,081	246.92	64
239	J-132	95.00	0	0	241.94	64
235	J-131	95.00	0	0	242.05	64
702	J-Venezia 4	97.00	1	32,513	244.34	64
1133	J-Venezia 24	95.33	1	16,646	242.86	64
895	J-Talichet 2	99.21	0	0	246.80	64
957	J-Venezia 25	95.00	1	10,404	242.82	64
827	J-Mission Rise 11	94.06	1	6,503	243.20	65
824	J-Mission Rise 10	94.09	1	6,503	243.24	65
818	J-Mission Rise 8	94.12	1	11,093	243.40	65
1168	J-Venezia TH 1	95.00	0	0	244.48	65
688	J-209	97.00	1	5,202	246.67	65
158	J-53	97.00	1	13,525	246.72	65
806	J-Mission Rise 4	94.43	1	11,093	244.29	65
1166	J-Venezia TH 2	94.00	1	6,885	244.38	65
881	J-Talichet II 1	94.95	1	5,738	245.38	65

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
192	J-50	96.50	1	1,040	247.06	65
704	J-Venezia 5	93.00	0	0	243.61	65
524	J-154	95.00	0	0	245.63	65
963	J-Venezia 21	92.72	1	13,525	243.38	65
154	J-58	96.00	1	1,040	246.72	65
629	J-196	96.00	1	13,525	246.73	65
1100	J-Golden Hills 1	92.58	1	232,178	243.37	65
465	J-78	95.00	0	0	246.17	65
934	J-Talichet 6	95.60	1	3,121	246.79	65
724	J-220	90.23	0	0	241.59	65
930	J-Talichet 3	95.16	1	6,242	246.80	66
607	J-189	95.00	0	0	246.72	66
932	J-Talichet 4	95.07	1	3,121	246.79	66
1112	J-Thompson Grove 1	92.46	1	104,040	244.20	66
1102	J-Lake Hills 11	92.23	0	0	244.16	66
245	J-134	90.00	1	10,404	241.93	66
241	J-133	90.00	0	0	241.93	66
1195	J-Lake Hills 10	92.00	1	27,158	244.15	66
255	J-79	94.00	1	4,162	246.17	66
186	J-49	95.08	1	1,040	247.51	66
730	J-Venezia 30	90.81	0	0	243.37	66
845	J-Mission Rise 17	90.35	1	10,710	242.97	66
386	J-153	93.00	1	6,242	245.63	66
388	J-159	93.00	0	0	245.63	66
367	J-146	93.00	1	3,121	245.63	66
720	J-Venezia 26	90.00	1	5,202	242.82	66
1152	J-Mission Rise 22	89.96	0	0	242.88	66
1138	J-Venezia 32	90.74	1	4,162	243.69	66
836	J-Mission Rise 14	90.07	1	6,503	243.05	66
1043	J-324	95.01	0	0	248.03	66
776	J-Cedar Creek 1	91.69	1	65,408	244.77	66
251	J-123	93.00	0	0	246.14	66
1041	J-323	94.88	0	0	248.10	66
581	J-184	93.00	0	0	246.25	66
879	J-Talichet II 2	92.00	1	2,295	245.34	66
1203	J-Venezia TH 3	91.00	1	8,798	244.36	66
1035	J-Venezia 34	90.25	1	2,081	243.69	66
830	J-Mission Rise 12	89.37	1	6,503	243.17	67
194	J-66	93.00	1	3,121	246.93	67
116	J-28	92.00	0	0	246.09	67
119	J-29	92.00	1	12,485	246.11	67
624	J-194	88.00	1	3,121	242.19	67
1142	J-Mission Rise 1	90.47	0	0	244.79	67

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
1004	J-Venezia 12	88.68	1	4,162	243.04	67
1129	J-Venezia 10	88.52	1	11,444	243.04	67
732	J-Venezia 31	89.16	1	6,242	243.69	67
851	J-Mission Rise 19	88.36	1	10,710	242.92	67
833	J-Mission Rise 13	88.53	1	6,503	243.12	67
803	J-Mission Rise 3	89.89	1	10,710	244.48	67
404	J-162	91.00	0	0	245.62	67
876	J-The Reserve 14	89.84	0	0	244.53	67
800	J-Mission Rise 2	89.97	1	10,710	244.73	67
1084	J-The Reserve 13	89.69	2	126,225	244.54	67
1081	J-The Reserve 12	89.60	1	2,295	244.58	67
883	J-Talichet 14	90.88	1	3,121	245.88	67
1078	J-The Reserve 11	89.47	1	2,295	244.64	67
475	J-120	91.00	0	0	246.19	67
1075	J-The Reserve 10	89.34	2	132,983	244.70	67
1064	J-329	88.47	0	0	244.00	67
400	J-160	90.00	1	16,646	245.62	67
152	J-76	91.00	1	8,323	246.81	67
1059	J-Talichet 13	90.07	1	1,040	245.96	67
133	J-33	91.00	0	0	246.90	67
936	J-Talichet 5	90.78	1	5,202	246.79	67
821	J-Mission Rise 9	87.13	1	6,503	243.27	68
480	J-118	90.00	0	0	246.25	68
268	J-81	90.00	1	4,162	246.25	68
762	J-234	88.95	0	0	245.21	68
1157	J-330	87.56	0	0	243.91	68
994	J-Venezia 22	86.52	1	4,162	243.04	68
1017	J-Venezia 6	86.57	0	0	243.12	68
621	J-193	85.00	1	1,040	241.59	68
712	J-215	86.31	0	0	242.99	68
738	J-Venezia 33	87.00	1	6,242	243.69	68
952	J-Venezia 29	85.03	1	5,202	241.78	68
873	J-The Reserve 8	86.99	0	0	243.86	68
597	J-187	90.00	0	0	246.92	68
179	J-67	90.00	0	0	246.93	68
706	J-Venezia 7	86.00	0	0	243.08	68
1119	J-Westminster 1	87.02	1	133,875	244.17	68
885	J-Talichet 12	88.74	1	2,081	246.01	68
893	J-Talichet 7	89.60	1	12,485	246.95	68
857	J-Mission Rise 21	85.31	1	10,710	242.90	68
407	J-163	88.00	1	3,121	245.62	68
728	J-Venezia 28	84.00	0	0	241.78	68
173	J-64	89.00	0	0	246.86	68

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
198	J-65	89.00	1	5,202	246.89	68
854	J-Mission Rise 20	85.00	1	10,710	242.91	68
452	J-41	89.00	1	5,202	246.93	68
432	J-44	90.00	0	0	248.06	68
436	J-45	90.00	0	0	248.10	68
257	J-80	88.00	1	4,162	246.20	68
126	J-30	88.00	0	0	246.22	68
793	J-Venezia 35	85.52	0	0	243.84	68
797	J-251	85.79	0	0	244.12	69
130	J-31	88.00	0	0	246.33	69
914	J-Talichet 17	87.41	1	5,202	245.96	69
402	J-161	87.00	0	0	245.62	69
426	J-168	87.00	0	0	245.63	69
722	J-Venezia 27	83.00	1	11,444	241.78	69
602	J-188	88.00	0	0	246.85	69
790	J-249	85.17	0	0	244.05	69
556	J-174	91.00	0	0	250.14	69
1097	J-The Reserve 7	85.00	1	92,565	244.24	69
301	J-85	87.00	0	0	246.29	69
1095	J-The Reserve 6	85.05	1	92,565	244.47	69
1093	J-The Reserve 5	85.01	1	3,825	244.60	69
1091	J-The Reserve 4	85.00	1	3,825	244.73	69
176	J-75	87.00	0	0	246.88	69
1089	J-The Reserve 3	85.01	1	25,628	245.04	69
718	J-Venezia 11	83.00	1	8,323	243.04	69
1183	J-Lake Hills 3	84.00	1	27,540	244.19	69
887	J-Talichet 11	86.01	1	31,860	246.22	69
585	J-185	90.00	0	0	250.29	69
1205	J-Venezia TH 4	84.00	1	27,540	244.35	69
775	J-The Reserve 1	85.21	0	0	245.63	69
1087	J-The Reserve 2	85.05	1	32,895	245.52	69
1012	J-Venezia 9	82.26	1	6,242	243.04	70
754	J-229	82.11	0	0	242.99	70
910	J-Talichet 15	85.00	1	11,444	245.90	70
912	J-Talichet 16	85.00	1	7,283	245.93	70
181	J-68	86.00	0	0	246.97	70
708	J-Venezia 8	82.00	1	2,081	243.05	70
470	J-122	85.00	0	0	246.12	70
759	J-The Reserve 9	86.74	1	8,798	248.03	70
1032	J-Venezia 17	81.62	1	2,081	243.00	70
1023	J-Venezia 13	81.45	1	3,121	243.03	70
756	J-Whispering Hills 1	81.37	0	0	243.10	70
889	J-Talichet 10	85.00	1	3,121	246.85	70

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
716	J-Venezia 16	81.00	1	4,162	243.00	70
1184	J-Lake Hills 4	82.00	1	27,540	244.15	70
891	J-Talichet 8	85.00	1	18,727	247.28	70
923	J-Talichet 9	85.00	1	3,121	247.33	70
143	J-71	85.00	0	0	247.39	70
135	J-34	84.00	1	10,404	246.40	70
757	J-231	80.71	0	0	243.12	70
999	J-Venezia 14	80.56	1	4,162	243.01	70
141	J-70	85.00	0	0	247.51	70
393	J-151	83.00	1	6,242	245.63	70
422	J-150	83.00	1	3,121	245.63	70
391	J-152	83.00	0	0	245.63	70
926	J-295	85.00	1	3,121	247.82	70
710	J-Venezia 15	80.00	1	3,121	243.00	71
549	J-Mitchell 1	85.00	1	13,525	248.03	71
592	J-186	85.00	1	7,283	248.08	71
249	J-121	83.00	1	5,202	246.12	71
457	J-125	82.31	1	10,404	245.49	71
429	J-43	84.00	1	9,364	247.19	71
139	J-42	84.00	0	0	247.20	71
1177	J-Lake Hills 2	81.00	2	169,575	244.21	71
554	J-173	84.00	0	0	248.07	71
1188	J-Lake Hills 6	80.00	1	27,158	244.14	71
264	J-117	82.00	0	0	246.25	71
485	J-108	82.00	0	0	246.28	71
677	J-WTP1-6	86.25	0	0	250.81	71
678	J-WTP1-5	86.25	0	0	250.81	71
679	J-WTP1-4	86.25	0	0	250.81	71
365	J-147	81.00	1	3,121	245.63	71
1214	J-Venezia S	79.00	0	0	243.91	71
769	J-238	85.00	0	0	250.12	71
1192	J-Lake Hills 7	79.00	1	27,158	244.14	71
273	J-113	81.00	0	0	246.34	72
275	J-82	81.00	0	0	246.34	72
150	J-74	81.00	1	2,081	246.81	72
231	J-130	77.00	0	0	243.00	72
1170	J-369	82.00	0	0	248.03	72
552	J-172	82.00	0	0	248.05	72
219	J-Island 1	77.00	1	2,081	244.93	73
1196	J-Lake Hills 9	76.00	1	27,540	244.14	73
259	J-119	78.00	1	11,444	246.19	73
419	J-149	77.00	0	0	245.64	73
1104	J-Drake Point 1	75.00	1	67,703	243.89	73

Howey In The Hills Water System

FlexTable: Junction Table

Active Scenario: Max Day - Pro Interconnect - WTP No. 3 Off-Line + Fire South 1000

ID	Label	Elevation (ft)	Unit Demand Collection <Count>	Demand (gpd)	Hydraulic Grade (ft)	Pressure (psi)
227	J-129	75.00	1	20,808	243.89	73
1187	J-Lake Hills 5	75.00	1	27,158	244.14	73
289	J-84	77.00	0	0	246.44	73
112	J-72	77.00	0	0	246.59	73
280	J-112	77.00	0	0	246.63	73
363	J-148	76.00	0	0	245.64	73
360	J-138	76.00	1	11,444	245.64	73
148	J-73	77.00	0	0	246.66	73
1114	J-Cypress Point 1	73.64	1	21,038	244.17	74
409	J-164	75.00	1	12,485	245.62	74
1068	J-Whispering Hills 3	70.72	1	47,813	243.02	75
1189	J-Lake Hills 8	71.00	1	27,158	244.14	75
413	J-166	72.00	0	0	245.62	75
1116	J-Cypress Point 2	70.02	1	21,038	244.17	75
327	J-101	71.00	1	13,525	245.90	76
346	J-137	70.00	1	13,525	245.68	76
646	J-200	70.00	0	0	245.72	76
343	J-135	70.00	1	13,525	245.74	76
330	J-100	70.00	1	7,283	245.84	76
313	J-103	70.00	1	19,768	246.06	76
519	J-169	69.00	0	0	245.63	76
417	J-167	68.00	1	8,323	245.63	77
1070	J-Whispering Hills 4	65.00	1	11,858	243.02	77
262	J-116	68.00	1	15,606	246.25	77
292	J-110	68.00	0	0	246.40	77
217	J-124	67.00	0	0	245.98	77
299	J-107	67.00	1	13,525	246.28	78
225	J-Island 3	65.00	1	9,364	244.92	78
310	J-105	66.00	1	14,566	246.17	78
411	J-165	64.00	1	5,202	245.50	79
271	J-115	64.00	1	9,364	246.33	79
296	J-109	64.00	0	0	246.37	79
286	J-111	64.00	1	1,040	246.38	79
221	J-Island 2	62.00	1	4,162	244.92	79