

Public services report

Regular grounds maintenance

Replaced 8 boards on the boardwalk, will continue to repair as needed

Sidewalk near Boondocks was trimmed back but will need further work with our tree contractor.

Replaced 3 outlets near Sara Maude Park in preparation for the Christmas festival

Sewer project had a walk through on Friday 12/3 - 4 items found during the walk thru that are being address, Camera the lines for final inspection, pulling the sump pump from the old Town Hall system, Documentation of septic tanks abandonment and sod in areas that need it still.

Utilities

Well 3 is offline due to the flow meter breaking. New meter has been ordered and will take roughly 18 days to be delivered. Main treatment plant is running the whole town until then.

Well 2 soft start has been ordered to repair that electrical issue and installation should start this week.