



LIBRARY BOARD ITEM DESCRIPTION

DATE OF MEETING: April 16, 2025

ITEM TITLE: Facilities Update

BACKGROUND:

The lighting transition to direct wiring instead of utilizing the low-voltage lighting panels is complete. We are very happy with the results.

The sprinkler system compressor has been running more than normal. The drain valve and air switch were replaced and some settings have been adjusted. These haven't fixed the problem, so the next recommendation is to have a company come in to check for leaks.

RECOMMENDATION:

Have updated information about the library facility.