

MEMBERS OF COUNCIL

HON. KIM REYNOLDS
GOVERNOR

HON. PAUL D. PATE
SECRETARY OF STATE

HON. ROB SAND
AUDITOR OF STATE

HON. ROBY SMITH
TREASURER OF STATE

HON. MIKE NAIG
SECRETARY OF AGRICULTURE



Executive Council of Iowa

CAPITOL BUILDING
DES MOINES, IOWA 50319
PHONE: 515 281-5368

August 7, 2023

Accounting Department
Office of the Treasurer
Lucas Building
321 E 12th Street
Des Moines, IA, 50319

The Executive Council, in a meeting held on this date, approved payment of the following cost item:

Department of Public Safety\$8,466.67

On January 18, 2023, the Keosauqua ISICS communication tower had its copper grounding cables stolen.
Request was to cover repair costs.

This represents full and final payment.

EXECUTIVE COUNCIL OF IOWA

Victoria Newton

Victoria Newton
Executive Secretary

cc: Captain Richard Pierce, Iowa State Patrol, Department of Public Safety
Joel Lunde, Department of Management



OFFICE OF AUDITOR OF STATE
STATE OF IOWA

Rob Sand
Auditor of State

State Capitol Building
Des Moines, Iowa 50319-0004
Telephone (515) 281-5834 Facsimile (515) 281-6518

August 22, 2023

Victoria Newton
Executive Council
L O C A L

Subject: Damages at Keosauqua ISICS Communications Tower – Stolen Copper
Grounding Cables on January 18, 2023
Department of Public Safety
Claim dated February 7, 2023
AOS Claim ID: 3445

In accordance with Executive Council policy, we have examined the invoices and supporting documentation for final payment on the loss. We have found the items to be in order as shown below:

Documented request		\$	<u>8,466.67</u>
Executive Council allocation		\$	8,466.67
Less:			
Previous payments	\$	0.00	
This payment		<u>8,466.67</u>	
Total			<u>\$ 8,466.67</u>
Remaining Executive Council allocation		\$	<u>0.00</u>

We recommend that reimbursement be made in the amount of \$8,466.67. This represents full and final payment on this allocation.

Sincerely,

Ernest H. Ruben, Jr., CPA
Deputy Auditor of State

cc: Captain Richard Pierce, Bureau Chief, Department of Public Safety

Kim Reynolds
Governor
Adam Gregg
Lt. Governor



Department of Public Safety

Stephan Bayens
Commissioner

February 7th, 2023

AON 29C20 Allocation Request ref. Keosauqua ISICS Tower - Theft of Copper Grounding Cables on 1-18-23

State of Iowa Executive Council:

On 1-25-23, we received a preliminary report from IPTV that on 1-18-23, a suspicious person was caught on security cameras with bolt cutters and appeared to be stealing copper grounding cables from the Keosauqua ISICS & IPTV shared Tower site. On 1-27-23, Motorola Representative Dave Gordon confirmed 11 copper grounding cables had been cut and stolen from outside the ISICS Tower site hut and tower. The theft is currently under investigation by local county law enforcement.

On 2-7-23, Motorola provided a repair estimate regarding the replacement /repair of the 11 stolen ground cables from the Keosauqua ISICS tower site. The estimated cost to repair this damage is \$8,466.67. Repairs are expected soon to avoid spring storms. Without copper grounding cables, a lightning strike to the tower greatly increases the chance of catastrophic damage to electronic equipment at the tower site.

The DPS Interoperability and Communications Bureau is respectfully submitting a 29C20 Allocation Request for \$8,466.67 regarding this theft.

Thank you for your consideration.

Sincerely,

Captain Richard Pierce
Bureau Chief
Iowa DPS Communications & Interoperability Bureau
Office of the Commissioner
215 E. 7th Street
Des Moines, Ia 50319



Motorola Solutions, Inc.
 500 West Monroe
 Chicago IL 60661
 United States
Federal Tax ID: 36-1115800

Visit our website at www.motorolasolutions.com

ORIGINAL INVOICE

Transaction Number 8330248658		Transaction Date 12-JUN-2023		Transaction Total 8,466.67 USD	
P.O. Number Captain Pierce			P.O. Date 12-JUN-2023		Customer Account No 1000199978
Payment Terms Net Due in 60 Days				Payment Due Date 11-AUG-2023	
Bill To Address IOWA, STATE OF ATTN: Accounts Payable 215 E 7TH ST DES MOINES IA 50319 United States			Ship To Address IOWA, STATE OF 22582 COUNTY RD J40 KEOSAUQUA IA 52565 United States		

IMPORTANT INFORMATION

Sales Order(s): 3203002414

For all invoice payment inquiries contact
 AccountsReceivable@motorolasolutions.com
 Telephone: 800-247-2346
 Fax: +1(631)883-4238

SPECIAL INSTRUCTIONS / COMMENTS

Depot SO#	Item Number	Description	Qty.	Unit Price (USD)	Amount (USD)
		Date Completed :20-FEB-23 Description of work :Replace and repair the 11 stolen ground cables at the Keosauqua ISICS Site listed in the January 27th 2023 report sent by Dave Gordon Authorized by : Captain Pierce			
	SVCFS-ONSITE-RSP-IO	FIELD SVC-ON SITE RESPONSE SVCS	1	8,466.67	8,466.67
	SVCFS-PARTS-IO	FIELD SERVICE - PARTS CHARGES	1	0.00	0.00
				USD Subtotal	8,466.67
				USD Total Tax	0.00
				USD Total	8,466.67
				USD Amount Due	8,466.67

Please detach here and return the bottom portion with your payment

Payment Coupon

Transaction Number 8330248658	Customer Account No 1000199978	Payment Due Date 11-AUG-2023	Transaction Total 8,466.67 USD	Amount Paid
---	--	--	---	--------------------

Please put your Transaction Number and your Customer Account Number on your payment for prompt processing.

IOWA, STATE OF
 ATTN: Accounts Payable
 215 E 7TH ST
 DES MOINES IA 50319
 United States

Payment Transfer Details

Bank of America, Dallas
 Bank Account No: 3756319806

Send Payments To:



Motorola Solutions, Inc.
 13108 Collections Center
 Chicago IL 60693
 United States
 Please provide your remittance details to:
US.remittance@motorolasolutions.com



Motorola Solutions, Inc.
 500 West Monroe
 Chicago IL 60661
 United States
Federal Tax ID: 36-1115800

ORIGINAL INVOICE			
Transaction Number 8330248658	Transaction Date 12-JUN-2023	Transaction Total 8,466.67 USD	
P.O. Number Captain Pierce		P.O. Date 12-JUN-2023	Customer Account No 1000199978
Payment Terms Net Due in 60 Days			Payment Due Date 11-AUG-2023

Visit our website at www.motorolasolutions.com

Kim Reynolds
Governor
Adam Gregg
Lt. Governor



Department of Public Safety

Stephan Bayens
Commissioner

June 16, 2023

AON 29C20 Reimbursement ref. Keosauqua ISICS Tower - Theft of Copper Grounding Cables on 1-18-23

State of Iowa Executive Council:

On 1-25-23, we received a preliminary report from IPTV that on 1-18-23, a suspicious person was caught on security cameras with bolt cutters and appeared to be stealing copper grounding cables from the Keosauqua ISICS & IPTV shared Tower site. On 1-27-23, Motorola Representative Dave Gordon confirmed 11 copper grounding cables had been cut and stolen from outside the ISICS Tower site hut and tower. The theft is currently under investigation by local county law enforcement.

On 2-7-23, Motorola provided a repair estimate regarding the replacement /repair of the 11 stolen ground cables from the Keosauqua ISICS tower site. The estimated cost to repair this damage is \$8,466.67. Repairs are expected soon to avoid spring storms. Without copper grounding cables, a lightning strike to the tower greatly increases the chance of catastrophic damage to electronic equipment at the tower site.

On 6-13-23, Motorola submitted an invoice for the repair and replacement of the stolen cooper at the Keosauqua ISICS Tower site for \$8466.67. They also submitted a repair report dated 6-13-23 detailing the work performed with photographs.

The DPS Interoperability and Communications Bureau is respectfully submitting a 29C20 Reimbursement Claim for \$8,466.67 regarding this theft. Attached to this email is the Repair Invoice, dated 6-12-23; the Initial 29C20 Notification, dated 1-25-23; the 29C20 Allocation Letter, dated 2-7-23, the Motorola Repair Report, dated 6-13-23, the Invoice, dated 6-12-23, and the I-3 Report reflecting payment of the Invoice by DPS Communications.

Thank you for your consideration.

Sincerely,

Captain Richard Pierce
Bureau Chief
Iowa DPS Communications & Interoperability Bureau
Office of the Commissioner
215 E.7th Street
Des Moines, Ia 50319

6-20-23 Keosauqua ISICS Tower – Copper Theft, I-3 Payment screed shot

Narrants

Fiscal Year	Warrant Number	Line Number	Line Amount	Issued	Redeemed	Vendor Customer
✓ 2023	72553708	1	\$8,466.67	06/19/2023		00002099390

First Prev Next Last

[Search](#)

Warrant Information

Fiscal Year : 2023 Amount : \$8,466.67
Warrant Number : 72553708 Vendor Customer : 00002099390
Line Number : 1 Last Updated : 6/19/23

Issue Information

Issued : 06/19/2023 Void :
Document ID : 061623SJD004COM Duplicate :
Document Line Number : 1 Stop :
Line Amount : \$8,466.67
Comments :

Motorola Solutions, Inc.
1301 E. Algonquin Road
Schaumburg, IL 60196
U.S.A.

Mobile: +1-319-321-1134
Email: dave.gordon@motorolasolutions.com

June 13, 2023

Captain Pierce
Iowa Department of Public Safety
Interoperability Communications Bureau
215 E. 7th St.
Des Moines, IA 50319

RE: Keosauqua Site Report – Stolen Cable Repairs

Good Afternoon Captain Pierce,

Attached you will find the Keosauqua site report that included the initial stolen cable report along with the repairs that have been completed.

Please review and contact me directly with any questions.

Thanks,



Dave Gordon
Customer Support Manager
State of Iowa
Motorola Solutions, Inc.

Motorola Solutions
Keosauqua Site Report – Stolen Cable Repairs
June 13th, 2023

Initial Report

On Thursday January 26th 2023, Connie Stufflebeem, who is the Assistant System Administrator – Interoperability Communications Bureau requested Motorola Solutions to send someone to the Keosauqua site to investigate and inspect the site. She had forwarded an email from Iowa PBS regarding a recent break in at the site on January 18th, 2023.

The Iowa Statewide Interoperable Communications System (ISICS) has a shelter and equipment located in the Iowa PBS compound at Keosauqua. They also have communications equipment on the tower.

Dave Gordon, Motorola Customer Support Manager arrived at the site at approximately 3:00 pm on January 26th, 2023. Shortly after arriving Deputy Spencer Rider stopped at the site from Van Buren County Sheriff's office. Dave Gordon showed Deputy Rider where the ground cables had been cut and stolen.

This report is only for the ISICS side of the compound since Iowa PBS indicated they were checking their shelter and equipment on their side of the compound.

There are a total of 11 ground cables that were cut and missing that are directly connected to the ISICS shelter and equipment in the compound.

Repair Report

On February 20th, 2023, Motorola Solutions had a contractor on site to repair/replace the stolen cables.

Below are the pictures taken highlighting the stolen ground cables and the repairs made.

HVAC Ground Missing Before



HVAC Ground after Repair



Shelter SE Corner Ground Missing



Shelter SE Corner after Repair



Ice Bridge Post #1 Ground Missing



Ice Bridge Post #1 after Repair



Ice Bridge Post #2 Ground Missing



Ice Bridge Post #2 after Repair



Ice Bridge Post #3 Ground Missing



Ice Bridge Post #3 after Repair



Ice Bridge Post #4 Ground Missing



Ice Bridge Post #4 after Repair



Ice Bridge Post #5 Ground Missing



Ice Bridge Post #5 after Repair



Ice Bridge Post #6 Ground Missing



Ice Bridge Post #6 after Repair



Isolation Transformer Ground Missing




Isolation Transformer after Repair



Tower Ground Bar Grounding Cables Missing



Tower Ground Bar after Repair



Newton, Victoria [TOS]

From: Pierce Richard <pierce@dps.state.ia.us>
Sent: Friday, January 27, 2023 3:07 PM
To: ExecutiveCouncil [TOS]; Hollingsworth, Tammy [AOS]
Cc: Duden Joshua; Dostal Sandra; Fisher Mike; Wittenwyler Jim
Subject: 1-25-23 Initial 29C20 Notification, Keosauqua ISICS Tower site - Theft of copper grounding cables
Attachments: ** External Email Alert ** Iowa PBS - Keosauqua; 1-18-23 IPTV Keosauqua security feed - Suspected theft.docx; ISICS Keosauqua Site Report Stolen Ground Cables 1-27-23.pdf; Re: ** External Email Alert ** Iowa PBS - Keosauqua

Executive Council & Tammy,

On 1-25-23, we received a preliminary report from IPTV that on 1-18-23, a suspicious person was caught on security cameras with bolt cutters and appeared to be stealing copper grounding cables from the Keosauqua ISICS & IPTV shared Tower site. On 1-27-23, Motorola Representative Dave Gordon confirmed 11 copper grounding cables had been cut and stolen from outside the ISICS Tower site hut and tower (See attached PDF and emails). We are obtaining estimates to have the cables repaired ASAP. For your situational awareness, the ISICS Keosauqua tower radio communication remains functional despite the theft of the copper cables; however, without the copper grounding cables in place, any lightning strike at the tower could result in catastrophic damage to equipment in the ISICS tower hut and tower equipment. A police report has been filed with local law enforcement regarding the theft.

Captain Richard Pierce

Bureau Chief
Iowa DPS Communications Interoperability Bureau
Office of the Commissioner
215 E.7th Street
Des Moines, Ia 50319
Work Ph# (515) 725-6113
Cell Ph# (712) 269-0730

Email: pierce@dps.state.ia.us

