MEMBERS OF COUNCIL

HON. KIM REYNOLDS GOVERNOR

HON. PAUL D. PATE SECRETARY OF STATE

HON. ROB SAND AUDITOR OF STATE

HON. ROBY SMITH TREASURER OF STATE

HON. MIKE NAIG SECRETARY OF AGRICULTURE



Executive Council of Jowa

CAPITOL BUILDING DES MOINES, IOWA 50319 PHONE: 515 281-5368

December 4, 2023

Accounting Department Office of the Treasurer Lucas Building 321 E 12th Street Des Moines, IA, 50319

The Executive Council, in a meeting held on today's date, approved Department of Administrative Services request for an emergency allocation in the amount of \$3,500.00, subject to the audit of actual invoices. On November 28, 2022, mice caused damages to the Cherokee ISICS tower generator. Request was to cover repair costs.

EXECUTIVE COUNCIL OF IOWA

Victoria Newton

Victoria Newton Executive Secretary

cc: Captain Richard Pierce, Bureau Chief, Department of Public Safety Joel Lunde, Department of Management

OR OF STRIFE OF TO THE OF THE OF

OFFICE OF AUDITOR OF STATE

STATE OF IOWA

Rob Sand Auditor of State

State Capitol Building
Des Moines, Iowa 50319-0004

Telephone (515) 281-5834 Facsimile (515) 281-6518

November 14, 2023

Victoria Newton Executive Council L O C A L

Subject: Damages to the Cherokee ISICS Tower Generator due to Mice Chewing the

Wiring on November 28, 2022

Department of Public Safety Claim dated August 9, 2023

AOS Claim ID: 2405

In accordance with Executive Council policy, we have examined the claim for 29C.20 funds for the above-mentioned damages. It is our conclusion that the above damage incurred by the Department of Public Safety is covered by Chapter 29C.20 of the Code of Iowa. Therefore, we recommend Executive Council approval in the amount of \$3,500.00 subject to an audit of actual invoices.

Sincerely,

Ernest H. Ruben, Jr., CPA Deputy Auditor of State

cc: Captain Richard Pierce, Bureau Chief, Department of Public Safety



Stephan Bayens Commissioner

August 9, 2023

Ref. AON 29C20 Allocation Request for 11-28-22 AON - Mice damage to the Cherokee ISICS Communication Tower Generator.

State of Iowa Executive Council:

On 11-29-22, during the bi-weekly Motorola Warranty Update Meeting, Dave Gordon, Motorola Service Representative, advised local tower crews responded to a generator alarm at the Cherokee ISICS Tower and on 11-28-22 discovered the tower generator was inoperable due to mice chewing the wiring inside the generator.

On 8-8-23, Motorola confirmed the repair estimate for the generator is approximately \$3,500.00. A final invoice will be received upon completion of the repairs.

The DPS Interoperability and Communications Bureau is respectfully submitting a 29C20 Reimbursement Allocation Request for \$3,500.00 for this AON damage.

Thank you for your consideration.

Sincerely,

Captain Richard Pierce

Bureau Chief

Iowa DPS Communications & Interoperability Bureau

Office of the Commissioner

215 E.7th Street

Des Moines, Ia 50319

Newton, Victoria [TOS]

From: Pierce Richard <pierce@dps.state.ia.us>
Sent: Tuesday, November 29, 2022 9:20 AM

To: ExecutiveCouncil [TOS]; Hollingsworth, Tammy [AOS]

Cc: Dostal Sandra; DAVID GORDON

Subject: 11-28-22 Initial 29C20 Notification ref. Cherokee ISICS Tower - AON Mice Damage to

Generator Wiring

Executive Council & Tammy,

During the 11-29-22, Motorola Warranty Update Meeting, Dave Gordon, Motorola Service Representative, advised local tower crews responded to a generator alarm at the Cherokee ISICS Tower and on 11-28-22 discovered the tower generator was inoperable due to mice chewing the wiring inside the generator. At this time we do not know the cost of these repairs. Please accept this email as the required 24 hour notification regarding Acts of Nature. I will advise the total repair cost upon the receipt of the repair estimate from Motorola.

Captain Richard Pierce

Bureau Chief Iowa DPS Communications Interoperability Bureau Office of the Commissioner 215 E.7th Street Des Moines, Ia 50319 Work Ph# (515) 725-6113 Cell Ph# (712) 269-0730

Email: pierce@dps.state.ia.us

