# **Planned Service Agreement**

Quoted Date: 12-6-21

Customer:	City of Jackson
	101 Court st

Job Site: 1149 Nell Green

Jackson, Mo 63755

Jackson, Mo

<u>CKIIIIPOWER</u>®

jackson,	1110	0.57	55

		JOB SITE CONTACT IN	FORMATION	
Name:	Kent Peetz			
Main Tel:	573-243-2300	Cell:	FAX:	
Email:	Kpeetz@jacksonmo.org			

PRICE PER PM SERVICE ITEM				
	MAJOR INSPECTION	Cost	\$ 1,070.00	
MINOR INSPECTION Cost \$720.00				
( Fee includes oil filters, fuel filters and lubricant during annual service )				

	PI	/ FREQUENCY	PRICING BR	EAKDOWN			
PM Frequency	Annual Minor Inspections	Annual Major Inspections	Annual Cost of Minor Inspections	Annual Cost of Major Inspections	Annual Agreement Services Cost	Length of Agreement	Total Agreement Service Cost
SEMI-ANNUAL	1	1	\$ 720.00	\$ 1,070.00	\$ 1,790.00	3 Years	\$ 5,370.00

Length of Agreement 3 Years

LINE ITE	M ADC	O-ONS
Load Bank Testing 2 Hou	rs 🖌	\$ 578.50
Fuel Testing	✓	\$ 150.00
Oil Sampling	✓	\$ 35.00
Anti-freeze testing	√	\$ 25.00
Add-ons Sub Total Length of Agreement (Years)		\$ 788.50 3
Total A	dd-Ons	\$ 2,365.50

(Includes PM Plan and Line Item Add Ons Selected)

\$ 7,735.50

TOTAL COST OF CONTRACT

LABOR HOURS CALCULATION			
Major Inspection	Minor Inspection	Load Bank	
Business Hours	Business Hours	Business Hours	

The owner agrees to pay CK Power for the following charges upon receipt of the invoice for:					
	THIS AGREEMENT COVERS THE E	QUIPMENT LISTED BELOW	FOR THE SPECIFIC L	OCATION INDICATED.	
Generator Mfr	Model	Serial No.	KW	Voltage	Туре
Kohler	145REOZT4	3336RGMJH0002	145	208	Commercial - Diesel
	ear This Agreement Shall Be Automati orm, In A Good and Workman Like Ma				
Account Manager	Email	Cell	FAX	Office Tel	Approved
Will Johnston	wjohnston@ckpower.com			314-868-8620	Scott Egelhoff Distaly signed by Scott Egehoff Des 2022.04.19 11:16:17 -0500'
Customer Signature:			Purchase Order:		Date:

Quote is Good for 30 days from Quoted Date



## Your Complete Source of Engine and Generator Power.

#### www.ckpower.com



### PLANNED SERVICE AGREEMENT FOR GENERATOR SYSTEMS

CKPower PLANNED SERVICE AGREEMENT is a coordinated program of inspection and service by trained technicians. The program is designed to enhance the performance and reliability of your standby or prime power generator . The owner understands this program is not a guarantee against equipment malfunction or failure, expressed or implied. The Planned Service Agreement is designed to perform the necessary service and, therefore, minimize the likelihood of failure or malfunction, while providing the owner a status report of said equipment.

CKPower will perform inspections annually on the equipment in accordance with the attached schedule. The Major and Minor inspections differ only in that the Major inspection includes an oil change, oil and fuel filters and water filter change.

#### MAJOR INSPECTION

- Change engine oil and filter (s)
- Record lube oil pressure
- Clean crankcase breather
- Record coolant level and mixture
- Record coolant temperature
- Check belt tension and condition
- Change water filter (s)
- Check duct work for defects
- Check block heater operation
- Check coolant hoses and connections
- Check for oil/coolant leakage
- Air cleaners check/oil for element
- Check for fuel leaks
- Change fuel filter

- Check exhaust-system for leaks
- Check battery specific gravity, electrolyte level, and clean connections
- Check battery charger operation
- Inspect ignition wiring, if equipped
- Check ignition timing, points and plugs, if equipped
- Adjust carburetor, if equipped
- meter, ammeter and safety systems
- including exerciser, time delays and contacts
- Check operation of remote annunciator, if equipped
- MINOR INSPECTION

Includes all services performed during Major inspection, less the following services:

• Change lube, oil and filter (s) • Change water filter (s)

Change fuel filter (s)

PREMIUM INSPECTION includes all Major changes and the following:

Belt and hose replacement	Battery replacement
Thermostat replacement	Coolant removal and replacement
Air Filter replacement	Radiator hose and fitting replacement

OPTIONAL SERVICES: These services are performed and proposed at customer request.

- Load bank testing (Recommended Annually for lightly loaded equipment to reduce likelihood of "Wet Stacking")
- Fuel testing and treatment (As needed) Will check for contaminates and general quality.
- Coolant treatment and replacement (Recommended every 3-5 years)
- Pressure washing (At customer request)
- Battery replacement (Recommended every 3 years)
- Rental generators (At customer request)
- Belt and hose replacement (Recommended every 3-5 years)
- Antifreeze testing (Recommended Annually)
- Oil Sampling (Recommended Annually) Will check for unusual engine wear and contaminates.



WAWAVEEXDOWEEEDHE

- Check governor operation • Operational check of volt meter, frequency
- · Check automatic transfer switch operation,