Planned Service Agreement

Quoted Date: 12-6-21

Customer: City of Jackson 101 Court st

Jackson, Mo

<u>CKIIIIPOWER°</u>

Job Site: 580 N Union

Jackson, Mo 63755

OB	SITE	CONTAG	T I	NFORMAT	ΙΟΝ	

		JOB BILL CONTINCT		
Name:	Brad Noel		_	
Main Tel:	573-243-5595	Cell:	FAX:	
Email:	bnoel@jacksonmo.org		_	

PRICE PER PM SERVICE ITEM				
	MAJOR INSPECTION	Cost	\$ 1,070.00	
4	MINOR INSPECTION	Cost	\$ 720.00	
(Fee includes oil filters, fuel filters and lubricant during annual service)				

PM FREQUENCY PRICING BREAKDOWN							
PM Frequency	Annual Minor Inspections	Annual Major Inspections	Annual Cost of Minor Inspections	Annual Cost of Major Inspections	Annual Agreement Services Cost	Length of Agreement	Total Agreement Service Cost
SEMI-ANNUAL	1	1	\$ 720.00	\$ 1,070.00	\$ 1,790.00	3 Years	\$ 5,370.00

Length of Agreement 3 Years

LINE ITE	M ADC	O-ONS
Load Bank Testing 2 Hou	rs 🖌	\$ 578.50
Fuel Testing	✓	\$ 150.00
Oil Sampling	✓	\$ 35.00
Anti-freeze testing	√	\$ 25.00
Add-ons Length of Agreeme	\$ 788.50 3	
Total A	\$ 2,365.50	

ANNUAL	COST	OF SERVICES	\$ 2,578,50
	0001	OI DERITCED	Ψ <u></u> 2,370.30

(Includes PM Plan and Line Item Add Ons Selected)

\$7,735.50

TOTAL COST OF CONTRACT

LA	BOR HOURS CAL	CULATION
Major Inspection	Minor Inspection	Load Bank
Business Hours	Business Hours	Business Hours

	ne owner agrees to pay CK Po	ower for the following cr	harges upon rece	ipt of the involce for	•
1	HIS AGREEMENT COVERS THE E	QUIPMENT LISTED BELOW I	FOR THE SPECIFIC L	OCATION INDICATED.	
Generator Mfr	Model	Serial No.	KW	Voltage	Туре
Kohler	145REOZT4	3336RGMJH0003	145	208	Commercial - Diesel
	ar This Agreement Shall Be Automati rm, In A Good and Workman Like Ma				
Account Manager	Email	Cell	FAX	Office Tel	Approved
	wjohnston@ckpower.com			314-868-8620	Digitally signed by Scott
Will Johnston	wjonnston@ckpower.com				Scott Egelhoff Egelhoff Date: 2022.04.19 11:16:58

Quote is Good for 30 days from Quoted Date



Your Complete Source of Engine and Generator Power.

www.ckpower.com



PLANNED SERVICE AGREEMENT FOR GENERATOR SYSTEMS

CKPower PLANNED SERVICE AGREEMENT is a coordinated program of inspection and service by trained technicians. The program is designed to enhance the performance and reliability of your standby or prime power generator . The owner understands this program is not a guarantee against equipment malfunction or failure, expressed or implied. The Planned Service Agreement is designed to perform the necessary service and, therefore, minimize the likelihood of failure or malfunction, while providing the owner a status report of said equipment.

CKPower will perform inspections annually on the equipment in accordance with the attached schedule. The Major and Minor inspections differ only in that the Major inspection includes an oil change, oil and fuel filters and water filter change.

MAJOR INSPECTION

- Change engine oil and filter (s)
- Record lube oil pressure
- Clean crankcase breather
- Record coolant level and mixture
- Record coolant temperature
- Check belt tension and condition
- Change water filter (s)
- Check duct work for defects
- Check block heater operation
- Check coolant hoses and connections
- Check for oil/coolant leakage
- Air cleaners check/oil for element
- Check for fuel leaks
- Change fuel filter

- Check exhaust-system for leaks
- Check battery specific gravity, electrolyte level, and clean connections
- Check battery charger operation
- Inspect ignition wiring, if equipped
- Check ignition timing, points and plugs, if equipped
- Adjust carburetor, if equipped
- meter, ammeter and safety systems
- including exerciser, time delays and contacts
- Check operation of remote annunciator, if equipped
- MINOR INSPECTION

Includes all services performed during Major inspection, less the following services:

• Change lube, oil and filter (s) • Change water filter (s)

Change fuel filter (s)

PREMIUM INSPECTION includes all Major changes and the following:

Belt and hose replacement	Battery replacement
Thermostat replacement	Coolant removal and replacement
Air Filter replacement	Radiator hose and fitting replacement

OPTIONAL SERVICES: These services are performed and proposed at customer request.

- Load bank testing (Recommended Annually for lightly loaded equipment to reduce likelihood of "Wet Stacking")
- Fuel testing and treatment (As needed) Will check for contaminates and general quality.
- Coolant treatment and replacement (Recommended every 3-5 years)
- Pressure washing (At customer request)
- Battery replacement (Recommended every 3 years)
- Rental generators (At customer request)
- Belt and hose replacement (Recommended every 3-5 years)
- Antifreeze testing (Recommended Annually)
- Oil Sampling (Recommended Annually) Will check for unusual engine wear and contaminates.



WAWAVEEXDOWEEEDHE

- Check governor operation • Operational check of volt meter, frequency
- · Check automatic transfer switch operation,