



**PUBLIC WORKS DEPARTMENT**  
**AGENDA ITEM REPORT**

**TO:** Mayor and City Council  
**FROM:** Porter Massengill, Director  
**DATE:** February 13, 2026  
**SUBJECT:** 60 HP VFD for the Permeate Pump at the WTP

---

**BACKGROUND:**

- There is need for a backup 60 HP VFD for the Permeate Pump to use at the Water Treatment Plant.
- We need this VFD as a back up to continue pumping finish water to the clear well.

**FISCAL IMPACT:**

A new 60 HP VFD Permeate Pump will cost approximately \$ 10,000.

**REQUEST/RECOMMENDATION:**

I request that the Council authorize the purchase of this drive which will require an amendment to the budget.