



PUBLIC WORKS DEPARTMENT

AGENDA ITEM REPORT

TO: City Council

FROM: Porter Massengill, Director

DATE: February 11, 2025

SUBJECT: Water Leak and Valve Insertion at Overlook Avenue and Old AJ Highway

BACKGROUND:

- There has been a water leak on a 90-degree fitting on the 8-inch water line. The crew is having to do a valve insertion in order to be able to isolate and repair the leak. The alternative would be a large number of customers being out of water for two to three days.
- Impact: The valve(s) are being installed with some traffic diversion and short-term water outages.

FISCAL IMPACT:

- Budget: A budget amendment will be needed.
- Cost: The cost is \$7,600 per valve.

REQUEST/RECOMMENDATION:

The valves have been installed so that the repairs can be made to the leaking pipe.

ATTACHMENTS:

Quote from G & C Supply for 2 Hydra-Stop Valve Insertions