



Founded 1876  
Incorporated 1899

## TOWN OF JEROME, ARIZONA

POST OFFICE BOX 335, JEROME, ARIZONA 86331  
(928) 634-7943 FAX (928) 634-0715 m.boland@jerome.az.gov

Celebrating Our 124th Anniversary  
1899 - 2023

### May 2023 PUBLIC WORKS MONTHLY REPORT

#### NORMAL WEEKLY DUTIES

- TRASH: Monday, Wednesday, and Friday.
- PARKS: Clean parks, Weed whip, and Mow.
- RECYCLE: Pickup cardboard Monday, Wednesday, and Friday. The trailer goes to recycle on Thursdays.
- WATER: Read water meters on Thursdays.
- HURF: Clean curb and gutters, Weed whip.
- SEWER: Repair lines.

#### OTHER PROJECTS

- Cleared reed beds at the sewer plant, dig out topsoil. Dig up and add leech rock to leech pipe.
- Bulk trash pickup on Mondays and Fridays throughout the month.
- Listen to and pothole the water line going down to the 500 level.
- Fix the water leak on upper bell.
- Repair and replace lids on cardboard bins at the 300-level parking lot.
- Run cables, install tv and camera for the council chambers.
- Swap and move dumpsters and cardboard bins at Vaqueros.
- Work on F-150's shifter.
- Fix the electrical issue on the garbage truck (with help from Carl).
- Spent time fixing, replacing, and adjusting sprinklers in the middle park.

# REGULATORS

## **Giroux St. 5/1/2023**

2" Complete rebuild- no parts replaced.

4" Complete rebuild- no parts replaced.

## **School St. 5/8/2023**

2" Complete rebuild- no parts replaced.

4" Complete rebuild- no parts replaced.

5/23/2023

Lower 2" Complete rebuild- no parts replaced.

## **Gulch Rd. 5/9 -5/10/2023**

2" Complete rebuild- replaced brass fittings.

4" Complete rebuild- no parts replaced.

## **Dundee Ave. (top regulator) 5/11/2023**

2" Complete rebuild- no parts replaced.

4" Complete rebuild- no parts replaced.

## **Verde St. 5/10-5/11**

2 1/2" Complete rebuild- no parts replaced.

4" Complete rebuild- gasket on CRD plug.

## **Dundee Ave. 5/15/2023**

2" Complete rebuild- no parts replaced.

## **County Rd. 5/16/2023**

2" Complete rebuild- copper line replaced, rubber disc seat.

4" is getting work done starting on the 26<sup>th</sup>. Valves need replacing, and a company will be here on the 26<sup>th</sup> to expose the line so we know the parts what are needed.