



Founded 1876
Incorporated 1899

TOWN OF JEROME, ARIZONA

POST OFFICE BOX 335, JEROME, ARIZONA 86331
(928) 634-7943 FAX (928) 634-0715 m.boland@jerome.az.gov

Celebrating Our 124th Anniversary
1899 - 2023

October 2023 PUBLIC WORKS MONTHLY REPORT

NORMAL WEEKLY DUTIES

- TRASH: Monday, Wednesday, and Friday.
- PARKS: Clean parks, Weed whip, and Mow.
- RECYCLE: Pickup cardboard Monday, Wednesday, and Friday. The trailer goes to recycling on Thursdays.
- WATER: Read water meters on Thursdays.
- HURF: Clean curb and gutters, Weed whip.
- SEWER: Repair lines.

OTHER PROJECTS

- Dug a trench from the garden to the new bathrooms and installed a new water line.
- Sewer snake by the Reeds, Lazano land, walk and snake the main trunk line.
- Process ab to grade on Beale St. (Shawn is learning to run the Gannon for grading the roads). North Dr., Gulch and Dundee.
- Used the water truck for Dust control and compaction on the road already graded.
- Weed eat throughout the town and sidewalks.
- Patch potholes asphalt throughout town.
- Work on brakes for the dump truck.
- Take the garbage truck to Pete's for diagnosis.
- Replace lights at Town Hall.
- Run new air lines at the town yard shop and new wire for the air compressor.
- Run new water line and electric for the Ice machine at the town yard.

- Rebuild parts of the road to Verde central and cleared brush around the meter box.
- Cleaned the gutter on 89a at County rd.
- Repair water leak on Hampshire.
- Replaced the thermostat on the garbage truck.
- Brake light repair and rewired sewer truck.
- Installed the new Kiosk at the police station and new signs in every parking areas.

REGULATORS

Giroux St.

10/16/23 4" rebuild- Replaced the copper line, seated the next day.

10/17/23 2" rebuild- No parts replaced.

Verde St.

10/17/23 4" rebuild- No parts replaced.

10/18/23 2 ½" rebuild- Repaired a copper line.

Dundee Ave. (upper/new regulator)

10/18/23 2" Rebuild- No parts replaced.


10/19/23 4" Rebuild- No parts replaced.

County Rd.

10/19/23 2" rebuild- No parts replaced.

Dundee Ave. (At Gary's house)

10/19/23 2" rebuild- Replaced the disc retainer.



Founded 1876
Incorporated 1899

TOWN OF JEROME, ARIZONA

POST OFFICE BOX 335, JEROME, ARIZONA 86331
(928) 634-7943 FAX (928) 634-0715 m.boland@jerome.az.gov

Celebrating Our 124th Anniversary
1899 - 2023

Gulch Rd.

9/21/23 2" rebuild- Replaced the stem, seat, and cover bearing (Had and issue when they were testing hydrants). The 2" came unseated again 10/3. Lyle pulled it apart, rebuilt it, but the issue continued. He realized the issue seemed to be the same as an issue we had with the Giroux St. regulator a few years ago, so he rebuilt and replaced a CRD and put a new copper line on. Once he did that, the issue seemed to go away.

10/16/23 4" rebuild- No parts replaced.

School St.

10/24/23 Lower 2" rebuild- No parts replaced.

10/24/23 2" rebuild- Replaced needle valve gasket.

10/24/23 4" rebuilt- No parts replaced.

This was Shawn's first time learning how to rebuild regulators with Lyle. He will have one more session next April when we do the next round, but he will start doing weekly checks.