



Founded 1876  
Incorporated 1899

## TOWN OF JEROME, ARIZONA

POST OFFICE BOX 335, JEROME, ARIZONA 86331  
(928) 634-7943 FAX (928) 634-0715 m.boland@jerome.az.gov

Celebrating Our 126nd Anniversary  
1899 - 2025

### March 2023 PUBLIC WORKS MONTHLY REPORT

#### NORMAL WEEKLY DUTIES

- TRASH: Monday, Wednesday, and Friday.
- PARKS: Clean parks, Weed whip, and Mow.
- RECYCLE: Pickup cardboard Monday, Wednesday, and Friday. The trailer goes to recycle on Thursdays.
- WATER: Read water meters on Thursdays.
- HURF: Clean curb and gutters, Weed whip.
- SEWER: Repair lines.

#### OTHER PROJECTS

- Paint “No Parking” area
- Snake sewer for the High school on Hampshire
- Clean gutters on 89A
- Dig a trench and install a new water line for the new meters on Verde Ex property.
- Fix the Rack and Pinion on the Side-by-side ranger
- Replace the batteries in the cameras on the springs.
- Dig out the drain in Higg’s driveway. It gets clogged with dirt from our drains up above.
- Clean out Muma’s shed
- Replace the cap on the 12” line on Sunshine hill
- Fix sewer lines in the Gulch
- Fix Water leak on Hampshire.
- Roothing roads.

# Regulators

## **County Rd.**

2" 11/7/2024- Rebuild, replaced rubber disc and yolk on the CRD.

4" 1/7/2025- Rebuild, no parts replaced.

## **Giroux St**

2" 1/6/2025- Rebuild, replaced the gauge.

4" 1/6/2025- Rebuild, Broken brass fittings, left on overnight, charged by next morning. 1/7/2025 replaced another broken fitting.

## **School St.**

2" 1/8/2025- Rebuild, no parts replaced.

4" 1/8/2025- Rebuild, no parts replaced.

Lower 2" 1/21/2025- Rebuild, no parts replaced.

## **Verde St.**

4" 1/2/2025- Rebuild, replaced restriction fitting. Left off overnight, seated the next morning.

2 ½" 1/3/2025- Rebuild, no parts replaced.

## **Dundee Ave. New regulator**

2" 1/13/2025- Rebuild, no parts replaced. 1/14/2025- Top was leaking, replaced a fitting

4" 1/14/2025- Rebuild, no parts replaced.

## **Dundee Ave. Lower regulator.**

2" 1/15/2025- Rebuild, no parts replaced.

## **Gulch Rd.**

2" 1/9/2025- Rebuild, no parts replaced

4" 1/10/2025- Rebuild, replaced pressure gauge.

We were a little behind on rebuilding regulators this year with all the parking lots, drains and other various jobs this year that set us back. Just know that we still check these regulators on a weekly schedule, usually on a Thursday or Friday so we know they're good for the weekends. We typically try to do the rebuilds in October and April of each year. Next round will be in April of this year, and we will get back on our regular schedule. This was Brandon's second time learning the rebuilds. That makes Lyle, Shawn, Brandon and myself familiar with the regulators, and are comfortable if there are any issues. Robert will be next in line for training. Hopefully for the first time, since I've been with The town Jerome, we will have a full crew that are familiar with our regulator system.