



Founded 1876  
Incorporated 1899

## TOWN OF JEROME, ARIZONA

POST OFFICE BOX 335, JEROME, ARIZONA 86331  
(928) 634-7943 FAX (928) 634-0715 m.boland@jerome.az.gov

Celebrating Our 124th Anniversary  
1899 - 2024

### March 2023 PUBLIC WORKS MONTHLY REPORT

#### NORMAL WEEKLY DUTIES

- TRASH: Monday, Wednesday, and Friday.
- PARKS: Clean parks, Weed whip, and Mow.
- RECYCLE: Pickup cardboard Monday, Wednesday, and Friday. The trailer goes to recycle on Thursdays.
- WATER: Read water meters on Thursdays.
- HURF: Clean curb and gutters, Weed whip.
- SEWER: Repair lines.

#### OTHER PROJECTS

- Grading and setting forms for curb at the Sliding Jail parking lot.
- Paint lines for parking spots and “No Parking/Fire lanes”.
- Water leak on Upper Bell Rd.
- Backfill and replace brick pavers at the regulator on County Rd.
- Dig up and prepare for a new storm drain on Juarez to help with the drainage problem
- Mix concrete and pour a new storm drain on Juarez, install new grate.
- Rent a 1-yard mixer and pour concrete on 5<sup>th</sup> St. to help with drainage and fill holes.
- Add new sprinklers, adjust and/or move old sprinklers in the middle park for better saturation.
- Pick up chlorine, take to the sewer plant and Walnut Springs.
- Grade Deception
- Fill potholes throughout town

## Regulators

The 4" valves on the 4" regulator finally gave out. We hired a company to expose the line outside of the box to find out what parts we need to replace the whole regulator. We ordered the parts and had the company come back to pull and replace the whole system. We replaced the 4" and 2" valves along with a brand new 4" regulator. I've added photos of the new and old. Unfortunately, I don't have any of the 2" before, but the wrong valves were put in on the 2" back in 2015/16 when they replaced the 2" regulator, so we replaced the valves on this swap out.