

	CITY OF JONESBORO, GEORGIA COUNCIL Agenda Item Summary		COUNCIL MEETING DATE: 9-14-26 Regular Meeting 10-5-26 Worksession
	Requesting Agency (Initiator): Public Works/City Manager's Office	Sponsor(s): Blue Cole	
Item Title:	Water Fountain Update		
Requested Action: None			
Requirement for Board Action: Yes			
Is this Item Goal Related? Yes			
Summary and Background: The three water fountains in Lee Street Park have not worked in several years. Since the last update (7-6-26) an additional water line break has been repaired, and another underground leak identified. Fountain #1- Market Area Current Status: The fountain is operational, and individuals are able to access drinking water. However, there is an active leak originating from underneath the fountain structure. Fountain #2- Amphitheater Area Current Status: The fountain is partially functional. The center drinking fountain is operational and provides water access to patrons. The side fountain and pet bowl are not operational. Fountain #3- Basketball and Tennis Courts Current Status: The fountain remains out of service. The fountain is owned by the City, but the water service is confirmed to be owned and controlled by the school. Incorrect parts were ordered, and have been sent back. This will require excavation and the removal of concrete.			
Fiscal Impact: Repair and/or replacement for all three water fountains will range from \$5,000 - \$74,000, depending on vendor and services.			
Exhibits Attached: 3 quotes for repair/replace, plus a chart of fountain prices			
Recommendation: Approval			

FOLLOW-UP APPROVAL ACTION (Completed by City Clerk)		
Typed Name and Title	Date	
Signature	City Clerk's Office	