



Fw: Quote from Plumb-All LLC - 06/11/2026

From Marcus Heard <MHeard@jonesboroga.gov>
Date Thu 6/11/2026 10:37 AM
To Blue Cole <bcole@jonesboroga.gov>
Cc City Manager <citymanager@jonesboroga.gov>

Marcus Heard, CPSI | Public Works Director|
City of Jonesboro, GA

Tel:(770)478-3800 |Cell:(470)372-8609| mheard@jonesboroga.gov | 1859 City Center Way|
Jonesboro, Georgia 30236 | www.jonesboroga.com
[Like Us On Facebook](#) [Like Us on Twitter](#)

From: Plumb-All LLC <notification@txn.getjobber.com>
Sent: Thursday, June 11, 2026 10:34:21 AM
To: John Burdin <jburdin@jonesboroga.com>; Marcus Heard <MHeard@jonesboroga.gov>
Subject: Quote from Plumb-All LLC - 06/11/2026



Plumb-All LLC

Quote

Hi City of Jonesboro,

Thank you for asking us to quote on your project. Please find a detailed copy of our quote attached to this email.

The quote total is \$42,500.00 as of 06/11/2026.

If you have any questions or concerns regarding this quote, please don't hesitate to get in touch with us at info@plumb-all.com.

Sincerely,

Plumb-All LLC

[View Quote](#)



Plumb-All LLC

(844) 758-6225

info@plumb-all.com

218 North McDonough Street

Jonesboro, GA 30236

Powered by Jobber

Copyright © 2026, Octopusapp, Inc.



Outdoor Drinking Water Fountain Quote Request | Lowe's

From Mayor of Jonesboro <mayor@jonesboroga.gov>

Date Tue 6/9/2026 1:50 PM

To keshia.mingo@store.lowes.com <keshia.mingo@store.lowes.com>; orlando.allen@lowes.com <orlando.allen@lowes.com>

Cc Marcus Heard <MHeard@jonesboroga.gov>; Blue Cole <bcole@jonesboroga.gov>; Makayla Stacey <mstacey@jonesboroga.gov>; Yvette Thomas <ythomas@jonesboroga.gov>

Good Afternoon,

The City of Jonesboro is looking to update the water fountains at Lee Street Park, located at 73 Lee Street, Jonesboro, GA 30236. We are currently soliciting quotes from multiple service providers and will be evaluating options based on pricing, product quality, and installation services.

Could you please provide a quote for the following:

- Three (3) outdoor water fountains
- Two (2) fountains that include integrated bottle-filling stations
- At least one (1) fountain that includes a pet/dog drinking station

Additionally, I understand that your company may provide installation services. If so, could you please connect us with a representative who can visit the park and assess the installation locations with our Public Works Director, Marcus Heard?

We would appreciate any product specifications, pricing information, estimated lead times, and installation costs that may apply.

We would like to move forward with this project as quickly as possible, so I hope to hear from you soon!

**Elkay**

LK4408BF Wall Mounted Outdoor BiLevel

Drinking Fountain and Bottle Filler Combo wit..

\$7,916^{.25}**Pickup** unavailable**Free Delivery** Thu, Jun 11



Elkay

Tubular Green 3 -Basin Push button
Freestanding Drinking fountain

\$5,955^{.99}

Pickup Wed, Jun 17

Delivery Wed, Jun 17

Thank You,

Taylor Johnson



Taylor Johnson | Office of the Mayor | City of Jonesboro, GA

Tel: 943-213-1430 | mayor@jonesboroga.gov

1859 City Center Way | Jonesboro, Georgia 30236 | www.jonesboroga.gov

From: Donya Sartor <dsartor@jonesboroga.gov>

Sent: Thursday, June 11, 2026 10:13:57 AM

To: Marcus Heard <MHeard@jonesboroga.gov>

Cc: City Manager <citymanager@jonesboroga.gov>; Blue Cole <bcole@jonesboroga.gov>; Mayor of Jonesboro <mayor@jonesboroga.gov>

Subject: Re: J2 Connect – Fountain Assessment Update

Have yall done something about it?

Sent from my iPhone

On Jun 11, 2026, at 6:14 AM, Marcus Heard <MHeard@jonesboroga.gov> wrote:

This is a video of how we found the fountain this morning.

Marcus Heard, CPSI | Public Works Director|

City of Jonesboro, GA

[Tel:\(770\)478-3800](tel:(770)478-3800) | Cell:(470)372-8609 | mheard@jonesboroga.gov | 1859 City Center Way| Jonesboro, Georgia 30236 | www.jonesboroga.com

[Like Us On Facebook](#)

[Like Us on Twitter](#)

From: Donya Sartor <dsartor@jonesboroga.gov>

Sent: Thursday, June 11, 2026 8:57:30 AM

To: City Manager <citymanager@jonesboroga.gov>; Blue Cole <bcole@jonesboroga.gov>; Marcus Heard <MHeard@jonesboroga.gov>

Cc: Mayor of Jonesboro <mayor@jonesboroga.gov>

Subject: Re: J2 Connect – Fountain Assessment Update

We will need to get 2 add'l quotes per procurement policy. Check with Candace or Marcus for plumbers we have used in the past.

Also, call the following. He has done work at Nouveau and City Hall.

Higher Power Plumbing LLC

[706 333 0606](tel:7063330606)

Donya L. Sartor, PhD | Mayor | City of Jonesboro, GA

Tel: [770-478-3800](tel:770-478-3800) | Cell: [470-925-3612](tel:470-925-3612) | dsartor@jonesboroga.com | 1859 City Center Way| Jonesboro, Georgia 30236 | www.jonesboroga.com

[Like Us On Facebook](#)

[Like Us on Twitter](#)

<[Outlook-zjydie14.png](#)> [Book time to meet with me](#)

From: City Manager <citymanager@jonesboroga.gov>

Sent: Thursday, June 11, 2026 8:14 AM

To: Blue Cole <bcole@jonesboroga.gov>; Marcus Heard <MHeard@jonesboroga.gov>; Donya Sartor <dsartor@jonesboroga.gov>

Cc: Mayor of Jonesboro <mayor@jonesboroga.gov>

Subject: Re: J2 Connect – Fountain Assessment Update

Good morning,

Please see the attached quote from J2 Connect for the park water fountains.

<Outlook-4i2p3io3.png>

Yvette Thomas | Office of the City Manager | City of Jonesboro, GA

Tel: 470.726.1625 | citymanager@jonesboroga.gov

1859 City Center Way | Jonesboro, Georgia 30236 | www.jonesboroga.gov

From: City Manager

Sent: Wednesday, June 10, 2026 12:28 PM

To: Blue Cole <bcole@jonesboroga.gov>; Marcus Heard <MHeard@jonesboroga.gov>

Subject: J2 Connect – Fountain Assessment Update

J2 Connect – Fountain Assessment Update

Technicians - Tj and Chris

Fountain Near Amphitheater

- The fountain is currently operational.
- Chris identified a cracked plastic hose that had excessive slack. He was able to repair the issue, flush the system, and restore water service.
- There is a slight delay in water pressure; however, the fountain is functioning properly at this time.
- If a leak reoccurs, Chris advised that the fountain can be shut off from the electrical room until repairs are made.
- Quotes for both repair and replacement will be provided.

Basketball/Tennis Courts Fountain

- The fountain appears to be repairable.
- Although the water supply was turned on, water was not flowing through the pump closest to the fountain.
- Chris disconnected a valve, and brown water was released from the line.
- He advised that the fountain can likely be repaired if a compatible "air switch" can be located, as this is an older-style fountain.
- Quotes for both repair and replacement will be provided.

Fountain Near the Restrooms

- The fountain appears to be repairable.
- Chris identified a pipe that had separated from a copper fitting, preventing proper operation.
- Quotes for both repair and replacement will be provided.

<Outlook-zp0eakxa.png>