

City of Kaukauna

Board of Public Works

April 17, 2023

jn/engr dept

Agenda Item #2c

Authorization to Seek Bids for Replacement of Tower Drive Storm Lift Station Back-up Generator

Background

The back-up generator at the Tower Drive Stormwater Lift Station has been declining for a number of years. Small repairs and service calls have been increasing. Larger concerns/issues with the injectors and now with low results from the load-bank testing signify that the generator is near the end of its useful life. We had previously budgeted and borrowed for this item in the 2021 CIP but were able to keep the unit operating with a good level of confidence until this year.



Recommended Action

- Authorize Street Department to seek bids for the replacement of the Tower Drive Storm Lift Station Back-up Generator.