


DRISSEVIEW DR




Luminaire Schedule										
Symbol	Qty	Tag	Label	Arrangement	Description	[MANUFAC]	LLF	Luminaire Lumens	Luminaire Watts	Total Watts
	9	WP	OWP-NC-201-21000L-DIM10-120-347V-30K-40K-50K-BZ(21000L)	GROUP	OWP-NC-201-9000L-11000L-15000L-17000L-21000L-DIM10-120-347V-30K-40K-50K-BZ(21000L)	ELITE	0.950	N.A.	N.A.	1270.868
	2	OA4	LED-ARL3-300W-T4-SF	Single	LED-ARL3-300W-T4-SF - ALREADY ORDERED		0.950	45559	291.277	582.554

Calculation Summary							
Label		CalcType		Units		Avg	Max
Calc Pts_Workplane		Illuminance		Fc		2.45	39.1
						Min	Avg/Min
						0.0	N.A.
						Max/Min	N.A.

1. Standard reflectance of 80/50/20 unless noted otherwise
2. Not a construction document, for design purposes only
3. Standard indoor calc points @ 30" AFF unless noted otherwise
4. Standard outdoor calc points @ grade unless noted otherwise
5. Visual Impact assumes no responsibility for installed light levels due to field conditions, etc.
6. Standard LLF of 0.95 unless noted otherwise

Visual Impact Lighting
1724 Industrial Drive
920-437-2069
visualimpactlighting.com




#	Date	Comments
Revisions		

Drawn By: ATH	Scale:
Checked By:	
Date:11/13/2023	

Enterprise Electric New Shop


Kaukauna, WI



- 1. Standard reflectance of 80/50/20 unless noted otherwise
- 2. Not a construction document, for design purposes only
- 3. Standard indoor calc points @ 30" AFF unless noted otherwise
- 4. Standard outdoor calc points @ grade unless noted otherwise
- 5. Visual Impact assumes no responsibility for installed light levels due to field conditions, etc.
- 6. Standard LLF of 0.95 unless noted otherwise



Visual Impact Lighting
1724 Industrial Drive
920-437-2069
visualimpactlighting.com



#	Date	Comments
Revisions		

Drawn By: ATH	
Checked By:	
Date: 11/13/2023	
Scale:	

Enterprise Electric New Shop	
Kaukauna, WI	