


LIFE SAFETY LEGEND

- INDICATES EMERGENCY LIGHTING WITH BATTERY PACK
- INDICATES NONDIRECTIONAL EMERGENCY EXIT LIGHTING
- INDICATES DIRECTIONAL EMERGENCY EXIT LIGHTING
- H.S. HOSE STATION
- FE1 FIRE EXTINGUISHER; MAX TRAVEL DISTANCE 75'
- S.S. SAFETY SHOWER / EYE WASH
- A.L. AUDIBLE/VISUAL ALARM

- NOTES:
1. ALL EXITS AND MEANS OF EGRESS ILLUMINATION FOR INTERIOR AND EXTERIOR DISCHARGE AREAS TO FOLLOW IBC 1008.
2. STRIPING LAYOUT IS FOR ILLUSTRATIVE PURPOSES ONLY. FINAL STRIPE LAYOUT TO BE APPROVED BY MILL SAFETY COORDINATOR. STRIPING MATERIAL TYPE PER OWNER.
3. ALL PORTABLE HANDHELD FIRE EXTINGUISHERS SHALL BE INSTALLED PER NFPA 10 AND IBC 906.



Digitally signed by Brent J. Robinson
Location: Baesch Engineering Inc., Kaukauna, WI
Reason: I attest to the accuracy and integrity of this document.
Contact Info: brent@baesch.com
9207668021
Date: 2023.10.20 11:59:25 -0500

 BAISCH ENGINEERING	REV. 01	BY JJW	DATE 10/20/23	DRAWING STATUS CODES:	
	AUTHORIZATION NUMBER N/A			A	Preliminary not for Construction
	PROJECT NUMBER KW0423137			B	Approval not for Construction
	DRAWING NUMBER 30474			C	Freeze not for Construction
	DRAWING CODE XX - XX - XX			D	Bid not for Construction
E				Reference not for Construction	
F				Fabrication	
I				Construction	
1				Record	

REFERENCES DWG. NO.



UTILITIES
POWER

B84 BOILER AND BUILDING INSTALLATION
GROUND FLOOR PLAN

SCALE:		JOB NO. KW0423137		ISSUE NO. A.1	
DATE: 08/08/23		PLOT DATE:		FILE NO. SIZE	
DWN. JJW ENGR. BJR		SERVICE LOCATION		X - 30474 - C	
CH. LJS APP.					

NO.	DESCRIPTION	DATE	BY
0.1	CONSTRUCTION	10/20/23	JJW
REVISIONS			

GROUND FLOOR PLAN

SCALE: 1/4" = 1'-0"

NOM T/FLOOR EL: 102'-0"

- NOTES:
1. FOR ALL GENERAL NOTES AND SPECIFICATIONS, SEE SPECIFICATION BOOK.