



City of Ketchum

### CITY COUNCIL MEETING AGENDA MEMO

Meeting Date:  Staff Member/Dept:

Agenda Item:

**Recommended Motion:**

I move to approve PO #23130 with Lunceford Excavation, INC. in a not to exceed amount of \$34,200 to install 180ft of mainline at the end of Parkway Dr. and Atkinsons Park connecting two dead end lines w/ fire hydrant and service line.

**Reasons for Recommendation:**

- This is a top priority item on our CIP Facilities Plan
- With the connection of the two dead end mainlines and installation of fire hydrant it will increase fire flows and protection.
- This will also alleviate stagnant dead ends that we must circulate through frost Free hydrants allowing us to conserve more water.
- In addition, we will be able to stub in a service to a buildable lot that did not have water available near property.

**Policy Analysis and Background (non-consent items only):**

**Sustainability Impact:**

Water Conservation, consistent flows, and pressures for neighborhood. Fire Protection

**Financial Impact:**

None OR Adequate funds exist in account:  Budgeted for in the CIP Construction 64-4340-7800

**Attachments:**

1. Quote
2. PO #23130
- 3.



Lunceford Excavation  
 alabama626@gmail.com  
 P.O. Box 739  
 Ketchum, ID 83340

Prepared For  
 Ketchum Utilities Department  
 P.O. Box 2315  
 Ketchum 83340

Estimate Date  
 08/08/2023

Estimate Number  
 14243

Reference  
 Parkside Drive

Description	Rate	Qty	Line Total
Parkside Drive	\$0.00	1	\$0.00
Excavate-Install 180' of 8" C-900 Water Pipe	\$130.00	180	\$23,400.00
Slurry Per City Spec	\$2,800.00	1	\$2,800.00
Asphalt Patch	\$3,200.00	1	\$3,200.00
Install Fire Hydrant-Labor and Parts-City to Provide Hydrant	\$2,300.00	1	\$2,300.00
Service to Empty Lot	\$2,500.00	1	\$2,500.00
		Subtotal	34,200.00
		Tax	0.00
		Estimate Total (USD)	\$34,200.00

**Terms**

**NOTE:** This proposal may be withdrawn by us if not accepted within 30 days. All material is guaranteed to be as specified. All work to be completed in a substantial workman like manner according to specifications submitted per standard practices. Any alteration or deviation from above specifications involving extra costs will be expected only upon written orders, and will become an extra charge over and above the estimate. All agreements contingent upon strikes, accidents, or delays beyond our control. Owner to carry fire, flood, and other necessary insurance. Our workers are fully covered by Workman's Compensation Insurance.

Any asbestos or other unforeseen conditions will be billed on a Time and Materials basis

All abnormal soil conditions, such as rock, caliche, water in excavation and any other unforeseen soil conditions will be billed on an agreed upon amount between client and Lunceford Excavation

ACCEPTANCE OF PROPOSAL: The above prices, specifications and conditions are satisfactory and are hereby accepted. You are authorized to do the work as specified. Payments will be made as outlined above.

X \_\_\_\_\_ (Client)

X \_\_\_\_\_ (Lunceford Excavation)



**CITY OF KETCHUM**  
 PO BOX 2315 \* 191 5TH ST. \* KETCHUM, ID 83340  
 Administration 208-726-3841 (fax) 208-726-8234

**PURCHASE ORDER**  
 BUDGETED ITEM?  Yes  No

**PURCHASE ORDER - NUMBER: 23130**

<b>To:</b> 2901 LUNCEFORD EXCAVATION, INC. P.O. BOX 739 KETCHUM ID 83340	<b>Ship to:</b> CITY OF KETCHUM PO BOX 2315 KETCHUM ID 83340
--	---

P. O. Date	Created By	Requested By	Department	Req Number	Terms
08/10/2023	KCHOMA	KCHOMA		0	

Quantity	Description	Unit Price	Total
1.00	180FT MAINLINE EXTENSION, FIRE HYDRA 64-4340-7800	34,200.00	34,200.00
	SHIPPING & HANDLING		0.00
	TOTAL PO AMOUNT		34,200.00

\_\_\_\_\_  
 Authorized Signature