



**CITY OF KING
CITY COUNCIL**

MEETING DATE:
February 2nd, 2026

PART A

Subject: Recommendation to Award Crooked Run Creek/ Farm Pump Station and Force Main Replacement Project

Action Requested: Approve awarding project contract to Garney Companies, Inc.

Attachments:
-Engineer's Recommendation of Award
-Farm PS & FM Bid Tab
-Notice of Intent to Award Document

This abstract requires review by:

City Manager

City Attorney

Benjamin Marion, City Engineer

PART B

Introduction and Background:

Staff along with KCI Technologies have been working on design of an upgrade to the city's existing Crooked Run Creek Pump Station, better known as the Farm Pump Station and Force Main line. The Farm Pump Station is the city's main pump station that carries sanitary sewer from King to the City of Winston Salem's Outfall and eventually to the City of Winston Salem's Lower Muddy Creek Wastewater Treatment Facility to be treated and disposed. This pump station was last upgraded in 2000, but the 4.7 miles of Force Main is the original main installed in 1983.

Discussion and Analysis:

The city received 3 bids for the project. Garney Companies Inc, from Apex, NC was the lowest responsive, responsible bidder based upon the modified scope of work outlined in the Request for Proposals. Scope of work highlights for this project are:

- Replace and upgrade 4.2 miles of existing 14" Ductile Iron force main piping (DIP) to 18" and 20" PVC and DIP piping
- Replace and upgrade 120 LF of 24" of existing DIP gravity sewer piping to 24" PVC
- Automatic Bar Screen Rake
- Upgrade to the Crooked Run Creek/ Farm Pump Station

Budgetary Impact:

This project is being funded through American Rescue Plan Act (ARPA). Breakdown of cost for this project and funding are as follows:

Contractor (Garney)	\$ 8,894,463
Contingency (5%)	\$ 444,723
Engineering	\$ 429,150
Farm PS Upgrades	\$ 2,281,171
	\$ 12,049,507

This Project will exhaust the \$22,000,000 ARPA funding.

Recommendation:

Approve awarding Garney Companies Inc the contract for the City of King's Crooked Run Creek/ Farm Pump Station and Force Main Replacement Project.