

AGENDA ACTION FORM

<u>Consideration of a Resolution to Amend CDM Smith Agreement for Wastewater</u> <u>Treatment Plant Electrical Improvements – Motor Control Center (MCC) 6 Replacement</u> <u>Project</u>

To: Board of Mayor and Aldermen

From: Chris McCartt, City Manager

Action Form No.: AF-389-2023 Work Session: December 18, 2023 First Reading: N/A Final Adoption:December 19, 2023Staff Work By:Niki EnsorPresentation By:Ryan McReynolds

Recommendation:

Approve the Resolution.

Executive Summary:

On April 20, 2020, the City entered into a professional service agreement with CDM Smith for design of motor control center 6 (MCC-6) at the wastewater treatment plant (WWTP). This project was identified in a condition assessment of the WWTP electrical system performed in 2016. The assessment prioritized projects based on the condition and risk to plant operations and compliance. <u>Electrical equipment greater</u> than 30 years of age has reached the end of its useful life and is not deemed reliable.

MCC-6 was installed in 1980. It has a single feeder and provides power to the return activated sludge (RAS) and waste activated sludge (WAS) pumping stations resulting in a single point of failure. To increase reliability, it is recommended MCC-6 be removed and replaced with two new main-tie-main motor control centers interlocked with kirk keys. New MCC-6A and MCC-6B will be fed from opposite sides of newly constructed switch board 1 (SB-1) to increase reliability. A new air-conditioned building housing two motor control centers and VFDs is recommended for this area.

This amendment moves the project into the construction phase. Total amendment request is \$214,075. This project was identified and funding was approved by the BMA for the FY 2022 Capital Improvements Plan. Funding is available in SW2206.

Original Contract Amount	\$	305,400.00
Contract Amendment 1	<u>\$</u>	214,075.00
Current Contract Amount	\$	519,475.00

Attachments:

Resolution
Agreement

	Y	Ν	0
Cooper			
Duncan			
George			
Montgomery			
Olterman			
Phillips			
Shull			