

Table A. User Discharge Restrictions

| Pollutant | Daily Maximum Limit(mg/l)* | Monthly Average Limit (mg/l)* |
|---------------------------------------|-----------------------------------|--------------------------------------|
| Ammonia nitrogen (NH ₃ -N) | 66.87 | 25.24 |
| Benzene | 0.048 | 0.032 |
| Carbon tetrachloride | 0.468 | 0.312 |
| Chloroform | 1.610 | 1.074 |
| Trans-1,2-Dichloroethylene | 0.035 | 0.023 |
| Ethylbenzene | 0.122 | 0.081 |
| Methylene chloride | 0.881 | 0.587 |
| Naphthalene | 0.026 | 0.017 |
| Tetrachloroethylene | 0.153 | 0.102 |
| Toluene | 0.248 | 0.165 |
| 1, 1, 1 Trichloroethane | 0.410 | 0.165 |
| Trichloroethylene | 0.289 | 0.193 |
| Total phthalates** | 1.301 | 0.867 |
| Arsenic (total) | 1.13 | 0.75 |
| Cadmium (total) | 0.12 | 0.08 |
| Chromium (total) | 3.68 | 2.43 |
| Copper (total) | 1.62 | 1.07 |
| Cyanide (total) | 0.52 | 0.35 |
| Lead (total) | 1.06 | 0.71 |
| Mercury (total) | 0.0126 | 0.0084 |
| Molybdenum (total) | 7.9 7.24 | 5.3 4.82 |

| Pollutant | Daily Maximum Limit(mg/l)* | Monthly Average Limit (mg/l)* |
|------------------|-----------------------------------|--------------------------------------|
| Nickel (total) | 1.97 | 1.30 |
| Phenols (total) | 0.70 | 0.46 |
| Selenium (total) | 3.46 | 2.31 |
| Silver (total) | 0.23 | 0.156 |
| Zinc (total) | 1.79 | 1.18 |
| Xylene | 0.180 | 0.120 |
| Hydrogen sulfide | 0.5 | NA |