



AGENDA ACTION FORM

Consideration of an Ordinance to Update Section 102-226, Table A - User Discharge Restrictions of the Sewer Use Ordinance

To: Board of Mayor and Aldermen
 From: Chris McCartt, City Manager *CM*

Action Form No.: AF-156-2024
 Work Session: June 17, 2024
 First Reading: June 18, 2024
 Final Adoption: July 16, 2024
 Staff Work By: Tom Hensley
 Presentation By: Ryan McReynolds

Recommendation:

Approve the Ordinance.

Executive Summary:

The wastewater treatment plant's National Pollution Discharge Elimination System (NPDES) Permit was renewed on January 1, 2024. The permit requires a Local Limits technical evaluation of wastewater discharge limits to be completed. Local limits regulate the type and quantity of pollutants discharged into the sewer system by industrial users, which could cause pass-through, interference or sludge contamination that may cause permit violations.

This evaluation determined that the molybdenum wastewater discharge limit be slightly decreased. No impact to commercial and industrial users is expected due to this change. State of Tennessee has approved the City of Kingsport Local Limit Review completed by our contractor MMS.

<u>Molybdenum</u>	<u>Previous Limit</u>	<u>New Limit</u>
Monthly Average	5.3 mg/l	4.82 mg/l
Daily Max	7.9 mg/l	7.24 mg/l

Attachments:

- Ordinance
- TDEC Approval letter
- Table A of Sewer Use Ordinance

	<u>Y</u>	<u>N</u>	<u>O</u>
Cooper	—	—	—
Duncan	—	—	—
George	—	—	—
Montgomery	—	—	—
Olterman	—	—	—
Phillips	—	—	—
Shull	—	—	—