



**AGENDA ACTION FORM**

**Consideration of an Ordinance to Update Section 102-226, Table A - User Discharge Restrictions of the Sewer Use Ordinance**

To: Board of Mayor and Aldermen  
From: Chris McCartt, City Manager *CM*

Action Form No.: AF-156-2024  
Work Session: June 17, 2024  
First Reading: June 18, 2024  
Final Adoption: July 16, 2024  
Staff Work By: Tom Hensley  
Presentation By: Ryan McReynolds

**Recommendation:**  
Approve the Ordinance.

**Executive Summary:**  
The wastewater treatment plant's National Pollution Discharge Elimination System (NPDES) Permit was renewed on January 1, 2024. The permit requires a Local Limits technical evaluation of wastewater discharge limits to be completed. Local limits regulate the type and quantity of pollutants discharged into the sewer system by industrial users, which could cause pass-through, interference or sludge contamination that may cause permit violations.

This evaluation determined that the molybdenum wastewater discharge limit be slightly decreased. No impact to commercial and industrial users is expected due to this change. State of Tennessee has approved the City of Kingsport Local Limit Review completed by our contractor MMS.

<u>Molybdenum</u>	<u>Previous Limit</u>	<u>New Limit</u>
Monthly Average	5.3 mg/l	4.82 mg/l
Daily Max	7.9 mg/l	7.24 mg/l

**Attachments:**  
1. Ordinance

	<u>Y</u>	<u>N</u>	<u>O</u>
Cooper	—	—	—
Duncan	—	—	—
George	—	—	—
Montgomery	—	—	—
Olterman	—	—	—
Phillips	—	—	—
Shull	—	—	—