

## **Report to Utility Committee**

Agenda Item: Discussion and Possible Action: Purchase of a Check Valve at Lift Station #3 for

\$2,936.00

Meeting Date: April 8, 2025

Referring Body: Utility Committee

**Committee Contact:** 

**Staff Contact:** Greg Ulman

Report Prepared by: Greg Ulman

AGENDA ITEM: Discussion and Possible Action: Purchase of a Check Valve at Lift Station #3 for

\$2,936.00

**OBJECTIVE(S):** To have B&M Technical Service install a check valve in lift station #3.

**HISTORY/BACKGROUND:** Lead Operator Mark Mackey is highly recommending replacing this check valve at LS #3 because it was installed in 1996. It is well past its life span and with the issues we've been experiencing at this lift station and that it needs to be professionally installed, he recommends replacing it now while we have sufficient funds in the account.

**RECOMMENDED ACTION:** To purchase the check valve at lift station #3 for \$2,936.00

## **FINANCIAL**

## **Financial Consideration/Action:**

## **FUNDING SOURCE:**

Account Number/Title: #650-53650-832-000

Current Adopted Budget: \$88,000 Spent to Date: \$4,053.53 Remaining Budget: \$83,946.47 Requested Amount: \$2,936.00

Remainder of Budgeted Amount, if approved: \$81,010.47

**ATTACHMENTS: Quote**