



Report to Utility Committee

Item Name: Discussion of Lift Station #4 Pump #2 Repair

Meeting Date: October 1, 2024

Referring Body:

Committee Contact:

Staff Contact: Greg Ulman

Report Prepared by: Greg Ulman

At lift station #4 on pump #2, we had a seal failure, and with the lift station running on only one pump staff asked our acting administrator, President Voll, his thoughts on this being an emergency repair. He decided that this indeed was an emergency and signed off on the quote for the repair of \$4,821.00. We are monitoring the lift station daily to be sure it keeps up with the demand. The pump should be rebuilt by October 1, and ready for re-installation.