



Report to Utility Committee

Item Name: Director of Public Works and Utilities Report

Meeting Date: November 4, 2025

Referring Body:

Committee Contact:

Staff Contact: Greg Ulman

Report Prepared by: Greg Ulman

- Earth Inc, has finished the bulk the boring work along Kronenwetter Dr. They are now by the intersection of Kowalski and Old Hwy 51, working their way north to the Lift Station #7 interceptor.
- Lift Station #3 is still giving us issues with rags and other issues clogging the pumps.
- There was a sewer back up at a residence on Falcon Crest Dr because of excess grease in the sewer main. The grease was an oval blob that got stuck in the line and prevented the passage of sewage in the line. After crews discovered this in the main we called the Village of Rib Mountain to help us clean the line and fee the grease. This area is scheduled for sewer cleaning in 2026. Staff also put door hangers in this neighborhood to let everyone know dumping grease and rags down the drain are prohibited.
- Work has started on Lift Stations 2&6 with the upgrade project. New panels and generators are being installed and work will be completed in spring 2026.
- Staff is working on the 2026 well and tower study RFP, and will have that sent out in the coming weeks.