



## **Report to Utility Committee**

**Agenda Item:** Discussion and Possible Action: Completion of Water Filtration Plant Items

**Meeting Date:** June 3, 2025

**Referring Body:** Utility Committee

**Committee Contact:**

**Staff Contact:** Greg Ulman

**Report Prepared by:** Greg Ulman

**AGENDA ITEM:** Discussion and Possible Action: Completion of Water Filtration Plant Items

**OBJECTIVE(S):** To approve the change order for the water filtration plant.

**HISTORY/BACKGROUND:** There have been warning alarms when we do the backwash sequence since the plant came online, we've been reaching out to Becher-Hoppe as well as Kurita for an explanation. After many site visits Kurita determined the piping for the air release valve needed to be upsized on the horizontal filter tank. This also requires 1-inch taps to be installed at the bottom of each pipe on the vertical detention tanks. Fixing this problem will allow the air to move properly in the backwash sequence and eliminate the alarms as well.

**RECOMMENDED ACTION:** Recommend the change order to the Village Board for approval.

**ATTACHMENTS:** Change Order paperwork