



Report to Utility Committee

Agenda Item: Discussion and Possible Action: Installing A/C in Well House and Well Rooms for \$4,260.00

Meeting Date: August 5, 2025

Referring Body: Utility Committee

Committee Contact:

Staff Contact: Greg Ulman

Report Prepared by: Greg Ulman

AGENDA ITEM: Discussion and Possible Action: Installing A/C in Well House and Well Rooms for \$4,260.00

OBJECTIVE(S): To have Malbrit Mechanical, Inc. install a central A/C unit in the Well House Offices.

HISTORY/BACKGROUND: During the hot days of July the temperatures in the well house offices reached 88 degrees and caused Marks computer to break. In those offices we also have other computers as well as our SCADA system which controls the water tower, wells, and is the central hub for a few of the lift stations. To prevent critical computers to break, as well as to keep our employees from working in the high heat staff would like to install a central A/C system for the offices. The forced air furnace is capable of handling the A/C. The funding would be split between the water and sewer budget.

RECOMMENDED ACTION: To purchase the A/C unit for the well house offices for \$4,260.00

FINANCIAL

FUNDING SOURCE:

Account Number/Title:	#601-53630-655-001
Current Adopted Budget:	\$ 8,000.00
Spent to Date:	\$ 60.00
Remaining Budget:	\$ 7,940.00
Requested Amount:	\$ 2,130.00
Remainder of Budgeted Amount, if approved:	\$5,810.00

Account Number/Title:	#650-53650-856-000
Current Adopted Budget:	\$ 3,000
Spent to Date:	\$ 275.43
Remaining Budget:	\$ 2,724.57
Requested Amount:	\$ 2,130.00
Remainder of Budgeted Amount, if approved:	\$594.57

ATTACHMENTS: Quote