



12/9/24

Brian Marquardt  
Superintendent  
Rhode Brothers Inc.  
W5745 Woodchuck Ln  
Plymouth, WI 53073

RE: Village of Kronenwetter, WI – Well No. 2 Water Treatment Facility  
Tonka Water Job #J0030780

Dear Brian:

This letter is being sent to meet requirements for recertification of one(1) of the Vertical Pressure Filters that was dropped on it's side on October 31, 2024 while being moved into the building.

After working with our fabrication and inspection team it has been determined that if the vessel has no visual damage, all paint, weld seams, and internal components are in tact and secure the vessel does not need to be brought back for repairs. As noted in communication with Rhode Brothers, Inc and the site engineer, this vessel will be tested on site at the expense of Rhode Brothers, Inc to pressure rating of 130psi per design and ASME code, if this tests without issue all factory warranties will remain.

Once testing is completed, Rhode Brothers, Inc will need to send a copy of the test results to Nina Halverson at Kurita to keep in the project files.

Should there be issues with the testing Kurita needs to be informed immediately so we can begin working with Rhode Brothers and the site to make any necessary arrangements to complete repair, which would be at the expense of Rhode Brothers, Inc if they are a result of the vessel being dropped during installation.

Please reach out if there are any questions or concerns.

Sincerely,

*Nina Halverson*

Nina Halverson  
Project Manager