



Report to Utility Committee

Item Name: Director of Public Works and Utilities Report

Meeting Date: December 2, 2025

Referring Body:

Committee Contact:

Staff Contact: Greg Ulman

Report Prepared by: Greg Ulman

- PGA has been working on the meter exchanges at the Weston Power Plant and have been running into issues replacing them, staff and crews have been working on getting this remedied.
- Lift Station #3 is still giving us issues with rags and other issues clogging the pumps.
- The well #1 rehab project is progressing with the contractor starting on November 24th. The project should be complete within 6 weeks.
- A few items need to be addressed to get the metering station with Rothschild up and running. The station was built 3 years ago but the purchasing of water was halted due to the PFAS in the Rothschild water. They have since added a filtering station and project to be below the DNR limits.
- Work has started on Lift Stations 2&6 with the upgrade project. New panels and generators are being installed and work will be completed in spring 2026.
- The water level has been lowered for the winter in the tower. This keeps fresher/warmer water flowing into the tower to prevent freeze up during the sever cold. The downside of this is a lower amount of storage capacity for fire protection.