

## Greg Ulman

---

**From:** Mark Mackey  
**Sent:** Wednesday, February 25, 2026 10:50 AM  
**To:** Greg Ulman  
**Subject:** FW: LS 4 (W Nelson Rd.)  
**Attachments:** 2020-183800.pdf; 15985.pdf

Invoices for last year's spring cleaning includes invoice for the landfill. Lincoln county is the only landfill in the area that will take the rags and grease when they are wet.

Mark Mackey  
Operator – Kronenwetter Water Utility  
(715)574-3868  
mmackey@kronenwetter.gov

**From:** Greg Ulman <gulman@kronenwetter.gov>  
**Sent:** Wednesday, February 25, 2026 10:41 AM  
**To:** Mark Mackey <mmackey@kronenwetter.gov>  
**Subject:** RE: LS 4 (W Nelson Rd.)

I'll be sure to let them know.

Greg Ulman  
Director of Public Works/Utilities Superintendent



1582 Kronenwetter Drive  
Kronenwetter, WI 54455  
715-693-4200 ext. 1731  
715-693-4202 Fax  
[www.kronenwetter.org](http://www.kronenwetter.org)

**From:** Mark Mackey <[mmackey@kronenwetter.gov](mailto:mmackey@kronenwetter.gov)>  
**Sent:** Wednesday, February 25, 2026 10:37 AM  
**To:** Greg Ulman <[gulman@kronenwetter.gov](mailto:gulman@kronenwetter.gov)>  
**Subject:** RE: LS 4 (W Nelson Rd.)

Before I forget, this is a good item to add to the UC agenda.

Mark Mackey  
Operator – Kronenwetter Water Utility  
(715)574-3868  
[mmackey@kronenwetter.gov](mailto:mmackey@kronenwetter.gov)

**From:** Greg Ulman <[gulman@kronenwetter.gov](mailto:gulman@kronenwetter.gov)>  
**Sent:** Wednesday, February 25, 2026 10:32 AM

**To:** Mark Mackey <[mmackey@kronenwetter.gov](mailto:mmackey@kronenwetter.gov)>  
**Subject:** RE: LS 4 (W Nelson Rd.)

Ok, think we can wait until spring to clean them?

Greg Ulman  
Director of Public Works/Utilities Superintendent



1582 Kronenwetter Drive  
Kronenwetter, WI 54455  
715-693-4200 ext. 1731  
715-693-4202 Fax  
[www.kronenwetter.org](http://www.kronenwetter.org)

---

**From:** Mark Mackey <[mmackey@kronenwetter.gov](mailto:mmackey@kronenwetter.gov)>  
**Sent:** Wednesday, February 25, 2026 10:28 AM  
**To:** Greg Ulman <[gulman@kronenwetter.gov](mailto:gulman@kronenwetter.gov)>  
**Subject:** RE: LS 4 (W Nelson Rd.)

We usually use Northern Pipe in the spring they are another vendor in the GB area. Rib mountain uses them and we typically piggyback with them in the spring when they get their wet wells cleaned. We usually save a bit on the mobilization costs that way. I can reach out to their foreman for pricing. Just a heads up though, the price doesn't include the tipping fee for the truck, last year it was nearly \$1k.

Mark Mackey  
Operator – Kronenwetter Water Utility  
(715)574-3868  
[mmackey@kronenwetter.gov](mailto:mmackey@kronenwetter.gov)

---

**From:** Greg Ulman <[gulman@kronenwetter.gov](mailto:gulman@kronenwetter.gov)>  
**Sent:** Wednesday, February 25, 2026 10:21 AM  
**To:** Mark Mackey <[mmackey@kronenwetter.gov](mailto:mmackey@kronenwetter.gov)>; Kimberly Coyle <[kcoyle@kronenwetter.gov](mailto:kcoyle@kronenwetter.gov)>  
**Cc:** James Davel <[jdavel@kronenwetter.gov](mailto:jdavel@kronenwetter.gov)>  
**Subject:** RE: LS 4 (W Nelson Rd.)

Thanks for letting me know Mark,

In your opinion do we wait to clean the wetwells until we do the mainline cleanings this year (which we can have happen soon in spring) or have a company come in quite soon to just clean all the lift stations?

Greg Ulman  
Director of Public Works/Utilities Superintendent



1582 Kronenwetter Drive  
Kronenwetter, WI 54455

715-693-4200 ext. 1731  
715-693-4202 Fax  
[www.kronenwetter.org](http://www.kronenwetter.org)

**From:** Mark Mackey <[mmackey@kronenwetter.gov](mailto:mmackey@kronenwetter.gov)>  
**Sent:** Wednesday, February 25, 2026 10:18 AM  
**To:** Greg Ulman <[gulman@kronenwetter.gov](mailto:gulman@kronenwetter.gov)>; Kimberly Coyle <[kcoyle@kronenwetter.gov](mailto:kcoyle@kronenwetter.gov)>  
**Cc:** James Davel <[jdavel@kronenwetter.gov](mailto:jdavel@kronenwetter.gov)>  
**Subject:** LS 4 (W Nelson Rd.)

Greg

During rounds this morning, Lorn discovered that p2 was not pumping down the level in the wetwell. Hopefully the pump is just clogged, it is pulling a normal amp load however so it may be something else. Right now, we have the pump off and p1 as the lead. With Scott plowing and filter plant backwash we will likely pull it tomorrow when it is a bit warmer out.

I had Scott open the hatch and inspect all of the wetwells last week, most of them were very dirty with large accumulations of rags and grease on the surface. These will need to be cleaned soon.

Mark Mackey  
Operator – Kronenwetter Water Utility  
(715)574-3868  
[mmackey@kronenwetter.gov](mailto:mmackey@kronenwetter.gov)