



## **Report to Utility Committee**

**Item Name:** Director of Public Works and Utilities Report

**Meeting Date:** February 11, 2025

**Referring Body:**

**Committee Contact:**

**Staff Contact:** Greg Ulman

**Report Prepared by:** Greg Ulman

- Pump 2 has failed at Lift Station 3 on Friday Feb 7<sup>th</sup>, we need to order one ASAP.
- We have a set of double doors that were supposed to be installed at the new filtration building, but instead installed a garage door. If those doors fit the frame of the existing double doors by the well, we are going to replace the old doors.
- The backup power supply at the elevated tower has failed, we purchased a new one for roughly \$80, and have it back in service already.
- We purchased a new chemical resistant table for the filtration plant, it'll be used for mixing potassium permanganate, the cost was \$790.
- We also purchased a new colorimeter for testing iron and manganese which will meet DNR requirements for testing the new filtration plant, cost was \$2,344.00
- We submitted the DNR 2025 Monitor Waiver Application in January. The application is a yearly form we fill out with information of nearby private wells and chemical storage location in proximity to our wells.
- We did an emergency purchase of the furnace at the well house for \$4,090.00 on January 22. The old one failed during the cold stretch in January.