

Wisconsin Department of Natural Resources
Drinking Water System
Electronic Monthly Operating Report Review

Report Ran On: 02/04/2025

District No: 6 PWS ID: 73717006 PWS Name: KRONENWETTER WATER & SEWER UTILITY
EPA ID: Inventory Name: System Operational Area

Process	Chlorine Residual - free	Fluoride Residual	Orthophosp hate Residual
Field	Chlorine Residual System (mg/L) - free	Fluoride Residual System (mg/L)	Orthophosp hate Residual System (mg/L)
01/01/2025	0.49	0.43	0.60
01/02/2025	0.02	0.37	1.51
01/03/2025	1.11	0.36	1.53
01/04/2025	0.81	0.33	1.07
01/05/2025	0.33	0.37	0.74
01/06/2025	1.08	0.34	0.82
01/07/2025	0.77	0.34	0.84
01/08/2025	1.28	0.32	1.01
01/09/2025	1.39	0.29	0.71
01/10/2025	0.25	0.44	0.94
01/11/2025	0.36	0.51	0.69
01/12/2025	0.32	0.50	0.79
01/13/2025	0.41	0.48	0.98
01/14/2025	1.31	0.62	0.73
01/15/2025	0.21	0.42	1.46
01/16/2025	1.41	0.69	0.05
01/17/2025	0.01	0.40	1.10
01/18/2025	1.36	0.62	0.20
01/19/2025	1.21	0.68	0.14
01/20/2025	0.03	0.51	0.98
01/21/2025	0.71	0.47	0.85
01/22/2025	1.10	0.58	0.77
01/23/2025	1.12	0.57	0.25

01/24/2025	0.95	0.60	0.69
01/25/2025	0.77	0.55	0.83
01/26/2025	0.99	0.53	0.91
01/27/2025	0.97	0.51	0.55
01/28/2025	0.91	0.39	0.84
01/29/2025	0.69	0.52	0.67
01/30/2025	0.08	0.64	0.39
01/31/2025	1.03	0.48	0.33
TOTAL	23.48	14.86	23.97
AVG	0.76	0.48	0.77
Used AVG	0.76	0.48	0.77
MIN	0.01	0.29	0.05
MAX	1.41	0.69	1.53

Wisconsin Department of Natural Resources
Drinking Water System
Electronic Monthly Operating Report Review

Report Ran On: 02/04/2025 PWS ID: 73717006 PWS Name: KRONENWETTER WATER & SEWER UTILITY
District No: 6 EPA ID: Inventory Name: System Operational Area

Comment
Comment
Comments

Wisconsin Department of Natural Resources
Drinking Water System
Electronic Monthly Operating Report Review

Report Ran On: 02/04/2025

District No: 6 PWS ID: 73717006 PWS Name: KRONENWETTER WATER & SEWER UTILITY
 EPA ID: 1 Inventory Name: Well 1

Process	Raw	Pump to Waste	Well Water Levels	Hours Rest	Well Water Levels	Static Water Level (feet)	Pumping Water Level (feet)	Chlorine	Chlorine	Chlorine Residual Entry Point (mg/L)	Fluoride	Fluoride	Fluoride
Field	Water Pumped (1000 gallons)	Pump to Waste (1000 gallons)									Amount Used (lbs)	Calculated Dose (mg/L)	Fluoride Residual Entry Point (mg/L)
01/01/2025	141.000							39.00	4.15		5.00	0.84	
01/02/2025	142.000		3.00		18.60			39.00	4.12		5.00	0.84	
01/03/2025	159.000							12.00	1.13		6.00	0.90	
01/04/2025	143.000							9.00	0.94		5.00	0.83	
01/05/2025	154.000							9.00	0.88		6.00	0.93	
01/06/2025	142.000							17.00	1.79		5.00	0.84	
01/07/2025	267.000							56.00	3.14		8.00	0.71	
01/08/2025	235.000							68.00	4.34		10.00	1.01	
01/09/2025	157.000							42.00	4.01		5.00	0.76	
01/10/2025	138.000						47.60	30.00	3.26		5.00	0.86	
01/11/2025	164.000							43.00	3.93		6.00	0.87	
01/12/2025	130.000							29.00	3.34		9.00	1.64	
01/13/2025	144.000							43.00	4.48		2.00	0.33	
01/14/2025	266.000		2.00		18.60			29.00	1.63		9.00	0.80	
01/15/2025	398.000							43.00	1.62		10.00	0.60	
01/16/2025	226.000						48.60	49.00	3.25		12.00	1.26	
01/17/2025	165.000							35.00	3.18		6.00	0.86	
01/18/2025	147.000							32.00	3.26		5.00	0.81	
01/19/2025	154.000							40.00	3.89		12.00	1.85	
01/20/2025	151.000							33.00	3.28		5.00	0.79	
01/21/2025	140.000							36.00	3.85		5.00	0.85	
01/22/2025	121.000		6.00		18.60			38.00	4.71		4.00	0.79	
01/23/2025	113.000							17.00	2.26		4.00	0.84	

01/24/2025	157.000						26.00	2.48			6.00	0.91	
01/25/2025	286.000						28.00	1.47			10.00	0.83	
01/26/2025	162.000						22.00	2.04			6.00	0.88	
01/27/2025	163.000					48.60	18.00	1.66			5.00	0.73	
01/28/2025	183.000			7.00	19.10		25.00	2.05			7.00	0.91	
01/29/2025	163.000						21.00	1.93			6.00	0.87	
01/30/2025	143.000						48.00	5.03			5.00	0.83	
01/31/2025	166.000			18.00	74.90	144.80	31.00	2.80			6.00	0.86	
TOTAL	5,420.000			0.58	2.42	4.67	1,007.00	89.90			200.00	27.63	
AVG	174.840			4.50	18.73	48.27	32.48	2.90			6.45	0.89	
Used AVG	174.840			2.00	18.60	47.60	32.48	2.90			6.45	0.89	
MIN	113.000			7.00	19.10	48.60	9.00	0.88			2.00	0.33	
MAX	398.000						68.00	5.03			12.00	1.85	

Wisconsin Department of Natural Resources
Drinking Water System
Electronic Monthly Operating Report Review

Report Ran On: 02/04/2025

District No: 6 PWS ID: 73717006 PWS Name: KRONENWETTER WATER & SEWER UTILITY
EPA ID: 1 Inventory Name: Well 1

Chemical	
Chlorine	
Concentration - Bulk %	12.5
Concentration - Active %	12.5
Fluoride	
Concentration - Bulk %	19.8
Concentration - Active %	19.8
Comment	
Comment	
Comments	

**Wisconsin Department of Natural Resources
Drinking Water System
Electronic Monthly Operating Report Review**

Report Ran On: 02/04/2025

District No: 6	PWS ID: 73717006	PWS Name: KRONENWETTER WATER & SEWER UTILITY
	EPA ID: 2	Inventory Name: Well 2

Process	Raw	Pump to Waste	Well Water Levels	Well Water Levels	Well Water Levels	Chlorine	Chlorine	Chlorine Pre	Chlorine Pre	Chlorine Pre	Chlorine Pre
Field	Water Pumped (1000 gallons)	Pump to Waste (1000 gallons)	Hours Rest	Static Water Level (feet)	Pumping Water Level (feet)	Amount Used (lbs)	Calculated Dose (mg/L)	Chlorine Residual Entry Point (mg/L)	Amount Used (lbs)	Calculated Dose (mg/L)	Chlorine Residual Entry Point (mg/L)
01/01/2025	171.000					31.00	2.72				
01/02/2025	173.000					30.00	2.60				
01/03/2025	189.000					34.00	2.70				
01/04/2025	171.000					31.00	2.72				
01/05/2025	183.000					25.00	2.05				
01/06/2025	171.000		3.00	41.00		30.00	2.63				
01/07/2025	23.000				59.00	5.00	3.26				
01/08/2025	99.000					17.00	2.57				
01/09/2025	187.000					22.00	1.76				
01/10/2025	163.000					36.00	3.31				
01/11/2025	196.000					36.00	2.75				
01/12/2025	155.000					28.00	2.71				
01/13/2025	172.000		2.00	41.00		32.00	2.79				
01/14/2025	127.000					21.00	2.48				
01/15/2025	233.000					25.00	1.61				
01/16/2025	179.000					12.00	1.01				
01/17/2025	338.000					37.00	1.64				
01/18/2025	181.000					33.00	2.73				
01/19/2025	191.000					35.00	2.75				
01/20/2025	183.000				59.00	34.00	2.79				
01/21/2025	173.000		3.00	41.00		31.00	2.69				
01/22/2025	181.000					36.00	2.98				
01/23/2025	189.000					18.00	1.43				

[illegible]

[illegible]

[illegible]

		0.02		0.006
		0.03		0.014
		0.00		0.000
		0.02		0.010
		0.01		0.010
		0.02		0.010

Wisconsin Department of Natural Resources
Drinking Water System
Electronic Monthly Operating Report Review

Report Ran On: 02/04/2025

District No: 6 PWS ID: 73717006 PWS Name: KRONENWETTER WATER & SEWER UTILITY
EPA ID: 2 Inventory Name: Well 2

Chemical	
Chlorine	
Concentration - Bulk %	12.5
Concentration - Active %	12.5
Chlorine Pre	
Concentration - Bulk %	12.5
Concentration - Active %	12.5
Chlorine Post	
Concentration - Bulk %	12.5
Concentration - Active %	12.5
Fluoride	
Concentration - Bulk %	19.8
Concentration - Active %	19.8
Phosphate (ortho)	
Product Name	Aquadene MP4130
Concentration - Active %	2.5
Oxidizer - Potassium Permanganate	
Concentration - Active %	3
Comment	
Comment	
Comments	Fluoride pump offline thru 1-7-25 during treatment plant construction. Poly feed shut off on 1-23-25 for DWTP. DWTP went online on 1-28-25.
Comments	